

DRAFT FEASIBILITY REPORT FEASIBILITY ANALYSIS OF WATER SUPPLY FOR SMALL PUBLIC WATER SYSTEMS

RIVIERA ISD
PWS ID# 1370019

Prepared for:

THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



Prepared by:

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC GEOLOGY
AND
PARSONS**

Preparation of this report was financed by the Texas Commission on Environmental Quality through the Drinking Water State Revolving Fund Small Systems Assistance Program

AUGUST 2008

DRAFT FEASIBILITY REPORT

**FEASIBILITY ANALYSIS OF WATER SUPPLY
FOR SMALL PUBLIC WATER SYSTEMS**

**RIVIERA ISD
PWS ID# 1370019**

Prepared for:

THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Prepared by:

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC
GEOLOGY**

AND

PARSONS

*Preparation of this report was financed by the Texas Commission on Environmental Quality
through the Drinking Water State Revolving Fund Small Systems Assistance Program*

THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF INTERIM REVIEW UNDER THE
AUTHORITY OF ERIC J. DAWSON, P.E. 79564, ON AUGUST 31, 2008. IT IS NOT TO BE USED
FOR CONSTRUCTION, BIDDING, OR PERMIT PURPOSES.

AUGUST 2008

EXECUTIVE SUMMARY

INTRODUCTION

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Transportation Group Inc. (Parsons), was contracted by the Texas Commission on Environmental Quality (TCEQ) to conduct a project to assist with identifying and analyzing alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

The overall goal of this project was to promote compliance using sound engineering and financial methods and data for PWSs that had recently recorded sample results exceeding maximum contaminant levels (MCL). The primary objectives of this project were to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS for future implementation.

This feasibility report provides an evaluation of water supply alternatives for the Riviera Independent School District (ISD) PWS, ID #1370019, located in Kleberg County. The Riviera ISD PWS is located approximately ¼ miles east of U.S. Highway 77 at 203 North 9th Street in Riviera, Texas. The water supply system has seven connections and serves a population of 500. The water source for the Riviera ISD PWS comes from one groundwater well completed to a depth of 727 feet in the Evangeline Aquifer (Code 121EVGL). Well #1 (G1370019A) is rated at 280 gallons per minute.

On March 8, 2007, the Riviera ISD PWS recorded a combined uranium concentration value of 0.088 milligrams per liter (mg/L), which exceeds the MCL of 0.030 mg/L. Therefore, it is likely the Riviera ISD PWS faces potential compliance issues under the standard.

Basic system information for the Riviera ISD PWS is shown in Table ES.1.

**Table ES.1 Riviera ISD PWS
Basic System Information**

Population served	500
Connections	7
Average daily flow rate	0.023 million gallons per day (mgd)
Peak demand flow rate	63.9 gallons per minute
Water system peak capacity	0.403 mgd
Typical combined uranium	0.088 mg/L

1 **STUDY METHODS**

2 The methods used for this project were based on a pilot project performed in 2004 and
3 2005 by TCEQ, BEG, and Parsons. Methods for identifying and analyzing compliance options
4 were developed in the pilot project (a decision tree approach).

5 The process for developing the feasibility study used the following general steps:

- 6 • Gather data from the TCEQ and Texas Water Development Board databases, from
7 TCEQ files, and from information maintained by the PWS;
- 8 • Conduct financial, managerial, and technical (FMT) evaluations of the PWS;
- 9 • Perform a geologic and hydrogeologic assessment of the study area;
- 10 • Develop treatment and non-treatment compliance alternatives which, in general, consist
11 of the following possible options:
 - 12 • Connecting to neighboring PWSs via new pipeline or by pumping water from a newly
13 installed well or an available surface water supply within the jurisdiction of the
14 neighboring PWS;
 - 15 • Installing new wells within the vicinity of the PWS into other aquifers with confirmed
16 water quality standards meeting the MCLs;
 - 17 • Installing a new intake system within the vicinity of the PWS to obtain water from a
18 surface water supply with confirmed water quality standards meeting the MCLs;
 - 19 • Treating the existing non-compliant water supply by various methods depending on the
20 type of contaminant; and
 - 21 • Delivering potable water by way of a bottled water program or a treated water dispenser
22 as an interim measure only.
 - 23 • Assess each of the potential alternatives with respect to economic and non-economic
24 criteria;
 - 25 • Prepare a feasibility report and present the results to the PWS.


26 This basic approach is summarized in Figure ES.1.

27 **HYDROGEOLOGICAL ANALYSIS**

28 The Riviera ISD PWS obtains groundwater from the Evangeline subunit of the Gulf Coast
29 Aquifer. Many nearby wells contain acceptable uranium concentrations. The NURE database
30 does not contain enough information to identify these wells, but this finding suggests that
31 further research into nearby wells that might serve as an alternative supply could prove useful.
32 In addition, based on depths of nearby wells that do and do not meet the MCL for uranium, it is
33 possible that deepening the PWS well below 850 feet might decrease uranium levels.

1

Figure ES.1 Summary of Project Methods



1 It may also be possible to do down-hole testing on non-compliant wells to determine the
2 source of the contaminants. If the contaminants derive primarily from a single part of the
3 formation, that part could be excluded by modifying the existing well, or avoided altogether by
4 completing a new well.

5 **COMPLIANCE ALTERNATIVES**

6 Overall, the system had a good level of FMT capacity. The system had some areas that
7 needed improvement to be able to address future compliance issues; however, the system does
8 have many positive aspects, including dedicated staff, and an emergency interconnection.
9 Areas of concern for the system included lack of compliance with the uranium standard, lack of
10 long-term planning for compliance and sustainability, and funding limitations.

11 There are several PWSs within 13 miles of the Riviera ISD PWS. Many of these nearby
12 systems also have water quality problems, but there are some with good quality water. In
13 general, feasibility alternatives were developed based on obtaining water from the nearest
14 PWSs, either by directly purchasing water, or by expanding the existing well field. There is a
15 minimum of surface water available in the area; however, the Baffin Bay Water Supply
16 Corporation is a potential larger regional water supplier that could potentially supply water to
17 Riviera ISD PWS.

18 Centralized treatment alternatives for radionuclide removal have been developed and were
19 considered for this report, including reverse osmosis, coagulation and filtration, and ion
20 exchange. Developing a new well close to the Riviera ISD PWS is likely to be the best
21 solution if compliant groundwater can be found. Having a new well close to the Riviera ISD
22 PWS is likely to be one of the lower cost alternatives since the PWS already possesses the
23 technical and managerial expertise needed to implement this option. The cost of new well
24 alternatives quickly increases with pipeline length, making proximity of the alternate source a
25 key concern. A new compliant well or obtaining water from a neighboring compliant PWS has
26 the advantage of providing compliant water to all taps in the system.

27 Central treatment can be cost-competitive with the alternative of new nearby wells, but
28 would require significant institutional changes to manage and operate. Similar to obtaining an
29 alternate compliant water source, central treatment would provide compliant water to all water
30 taps.

31 **FINANCIAL ANALYSIS**

32 A financial analysis of the various alternatives for the Riviera ISD PWS was performed
33 using estimated system revenues and expenses. Table ES.2 provides a summary of the
34 financial impact of implementing selected compliance alternatives, including the rate increase
35 necessary to meet current operating expenses. The alternatives were selected to highlight
36 results for the best alternatives from each different type or category.

37 Some of the compliance alternatives offer potential for shared or regional solutions. A
38 group of PWSs could work together to implement alternatives for developing a new

1 groundwater source or expanding an existing source, obtaining compliant water from a large
2 regional provider, or for central treatment. Sharing the cost for implementation of these
3 alternatives could reduce the cost on a per user basis. Additionally, merging PWSs or
4 management of several PWSs by a single entity offers the potential for reduction in
5 administrative costs.

6 **Table ES.2 Selected Financial Analysis Results**

Alternative	Funding Option	Average Annual Water Cost per Student	Percent of MHI
Current	NA	\$10	0.03
To meet current expenses	NA	10	0.03
Purchase water from Baffin Bay WSC	100% Grant	\$101	0.3
	Loan/Bond	\$262	0.9
Central IX treatment	100% Grant	\$90	0.3
	Loan/Bond	\$151	0.5

7

TABLE OF CONTENTS

1		
2	LIST OF TABLES.....	iii
3	LIST OF FIGURES.....	iv
4	ACRONYMS AND ABBREVIATIONS	v
5	SECTION 1 INTRODUCTION	1-1
6	1.1 Public Health and Compliance with MCLs.....	1-4
7	1.2 Method.....	1-4
8	1.3 Regulatory Perspective.....	1-4
9	1.4 Abatement Options.....	1-5
10	1.4.1 Existing Public Water Supply Systems.....	1-5
11	1.4.2 Potential for New Groundwater Sources	1-6
12	1.4.3 Potential for Surface Water Sources	1-8
13	1.4.4 Identification of Treatment Technologies.....	1-9
14	1.4.5 Treatment Technologies Description.....	1-10
15	1.4.6 Point-of-Entry and Point-of-Use Treatment Systems	1-14
16	1.4.7 Water Delivery or Central Drinking Water Dispensers.....	1-15
17	SECTION 2 EVALUATION METHOD.....	2-1
18	2.1 Decision Tree.....	2-1
19	2.2 Data Sources and Data Collection.....	2-1
20	2.2.1 Data Search	2-1
21	2.2.2 PWS Interviews.....	2-7
22	2.3 Alternative Development and Analysis.....	2-9
23	2.3.1 Existing PWS	2-10
24	2.3.2 New Groundwater Source.....	2-10
25	2.3.3 New Surface Water Source	2-11
26	2.3.4 Treatment	2-11
27	2.4 Cost of Service and Funding Analysis	2-11
28	2.4.1 Financial Feasibility.....	2-12
29	2.4.2 Median Household Income	2-12
30	2.4.3 Annual Average Water Bill	2-12
31	2.4.4 Financial Plan Development.....	2-13
32	2.4.5 Financial Plan Results.....	2-14

1	SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS	3-1
2	3.1 Regional Analysis.....	3-1
3	3.1.1 Overview of the Study Area	3-1
4	3.1.2 Contaminants of Concern in the Study Area	3-3
5	3.1.3 Regional Hydrogeology	3-14
6	3.2 Detailed Assessment for Riviera Independent School District	3-15
7	3.2.1 Summary of Alternative Groundwater Sources for the Riviera ISD	
8	PWS	3-17
9	SECTION 4 ANALYSIS OF THE RIVIERA ISD PWS	4-1
10	4.1 Description of Existing System.....	4-1
11	4.1.1 Existing System	4-1
12	4.1.2 Capacity Assessment for the Riviera ISD PWS.....	4-3
13	4.2 Alternative Water Source Development.....	4-5
14	4.2.1 Identification of Alternative Existing Public Water Supply Sources	4-5
15	4.2.2 Potential for New Groundwater Sources	4-7
16	4.2.3 Potential for New Surface Water Sources	4-9
17	4.2.4 Options for Detailed Consideration	4-9
18	4.3 Central Treatment Options	4-10
19	4.4 Alternative Development and Analysis.....	4-10
20	4.4.1 Alternative RI-1: Purchase Water from Baffin Bay WSC.....	4-10
21	4.4.2 Alternative RI-2: New Well at 10 miles	4-11
22	4.4.3 Alternative RI-3: New Well at 5 miles	4-12
23	4.4.4 Alternative RI-4: New Well at 1 mile.....	4-13
24	4.4.5 Alternative RI-5: Central RO Treatment	4-14
25	4.4.6 Alternative RI-6: Central Coagulation Filtration Treatment	4-14
26	4.4.7 Alternative RI-7: Central IX Treatment.....	4-15
27	4.4.8 Summary of Alternatives	4-15
28	4.5 Cost of Service and Funding Analysis	4-17
29	4.5.1 Financial Plan Development	4-17
30	4.5.2 Current Financial Condition	4-18
31	4.5.3 Financial Plan Results.....	4-18
32	4.5.4 Evaluation of Potential Funding Options.....	4-21
33	SECTION 5 REFERENCES	5-1
34		

1 **APPENDICES**

- 2 Appendix A PWS Interview Form
3 Appendix B Cost Basis
4 Appendix C Compliance Alternative Conceptual Cost Estimates
5 Appendix D Example Financial Model
6 Appendix E Analysis of Shared Solutions for Obtaining Water from Baffin Bay
7 Water System

8

9

LIST OF TABLES

- 10 Table ES.1 Riviera ISD PWS Basic System Information ES-1
11 Table ES.2 Selected Financial Analysis Results ES-5
12 Table 3.1 Summary of Wells that Exceed the MCL for Arsenic, by Aquifer 3-4
13 Table 3.2 Uranium Concentration in the Riviera ISD PWS 3-15
14 Table 4.1 Selected Public Water Systems within 15 Miles of the Riviera ISD PWS 4-6
15 Table 4.2 Public Water Systems within the Vicinity of the Riviera ISD PWS Selected for
16 Further Evaluation 4-7
17 Table 4.3 Summary of Compliance Alternatives for the Riviera ISD PWS 4-16
18 Table 4.4 Financial Impact on Households for the Riviera ISD PWS 4-19

19

LIST OF FIGURES

1		
2	Figure ES.1 Summary of Project Methods.....	ES-3
3	Figure 1.1 Riviera ISD PWS Location Map.....	1-2
4	Figure 1.2 Groundwater Districts, Conservation Areas, Municipal Authorities, and Planning	
5	Groups	1-3
6	Figure 2.1 Decision Tree – Tree 1 Existing Facility Analysis.....	2-2
7	Figure 2.2 Decision Tree – Tree 2 Develop Treatment Alternatives.....	2-3
8	Figure 2.3 Decision Tree – Tree 3 Preliminary Analysis	2-4
9	Figure 2.4 Decision Tree – Tree 4 Financial and Managerial	2-5
10	Figure 3.1 Regional Study Area and Locations of the PWS Wells Assessed.....	3-1
11	Figure 3.2 Major (a) and Minor (b) Aquifers in the Study Area	3-2
12	Figure 3.3 Spatial Distribution of Arsenic Concentrations.....	3-3
13	Figure 3.4 Arsenic Concentrations and Well Depths within the Study Area	3-5
14	Figure 3.5 Arsenic Concentrations and Well Depths in the Study Area from the TWDB	
15	Database	3-6
16	Figure 3.6 Locations of Possible Sources of Arsenic Contamination	3-7
17	Figure 3.7 Spatial Distribution of Uranium Concentrations.....	3-8
18	Figure 3.8 Uranium Concentrations and Well Depths within the Study Area.....	3-9
19	Figure 3.9 Uranium Concentrations and Well Depths in the Study Area from the NURE	
20	Database	3-10
21	Figure 3.10 Spatial Distribution of Gross Alpha Concentrations in the Study Area.....	3-11
22	Figure 3.11 Spatial Distribution of Combined Radium Concentrations in the Study Area...3-12	
23	Figure 3.12 Combined Radium Concentrations and Well Depths within the Study Area3-13	
24	Figure 3.13 Locations of Possible Sources of Radium Contamination in the Study Area3-14	
25	Figure 3.14 Uranium Concentrations within 5- and 10-km Buffers around the Riviera ISD	
26	PWS.....	3-16
27	Figure 4.1 Riviera ISD PWS.....	4-2
28	Figure 4.2 Alternative Cost Summary: Riviera ISD PWS.....	4-20
29		

1

ACRONYMS AND ABBREVIATIONS

µg/L	Micrograms per liter
BAT	best available technology
BEG	Bureau of Economic Geology
CA	cellulose acetate
CCN	certificate of convenience and necessity
CD	Community Development
CDBG	Community Development Block Grant
CFR	Code of Federal Regulations
DWSRF	Drinking Water State Revolving Fund
EDAP	Economically distressed Areas Program
FMT	Financial, managerial, and technical
GAM	Groundwater Availability Model
gpd	gallons per day
HUD	U.S. Department of Housing and Urban Development
ISD	Independent School District
IX	Ion exchange
MCL	Maximum contaminant level
mg/L	Milligram per liter
mgd	Million gallons per day
MHI	Median household income
NF	nanofiltration
NMEFC	New Mexico Environmental Financial Center
NURE	National Uranium Resource Evaluation
O&M	Operation and Maintenance
ORCA	Office of Rural Community Affairs
Parsons	Parsons Transportation Group, Inc.
pCi/L	picoCuries per liter
POE	Point-of-entry
POU	Point-of-use
psi	pounds per square inch
PWS	Public Water System
RFP	Revolving Fund Program
RO	Reverse osmosis
RUS	Rural Utilities Service
RWAF	Rural Water Assistance Fund
SDWA	Safe Drinking Water Act
STEP	Small Towns Environment Program

TAC	Texas Administrative Code
TCEQ	Texas Commission on Environmental Quality
TCF	Texas Capital Fund
TDA	Texas Department of Agriculture
TDS	total dissolved solids
TFC	thin film composite
TSS	total suspended solids
TWDB	Texas Water Development Board
USEPA	United States Environmental Protection Agency
WAM	Water Availability Model
WEP	Water and Environment Program
WRT	Water Remediation Technologies, Inc.
WSC	water supply corporation

1
2
3



SECTION 1 INTRODUCTION

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Transportation Group Inc. (Parsons), were contracted by the Texas Commission on Environmental Quality (TCEQ) to assist with identifying and analyzing compliance alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

The overall goal of this project is to promote compliance using sound engineering and financial methods and data for PWSs that have recently had sample results that exceed maximum contaminant levels (MCL). The primary objectives of this project are to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS with regard to future implementation. The feasibility studies identify a range of potential compliance alternatives, and present basic data that can be used for evaluating feasibility. The compliance alternatives addressed include a description of what would be required for implementation, conceptual cost estimates for implementation, and non-cost factors that could be used to differentiate between alternatives. The cost estimates are intended for comparing compliance alternatives, and to give a preliminary indication of potential impacts on water rates resulting from implementation.

It is anticipated the PWS will review the compliance alternatives in this report to determine if there are promising alternatives, and then select the most attractive alternative(s) for more detailed evaluation and possible subsequent implementation. This report contains a decision tree approach that guided the efforts for this project, and also contains steps to guide a PWS through the subsequent evaluation, selection, and implementation of a compliance alternative.

This feasibility report provides an evaluation of water supply compliance options for the Riviera Independent School District (ISD) Public Water Supply, PWS ID# 1370019, located in Kleberg County, Texas, hereinafter referred to in this document as the “Riviera ISD PWS.” Recent sample results from the Riviera ISD PWS exceeded the MCL for combined uranium of 0.030 milligrams per liter (mg/L) (USEPA 2008a; TCEQ 2004). The location of the Riviera ISD PWS is shown on Figure 1.1. Various water supply and planning jurisdictions are shown on Figure 1.2. These water supply and planning jurisdictions are used in the evaluation of alternate water supplies that may be available in the area.



J:\647647010.BEG 2008\GIS\mxd\Report\Figure1-1.mxd August 14, 2008 10:54:54 AM




 	Legend	
	<ul style="list-style-type: none">  Study System  PWS's  Cities  City Limits  Counties 	<ul style="list-style-type: none">  Interstate  Highway  Major Road  Minor Road

Figure 1.1

RIVIERA ISD

Location Map



- Legend**
- Study System
 - PWS's
 - ▲ Cities
 - City Limits
 - Counties
 - Interstate
 - Highway
 - Major Road
 - Minor Road
 - Kenedy County GCD




Figure 1.2

RIVIERA ISD
Groundwater Conservation Districts

1.1 PUBLIC HEALTH AND COMPLIANCE WITH MCLs

The goal of this project is to promote compliance for PWSs that supply drinking water exceeding regulatory MCLs. This project only addresses those contaminants and does not address any other violations that may exist for a PWS. As mentioned above, the Riviera ISD PWS had recent sample results exceeding the MCL for combined uranium. In general, contaminant(s) in drinking water above the MCL(s) can have both short-term (acute) and long-term or lifetime (chronic) effects. Long-term ingestion of drinking water with combined uranium above the MCL may increase the risk of cancer and kidney toxicity (USEPA 2008b).

1.2 METHOD

The method for this project follows that of a pilot project performed by TCEQ, BEG, and Parsons. The pilot project evaluated water supply alternatives for PWSs that supplied drinking water with contaminant concentrations above U.S. Environmental Protection Agency (USEPA) and Texas drinking water standards. Three PWSs were evaluated in the pilot project to develop the method (*i.e.*, decision tree approach) for analyzing options for provision of compliant drinking water. This project is performed using the decision tree approach that was developed for the pilot project, and which was also used for subsequent projects.

Other tasks of the feasibility study are as follows:

- Identifying available data sources;
- Gathering and compiling data;
- Conducting financial, managerial, and technical (FMT) evaluations of the selected PWSs;
- Performing a geologic and hydrogeologic assessment of the area;
- Developing treatment and non-treatment compliance alternatives;
- Assessing potential alternatives with respect to economic and non-economic criteria;
- Preparing a feasibility report; and
- Suggesting refinements to the approach for future studies.

The remainder of Section 1 of this report addresses the regulatory background, and provides a summary of combined uranium abatement options. Section 2 describes the method used to develop and assess compliance alternatives. The groundwater sources of combined uranium are addressed in Section 3. Findings for the Riviera ISD PWS, along with compliance alternatives development and evaluation, can be found in Section 4. Section 5 references the sources used in this report.

1.3 REGULATORY PERSPECTIVE

The Utilities & Districts and Public Drinking Water Sections of the TCEQ Water Supply Division are responsible for implementing requirements of the Federal Safe Drinking Water

1 Act (SDWA), which include oversight of PWSs and water utilities. These responsibilities
2 include:

- 3 • Monitoring public drinking water quality;
- 4 • Processing enforcement referrals for MCL violators;
- 5 • Tracking and analyzing compliance options for MCL violators;
- 6 • Providing FMT assessment and assistance to PWSs;
- 7 • Participating in the Drinking Water State Revolving Fund program to assist PWSs in
8 achieving regulatory compliance; and
- 9 • Setting rates for privately owned water utilities.

10 This project was conducted to assist in achieving these responsibilities.

11 **1.4 ABATEMENT OPTIONS**

12 When a PWS exceeds a regulatory MCL, the PWS must take action to correct the
13 violation. The MCL exceedances at the Riviera ISD PWS involve combined uranium. The
14 following subsections explore alternatives considered as potential options for
15 obtaining/providing compliant drinking water.

16 **1.4.1 Existing Public Water Supply Systems**

17 A common approach to achieving compliance is for the PWS to make arrangements with a
18 neighboring PWS for water supply. For this arrangement to work, the PWS from which water
19 is being purchased (supplier PWS) must have water in sufficient quantity and quality, the
20 political will must exist, and it must be economically feasible.

21 **1.4.1.1 Quantity**

22 For purposes of this report, quantity refers to water volume, flowrate, and pressure. Before
23 approaching a potential supplier PWS, the non-compliant PWS should determine its water
24 demand on the basis of average day and maximum day. Peak instantaneous demands can be
25 met through proper sizing of storage facilities. Further, the potential for obtaining the
26 appropriate quantity of water to blend to achieve compliance should be considered. The
27 concept of blending involves combining water with low levels of contaminants with non-
28 compliant water in sufficient quantity that the resulting blended water is compliant. The exact
29 blend ratio would depend on the quality of the water a potential supplier PWS can provide, and
30 would likely vary over time. If high quality water is purchased, produced or otherwise
31 obtained, blending can reduce the amount of high quality water required. Implementation of
32 blending will require a control system to ensure the blended water is compliant.

33 If the supplier PWS does not have sufficient quantity, the non-compliant community could
34 pay for the facilities necessary to increase the quantity to the extent necessary to supply the

1 needs of the non-compliant PWS. Potential improvements might include, but are not limited
2 to:

- 3 • Additional wells;
- 4 • Developing a new surface water supply,
- 5 • Additional or larger-diameter piping;
- 6 • Increasing water treatment plant capacity
- 7 • Additional storage tank volume;
- 8 • Reduction of system losses,
- 9 • Higher-pressure pumps; or
- 10 • Upsized, or additional, disinfection equipment.

11 In addition to the necessary improvements, a transmission pipeline would need to be
12 constructed to tie the two PWSs together. The pipeline must tie-in at a point in the supplier
13 PWS where all the upstream pipes and appurtenances are of sufficient capacity to handle the
14 new demand. In the non-compliant PWS, the pipeline must tie in at a point where no down
15 stream bottlenecks are present. If blending is the selected method of operation, the tie-in point
16 must be selected to ensure all the water in the system is blended to achieve regulatory
17 compliance.

18 **1.4.1.2 Quality**

19 If a potential supplier PWS obtains its water from the same aquifer (or same portion of the
20 aquifer) as the non-compliant PWS, the quality of water may not be significantly better.
21 However, water quality can vary significantly due to well location, even within the same
22 aquifer. If localized areas with good water quality cannot be identified, the non-compliant
23 PWS would need to find a potential supplier PWS that obtains its water from a different aquifer
24 or from a surface water source. Additionally, a potential supplier PWS may treat non-
25 compliant raw water to an acceptable level.

26 Surface water sources may offer a potential higher-quality source. Since there are
27 significant treatment requirements, utilization of surface water for drinking water is typically
28 most feasible for larger local or regional authorities or other entities that may provide water to
29 several PWSs. Where PWSs that obtain surface water are neighbors, the non-compliant PWS
30 may need to deal with those systems as well as with the water authorities that supply the
31 surface water.

32 **1.4.2 Potential for New Groundwater Sources**

33 **1.4.2.1 Existing Non-Public Supply Wells**

34 Often there are wells not associated with PWSs located in the vicinity of the non-compliant
35 PWS. The current use of these wells may be for irrigation, industrial purposes, domestic

1 supply, stock watering, and other purposes. The process for investigating existing wells is as
2 follows:

- 3 • Existing data sources (see below) will be used to identify wells in the areas that have
4 satisfactory quality. For the Riviera ISD PWS, the following standards could be used in
5 a rough screening to identify compliant groundwater in surrounding systems:
 - 6 ○ Nitrate (measured as nitrogen) concentrations less than 8 mg/L (below the MCL
7 of 10 mg/L);
 - 8 ○ Fluoride concentration less than 2.0 mg/L (below the Secondary MCL of
9 2 mg/L);
 - 10 ○ Arsenic concentration less than 0.008 mg/L (below the MCL of 0.01 mg/L);
 - 11 ○ Uranium concentration less than 0.024 mg/L (below the MCL of 0.030 mg/L;
12 and
 - 13 ○ Selenium concentration less than 0.04 mg/L (below the MCL of 0.05 mg/L).
- 14 • The recorded well information will be reviewed to eliminate those wells that appear to
15 be unsuitable for the application. Often, the “Remarks” column in the Texas Water
16 Development Board (TWDB) hard-copy database provides helpful information. Wells
17 eliminated from consideration generally include domestic and stock wells, dug wells,
18 test holes, observation wells, seeps and springs, destroyed wells, wells used by other
19 communities, etc.
- 20 • Wells of sufficient size are identified. Some may be used for industrial or irrigation
21 purposes. Often the TWDB database will include well yields, which may indicate the
22 likelihood that a particular well is a satisfactory source.
- 23 • At this point in the process, the local groundwater control district (if one exists) should
24 be contacted to obtain information about pumping restrictions. Also, preliminary cost
25 estimates should be made to establish the feasibility of pursuing further well
26 development options.
- 27 • If particular wells appear to be acceptable, the owner(s) should be contacted to ascertain
28 their willingness to work with the PWS. Once the owner agrees to participate in the
29 program, questions should be asked about the wells. Many owners have more than one
30 well, and would probably be the best source of information regarding the latest test
31 dates, who tested the water, flowrates, and other well characteristics.
- 32 • After collecting as much information as possible from cooperative owners, the PWS
33 would then narrow the selection of wells and sample and analyze them for quality.
34 Wells with good quality water would then be potential candidates for test pumping. In
35 some cases, a particular well may need to be refurbished before test pumping.
36 Information obtained from test pumping would then be used in combination with
37 information about the general characteristics of the aquifer to determine whether a well
38 at that location would be suitable as a supply source.

- 1 • It is recommended that new wells be installed instead of using existing wells to ensure
2 the well characteristics are known and the well meets construction standards.
- 3 • Permit(s) would then be obtained from the groundwater control district or other
4 regulatory authority, and an agreement with the owner (purchase or lease, access
5 easements, etc.) would then be negotiated.

6 **1.4.2.2 Develop New Wells**

7 If no existing wells are available for development, the PWS or group of PWSs has an
8 option of developing new wells. Records of existing wells, along with other hydrogeologic
9 information and modern geophysical techniques, should be used to identify potential locations
10 for new wells. In some areas, the TWDB’s Groundwater Availability Model (GAM) may be
11 applied to indicate potential sources. Once a general area is identified, land owners and
12 regulatory agencies should be contacted to determine an exact location for a new well or well
13 field. Pump tests and water quality tests would be required to determine if a new well will
14 produce an adequate quantity of good quality water. Permits from the local groundwater
15 control district or other regulatory authority could also be required for a new well.

16 **1.4.3 Potential for Surface Water Sources**

17 Water rights law dominates the acquisition of water from surface water sources. For a
18 PWS, 100 percent availability of water is required, except where a back-up source is available.
19 For PWSs with an existing water source, although it may be non-compliant because of elevated
20 concentrations of one or more parameters, water rights may not need to be 100 percent
21 available.

22 **1.4.3.1 Existing Surface Water Sources**

23 “Existing surface water sources” of water refers to municipal water authorities and cities
24 that obtain water from surface water sources. The process of obtaining water from such a
25 source is generally less time consuming and less costly than the process of developing a new
26 source; therefore, it should be a primary course of investigation. An existing source would be
27 limited by its water rights, the safe yield of a reservoir or river, or by its water treatment or
28 water conveyance capability. The source must be able to meet the current demand and honor
29 contracts with communities it currently supplies. In many cases, the contract amounts reflect
30 projected future water demand based on population or industrial growth.

31 A non-compliant PWS would look for a source with sufficient spare capacity. Where no
32 such capacity exists, the non-compliant PWS could offer to fund the improvements necessary
33 to obtain the capacity. This approach would work only where the safe yield could be increased
34 (perhaps by enlarging a reservoir) or where treatment capacity could be increased. In some
35 instances water rights, where they are available, could possibly be purchased.

36 In addition to securing the water supply from an existing source, the non-compliant PWS
37 would need to arrange for transmission of the water to the PWS. In some cases, that could
38 require negotiations with, contracts with, and payments to an intermediate PWS (an

1 intermediate PWS is one where the infrastructure is used to transmit water from a “supplier”
2 PWS to a “supplied” PWS, but does not provide any additional treatment to the supplied
3 water). The non-compliant PWS could be faced with having to fund improvements to the
4 intermediate PWS in addition to constructing its own necessary transmission facilities.

5 **1.4.3.2 New Surface Water Sources**

6 Communication with the TCEQ and relevant planning groups from the beginning is
7 essential in the process of obtaining a new surface water source. Preliminary assessment of the
8 potential for acquiring new rights may be based on surface water availability maps located on
9 the TWDB website. Where water rights appear to be available, the following activities need to
10 occur:

- 11 • Discussions with TCEQ to indicate the likelihood of obtaining those rights. The TCEQ
12 may use the Water Availability Model (WAM) to assist in the determination.
- 13 • Discussions with land owners to indicate potential treatment plant locations.
- 14 • Coordination with U.S. Army Corps of Engineers and local river authorities.
- 15 • Preliminary engineering design to determine the feasibility, costs, and environmental
16 issues of a new treatment plant.

17 Should these discussions indicate that a new surface water source is the best option, the
18 community would proceed with more intensive planning (initially obtaining funding),
19 permitting, land acquisition, and detailed designs.

20 **1.4.4 Identification of Treatment Technologies**

21 Various treatment technologies were also investigated as compliance alternatives for
22 treatment of uranium to regulatory levels (*i.e.*, MCLs). Several options have been identified by
23 the USEPA as best available technologies (BAT) for non-compliant constituents. Identification
24 and descriptions of the various BATs are provided in the following sections.

25 The MCL for uranium was set at 30 mg/L by the USEPA on December 7, 2000. This
26 MCL applies to all community water systems with 15 or more service connections or 25
27 residents regularly year round.

28 The uranium isotopes U-234, U-235, and U-238 combine with carbonate to form
29 complexed anions (*e.g.*, $\text{UO}_2(\text{CO}_3)_2^{2-}$ and $\text{UO}_2(\text{CO}_3)_3^{4-}$), which are dissolved in water at pH
30 between 6.0 and 8.2, and are not easily removed by particle filtration. The MCL for total
31 uranium is 0.030 mg/L, which is equivalent to 20.1 pCi/L as radioactivity.

32 The following BATs were identified in the Radionuclides Final Rule for achieving
33 compliance with the uranium MCL:

- 34 • Ion exchange;
- 35 • Reverse osmosis;

- 1 • Lime softening; and
- 2 • Coagulation/filtration.

3 In addition, the following technologies are included in the Radionuclides Final Rule as
4 small system compliance technologies:

- 5 • Ion Exchange (Centralized and Point-of-use);
- 6 • Reverse Osmosis (Centralized and Point-of-use);
- 7 • Lime softening;
- 8 • Activated Alumina; and
- 9 • Coagulation/filtration.

10 Other technologies that can removal uranium include electro dialysis or electro dialysis
11 reversal and Water Remediation Technologies, Inc. (WRT) Z-92 adsorption.

12 The Reverse Osmosis (RO) and Ion Exchange (IX) processes are suitable for point-of-use
13 systems.

14 **1.4.5 Treatment Technologies Description**

15 The suitability of a particular BAT depends on multiple factors including the size of the
16 system, the quality of the raw water and the available skill of the operators. The lime softening
17 process requires an advanced level of operator skill and is generally suitable for larger capacity
18 systems. In this section the other three BAT technologies for uranium removal suitable for
19 small community central treatment systems are described.

20 **1.4.5.1 Reverse Osmosis**

21 Process. RO is a physical process in which contaminants are removed by applying
22 pressure on the feed water to force it through a semi-permeable membrane. RO membranes
23 reject ions based on size and electrical charge. The raw water is typically called feed; the
24 product water is called permeate; and the concentrated reject is called concentrate. Common
25 RO membrane materials include asymmetric cellulose acetate (CA) or polyamide thin film
26 composite (TFC). The TFC membrane operates at much lower pressure and can achieve higher
27 salt rejection than the CA membranes but is less chlorine resistant. Each material has specific
28 benefits and limitations depending on the raw water characteristics and pre-treatment. A
29 newer, lower pressure type membrane that is similar in operation to spiral wound RO, is
30 nanofiltration (NF), which has higher rejection for divalent ions than mono-valent ions. NF is
31 sometimes used instead of RO for treating water with high hardness and sulfate concentrations.
32 A typical RO installation includes a high pressure feed pump; parallel first and second stage
33 membrane elements (in pressure vessels); and valves and piping for feed, permeate, and
34 concentrate streams. Factors influencing membrane selection are cost, recovery, rejection, raw
35 water characteristics, and pre-treatment. Factors influencing performance are raw water
36 characteristics, pressure, temperature, and regular monitoring and maintenance. Depending on

1 the membrane type and operating pressure, RO is capable of removing 90-98 percent of the
2 uranium. The treatment process is relatively insensitive to pH. Water recovery is 60-
3 80 percent, depending on raw water characteristics. The concentrate volume for disposal can
4 be significant. The conventional RO treatment train for well water uses anti-scalant addition,
5 cartridge filtration, RO membranes, chlorine disinfection, and clearwell storage.

6 Pre-treatment. RO requires careful review of raw water characteristics, and pre-treatment
7 needs to prevent membranes from fouling, scaling, or other membrane degradation. Removal
8 or sequestering of suspended solids is necessary to prevent colloidal and bio-fouling, and
9 removal of sparingly soluble constituents such as calcium, magnesium, silica, sulfate, barium,
10 *etc.*, may be required to prevent scaling. Pretreatment can include media filters to remove
11 suspended particles; IX softening to remove hardness; antiscalant feed; temperature and pH
12 adjustment to maintain efficiency; acid to prevent scaling and membrane damage; activated
13 carbon or bisulfite to remove chlorine (post-disinfection may be required); and cartridge filters
14 to remove any remaining suspended particles to protect membranes from upsets.

15 Maintenance. Rejection percentages must be monitored to ensure contaminant removal
16 below MCLs. Regular monitoring of membrane performance is necessary to determine
17 fouling, scaling, or other membrane degradation. Use of monitoring equipment to track
18 membrane performance is recommended. Acidic or caustic solutions are regularly flushed
19 through the system at high volume/low pressure with a cleaning agent to remove fouling and
20 scaling. The system is flushed and returned to service. RO stages are cleaned sequentially.
21 Frequency of membrane replacement is dependent on raw water characteristics, pre-treatment,
22 and maintenance.

23 Waste Disposal. Pre-treatment waste streams, concentrate flows, and spent filters and
24 membrane elements all require approved disposal methods. Disposal of the significant volume
25 of the concentrate stream is a problem for many utilities.

26 **Advantages (RO)**

- 27 • Produces the highest water quality.
- 28 • Can effectively treat a wide range of dissolved salts and minerals, turbidity, health and
29 aesthetic contaminants, and certain organics. Some highly-maintained units are capable
30 of treating biological contaminants.
- 31 • Low pressure - less than 100 pounds per square inch (psi), compact, self-contained,
32 single membrane units are available for small installations.

33 **Disadvantages (RO)**

- 34 • Relatively expensive to install and operate.
- 35 • Provides a higher level of treatment than required, especially if total dissolved solids
36 (TDS) reduction not required.

- 1 • Frequent membrane monitoring and maintenance; pressure, temperature, and pH
- 2 requirements to meet membrane tolerances. Membranes can be chemically sensitive.
- 3 • Additional water usage depending on rejection rate.
- 4 • Concentrate disposal required.

5 A concern with RO for treatment of inorganics is that if the full stream is treated, then
6 most of the alkalinity and hardness would also be removed. In that event, post-treatment may
7 be necessary to avoid corrosion problems. If feasible, a way to avoid this issue is to treat a slip
8 stream of raw water and blend the slip stream back with the raw water rather than treat the full
9 stream. The amount of water rejected is also an issue with RO. Discharge concentrate flow
10 can be between 10 and 50 percent of the influent flow.

11 **1.4.5.2 Enhanced Coagulation/Filtration**

12 Process – The coagulation-filtration process when enhanced by the addition of iron or
13 aluminum coagulants can remove 50 to 90 percent of the uranium. Filtration can be
14 accomplished with granular media filters or microfilters. The coagulant is added and then the
15 water is mixed to provide 30 to 120 seconds for precipitation of the coagulant. In some
16 systems a longer coagulation period is required, typically determined by pilot or bench scale
17 testing.

18 The actual capacity to remove uranium by the enhanced coagulation-filtration process
19 depends on a number of factors, including the amount of uranium present, the uranium
20 speciation, pH, amount and type of coagulant used, and the overall water composition. The
21 filters used in groundwater treatment are usually pressure filters fed directly by the well pumps.
22 The filter media can be regular dual media filters or proprietary media such as the engineered
23 ceramic filtration media, Macrolite, developed by Kinetico. Macrolite is a low-density,
24 spherical media designed to allow for filtration rates up to 10 gpm/ft², which is a higher loading
25 rate than commonly used for conventional filtration media.

26 Maintenance – Maintenance is mainly to handle the coagulant chemicals, the coagulant
27 feed system, and to provide for regular backwash of the filters. The filters typically last 5 to 8
28 years.

29 Waste Disposal – The waste from the coagulation/filtration process is mainly the iron
30 hydroxide or alum sludge with adsorbed uranium in the backwash water. The backwash water
31 can possibly be discharged to a public sewer if it is available and if the uranium concentration
32 is below regulatory limits. If a sewer is not available, the backwash water can be discharged to
33 a storage-settling tank from where the supernatant is recycled in a controlled rate to the front of
34 the treatment system and the settled sludge can be disposed of appropriately. Depending on the
35 concentration of uranium in the sludge, it may be classified as a radioactive waste and require
36 special disposal.

1 **Advantages (Coagulation/Filtration)**

- 2 • Established technology for uranium removal; and
3 • Economical process for uranium removal.

4 **Disadvantages (Coagulation/Filtration)**

- 5 • Need to handle chemical;
6 • Need to dispose of regular backwash wastewater; and
7 • Need to dispose of sludge.

8 A concern for enhanced coagulation-filtration is management of the filter backwash. This
9 often involves sludge thickening and dewatering. For small capacity systems, the thickened
10 spent backwash can be trucked to an approved disposal site.

11 **1.4.5.3 Ion Exchange**

12 Process – In solution, salts separate into positively charged cations and negatively charged
13 anions. Ion exchange is a reversible chemical process in which ions from an insoluble,
14 permanent, solid resin bed are exchanged for ions in the water. The process relies on the fact
15 that certain ions are preferentially adsorbed on the ion exchange resin. Operation begins with a
16 fully charged cation or anion bed, having enough positively or negatively charged ions to carry
17 out the cation or anion exchange. Usually a polymeric resin bed is composed of millions of
18 spherical beads about the size of medium sand grains. As water passes the resin bed, the
19 charged ions are released into the water, being substituted or replaced with the contaminants in
20 the water (IX). When the resin becomes saturated with the contaminant ions, the bed must be
21 regenerated by passing or pumping a concentrated sodium chloride solution over the resin,
22 displacing the contaminant ions with sodium ions for cation exchange resins and chloride ions
23 for anion exchange resins. Many different types of resins can be used depending on the
24 specific contaminant to be removed.

25 The IX treatment train for groundwater typically consists of an ion exchange system
26 containing cation or anion resin, chlorine disinfection, and clear well storage. The ion
27 exchange system has provisions for regeneration with salt (sodium chloride) and generates
28 approximately 2 to 4% of waste or “spent” regeneration solutions. Treatment trains for surface
29 water may also include raw water pumps, debris screens, and filters for pre-treatment.
30 Additional treatment or management of the spent regeneration salt solutions and the removed
31 solids will be necessary prior to disposal, especially for radium removal resins which have
32 elevated radioactivity.

33 For uranium removal, a strong base anionic exchange resin in the chloride form can
34 remove 90 to 95 percent of the uranium. The uranium carbonate complex has a relatively high
35 affinity for strong base anion exchange resins that is over 100 times greater than any common
36 ions, including divalent anions like sulfate and carbonate. Typically 10,000 to 50,000 bed
37 volumes are treated before the resin has to be regenerated.

1 Pretreatment – Pretreatment guidelines are available on accepted limits for pH, organics,
2 turbidity, and other raw water characteristics. Pretreatment may be required to reduce
3 excessive amounts of total suspended solids (TSS), iron, and manganese, which could plug the
4 resin bed, and typically includes media or carbon filtration.

5 Maintenance – The IX resin requires regular on-site regeneration, the frequency of which
6 depends on raw water characteristics (especially hardness), the contaminant concentration, and
7 the size and number of IX vessels. Many systems have undersized the IX vessels only to
8 realize higher than necessary operating costs. Preparation of the sodium chloride solution is
9 required. If used, filter replacement and backwashing will be required.

10 Waste Disposal – Approval from local authorities is usually required for disposal of
11 concentrate from the regeneration cycle (highly concentrated salt solution with radioactivity);
12 occasional solids wastes (in the form of broken resin beads) which are backwashed during
13 regeneration; and if used, spent filters and backwash wastewater.

14 **Advantages**

- 15 • Well established process for radium removal.
- 16 • Fully automated and highly reliable process.
- 17 • Suitable for small and large installations.

18 **Disadvantages**

- 19 • Requires salt storage; regular regeneration.
- 20 • Generates a liquid waste requiring disposal.
- 21 • Resins are sensitive to the presence of competing ions such as calcium and
22 magnesium which reduces the effectiveness for radium removal.

23 In considering application of IX for inorganic, it is important to understand what the effect
24 of competing ions will be, and to what extent the brine can be recycled. Spent regenerant is
25 produced during IX bed regeneration, and it may have concentrations of the sorbed
26 contaminants which will be expensive to treat and/or dispose because of hazardous waste
27 regulations.

28 **1.4.6 Point-of-Entry and Point-of-Use Treatment Systems**

29 Point of entry treatment, while a possible alternative for residences, was not considered for
30 Riviera ISD PWS, since the large demands for the school connections would require treatment
31 units similar in size to central treatment units. Similarly, a POU alternative was not considered
32 for Roosevelt ISD due to the difficulty in providing POU units for all possible drinking water
33 taps.

1 **1.4.7 Water Delivery or Central Drinking Water Dispensers**

2 Water delivery and central drinking water dispensers were not considered viable
3 alternatives for a school application.

4

SECTION 2 EVALUATION METHOD

2.1 DECISION TREE

The decision tree is a flow chart for conducting feasibility studies for a non-compliant PWS. The decision tree is shown in Figures 2.1 through 2.4. The tree guides the user through a series of phases in the design process. Figure 2.1 shows Tree 1, which outlines the process for defining the existing system parameters, followed by optimizing the existing treatment system operation. If optimizing the existing system does not correct the deficiency, the tree leads to six alternative preliminary branches for investigation. The groundwater branch leads through investigating existing wells to developing a new well field. The treatment alternatives address centralized and on-site treatment. The objective of this phase is to develop conceptual designs and cost estimates for the six types of alternatives. The work done for this report follows through Tree 1 and Tree 2, as well as a preliminary pass through Tree 4.

Tree 3, which begins at the conclusion of the work for this report, starts with a comparison of the conceptual designs, selecting the two or three alternatives that appear to be most promising, and eliminating those alternatives that are obviously infeasible. It is envisaged that a process similar to this would be used by the study PWS to refine the list of viable alternatives. The selected alternatives are then subjected to intensive investigation, and highlighted by an investigation into the socio-political aspects of implementation. Designs are further refined and compared, resulting in the selection of a preferred alternative. The steps for assessing the financial and economic aspects of the alternatives (one of the steps in Tree 3) are given in Tree 4 in Figure 2.4.

2.2 DATA SOURCES AND DATA COLLECTION

2.2.1 Data Search

2.2.1.1 Water Supply Systems

The TCEQ maintains a set of files on public water systems, utilities, and districts at its headquarters in Austin, Texas. The files are organized under two identifiers: a PWS identification number and a Certificate of Convenience and Necessity (CCN) number. The PWS identification number is used to retrieve four types of files:

- CO – Correspondence,
- CA – Chemical analysis,
- MOR – Monthly operating reports (quality/quantity), and
- FMT – Financial, managerial and technical issues.

Figure 2.1
TREE 1 – EXISTING FACILITY ANALYSIS




Figure 2.2
TREE 2 – DEVELOP TREATMENT ALTERNATIVES





Figure 2.4
TREE 4 – FINANCIAL



1 The CCN files generally contain a copy of the system’s Certificate of Convenience and
2 Necessity, along with maps and other technical data.

3 These files were reviewed for the PWS and surrounding systems.

4 The following websites were consulted to identify the water supply systems in the area:

- 5 • Texas Commission on Environmental Quality
6 www3.tceq.state.tx.us/iwud/.
- 7 • USEPA Safe Drinking Water Information System
8 www.epa.gov/safewater/data/getdata.html

9 Groundwater Control Districts were identified on the TWDB web site, which has a series
10 of maps covering various groundwater and surface water subjects. One of those maps shows
11 groundwater control districts in the State of Texas.

12 **2.2.1.2 Existing Wells**

13 The TWDB maintains a groundwater database available at www.twdb.state.tx.us that has
14 two tables with helpful information. The “Well Data Table” provides a physical description of
15 the well, owner, location in terms of latitude and longitude, current use, and for some wells,
16 items such as flowrate, and nature of the surrounding formation. The “Water Quality Table”
17 provides information on the aquifer and the various chemical concentrations in the water.

18 **2.2.1.3 Surface Water Sources**

19 Regional planning documents were consulted for lists of surface water sources.

20 **2.2.1.4 Groundwater Availability Model**

21 GAMs, developed by the TWDB, are planning tools and should be consulted as part of a
22 search for new or supplementary water sources. The GAM for the southern Gulf Coast Aquifer
23 was investigated as a potential tool for identifying available and suitable groundwater
24 resources.

25 **2.2.1.5 Water Availability Model**

26 The WAM is a computer-based simulation predicting the amount of water that would be in
27 a river or stream under a specified set of conditions. WAMs are used to determine whether
28 water would be available for a newly requested water right or amendment. If water is
29 available, these models estimate how often the applicant could count on water under various
30 conditions (*e.g.*, whether water would be available only one month out of the year, half the
31 year, or all year, and whether that water would be available in a repeat of the drought of
32 record).

33 WAMs provide information that assist TCEQ staff in determining whether to recommend
34 the granting or denial of an application.

1 **2.2.1.6 Financial Data**

2 An evaluation of existing data will yield an up-to-date assessment of the financial
3 condition of the water system. As part of a site visit, financial data were collected in various
4 forms such as electronic files, hard copy documents, and focused interviews. Financial data
5 were collected through a site visit. Data sought included:

- 6 • Annual Budget
- 7 • Audited Financial Statements
 - 8 ○ Balance Sheet
 - 9 ○ Income & Expense Statement
 - 10 ○ Cash Flow Statement
 - 11 ○ Debt Schedule
- 12 • Water Rate Structure
- 13 • Water Use Data
 - 14 ○ Production
 - 15 ○ Billing
 - 16 ○ Customer Counts

17 **2.2.1.7 Demographic Data**

18 Basic demographic data were collected from the 2000 Census to establish incomes and
19 eligibility for potential low cost funding for capital improvements. Median household income
20 (MHI) and number of families below poverty level were the primary data points of
21 significance. If available, MHI for the customers of the PWS should be used. In addition,
22 unemployment data were collected from current U.S. Bureau of Labor Statistics. These data
23 were collected for the following levels: national, state, and county.

24 **2.2.2 PWS Interviews**

25 **2.2.2.1 PWS Capacity Assessment Process**

26 Capacity assessment is the industry standard term for evaluation of a water system's FMT
27 capacity to effectively deliver safe drinking water to its customers now and in the future at a
28 reasonable cost, and to achieve, maintain and plan for compliance with applicable regulations.
29 The assessment process involves interviews with staff and management who have a
30 responsibility in the operations and management of the system.

31 Financial, managerial, and technical capacity are individual yet highly interrelated
32 components of a system's capacity. A system cannot sustain capacity without maintaining
33 adequate capability in all three components.

1 **Financial capacity** is a water system’s ability to acquire and manage sufficient financial
2 resources to allow the system to achieve and maintain compliance with SDWA regulations.
3 Financial capacity refers to the financial resources of the water system, including but not
4 limited to, revenue sufficiency, credit worthiness, and fiscal controls.

5 **Managerial capacity** is the ability of a water system to conduct its affairs so the system is
6 able to achieve and maintain compliance with SDWA requirements. Managerial capacity
7 refers to the management structure of the water system, including but not limited to, ownership
8 accountability, staffing and organization, and effective relationships with customers and
9 regulatory agencies.

10 **Technical capacity** is the physical and operational ability of a water system to achieve and
11 maintain compliance with SDWA regulations. It refers to the physical infrastructure of the
12 water system, including the adequacy of the source water, treatment, storage and distribution
13 infrastructure. It also refers to the ability of system personnel to effectively operate and
14 maintain the system and to otherwise implement essential technical knowledge.

15 Many aspects of water system operations involve more than one component of capacity.
16 Infrastructure replacement or improvement, for example, requires financial resources,
17 management planning and oversight, and technical knowledge. A deficiency in any one area
18 could disrupt the entire operation. A system that is able to meet both its immediate and long-
19 term challenges demonstrates that it has sufficient FMT capacity.

20 Assessment of FMT capacity of the PWS was based on an approach developed by the New
21 Mexico Environmental Finance Center (NMEFC), which is consistent with the TCEQ FMT
22 assessment process. This method was developed from work the NMEFC did while assisting
23 USEPA Region 6 in developing and piloting groundwater comprehensive performance
24 evaluations. The NMEFC developed a standard list of questions that could be asked of water
25 system personnel. The list was then tailored slightly to have two sets of questions – one for
26 managerial and financial personnel, and one for operations personnel (the questions are
27 included in Appendix A). Each person with a role in the FMT capacity of the system was
28 asked the applicable standard set of questions individually. The interviewees were not given
29 the questions in advance and were not told the answers others provided. Also, most of the
30 questions are open ended type questions so they were not asked in a fashion to indicate what
31 would be the “right” or “wrong” answer. The interviews lasted between 45 minutes to
32 75 minutes depending on the individual’s role in the system and the length of the individual’s
33 answers.

34 In addition to the interview process, visual observations of the physical components of the
35 system were made. A technical information form was created to capture this information. This
36 form is also contained in Appendix A. This information was considered supplemental to the
37 interviews because it served as a check on information provided in the interviews. For
38 example, if an interviewee stated he or she had an excellent preventative maintenance schedule
39 and the visit to the facility indicated a significant amount of deterioration (more than would be
40 expected for the age of the facility) then the preventative maintenance program could be further

1 investigated or the assessor could decide that the preventative maintenance program was
2 inadequate.

3 Following interviews and observations of the facility, answers that all personnel provided
4 were compared and contrasted to provide a clearer picture of the true operations at the water
5 system. The intent was to go beyond simply asking the question, “Do you have a budget?” to
6 actually finding out if the budget was developed and being used appropriately. For example, if
7 a water system manager was asked the question, “Do you have a budget?” he or she may say,
8 “yes” and the capacity assessor would be left with the impression that the system is doing well
9 in this area. However, if several different people are asked about the budget in more detail, the
10 assessor may find that although a budget is present, operations personnel do not have input into
11 the budget, the budget is not used by the financial personnel, the budget is not updated
12 regularly, or the budget is not used in setting or evaluating rates. With this approach, the
13 inadequacy of the budget would be discovered and the capacity deficiency in this area would be
14 noted.

15 Following the comparison of answers, the next step was to determine which items noted as
16 a potential deficiency truly had a negative effect on the system’s operations. If a system had
17 what appeared to be a deficiency, but this deficiency was not creating a problem in terms of the
18 operations or management of the system, it was not considered critical and may not have
19 needed to be addressed as a high priority. As an example, the assessment may have revealed an
20 insufficient number of staff members to operate the facility. However, it may also have been
21 revealed that the system was able to work around that problem by receiving assistance from a
22 neighboring system, so no severe problems resulted from the number of staff members.
23 Although staffing may not be ideal, the system does not need to focus on this particular issue.
24 The system needs to focus on items that are truly affecting operations. As an example of this
25 type of deficiency, a system may lack a reserve account which can then lead the system to
26 delay much-needed maintenance or repair on its storage tank. In this case, the system needs to
27 address the reserve account issue so that proper maintenance can be completed.

28 The intent was to develop a list of capacity deficiencies with the greatest impact on the
29 system’s overall capacity. Those were the most critical items to address through follow-up
30 technical assistance or by the system itself.

31 **2.2.2.2 Interview Process**

32 PWS personnel were interviewed by the project team, and each was interviewed
33 separately. Interview forms were completed during each interview.

34 **2.3 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

35 The initial objective for developing alternatives to address compliance issues is to identify
36 a comprehensive range of possible options that can be evaluated to determine the most
37 promising for implementation. Once the possible alternatives are identified, they must be
38 defined in sufficient detail so a conceptual cost estimate (capital and operation and
39 maintenance [O&M] costs) can be developed. These conceptual cost estimates are used to

1 compare the affordability of compliance alternatives, and to give a preliminary indication of
2 rate impacts. Consequently, these costs are pre-planning level and should not be viewed as
3 final estimated costs for alternative implementation. The basis for the unit costs used for the
4 compliance alternative cost estimates is summarized in Appendix B. Other non-economic
5 factors for the alternatives, such as reliability and ease of implementation, are also addressed

6 **2.3.1 Existing PWS**

7 The neighboring PWSs were identified, and the extents of their systems were investigated.
8 PWSs farther than 15 miles from the non-compliant PWSs were not considered because the
9 length of the pipeline required would make the alternative cost prohibitive. The quality of
10 water provided was also investigated. For neighboring PWSs with compliant water, options for
11 water purchase and/or expansion of existing well fields were considered. The neighboring
12 PWSs with non-compliant water were considered as possible partners in sharing the cost for
13 obtaining compliant water either through treatment or developing an alternate source.

14 The neighboring PWSs were investigated to get an idea of the water sources in use and the
15 quantity of water that might be available for sale. They were contacted to identify key
16 locations in their systems where a connection might be made to obtain water, and to explore on
17 a preliminary basis their willingness to partner or sell water. Then, the major system
18 components that would be required to provide compliant water were identified. The major
19 system components included treatment units, wells, storage tanks, pump stations, and pipelines.

20 Once the major components were identified, a preliminary design was developed to
21 identify sizing requirements and routings. A capital cost estimate was then developed based on
22 the preliminary design of the required system components. An annual O&M cost was also
23 estimated to reflect the change in O&M expenditures that would be needed if the alternative
24 was implemented.

25 Non-economic factors were also identified. Ease of implementation was considered, as
26 well as the reliability for providing adequate quantities of compliant water. Additional factors
27 were whether implementation of an alternative would require significant increase in the
28 management or technical capability of the PWS, and whether the alternative had the potential
29 for regionalization.

30 **2.3.2 New Groundwater Source**

31 It was not possible in the scope of this project to determine conclusively whether new
32 wells could be installed to provide compliant drinking water. To evaluate potential new
33 groundwater source alternatives, three test cases were developed based on distance from the
34 PWS intake point. The test cases were based on distances of 10 miles, 5 miles, and 1 mile. It
35 was assumed that a pipeline would be required for all three test cases, and a storage tank and
36 pump station would be required for the 10-mile and 5-mile alternatives. It was also assumed
37 that new wells would be installed, and that their depths would be similar to the depths of the
38 existing wells, or other existing drinking water wells in the area.

1 A preliminary design was developed to identify sizing requirements for the required
2 system components. A capital cost estimate was then developed based on the preliminary
3 design of the required system components. An annual O&M cost was also estimated to reflect
4 the change (*i.e.*, from current expenditures) in O&M expenditures that would be needed if the
5 alternative was implemented.

6 Non-economic factors were also identified. Ease of implementation was considered, as
7 well as the reliability for providing adequate quantities of compliant water. Additional factors
8 were whether implementation of an alternative would require significant increase in the
9 management or technical capability of the PWS, and whether the alternative had the potential
10 for regionalization.

11 **2.3.3 New Surface Water Source**

12 New surface water sources were investigated. Availability of adequate quality water was
13 investigated for the main rivers in the area, as well as the major reservoirs. TCEQ WAMs were
14 inspected, and the WAM was run, where appropriate.

15 **2.3.4 Treatment**

16 Treatment technologies considered potentially applicable to uranium removal are RO, IX,
17 and enhanced coagulation-filtration. RO treatment produces a liquid waste (reject or
18 concentrate) which represents 25 to 40% of the volume of the potable water produced. As a
19 result, the treated volume of water is less than the volume of raw water that enters the treatment
20 system. The amount of raw water used increases to produce the same amount of treated water
21 if RO treatment is implemented. The treatment units were sized based on flow rates, and
22 capital and annual O&M cost estimates were made based on the size of the treatment
23 equipment required. Neighboring non-compliant PWSs were identified to look for
24 opportunities where the costs and benefits of central treatment could be shared between
25 systems.

26 Non-economic factors were also identified. Ease of implementation was considered, as
27 well as reliability for providing adequate quantities of compliant water. Additional factors
28 were whether implementation of an alternative would require significant increase in the
29 management or technical capability of the PWS, and whether the alternative had the potential
30 for regionalization.

31 **2.4 COST OF SERVICE AND FUNDING ANALYSIS**

32 The primary purpose of the cost of service and funding analysis is to determine the
33 financial impact of implementing compliance alternatives, primarily by examining the required
34 rate increases, and also the fraction of household income that water bills represent. The current
35 financial situation is also reviewed to determine what rate increases are necessary for the PWS
36 to achieve or maintain financial viability.

1 **2.4.1 Financial Feasibility**

2 A key financial metric is the comparison of an average annual household water bill for a
3 PWS customer to the MHI for the area. MHI data from the 2000 census are used at the most
4 detailed level available for the community. Typically, county level data are used for small rural
5 water utilities due to small population sizes. Annual water bills are determined for existing
6 base conditions, including consideration of additional rate increases needed under current
7 conditions. Annual water bills are also calculated after adding incremental capital and
8 operating costs for each of the alternatives to determine feasibility under several potential
9 funding sources. It has been suggested by agencies such as USEPA that federal and state
10 programs consider several criteria to determine “disadvantaged communities” with one based
11 on the typical residential water bill as a percentage of MHI.

12 Additionally, the use of standard ratios provides insight into the financial condition of any
13 business. Three ratios are particularly significant for water utilities:

- 14 • Current Ratio = current assets (items that could be converted to cash) divided by current
15 liabilities (accounts payable, accrued expenses, and debt) provides insight into the
16 ability to meet short-term payments. For a healthy utility, the value should be greater
17 than 1.0.
- 18 • Debt to Net Worth Ratio = total debt (total amount of money borrowed) divided by net
19 worth (total assets minus total liabilities) shows to what degree assets of the company
20 have been funded through borrowing. A lower ratio indicates a healthier condition.
- 21 • Operating Ratio = total operating revenues divided by total operating expenses show the
22 degree to which revenues cover ongoing expenses. The value is greater than 1.0 if the
23 utility is covering its expenses.

24 **2.4.2 Median Household Income**

25 The 2000 U.S. Census is used as the basis for MHI. In addition to consideration of
26 affordability, the annual MHI may also be an important factor for sources of funds for capital
27 programs needed to resolve water quality issues. Many grant and loan programs are available
28 to lower income rural areas, based on comparisons of local income to statewide incomes. In
29 the 2000 Census, MHI for the State of Texas was \$39,927, compared to the U.S. level of
30 \$41,994. The census broke down MHIs geographically by block group and ZIP code. The
31 MHIs can vary significantly for the same location, depending on the geographic subdivision
32 chosen. The MHI for each PWS was estimated by selecting the most appropriate value based
33 on block group or ZIP code based on results of the site interview and a comparison with the
34 surrounding area.

35 **2.4.3 Annual Average Water Bill**

36 The annual average household water bill was calculated for existing conditions and for
37 future conditions incorporating the alternative solutions. Average residential consumption is
38 estimated and applied to the existing rate structure to estimate the annual water bill. The

1 estimates are generated from a long-term financial planning model that details annual revenue,
2 expenditure, and cash reserve requirements over a 30-year period.

3 **2.4.4 Financial Plan Development**

4 The financial planning model uses available data to establish base conditions under which
5 the system operates. The model includes, as available:

- 6 • Accounts and consumption data
- 7 • Water tariff structure
- 8 • Beginning available cash balance
- 9 • Sources of receipts:
 - 10 ○ Customer billings
 - 11 ○ Membership fees
 - 12 ○ Capital Funding receipts from:
 - 13 ❖ Grants
 - 14 ❖ Proceeds from borrowing
- 15 • Operating expenditures:
 - 16 ○ Water purchases
 - 17 ○ Utilities
 - 18 ○ Administrative costs
 - 19 ○ Salaries
- 20 • Capital expenditures
- 21 • Debt service:
 - 22 ○ Existing principal and interest payments
 - 23 ○ Future principal and interest necessary to fund viable operations
- 24 • Net cash flow
- 25 • Restricted or desired cash balances:
 - 26 ○ Working capital reserve (based on 1-4 months of operating expenses)
 - 27 ○ Replacement reserves to provide funding for planned and unplanned
 - 28 repairs and replacements

29 From the model, changes in water rates are determined for existing conditions and for
30 implementing the compliance alternatives.

1 **2.4.5 Financial Plan Results**

2 Results from the financial planning model are summarized in two areas: percentage of
3 household income and total water rate increase necessary to implement the alternatives and
4 maintain financial viability.

5 **2.4.5.1 Funding Options**

6 Results are summarized in a table that shows the following according to alternative and
7 funding source:

- 8 • Percentage of the median annual household income the average annual residential water
9 bill represents.
- 10 • The first year in which a water rate increase would be required
- 11 • The total increase in water rates required, compared to current rates

12 Water rates resulting from the incremental capital costs of the alternative solutions are
13 examined under a number of funding options. The first alternative examined is always funding
14 from existing reserves plus future rate increases. Several funding options were analyzed to
15 frame a range of possible outcomes.

- 16 • Grant funds for 100 percent of required capital. In this case, the PWS is only
17 responsible for the associated O&M costs.
- 18 • Grant funds for 75 percent of required capital, with the balance treated as if revenue
19 bond funded.
- 20 • Grant funds for 50 percent of required capital, with the balance treated as if revenue
21 bond funded.
- 22 • State revolving fund loan at the most favorable available rates and terms applicable to
23 the communities.
- 24 • If local MHI > 75 percent of state MHI, standard terms, currently at 3.8 percent interest
25 for non-rated entities. Additionally:
 - 26 ○ If local MHI = 70-75 percent of state MHI, 1 percent interest rate on loan.
 - 27 ○ If local MHI = 60-70 percent of state MHI, 0 percent interest rate on loan.
 - 28 ○ If local MHI = 50-60 percent of state MHI, 0 percent interest and
29 15 percent forgiveness of principal.
 - 30 ○ If local MHI less than 50 percent of state MHI, 0 percent interest and
31 35 percent forgiveness of principal.
- 32 • Terms of revenue bonds assumed to be 25-year term at 6.0 percent interest rate.

2.4.5.2 General Assumptions Embodied in Financial Plan Results

The basis used to project future financial performance for the financial plan model includes:

- No account growth (either positive or negative).
- No change in estimate of uncollectible revenues over time.
- Average consumption per account unchanged over time.
- No change in unaccounted for water as percentage of total (more efficient water use would lower total water requirements and costs).
- No inflation included in the analyses (although the model has provisions to add escalation of O&M costs, doing so would mix water rate impacts from inflation with the impacts from the alternatives being examined).
- Minimum working capital fund established for each district, based on specified months of O&M expenditures.
- O&M for alternatives begins 1 year after capital implementation.
- Balance of capital expenditures not funded from primary grant program is funded through debt (bond equivalent).
- Cash balance drives rate increases, unless provision chosen to override where current net cash flow is positive.

2.4.5.3 Interpretation of Financial Plan Results

Results from the financial plan model are presented in a Table 4.4, which shows the percentage of MHI represented by the annual water bill that results from any rate increases necessary to maintain financial viability over time. In some cases, this may require rate increases even without implementing a compliance alternative (the no action alternative). The table shows any increases such as these separately. The results table shows the total increase in rates necessary, including both the no-action alternative increase and any increase required for the alternative. For example, if the no action alternative requires a 10 percent increase in rates and the results table shows a rate increase of 25 percent, then the impact from the alternative is an increase in water rates of 15 percent. Likewise, the percentage of household income in the table reflects the total impact from all rate increases.

2.4.5.4 Potential Funding Sources

A number of potential funding sources exist for rural utilities, which typically provide service to less than 50,000 people. Both state and federal agencies offer grant and loan programs to assist rural communities in meeting their infrastructure needs. Most are available to “political subdivisions” such as counties, municipalities, school districts, special districts, or authorities of the state with some programs providing access to private individuals. Grant funds are made more available with demonstration of economic stress, typically indicated with

1 MHI below 80 percent that of the state. The funds may be used for planning, design, and
2 construction of water supply construction projects including, but not limited to, line extensions,
3 elevated storage, purchase of well fields, and purchase or lease of rights to produce
4 groundwater. Interim financing of water projects and water quality enhancement projects such
5 as wastewater collection and treatment projects are also eligible. Some funds are used to
6 enable a rural water utility to obtain water or wastewater service supplied by a larger utility or
7 to finance the consolidation or regionalization of neighboring utilities. Three Texas agencies
8 that offer financial assistance for water infrastructure are:

- 9 • Texas Water Development Board has several programs that offer loans at interest rates
10 lower than the market offers to finance projects for public drinking water systems that
11 facilitate compliance with primary drinking water regulations. Additional subsidies
12 may be available for disadvantaged communities. Low interest rate loans with short
13 and long-term finance options at tax exempt rates for water or water-related projects
14 give an added benefit by making construction purchases qualify for a sales tax
15 exemption. Generally, the program targets customers with eligible water supply
16 projects for all political subdivisions of the state (at tax exempt rates) and Water Supply
17 Corporations (at taxable rates) with projects.
- 18 • Office of Rural Community Affairs (ORCA) is a Texas state agency with a focus on
19 rural Texas by making state and federal resources accessible to rural communities.
20 Funds from the U.S. Department of Housing and Urban Development Community
21 Development Block Grants (CDBG) are administered by ORCA for small, rural
22 communities with populations less than 50,000 that cannot directly receive federal
23 grants. These communities are known as non-entitlement areas. One of the program
24 objectives is to meet a need having a particular urgency, which represents an immediate
25 threat to the health and safety of residents, principally for low- and moderate-income
26 persons.
- 27 • U.S. Department of Agriculture Rural Development Texas (Texas Rural Development)
28 coordinates federal assistance to rural Texas to help rural Americans improve their
29 quality of life. The Rural Utilities Service (RUS) programs provide funding for water
30 and wastewater disposal systems.

31 The application process, eligibility requirements, and funding structure vary for each of
32 these programs. There are many conditions that must be considered by each agency to
33 determine eligibility and ranking of projects. The principal factors that affect this choice are
34 population, percent of the population under the state MHI, health concerns, compliance with
35 standards, Colonia status, and compatibility with regional and state plans.

36 **2.4.5.5 Texas Community Development Block Grants**

37 **Introduction**

38 Every year, the U.S. Department of Housing and Urban Development (HUD) provides
39 federal CDBG funds directly to states, which, in turn, provide the funds to small, rural cities
40 with populations of less than 50,000, and to counties that have a non-metropolitan population

1 under 200,000 and are not eligible for direct funding from HUD. These small communities are
2 called “non-entitlement” areas because they must apply for CDBG dollars through state
3 agencies. The grants may be used for community and economic development activities, but are
4 primarily used for housing rehabilitation, wastewater and drinking water facilities, public
5 works facilities, and economic development. Seventy percent of grant funds must be used for
6 activities that principally benefit low to moderate-income persons.

7 CDBG funds are administered through the ORCA and the Texas Department of
8 Agriculture (TDA). ORCA administers the Texas CDBG Program and TDA administers the
9 Texas Capital Fund (TCF) through an interagency agreement between ORCA and TDA.
10 ORCA was created not only to focus on rural issues, but to monitor government performance,
11 research problems and find solutions, and to coordinate rural programs among state agencies.
12 TDA offers the infrastructure development program as part of the TCF, which provides
13 assistance with public infrastructure projects needed to by businesses to create or retain jobs for
14 low and moderate income persons.

15 ORCA’s CDBG program of Texas is the largest in the nation. The rural-focused program
16 serves approximately 1,017 eligible rural communities, 245 rural counties, and provides
17 services to over 375,000 low- to moderate-income beneficiaries each year. Of the
18 1,017 communities eligible for CDBG funds, 740 have a population of less than 3,000, and
19 424 have a population of less than 1,000. The demographics and rural characteristics of Texas
20 have shaped a program that focuses on providing basic human needs and sanitary infrastructure
21 to small rural communities in outlying areas.

22 **Eligible Applicants**

23 Eligible applicants are nonentitlement general purpose units of local government,
24 including cities and counties that are not participating or designated as eligible to participate in
25 the entitlement portion of the federal CDBG. Nonentitlement cities that are not participating in
26 urban county programs through existing participation agreements are eligible applicants (unless
27 the city’s population is counted toward the urban county CDBG allocation).

28 Nonentitlement cities are located predominately in rural areas and are cities with
29 populations less than 50,000 thousand persons; cities that are not designated as a central city of
30 a metropolitan statistical area; and cities that are not participating in urban county programs.
31 Nonentitlement counties are also predominately rural in nature and are counties that generally
32 have fewer than 200,000 persons in the nonentitlement communities and unincorporated areas
33 located in the county.

34 **Eligible Activities**

35 Eligible activities under the Texas CDBG Program are listed in 42 United States Code
36 Section 5305. The Texas CDBG staff reviews all proposed project activities included in
37 applications for all fund categories. The TDA determines the eligibility of activities included
38 in TCF applications.

1 All proposed activities must meet one of the following three National Program Objectives:

- 2 1. Benefit principally low- and moderate-income persons; or
- 3 2. Aid in the elimination of slums or blight; or
- 4 3. Meet other community development needs of particular urgency that represent
5 an immediate threat to the health and safety of residents of the community.

6 **Ineligible Activities**

7 In general, any type of activity not described or referred to in 42 United States Code
8 Section 5305 is ineligible. Specific activities ineligible under the Texas CDBG Program are:

- 9 1. Construction of buildings and facilities used for the general conduct of government
10 (*e.g.* city halls, courthouses, *etc.*);
- 11 2. Construction of new housing, except as last resort housing under 49 Code of Federal
12 Regulations (CFR) Part 24 or affordable housing through eligible subrecipients in
13 accordance with 24 CFR 570.204;
- 14 3. Financing of political activities;
- 15 4. Purchases of construction equipment (except in limited circumstances under the
16 STEP Program);
- 17 5. Income payments, such as housing allowances; and
- 18 6. Most O&M expenses (including smoke testing, televising/video taping line work, or
19 any other investigative method to determine the overall scope and location of the
20 project work activities)

21 The TCF will not accept applications in support of public or private prisons, racetracks,
22 and projects that address job creation/retention through a government supported facility. The
23 TCF Program may be used to financially assist/facilitate the relocation of a business when
24 certain requirements, as defined in the application guidelines, are met.

25 **Primary Beneficiaries**

26 The primary beneficiaries of the Texas CDBG Program are low to moderate income
27 persons as defined under HUD, Section 8 Assisted Housing Program (Section 102(c)). Low
28 income families are defined as those earning less than 50 percent of the area MHI. Moderate
29 income families are defined as those earning less than 80 percent of the area MHI. The area
30 median family can be based on a metropolitan statistical area, a non-metropolitan county, or the
31 statewide non-metropolitan MHI figure.

1 **Section 108 Loan Guarantee Program**


2 Section 108 is the loan guarantee provision of the Texas CDBG Program. Section 108
3 provides communities with a source of financing for economic development, housing
4 rehabilitation, public facilities, and large-scale physical development projects. This makes it
5 one of the most potent and important public investment tools that HUD offers to local
6 governments. It allows these local governments to transform a small portion of their CDBG
7 funds into federally guaranteed loans large enough to pursue physical and economic
8 revitalization projects that can renew entire neighborhoods. Such public investment is often
9 needed to inspire private economic activity, providing the initial resources, or simply the
10 confidence that private firms and individuals may need to invest in distressed areas.
11 Section 108 loans are not risk-free; however, local governments borrowing funds guaranteed by
12 Section 108 must pledge their current and future CDBG allocations to cover the loan amount as
13 security for the loan.

14 The loan is made by a private lender to an eligible nonentitlement city or county. HUD
15 guarantees the loan; however, Texas CDBG must pledge the state’s current and future CDBG
16 nonentitlement area funds to cover any losses. To provide eligible nonentitlement communities
17 an additional funding source, the State is authorizing a loan guarantee pilot program for 2008
18 consisting of one application up to a maximum of \$500,000 for a particular project. An
19 application guide containing the submission date and qualifications will be available for
20 applicants interested in being selected as the pilot project under this program.

21

1 Major and minor aquifers found in this region are shown in Figure 3.2. All PWS wells of
2 concern were drilled within the Gulf Coast aquifer system, which consists of a number of
3 distinct aquifers and is described in more detail below. From oldest to youngest, and from
4 northwest to southeast, these aquifers are known as the Jasper, Evangeline, and Chicot. In
5 addition, the Carrizo-Wilcox and Yegua-Jackson aquifers are present in the western part of the
6 study area. Other aquifers that are near, but not within, the study area include the Edwards
7 (Balcones Fault Zone), Queen City, Sparta, and Trinity aquifers.

8 **Figure 3.2 Major (a) and Minor (b) Aquifers in the Study Area**



9 Solid indicates a portion of an aquifer that lies at the land surface. Hatched indicates a portion of an aquifer
that underlies other formations.

10 Data used for this study include information from three sources:

- 11 ■ Texas Water Development Board groundwater database available at
12 www.twdb.state.tx.us. The database includes information on the location and
13 construction of wells throughout the state as well as historical measurements of water
14 chemistry and levels in the wells.
- 15 ■ Texas Commission on Environmental Quality Public Water Supply database (not
16 publicly available). The database includes information on the location, type, and
17 construction of water sources used by PWSs in Texas, along with historical
18 measurements of water levels and chemistry.
- 19 ■ National Uranium Resource Evaluation (NURE) database available at:
20 tin.er.usgs.gov/nure/water. The NURE dataset includes groundwater quality data
21 collected between 1975 and 1980. The database provides well locations and depths
22 with an array of analyzed chemical data.


3.1.2 Contaminants of Concern in the Study Area

Contaminants addressed in this study include arsenic, combined radium, gross alpha, and uranium. Groundwater supplies from PWSs in the study area assessed in Section 2 have been found to contain levels of one or more of these contaminants in excess of the USEPA’s MCL. The database or databases used to assess each constituent are those with the most available measurements. For individual wells sampled for a given constituent multiple times, the most recent measurement is shown.

Arsenic

Arsenic levels exceed the MCL (10 µg/L) in many wells drilled within the Gulf Coast aquifer system (Figure 3.3). The values shown in these figures are based on the most recent sample for each well. In particular, these maps show many wells with high arsenic concentrations along the western, updip area of the aquifer system.

Figure 3.3 Spatial Distribution of Arsenic Concentrations



14

The distribution of arsenic within the study area can be further described by looking at the number of wells in each aquifer that exceeds the MCL (Table 3.1). Arsenic concentrations are distinctively higher in the Jasper aquifer, where 62 percent of the wells exceed the MCL for arsenic, than in the rest of the Gulf Coast aquifer system, where 13–24 percent of wells exceed the MCL. Because the units in the aquifer system become progressively older from southeast to northwest, many of the high arsenic wells along the northwest edge of the aquifer likely belong to the Jasper aquifer, the oldest aquifer in the system. All wells in the Carrizo-Wilcox and Yegua-Jackson aquifers contain acceptable levels of arsenic.

The data in Table 3.1 were obtained from the TWDB groundwater database (samples from the NURE database were not included because the database does not associate sampled wells with aquifers). TWDB aquifer codes used to define the aquifers within the Gulf Coast aquifer system include

- Chicot Aquifer: Codes 110AVLS, 112BMLG, 112BMLS, 112BMNT, 112CHCT, 112CHCTL, 112CHCTU, and 112LISS
- Evangeline Aquifer: Codes 110AVGL, 121EVGL, 112GOLD, and 121GOLD.
- Jasper Aquifer: Codes 112CTHL, 112JSPR, 112LGRT, and 112OKVC.

Wells in the Gulf Coast aquifer system that are not identified as being within one of these aquifers are not included.


Table 3.1 Summary of Wells that Exceed the MCL for Arsenic, by Aquifer

Aquifer	Wells with measurements	Wells that exceed 10 µg/L	Percentage of wells that exceed 10 µg/L
Chicot	39	5	13
Evangeline	175	42	24
Jasper	69	43	62
Carrizo-Wilcox	16	0	0
Yegua-Jackson	4	0	0
other	21	6	29

Data from the TWDBD Database.


In addition, arsenic concentrations are generally associated with well depths within the study area (Figures 3.4 and 3.5). Wells between about 230 and 400 feet deep are more likely to have arsenic concentrations above the MCL (Figure 3.5). This suggests that deepening shallow wells or casing off portions of wells above or below this depth range might decrease arsenic concentrations. However, the thickness of the Gulf Coast aquifer system, and thus the depth of the aquifer, increases toward the coast. Along the updip edge of the aquifer, where the saturated thickness may be limited to relatively shallow depths, deepening wells might not be a viable option.

1 **Figure 3.4 Arsenic Concentrations and Well Depths within the Study Area**



2
3
4
Gray squares indicate NURE data; red circles indicate TWDB data.

1 **Figure 3.5 Arsenic Concentrations and Well Depths in the Study Area from the**
2 **TWDB Database**




3
4 *Depths plotted are the medians of the 25th, 50th, 75th, and 100th percentiles. Concentrations represent the 10th, 25th, 50th,*
5 *75th, and 90th percentiles of values within each depth range.*

6 Some of the high arsenic levels in the region might be explained by point source
7 contaminants. The TCEQ Source Water Assessment and Protection program compiled a
8 database of potential sources of arsenic contamination, such as animal feeding operations,
9 certain businesses, injection wells used in oil production, transportation-related sites, and sites
10 that store waste and wastewater (Figure 3.6). These anthropogenic sources of arsenic might
11 explain high arsenic levels along the Rio Grande, Nueces, and Guadalupe Rivers (Figure 3.3).

1

Figure 3.6 Locations of Possible Sources of Arsenic Contamination




2

1 **Uranium**

2 A small but significant number of wells in the area contain uranium concentrations that
3 exceed the MCL for uranium (30 µg/L). The distribution of measured uranium levels in
4 groundwater in the study area from the NURE database is shown in Figure 3.7. This map
5 indicates that many of the high uranium levels occur along the updip edge of the Gulf Coast
6 aquifer system and in the Rio Grande valley.


7 **Figure 3.7 Spatial Distribution of Uranium Concentrations**



8


1 Because the NURE database does not include information about which aquifer the sampled
2 wells represent, it is not possible to compare uranium concentrations by aquifer. However,
3 because well depths are included in the database, differences in uranium concentrations in
4 wells of different depths can be compared (Figure 3.8 and 3.9). Based on Figure 3.9, the
5 lowest uranium concentrations are generally found in wells between about 140 and 260 feet
6 deep. However, only three wells below 800 feet exceed the MCL for uranium. The relatively
7 small number of wells more than about 900 feet deep make the trend in uranium levels in these
8 deeper wells more difficult to discern.

9 **Figure 3.8 Uranium Concentrations and Well Depths within the Study Area**



10

1 **Figure 3.9 Uranium Concentrations and Well Depths in the Study Area from the**
2 **NURE Database**




3
4 *Depths plotted are the medians of the 25th, 50th, 75th, and 100th percentiles. Concentrations represent the 10th, 25th, 50th,*
5 *75th, and 90th percentiles of values within each depth range.*

1 **Gross Alpha**

2 Based on the small number of gross alpha measurements available, the highest
3 concentrations appear to occur in the central part of the study area, while most other wells
4 show acceptable levels. Figure 3.10 shows the distribution of gross alpha measured in wells in
5 the study area. Because measurements from the TCEQ database are commonly from samples
6 that are a mixture of water from multiple wells, an assessment of how gross alpha
7 concentrations vary with well depth or aquifer is not possible.

8 **Figure 3.10 Spatial Distribution of Gross Alpha Concentrations in the Study Area**




9

1 **Combined Radium**

2 The concentration of combined radium, which refers to radium 226 plus radium 228, is
3 generally below the MCL (5 pCi/L) throughout the study area. An exception is the combined
4 radium measured at the Arenosa Creek Estates PWS, discussed in more detail below. The
5 distribution of available combined radium measurements is shown in Figure 3.11. The values
6 shown in this analysis represent an upper limit of the possible concentration, because in wells
7 that contained less than 1 pCi/L of radium 228 (the detection limit), 1 pCi/L was used in the
8 combined concentration.


9 **Figure 3.11 Spatial Distribution of Combined Radium Concentrations in the Study**
10 **Area**



11


1 There is no clear correlation between combined radium concentration and well depth in the
2 study area (Figure 3.12). Although the highest measured concentrations occur in shallower
3 wells, the small number of measurements available makes it difficult to conclusively
4 demonstrate any trend.

5 **Figure 3.12 Combined Radium Concentrations and Well Depths within the Study Area**



6
7 High radium concentrations can also be caused by anthropogenic sources of
8 contamination. The TCEQ SWAP compiled a database of potential sources of radium
9 contamination, including certain businesses, injection wells related to oil production, and waste
10 disposal sites (Figure 3.13). The low measured levels of combined radium in the region do not
11 indicate significant contamination caused by these sources.

1 **Figure 3.13** Locations of Possible Sources of Radium Contamination in the Study Area



2

3 3.1.3 Regional Hydrogeology

4 The Gulf Coast aquifer system is the primary source of groundwater along the coastal
5 plains of Texas, extending about 62 miles inland from the Gulf of Mexico. South of the study
6 area, this aquifer system extends across the Rio Grande and into Mexico. North of the study
7 area, it extends along the Gulf Coast into Louisiana. The aquifer system consists of several
8 hydrologically connected sedimentary units, Miocene age and younger, composed of
9 interbedded gravel, sand, silt, and clay. These sediments were deposited in alluvial, deltaic,
10 lagoon, beach, and continental shelf environments as the depositional basin that forms the Gulf
11 of Mexico. As a result of the gradual subsidence of the basin, these units all dip toward the
12 coast (Ryder 1996), so the geologic units at the surface are youngest at the coast and oldest
13 inland (Ashworth and Hopkins 1995). The units also generally thicken toward the coast, so the
14 main producing units are very thin at the inland boundary of the aquifer and increase to nearly
15 6,000 feet thick at the coast within the study area (Baker 1979).

1 The oldest and deepest formation is the Miocene age Catahoula Tuff or Sandstone, which
2 in most places serves as a confining unit between the Gulf Coast aquifer system and the
3 underlying Jackson Group. Overlying the Catahoula is the Miocene age Jasper aquifer, in
4 which the Oakville Sandstone forms a productive aquifer unit. Above the Jasper aquifer is the
5 Burkeville confining unit, made up primarily of a clay-rich unit known as the Fleming
6 Formation (Baker 1979) or the Lagarto Clay (Shafer and Baker 1973), which separates the
7 Jasper from the overlying Evangeline aquifer. The Evangeline aquifer consists of the Pliocene
8 age Goliad Sand. Above the Evangeline, the top of the Gulf Coast aquifer system, known as
9 the Chicot aquifer, includes the Pleistocene age Lissie, Willis, Bentley, Montgomery, and
10 Beaumont formations, as well as recent alluvial deposits (Baker 1979). Locally, formations
11 that make up the Chicot aquifer might not all be present or discernable (Shafer 1968; Shafer
12 and Baker 1973; Shafer 1974).

13 Water quality in the Gulf Coast aquifer system is generally good in the shallower parts of
14 the aquifer, but worsens toward the Rio Grande valley. Along the coast, the quality is poor in
15 some locations due to saltwater encroachment (Ashworth and Hopkins 1995). In some areas,
16 including Kleberg, Kenedy, and Jim Wells Counties, improperly cased wells in the Evangeline
17 aquifer have experienced increases in salinity due to leakage of shallow saline water from
18 overlying formations (Shafer and Baker 1973). Saline waters near the surface might be natural
19 or a result of human activities such as oil production or pesticide application, although
20 historically pesticides have not been a known source of contamination (Shafer 1968; Shafer and
21 Baker, 1973; Shafer, 1974).

22 Other aquifers that provide water supplies in the western part of the study area include the
23 Carrizo-Wilcox and the Yegua-Jackson. The Carrizo-Wilcox aquifer includes the Tertiary age
24 Wilcox Group and the Carrizo Formation (Ashworth and Hopkins 1995). Where it is present in
25 the study area, the Carrizo-Wilcox is primarily located only at depth; it outcrops only in a small
26 area in northwestern Webb County. The Yegua-Jackson aquifer consists of the Eocene age
27 Yegua Formation and the Eocene–Pleistocene Jackson Group, both of which are made up of
28 interbedded sands, silts, and clays, some of which include volcanic sediments, lignite, and
29 uranium (Preston 2006). This aquifer only occurs in the subsurface within the study area.

30 **3.2 DETAILED ASSESSMENT FOR RIVIERA INDEPENDENT SCHOOL** 31 **DISTRICT**

32 The Riviera ISD PWS has one well: G1370019A. This well is 727 feet deep and is within
33 the Evangeline aquifer. The one historical measurement of uranium in this well is shown in
34 Table 3.2.


35 **Table 3.2 Uranium Concentration in the Riviera ISD PWS**

Date	Uranium (µg/L)	Well sampled
3/8/2007	88	raw sample, G1370019A

Data from the TCEQ PWS Database.

1 The only available measurement of uranium in this well is 88 µg/L, significantly above the
2 MCL (30 µg/L). The distribution of uranium concentrations measured in nearby wells is
3 shown in Figure 3.14.

4 **Figure 3.14 Uranium Concentrations within 5- and 10-km Buffers around the Riviera**
5 **ISD PWS**



6
7 Data are from the TCEQ, TWDB, and NURE databases, although no wells from the
8 TWDB database are present in the vicinity of the PWS. Two types of samples were included in
9 the analysis. Samples from the TCEQ database (shown as squares on the map) represent the
10 most recent sample taken at a PWS, which can be raw samples from a single well or entry point
11 samples that may combine water from multiple sources. Samples from the NURE database
12 (shown as diamonds on the map) are taken from single wells. Where more than one
13 measurement has been made from a source, the most recent concentration is shown.


14 Several nearby wells in the NURE database, including one close to the PWS well, show
15 uranium levels below the MCL. However, the NURE database does not associate well

1 measurements with state well numbers or owner information; therefore, these measurements
2 cannot be traced to individual wells. The depths of those wells in the NURE database that
3 show acceptable uranium levels range from 735 to 912 feet. The depths of the two wells in the
4 NURE database that exceed the MCL are 709 and 761 feet, and the depths of the PWS wells
5 located approximately 5 miles south-southeast of the Riviera ISD PWS wells, which exceed the
6 MCL, are 800, 802, and 850 feet. Based on this information and the regional assessment,
7 deepening the PWS well below 850 feet might decrease uranium levels.

8 **3.2.1 Summary of Alternative Groundwater Sources for the Riviera ISD PWS**

9 Many nearby wells contain acceptable uranium concentrations. The NURE database does
10 not contain enough information to identify these wells, but this finding suggests that further
11 research into nearby wells that might serve as an alternative supply could prove useful. In
12 addition, based on depths of nearby wells that do and do not meet the MCL for uranium, it is
13 possible that deepening the PWS well below 850 feet might decrease uranium levels.

14



Legend

- Study System
- PWS's
- Cities
- City Limits
- Counties
- Major Road
- Minor Road
- CRMWA Pipeline
- Lubbock Pipeline
- Grass Valley Pipeline
- RI-1 Baffin Bay WSC - 6.8 Miles




Figure 4.1

**RIVIERA ISD
Pipeline Alternative**

J:\647647010 BEG 2008\GIS\mxd\Report\Figure4.1.mxd August 14, 2008 9:08:23 AM

- 1 • Typical magnesium range: 5 to 6.71 mg/L
- 2 • Typical manganese range: <0.008 to 0.00203 mg/L
- 3 • Typical nitrate range: 0.31 to 0.4 mg/L
- 4 • Typical selenium range: 0.0128 to 0.0161 mg/L
- 5 • Typical sodium range: 269 to 300 mg/L
- 6 • Typical sulfate range: 174 to 178 mg/L
- 7 • Total Hardness as CaCO₃ range: 77 to 85 mg/L
- 8 • Typical pH range: 7.6 to 8.03
- 9 • Total alkalinity as CaCO₃ range: 273 to 280 mg/L
- 10 • Typical bicarbonate range: 339 to 342 mg/L
- 11 • Typical total dissolved solids range: 872 to 875 mg/L

12 The typical ranges for water quality data listed above are based on a TCEQ database that
13 contains data updated through the beginning of 2005.

14 **4.1.2 Capacity Assessment for the Riviera ISD PWS**

15 The project team conducted a capacity assessment of the Riviera ISD PWS on August 4,
16 2008. Results of this evaluation are separated into four categories: general assessment of
17 capacity, positive aspects of capacity, capacity deficiencies, and capacity concerns. The
18 general assessment of capacity describes the overall impression of FMT capability of the water
19 system. The positive aspects of capacity describe the strengths of the system. These factors
20 can provide the building blocks for the system to improve capacity deficiencies. The capacity
21 deficiencies noted are those aspects creating a particular problem for the system related to long-
22 term sustainability. Primarily, those problems are related to the system's ability to meet current
23 or future compliance, ensure proper revenue to pay the expenses of running the system, and
24 ensure proper operation of the system. The last category, capacity concerns, are items that are
25 not causing significant problems for the system at this time. However, the system may want to
26 address them before they become problematic.

27 Because of the challenges facing very small water systems, it is increasingly important for
28 them to develop the internal capacity to comply with all state and federal requirements for
29 public drinking water systems. For example, it is especially important for very small water
30 systems to develop long-term plans, set aside money in reserve accounts, and track system
31 expenses and revenues because they cannot rely on increased growth and economies of scale to
32 offset their costs. In addition, it is crucial for the owner, manager, and operator of a very small
33 water system to understand the regulations and participate in appropriate training. Providing
34 safe drinking water is the responsibility of every public water system, including those very
35 small water systems that face increased challenges with compliance.

36 The project team interviewed the following individuals.

- 1 • Ernest Havner, Riviera ISD Superintendent
- 2 • Dana Hickey, Riviera ISD Business Manager
- 3 • Bill Shronfeld, Contract Water Operator
- 4 • Billy Griffith, Board Member

5 Others who attended the meeting but did not participate included:

- 6 • Wilson Martin, Board Member
- 7 • Sylvia Arguijo, Board Member
- 8 • George Samanko, Riviera ISD Maintenance Supervisor
- 9 • Roy Cantu, County Commissioner
- 10 • Poncho Hubert, Concerned Citizen

11 **4.1.2.1 General Structure of the Water System**

12 The Riviera ISD PWS, classified as a non-community, non-transit water system, provides
13 water to school buildings serving approximately 500 students. The school district contracts
14 with Bill Shronfeld for water and wastewater operations. However, when the maintenance
15 supervisor receives his license, the contract operator will be used only as needed. The Riviera
16 ISD is designated a Chapter 41 school by the Texas Education Agency and receives 75 percent
17 of its annual funding from the local taxes and 25 percent from the state. The district’s budget is
18 capped at \$5,000,000 annually.

19 The district water system exceeds the standards for uranium and is under a Compliance
20 Order with TCEQ.

21 **4.1.2.2 General Assessment of Capacity**

22 Based on the team’s assessment, this system has a good level of capacity. There are
23 several positive managerial, financial and technical aspects of the water system, but there are
24 also some areas that need improvement. The deficiencies noted could prevent the water system
25 from being able to meet compliance now or in the future and may also impact the water
26 system’s long-term sustainability.

27 **4.1.2.3 Positive Aspects of Capacity**

28 In assessing a system’s overall capacity, it is important to look at all aspects – positive and
29 negative. It is important for systems to understand those characteristics that are working well,
30 so those activities can be continued or strengthened. In addition, these positive aspects can
31 assist the system in addressing the capacity deficiencies or concerns. The factors particularly
32 important for the Riviera ISD are listed below.

- 33 • **Dedicated Staff** – The school superintendent, board members, business manager, and
34 water operator are very concerned about the non-compliance issues and in learning

1 about the best options to protect health of the students. In addition, there is a great deal
2 of community concern about the short-term as well as long-term impacts of uranium on
3 the students. It appears the school will provide an alternate source for drinking water
4 for the students for the upcoming school year.

- 5 • **Emergency Interconnection** – Riviera ISD water system has an interconnection with
6 the Riviera community water system for emergencies.

7 **4.1.2.4 Capacity Deficiencies**

8 The following capacity deficiencies were noted in conducting the assessment and seriously
9 impact the ability of the water system to comply with current and future regulations and ensure
10 long-term sustainability.

- 11 • **Lack of Compliance with Uranium Standards** – The Riviera ISD PWS is not in
12 compliance with the uranium standard and has been under a Compliance Agreement
13 with TCEQ since 2006.
- 14 • **Lack of Long-Term Planning for Compliance and Sustainability** – The school
15 district does not have a long-term capital plan in place for water system improvements.
16 This lack of a long-term plan makes it difficult to know the financial impact on the
17 district’s budget of future projects, including installation of treatment to meet
18 compliance. Having a long-term plan for capital improvements is especially important
19 if the school district must rely on grants to fund capital projects

20 **4.1.2.5 Potential Capacity Concerns**

21 The following items were concerns regarding capacity but no specific operational,
22 managerial, or financial problems can be attributed to these items at this time. The system
23 should address the items listed below to further improve FMT capabilities to improve the
24 system’s long-term sustainability.

- 25 • **Funding Limitations** – The district’s school’s funding amount is set by the
26 Comptrollers Office, which is based on formulas and the number of students attending
27 the school. Expenses for the water and wastewater system are included in the “plant
28 maintenance and operations” budget line item. Emergency expenses for the water
29 system are paid for out of the fund balance and must be repaid. Because the district’s
30 funding is capped at \$5,000,000 annually, there is a potentially a lack of available funds
31 to ensure the ability of the district to comply with current and future drinking water
32 regulations.

33 **4.2 ALTERNATIVE WATER SOURCE DEVELOPMENT**

34 **4.2.1 Identification of Alternative Existing Public Water Supply Sources**

35 Using data drawn from the TCEQ drinking water and TWDB groundwater well databases,
36 the PWSs surrounding the Riviera ISD PWS were reviewed with regard to their reported
37 drinking water quality and production capacity. PWSs that appeared to have water supplies

1 with water quality issues were ruled out from evaluation as alternative sources, while those
2 without identified water quality issues were investigated further. Small systems were only
3 considered if they were within 15 miles of the Riviera ISD PWS. Large systems or systems
4 capable of producing greater than four times the daily volume produced by the study system
5 were considered if they were within 15 miles of the study system. A distance of 15 miles was
6 considered to be the upper limit of economic feasibility for constructing a new water line.
7 Table 4.1 is a list of the selected PWSs based on these criteria for large and small PWSs within
8 15 miles of the Riviera ISD PWS. If it was determined these PWSs had excess supply capacity
9 and might be willing to sell the excess, or might be a suitable location for a new groundwater
10 well, the system was taken forward for further consideration and identified with “EVALUATE
11 FURTHER” in the comments column of Table 4.1.

12 **Table 4.1 Selected Public Water Systems within 15 Miles of the Riviera ISD PWS**

PWS ID	PWS Name	Distance from the Riviera ISD PWS (miles)	Comments/Other Issues
1370007	RIVIERA WATER SUPPLY	0.26	Larger GW System. WQ issues: Combined Uranium and Gross Alpha.
1370033	EAST RIVIERA WATER SYSTEM	3.64	Larger GW System. No uranium data. Do not evaluate further.
1310001	SARITA SEWER SERVICE & WATER SUPPLY	5.19	Larger GW System. WQ issues: Combined Uranium and Sulfate.
1370032	BAFFIN BAY WATER SUPPLY CORP	6.26	Larger GW System. Marginal gross alpha issues. Evaluate Further
1370006	RICARDO WATER SUPPLY CORP	9.75	Larger GW System. WQ issues: gross alpha.
1370009	PRESBYTERIAN PAN AMERICAN SCHOOL	11.01	Larger Non-residential. GW System. No WQ issues.
1310005	US HWY 77 COMFORT STA SARIT	11.37	Larger Non-residential. GW System. No WQ issues.
1370034	ESCONDIDO CREEK WATER SYSTEM	12.59	Larger GW System. No WQ issues. This PWS no longer uses its well. It receives water from the City of Kingsville.

WQ = water quality
GW = groundwater

13 After the PWSs in Table 4.1 with water quality problems were eliminated from further
14 consideration, the remaining PWSs were screened by proximity to the Riviera ISD PWS and
15 sufficient total production capacity for selling or sharing water. Based on the initial screening
16 summarized in Table 4.1, one alternative was selected for further evaluation. The alternative is
17 summarized in Table 4.2. The alternative is a connection to the Baffin Bay Water Supply
18 Corporation (WSC) system. A description of the Baffin Bay WSC follows Table 4.2.

1 **Table 4.2 Public Water Systems within the Vicinity of the Riviera ISD PWS Selected**
2 **for Further Evaluation**

PWS ID	PWS Name	Pop	Connections	Total Production (mgd)	Avg Daily Usage (mgd)	Approx. Dist. from the Riviera ISD PWS	Comments/Other Issues
1370032	BAFFIN BAY WSC	750	335	0.605	0.119	6.26	Larger GW System. Recommend additional analysis of gross alpha

3 **4.2.1.1 Baffin Bay Water Supply Corporation (1370032)**

4 Baffin Bay WSC is located approximately 6 miles east from the Riviera ISD PWS.
5 Records indicate that its groundwater production is 80,000 gallons per day with current service
6 to about 380 connections. Baffin Bay WSC has two wells and three storage tanks. According
7 to available information on this PWS, there are no reported exceedances for constituents of
8 concern above the associated MCLs. However, the PWS has no excess capacity. The cost to
9 expand the system has been estimated at \$1.2 million. The WSC is willing to consider selling
10 water if its current system is expanded.

11 Baffin Bay recorded a single gross alpha result of 15.9 pCi/L (18.9 pCi/L \pm 3 pCi/L error
12 rate) in May 2000. There have also been lower gross alpha particle activity results of <2.0
13 pCi/L and 11.5 pCi/L (14.5 pCi/L – 3 pCi/L error rate). Therefore additional analyses of gross
14 alpha are needed to identify whether the contaminant currently exceeds the MCL of 15 pCi/L
15 prior to any agreements to use the source of water as an alternative for Riviera ISD PWS.

16 **4.2.2 Potential for New Groundwater Sources**

17 **4.2.2.1 Installing New Compliant Wells**

18 Developing new wells or well fields is recommended, provided good quality groundwater
19 available in sufficient quantity can be identified. Since a number of water systems in the area
20 have water quality problems, it should be possible to share in the cost and effort of identifying
21 compliant groundwater and constructing well fields.

22 Installation of a new well in the vicinity of the system intake point is likely to be an
23 attractive option provided compliant groundwater can be found, since the PWS is already
24 familiar with operation of a water well. As a result, existing nearby wells with good water
25 quality should be investigated. Re-sampling and test pumping would be required to verify and
26 determine the quality and quantity of water at those wells.

27 The use of existing wells should probably be limited to use as indicators of groundwater
28 quality and availability. If a new groundwater source is to be developed, it is recommended
29 that a new well or wells be installed instead of using existing wells. This would ensure well
30 characteristics are known and meet standards for drinking water wells.

1 Some of the alternatives suggest new wells be drilled in areas where existing wells have
2 acceptable water quality. In developing the cost estimates, Parsons assumed the aquifer in
3 these areas would produce the required amount of water with only one well. Site investigations
4 and geological research, which are beyond the scope of this study, could indicate whether the
5 aquifer at a particular site and depth would provide the amount of water needed or if more than
6 one well would need to be drilled in separate areas.

7 **4.2.2.2 Results of Groundwater Availability Modeling**

8 The southern section of the Gulf Coast Aquifer supplies groundwater throughout Kleberg
9 County, where the PWS is located, as well as surrounding counties. One of five
10 hydrogeological units that comprise the Gulf Coast Aquifer, the Evangeline Aquifer, is the
11 water source for a single 727-foot deep well operated by the Riviera ISD PWS.

12 A search of registered wells was conducted using TCEQ’s Public Water Supply database
13 to assess groundwater sources utilized within a 10-mile radius of the PWS. The search
14 indicated that in the search area, all public water supply and domestic wells are completed in
15 the Goliad Sand Formation of the Evangeline Aquifer. This Formation, one of two components
16 of the aquifer, is also the groundwater source for most irrigation, stock watering and industrial
17 supply wells within the search area.

18 ***Groundwater Supply***

19 The Gulf Coast Aquifer, the main groundwater source in Kleberg and surrounding
20 counties, is a high-yield aquifer composed of discontinuous sand, silt, clay and gravel beds that
21 extends over the entire Texas coastal region. Municipal and irrigation uses account for 90
22 percent of the total pumpage from the aquifer. The Gulf Coast Aquifer, which has an average
23 freshwater thickness of 1,000 feet (TWDB 2007), consists of five hydrogeologic units; from the
24 land surface downward, those units are the Chicot Aquifer, the Evangeline Aquifer, the
25 Burkenville Formation, the Jasper Aquifer, and the Catahoula Sandstone Formation.

26 In the southern section of the Gulf Coast Aquifer, where the PWS is located, the
27 groundwater yield is relatively low compared to the north section and central sections of the
28 aquifer, and of lower water quality due to a high content of total dissolved solids
29 (TWDB 2007). The State Water Plan, updated in 2007 by the TWDB, estimated that
30 availability of water from the Gulf Coast Aquifer water will have a moderate decrease, from
31 over 1.8 million acre-feet per year (AFY) in 2010 to slightly less than 1.7 million AFY in the
32 year 2060.

33 ***Groundwater Availability***

34 Regional groundwater withdrawal in the PWS area is extensive, and likely to increase over
35 current levels over the next decades. The 2007 State Water Plan summarized estimates of
36 groundwater supply and demand over a 50-year planning period, from current values
37 extrapolated to the year 2010 to projections for the year 2060. For Kleberg County it was
38 estimated that, with implementation of additional water management strategies, projected water

1 supply estimates will meet the increasing water demand. For the 50-year planning period, the
2 additional water need would be associated with municipal water use, and limited to 155 AFY.

3 A GAM was developed by TWDB for the southern section of the Gulf Coast Aquifer,
4 including Kleberg and adjacent counties. On a regional basis, the GAM model predicted that
5 by the year 2050, current aquifer utilization would increase more than 10 percent (Chowdhury
6 and Mace, 2003). A GAM evaluation was not run for the PWS. Water use by the system
7 would represent a minor addition to regional withdrawal conditions, making potential changes
8 in aquifer levels beyond the spatial resolution of the regional GAM model.

9 **4.2.3 Potential for New Surface Water Sources**

10 The Riviera ISD PWS is located is located within the Nueces-Rio Grande Coastal Basin
11 where current demand for surface water is expected to increase over the next 50 years due
12 increased population, and decline in the groundwater supply due to overpumping and
13 salinization. The Texas State Water Plan, updated by the TWDB in 2007, estimates that the
14 basin’s surface water availability in the year 2010 will be approximately 8,900 AFY.

15 In Kleberg County, where the PWS is located, the entire water supply will be allocated for
16 municipal use. The 2007 State Water Plan estimated that, with implementation of additional
17 water management strategies, the projected water supply estimates will meet the increasing
18 water demand in the county. For the 50-year planning period, the additional water need would
19 be associated with municipal water use, and limited to 155 AFY.

20 There is a minimum potential for development of new surface water sources for the
21 Riviera ISD PWS, as indicated by limited water availability within the site vicinity. The
22 surface water availability model for the Nueces-Rio Grande Coastal Basin, developed by the
23 TWDB as a tool to determine the maximum amount of water available during the drought of
24 record over the simulation period, indicates that in PWS vicinity there is a minimum
25 availability of surface water for new uses. Surface water availability maps developed by TCEQ
26 for the Nueces-Rio Grande Basin --illustrating percent of months of flow per year-- indicate
27 that in the site vicinity, and over all of Kleberg County, unappropriated flows for new
28 applications are typically available less than 50 percent of the time. This availability is
29 inadequate for development of new municipal water supplies as a 100 percent year-round
30 availability is required by TCEQ for new surface water source permit applications.

31 **4.2.4 Options for Detailed Consideration**

32 The initial review of alternative sources of water results in the following options for more-
33 detailed consideration:

- 34 1. Baffin Bay Water Supply Corp. Compliant water would be purchased from the
35 Baffin Bay WSC to be used by the Riviera ISD PWS. A pipeline would be
36 constructed to convey water from Baffin Bay WSC to the Riviera ISD PWS
37 (Alternative RI-1).

- 1 2. New Wells at 10, 5, and 1 mile. Installing a new well within 10, 5, or 1 mile of the
2 Riviera ISD PWS may produce compliant water in place of the water produced by
3 the existing active well (Alternatives RI-2, RI-3, and RI-4).

4 **4.3 CENTRAL TREATMENT OPTIONS**

5 Centralized treatment of the well water is identified as a potential option. Reverse
6 Osmosis, coagulation filtration, and ion exchange treatment are potential applicable processes.
7 The central RO treatment alternative is Alternative RI-5, the central coagulation filtration
8 treatment alternative is Alternative RI-6, and the central ion exchange treatment process
9 alternative is Alternative RI-7.

10 **4.4 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

11 A number of potential alternatives for compliance with the MCL for combined uranium
12 have been identified. Each of the potential alternatives is described in the following
13 subsections. It should be noted that the cost information given is the capital cost and change in
14 O&M costs associated with implementing the particular alternative. Appendix C contains cost
15 estimates for the compliance alternatives. These compliance alternatives represent a range of
16 possibilities, and a number of them are likely not feasible. However, all have been presented to
17 provide a complete picture of the range of alternatives considered. It is anticipated that a PWS
18 will be able to use the information contained herein to select the most attractive alternative(s)
19 for more detailed evaluation and possible subsequent implementation.

20 **4.4.1 Alternative RI-1: Purchase Water from Baffin Bay WSC**

21 This alternative involves purchasing compliant water from the Baffin Bay WSC, which
22 will be used to supply the Riviera ISD PWS. According to the TCEQ's Water Utilities
23 Database, the Baffin Bay WSC currently has sufficient excess capacity for this alternative to be
24 feasible. It is assumed that Riviera ISD would obtain all its water from the Baffin Bay WSC.

25 This alternative would require constructing a pipeline from the Baffin Bay WSC's water
26 main to the existing storage tank for the Riviera ISD system. A pump station and 5,000 gallon
27 feed tank would also be required to overcome pipe friction and the elevation differences
28 between Baffin Bay WSC and Riviera ISD. The required pipeline would be 4-inches in
29 diameter, and approximately 6.8 miles long.

30 The pump station would include two pumps, including one standby, and would be housed
31 in a building. A 5,000 gallon feed tank would also be constructed for the pumps to draw from.
32 It is assumed the pumps and piping would be installed with capacity to meet all water demand
33 for the Riviera ISD, since the incremental cost would be relatively small, and would provide
34 operational flexibility.

35 By definition this alternative involves regionalization, since Riviera ISD would be
36 obtaining drinking water from an existing larger supplier. Also, other PWSs near Riviera ISD

1 are in need of compliant drinking water and could share in implementation of this alternative if
2 Baffin Bay WSC expands their well field.

3 The estimated capital cost for this alternative includes constructing the pipeline, feed tank,
4 pump house, and pump station. The estimated O&M cost for this alternative includes the
5 purchase price for the treated water minus the cost related to current operation of the Riviera
6 ISD wells, plus maintenance cost for the pipeline, and power and O&M labor and materials for
7 the pump station. The estimated capital cost for this alternative is \$1.03 million, with an
8 estimated annual O&M cost of \$45,400.

9 The reliability of adequate amounts of compliant water under this alternative should be
10 good; however, Baffin Bay has recorded an instance where gross alpha particle activity
11 exceeded the MCL. Baffin Bay WSC provides water on a larger scale, facilitating adequate
12 O&M resources. From the Riviera ISD PWS's perspective, this alternative would be
13 characterized as easy to operate and repair, since O&M and repair of pipelines and pump
14 stations is well understood. If the decision was made to perform blending then the operational
15 complexity would increase.

16 The feasibility of this alternative is dependent on an agreement being reached with the
17 Baffin Bay WSC to purchase treated drinking water. Additional analyses of gross alpha are
18 needed to identify whether the contaminant currently exceeds the MCL prior to any use
19 agreements. There is a limited number of small PWSs relatively close to the Riviera ISD PWS
20 that have water quality problems and would be good candidates for sharing the cost for
21 obtaining water from Baffin Bay. The cost to Riviera ISD for this alternative could be reduced
22 if the other PWSs would be willing to share the costs. The analysis for a shared solution is
23 presented in Appendix E. This analysis shows that Riviera ISD could expect a capital cost
24 savings between \$371,300 to \$726,600 if they were to implement a shared solution like this,
25 which would be a savings between 37 to 72 percent..

26 **4.4.2 Alternative RI-2: New Well at 10 miles**

27 This alternative consists of installing one new well within 10 miles of the Riviera ISD
28 PWS that would produce compliant water in place of the water produced by the existing well.
29 At this level of study, it is not possible to positively identify an existing well or the location
30 where a new well could be installed.

31 This alternative would require constructing one new 727-foot well, a new pump station
32 with a 5,000-gallon feed tank near the new well, an additional pump station and 5,000 gallon
33 feed tank along the pipeline, and a pipeline from the new well/feed tank to the existing intake
34 point for the Riviera ISD PWS. The pump stations and feed tanks would be necessary to
35 overcome pipe friction and changes in land elevation. For this alternative, the pipeline is
36 assumed to be approximately 10 miles long, and would be a 4-inches in diameter and discharge
37 to the existing storage tank at the Riviera ISD PWS. Each pump station would include two
38 transfer pumps, including one standby, and would be housed in a building.

1 Depending on well location and capacity, this alternative could present some options for a
2 more regional solution. It may be possible to share water and costs with another nearby
3 system.

4 The estimated capital cost for this alternative includes installing the well, constructing the
5 pipeline, the pump stations, the feed tanks, service pumps and pump houses. The estimated
6 O&M cost for this alternative includes O&M for the pipeline and pump stations. The estimated
7 capital cost for this alternative is \$1.74 million, and the estimated annual O&M cost for this
8 alternative is \$54,400.

9 The reliability of adequate amounts of compliant water under this alternative should be
10 good, since water wells, pump stations and pipelines are commonly employed. From the
11 perspective of the Riviera ISD PWS, this alternative would be similar to operate as the existing
12 system. Riviera ISD PWS personnel have experience with O&M of wells, pipelines, and pump
13 stations.

14 The feasibility of this alternative is dependent on the ability to find an adequate existing
15 well or success in installing a well that produces an adequate supply of compliant water. It is
16 likely that an alternate groundwater source would not be found on land owned by Riviera ISD
17 PWS, so landowner cooperation would likely be required.

18 **4.4.3 Alternative RI-3: New Well at 5 miles**

19 This alternative consists of installing one new well within 5 miles of the Riviera ISD PWS
20 that would produce compliant water in place of the water produced by the existing well. At
21 this level of study, it is not possible to positively identify an existing well or the location where
22 new wells could be installed.

23 This alternative would require constructing one new 727-foot well, a new pump station
24 with a 5,000 gallon feed tank near the new well, and a pipeline from the new well/feed tank to
25 the existing intake point for the Riviera ISD PWS. The pump station and feed tank would be
26 necessary to overcome pipe friction and changes in land elevation. For this alternative, the
27 pipeline is assumed to be 4-inches in diameter, approximately 5 miles long, and would
28 discharge to the existing storage tank at the Riviera ISD PWS. The pump station near the well
29 would include two transfer pumps, including one standby, and would be housed in a building.

30 Depending on well location and capacity, this alternative could present some options for a
31 more regional solution. It may be possible to share water and costs with another nearby
32 system.

33 The estimated capital cost for this alternative includes installing the well, and constructing
34 the pipeline and pump station. The estimated O&M cost for this alternative includes O&M for
35 the pipeline and pump station. The estimated capital cost for this alternative is \$966,000, and
36 the estimated annual O&M cost for this alternative is \$27,200.

1 The reliability of adequate amounts of compliant water under this alternative should be
2 good, since water wells, pump stations and pipelines are commonly employed. From the
3 perspective of the Riviera ISD PWS, this alternative would be similar to operate as the existing
4 system. Riviera ISD PWS personnel have experience with O&M of wells, pipelines and pump
5 stations.

6 The feasibility of this alternative is dependent on the ability to find an adequate existing
7 well or success in installing a well that produces an adequate supply of compliant water. It is
8 likely an alternate groundwater source would not be found on land owned by the Riviera ISD
9 PWS, so landowner cooperation would likely be required.

10 **4.4.4 Alternative RI-4: New Well at 1 mile**

11 This alternative consists of installing one new well within 1 mile of the Riviera ISD PWS
12 that would produce compliant water in place of the water produced by the existing well. At
13 this level of study, it is not possible to positively identify an existing well or the location where
14 a new well could be installed.

15 This alternative would require constructing one new 727-foot well and a pipeline from the
16 new well to the existing intake point for the Riviera ISD PWS. Since the new well is relatively
17 close, a pump station would not be necessary. For this alternative, the pipeline is assumed to
18 be 4 inches in diameter, approximately 1 mile long, and would discharge to the existing storage
19 tank at the Riviera ISD PWS.

20 Depending on well location and capacity, this alternative could present some options for a
21 more regional solution. It may be possible to share water and costs with another nearby
22 system.

23 The estimated capital cost for this alternative includes installing the well, and constructing
24 the pipeline. The estimated O&M cost for this alternative includes O&M for the pipeline. The
25 estimated capital cost for this alternative is \$319,500, and the estimated annual O&M cost for
26 this alternative is \$300.

27 The reliability of adequate amounts of compliant water under this alternative should be
28 good, since water wells and pipelines are commonly employed. From the perspective of the
29 Riviera ISD PWS, this alternative would be similar to operate as the existing system. Riviera
30 ISD PWS personnel have experience with O&M of wells, pipelines, and pump stations.

31 The feasibility of this alternative is dependent on the ability to find an adequate existing
32 well or success in installing a well that produces an adequate supply of compliant water. It is
33 possible an alternate groundwater source would not be found on land owned by Riviera ISD
34 PWS, so landowner cooperation may be required.

1 **4.4.5 Alternative RI-5: Central RO Treatment**

2 This system would continue to pump water from the existing well, and would treat the
3 water through an RO treatment system prior to distribution. For this option, 100 percent of the
4 raw water would be treated to obtain compliant water. The RO process concentrates impurities
5 in the reject stream which would require disposal. It is estimated the total RO reject generation
6 would be approximately 6,500 gallons per day (gpd) when the systems are operated at the
7 average daily consumption (0.023 mgd).

8 This alternative consists of constructing the RO treatment plant near the existing ground
9 storage tank. The plant includes a 400 square foot building with paved a driveway; a skid with
10 the pre-constructed RO plant; a set of two transfer pumps, a 15,000-gallon tank for storing the
11 treated water, and a connection to the sewer for discharge of the reject water. The treated water
12 would be chlorinated and stored in the new treated water tank prior to being pumped into the
13 existing ground storage tank. The entire facility is fenced.

14 The estimated capital cost for this alternative is \$480,500, and the estimated annual O&M
15 cost is \$64,100. Installing a separate irrigation system that would not require treatment would
16 reduce the cost of this alternative.

17 The reliability of adequate amount of compliant water under this alternative is good, since
18 RO treatment is a common and well-understood treatment technology. However, O&M efforts
19 required for the central RO treatment plant may be significant, and O&M personnel would
20 require training with RO. The feasibility of this alternative is not dependent on the
21 cooperation, willingness, or capability of other water supply entities.

22 **4.4.6 Alternative RI-6: Central Coagulation Filtration Treatment**

23 The system would continue to pump water from the Riviera ISD PWS well, and would
24 treat the water through a coagulation/filtration system prior to distribution. For this option, the
25 entire flow of the raw water will be treated and the flow will be decreased when one of the two
26 50 percent filters is being backwashed by raw water. It is assumed the existing well pump has
27 adequate pressure to pump the water through the coagulation/filtration system.

28 The coagulation/filtration plant, located at the Riviera ISD PWS well site, features a
29 300 ft² building with a paved driveway; the pre-constructed filters and a coagulant solution
30 tank on a skid; a 4,000-gallon spent backwash tank, and piping systems. The spent backwash
31 would be allowed to settle in the spent backwash tank, and the water would be recycled to the
32 head of the plant, and there would be discharge of the sludge to the sewer system. The entire
33 facility is fenced.

34 The estimated capital cost for this alternative is \$372,700, and the estimated annual O&M
35 cost is \$43,400. Installing a separate irrigation system that would not require treatment would
36 reduce the cost of this alternative.

1 Reliability of supply of adequate amounts of compliant water under this alternative is
2 good, since coagulation/filtration is an established treatment technology for uranium removal.
3 The O&M efforts required is moderate and the operating personnel need to ensure that
4 coagulant is not overfed. The spent backwash water contains metal oxide particles with sorbed
5 uranium and the level of radioactivity in the backwash is relatively low.

6 **4.4.7 Alternative RI-7: Central IX Treatment**

7 The system would continue to pump water from the Riviera ISD PWS well, and would
8 treat the water through an IX system prior to distribution. For this option, the entire flow of the
9 raw water will be treated to obtain compliant water. Water in excess of that currently produced
10 would be required for backwashing and regeneration of the resin beds.

11 The IX treatment plant, located at the Riviera ISD PWS well field, features a 300 square
12 foot building with a paved driveway, a skid holding the pre-constructed IX equipment, a brine
13 tank with regeneration equipment, two transfer pumps, a 12,000-gallon feed tank, and a
14 5,670-gallon tank for storing regenerant waste. Spent backwash water and regenerant waste
15 would be discharged to the sewer at a controlled rate. The treated water would be chlorinated
16 and pump to the existing ground storage tank. The entire facility is fenced.

17 The estimated capital cost for this alternative is \$389,900, and the estimated annual O&M
18 cost is \$40,100.

19 The reliability of adequate amounts of compliant water under this alternative is good, since
20 IX treatment is a common and well-understood technology. IX treatment does not require high
21 pressure, but can be affected by interfering constituents in the water. The O&M efforts
22 required for the central IX treatment plant may be significant, and operating personnel would
23 require training with ion exchange.

24 **4.4.8 Summary of Alternatives**

25 Table 4.3 provides a summary of the key features of each alternative for Riviera ISD PWS.

26

1 **Table 4.3 Summary of Compliance Alternatives for the Riviera ISD PWS**

Alt No.	Alternative Description	Major Components	Capital Cost ¹	Annual O&M Cost	Total Annualized Cost	Reliability	System Impact	Remarks
RI-1	Purchase Water from Baffin Bay WSC	- 1 new pump station / feed tank - 6.8-mile pipeline	\$ 1,029,300	\$45,400	\$ 135,100	Good	N	Agreement must be successfully negotiated with Baffin Bay WSC. Blending may be possible. Costs could possibly be shared with small systems along pipeline route.
RI-2	Install new compliant well at 10 Miles	- New well - 2 new pump stations / feed tanks - 10-mile pipeline	\$1,743,600	\$54,400	\$206,400	Good	N	May be difficult to find well with good water quality. Costs could possibly be shared with small systems along pipeline route.
RI-3	Install new compliant well at 5 Miles	- New well - New pump station / feed tank - 5-mile pipeline	\$966,000	\$27,200	\$111,400	Good	N	May be difficult to find well with good water quality. Costs could possibly be shared with small systems along pipeline route.
RI-4	Install new compliant well at 1 Mile	- New well - 1-mile pipeline	\$319,500	\$300	\$28,100	Good	N	May be difficult to find well with good water quality.
RI-5	Continue operation of Riviera ISD well with central RO treatment	- Central RO treatment plant	\$480,500	\$64,100	\$106,000	Good	T	Costs could possibly be shared with nearby small systems.
RI-6	Continue operation of Riviera ISD well with central coagulation filtration treatment	- Central coagulation filtration treatment plant	\$372,700	\$43,400	\$75,900	Good	T	Costs could possibly be shared with nearby small systems.
RI-7	Continue operation of Riviera ISD well with central IX treatment	- Central IX treatment plant	\$389,891	\$40,125	\$74,117	Good	T	Costs could possibly be shared with nearby small systems.

2
3
4
5
6
7

Notes: N – No significant increase required in technical or management capability
T – Implementation of alternative will require increase in technical capability
M – Implementation of alternative will require increase in management capability
1 – See cost breakdown in Appendix C
2 – 20-year return period and 6 percent interest

1 **4.5 COST OF SERVICE AND FUNDING ANALYSIS**

2 To evaluate the financial impact of implementing the compliance alternatives, a 30-year
3 financial planning model was developed. This model can be found in Appendix D. Since the
4 model was developed for water systems that collect revenue from paying customers for water
5 usage, it had to be adapted for Riviera ISD PWS whose water system costs are funded by
6 property taxes and State funds. Data for such models are typically derived from established
7 budgets, audited financial reports, published water tariffs, and consumption data. Riviera ISD
8 PWS does not track expenses for the water system separately.

9 Since the Riviera ISD is a public school there are no revenues from the sale of water.
10 Information available to complete the financial analysis included estimated expenses for the
11 PWS from Riviera ISD personnel, water production capacity data for the Riviera ISD PWS
12 from the TCEQ website, and estimated water usage based on a per capita usage rate of 30
13 gallon per day.

14 This analysis will need to be performed in a more detailed fashion and applied to
15 alternatives deemed attractive and worthy of more detailed evaluation. A more detailed
16 analysis should include additional factors such as:

- 17 • Cost escalation,
- 18 • Price elasticity effects where increased rates may result in lower water consumption,
- 19 • Costs for other system upgrades and rehabilitation needed to maintain compliant
20 operation.

21 **4.5.1 Financial Plan Development**

22 Since financial records for Riviera ISD were not available and no revenues are generated
23 from the sale of water, the following assumptions were made to derive estimates for input into
24 the financial planning model. These assumptions were:

- 25 1) Water system expenses are \$5,000
- 26 2) 2006 revenues equal 2006 expenses for operation of the water system.
- 27 3) The existing potable water system is paid for and has been fully depreciated
- 28 4) A nominal fee per student/teacher for water use was assigned in order to simulate a
29 revenue stream.
- 30 5) An average consumption of 0.023 mgd is held constant across the year to account for
31 irrigation, housekeeping, school events, and other water needs throughout the year.

32 The Riviera ISD has a population of 500. While students/teachers do not pay for the water
33 they consume, an annual base rate of \$10.00 per person was established which accounts for

1 \$5,000 of the water system revenues. This arbitrary value results in a theoretical revenue equal
2 to the \$5,000 in operating expenses. These values were used in the financial planning model.

3 While these assumptions are arbitrary, they help to frame costs of the water system
4 operation and allow impacts of the incremental costs of the various alternatives to be evaluated.

5 **4.5.2 Current Financial Condition**

6 **4.5.2.1 Cash Flow Needs**

7 Cash flow needs could not be evaluated for the Riviera ISD PWS because the system
8 provides water to the school campus without cost. The school budget covers the operation of
9 the water system. However, since it was assumed that theoretical water revenues are equal to
10 the operating expenses, any capital improvements to the water system would require additional
11 funding.

12 **4.5.2.2 Ratio Analysis**

13 *Current Ratio*

14 The Current Ratio for the Riviera ISD PWS could not be determined due to lack of
15 necessary financial data to determine this ratio.

16 *Debt to Net Worth Ratio*

17 A Debt-to-Net-Worth Ratio also could not be determined owing to lack of the necessary
18 financial data to determine this ratio.

19 *Operating Ratio*

20 Because of the lack of complete separate financial data specifically related to the Riviera
21 ISD PWS, the Operating Ratio could not be accurately determined.

22 **4.5.3 Financial Plan Results**

23 Each of the compliance alternatives for the Riviera ISD PWS was evaluated using the
24 financial model to determine the overall increase in water rates that would be necessary to pay
25 for the improvements. Each alternative was examined under the various funding options
26 described in Section 2.4.

27 Results of the financial impact analysis are provided in Table 4.4 and Figure 4.2.
28 Table 4.4 and Figure 4.2 present rate impacts assuming that revenues match expenses, without
29 funding reserve accounts, and that operations and implementation of compliance alternatives
30 are funded with revenue and are not paid for from reserve accounts. Figure 4.2 provides a bar
31 chart that, in terms of the yearly billing to an average customer, shows the following:

- 32 • Current annual average bill,

Riviera ISD
Table 4.4 Financial Impact on Students

Alternative	Description		All Revenue	100% Grant	75% Grant	50% Grant	SRF	Bond
1	Purchase Water from Baffin Bay WSC	Maximum % of MHI	6.7%	0.3%	0.5%	0.6%	0.8%	0.9%
		Percentage Rate Increase Compared to Current	20585%	908%	1310%	1713%	2278%	2518%
		Average Annual Water Bill	\$2,069	\$101	\$141	\$181	\$238	\$262
2	New Well at 10 Miles	Maximum % of MHI	11.4%	0.4%	0.6%	0.8%	1.1%	1.3%
		Percentage Rate Increase Compared to Current	34873%	1089%	1770%	2452%	3411%	3816%
		Average Annual Water Bill	\$3,497	\$119	\$187	\$255	\$351	\$392
3	New Well at 5 Miles	Maximum % of MHI	6.3%	0.2%	0.3%	0.5%	0.6%	0.7%
		Percentage Rate Increase Compared to Current	19319%	544%	922%	1300%	1831%	2056%
		Average Annual Water Bill	\$1,942	\$64	\$102	\$140	\$193	\$216
4	New Well at 1 Mile	Maximum % of MHI	2.1%	0.0%	0.1%	0.1%	0.2%	0.2%
		Percentage Rate Increase Compared to Current	6389%	6%	130%	255%	431%	505%
		Average Annual Water Bill	\$649	\$11	\$23	\$36	\$53	\$61
5	Central Treatment - RO	Maximum % of MHI	3.2%	0.4%	0.5%	0.6%	0.7%	0.7%
		Percentage Rate Increase Compared to Current	9611%	1283%	1471%	1659%	1923%	2035%
		Average Annual Water Bill	\$971	\$138	\$157	\$176	\$202	\$213
6	Central Treatment - Coag/filtration	Maximum % of MHI	2.5%	0.3%	0.4%	0.4%	0.5%	0.5%
		Percentage Rate Increase Compared to Current	7454%	868%	1014%	1160%	1364%	1451%
		Average Annual Water Bill	\$755	\$97	\$111	\$126	\$146	\$155
7	Central Treatment - IE	Maximum % of MHI	2.6%	0.3%	0.3%	0.4%	0.5%	0.5%
		Percentage Rate Increase Compared to Current	7798%	803%	955%	1107%	1322%	1412%
		Average Annual Water Bill	\$790	\$90	\$105	\$121	\$142	\$151

- 1 • Projected annual average bill including rate increase, if needed, to match existing
2 expenditures, and
- 3 • Projected annual bill including rate increases needed to fund implementation of a
4 compliance alternative (this does not include funding for reserve accounts).

5 The two bars shown for each compliance alternative represent the rate changes necessary
6 for revenues to match total expenditures assuming 100 percent grant funding and 100 percent
7 loan/bond funding. Most funding options will fall between 100 percent grant and 100 percent
8 loan/bond funding, with the exception of 100 percent revenue financing. Establishing or
9 increasing reserve accounts would require an increase in rates. If existing reserves are
10 insufficient to fund a compliance alternative, rates would need to be raised before
11 implementing the compliance alternative. This would allow for accumulation of sufficient
12 reserves to avoid larger but temporary rate increases during the years the compliance
13 alternative was being implemented.

14 **4.5.4 Evaluation of Potential Funding Options**

15 There are a variety of funding programs available to entities as described in Section 2.4.
16 Riviera ISD PWS is most likely to obtain funding from programs administered by the TWDB,
17 ORCA, and Rural Development. This report contains information that would be used for an
18 application for funding. Information such as financial analyses, water supply assessment, and
19 records demonstrating health concerns, failing infrastructure, and financial need, may be
20 required by these agencies. This section describes the candidate funding agencies and their
21 appropriate programs as well as information and steps needed to begin the application process.

22 This report should serve to document the existing water quality issues, infrastructure need
23 and costs, and water system information needed to begin the application process. Although this
24 report is at the conceptual level, it demonstrates that significant funding will be needed to meet
25 Safe Drinking Water Standards. The information provided in this report may serve as the
26 needed documentation to justify a project that may only be possible with significant financial
27 assistance.

28 **4.5.4.1 TWDB Funding Options**

29 The programs offered by the TWDB include the Drinking Water State Revolving Fund
30 (DWSRF), Rural Water Assistance Fund (RWAFF), State Loan Program (Development Fund
31 II), and Economically Distressed Areas Program (EDAP).

32 **Drinking Water State Revolving Fund**

33 The DWSRF offers net long-term interest lending rates below the rate the borrower would
34 receive on the open market for a period of 20 years. A cost-recovery loan origination charge is
35 imposed to cover the administrative costs of operating the DWSRF, but an additional interest
36 rate subsidy is offered to offset the charge. The terms of the loan typically require a revenue or
37 tax pledge. Depending on how the origination charge is handled, interest rates can be as low as
38 0.95 percent below market rates with the possibility of additional federal subsidies for total

1 interest rates 1.95 percent below market rates. Disadvantaged communities may obtain loans at
2 interest rates between 0 percent and 1 percent.

3 The loan application process has several steps: pre-application, application and
4 commitment, loan closing, funding and construction monitoring, and any other special
5 requirements. In the pre-application phase, prospective loan applicants are asked to submit a
6 brief DWSRF Information Form to the TWDB that describes the applicant’s existing water
7 facilities, additional facility needs and the nature of projects being considered for meeting those
8 needs, project cost estimates, and “disadvantaged community” status. The TCEQ assigns a
9 priority rating that includes an applicant’s readiness to proceed. TWDB staff notify
10 prospective applicants of their priority rating and encourage them to schedule a pre-planning
11 conference for guidance in preparing the engineering, planning, environmental, financial, and
12 water conservation portions of the DWSRF application.

13 Additional information can be found online at the TWDB website under the Assistance
14 tab, Financial Assistance section, Public Works Infrastructure Construction subsection, and
15 under the links “Clean Water State Revolving Fund Loan Program.”

16 **State Loan Program (Development Fund II)**

17 The State Loan Program is a diverse lending program directly from state funding
18 sources. As it does not receive federal subsidies, it is more streamlined. The loans can
19 incorporate more than one project under the umbrella of one loan. Political subdivision of the
20 state are eligible for tax exempt rates. Projects can include purchase of water rights, treatment
21 plants, storage and pumping facilities, transmission lines, well development, and acquisitions.

22 The loan requires that the applicant pledge revenue or taxes. The maximum financing
23 life is 50 years. The average financing period is 20 to 23 years. The lending rate scale varies
24 according to several factors, but is set by the TWDB based on cost of funds to the board, risk
25 factors of managing the board loan portfolio, and market rate scales. The TWDB seeks to
26 make reasonable loans with minimal risk to the state. The TWDB post rates for comparison for
27 applicants and in August 2008, the TWDB showed their rates for a 22-year, taxable loan at
28 5.5 percent where the market was at 7.84 percent.

29 The TWDB staff can discuss the terms of the loan and assist applicants during preparation
30 of the application, and a preapplication conference is encouraged. The application materials
31 must include an engineering feasibility report, environmental information, rates and customer
32 base, operating budgets, financial statements, and project information. The TWDB considers
33 the needs of the area; benefits of the project; the relationship of the project to the overall state
34 water needs and the State Water Plan; and the availability of all sources of revenue to the rural
35 utility for the ultimate repayment of the loan. The board considers applications monthly.

36 Additional information can be found online at the TWDB website under the Assistance
37 tab, Financial Assistance section, Public Works Infrastructure Construction subsection, and
38 under the link “Water and Wastewater Loan Program.”

1 **Economically Distressed Areas Program**

2 The EDAP Program was designed to assist areas along the U.S./Mexico border in areas that
3 were economically distressed. In 2008, this program was extended to apply to the entire state
4 so long as requirements are met. This program provides financial assistance through the
5 provision of grants and loans to communities where present facilities are inadequate to meet
6 residents minimal needs. Eligible communities are those that have median household income
7 less than 75 percent of the state household income. Non-profit water supply corporations can
8 apply, but they must be capable of maintaining and operating the completed system, and hold
9 or be in the process of obtaining a Certificate of Convenience and Necessity. The county
10 where the project is located must adopt model rules for the regulation of subdivisions prior to
11 application for financial assistance. If the applicant is a city, the city must also adopt Model
12 Subdivision Rules of TWDB (31 Texas Administrative Code [TAC] Chapter 364). The
13 program funds design, construction, improvements, and acquisition, and includes measures to
14 prevent future substandard development. The TWDB works with the applicant to find ways to
15 leverage other state and federal financial resources.

16 The loan requires that the applicant pledge revenue or taxes. The maximum financing
17 life is 50 years. The average financing period is 20 to 23 years. The lending rate scale varies
18 according to several factors but is set by the TWDB based on cost of funds to the board, risk
19 factors of managing the board loan portfolio, and market rate scales. The TWDB seeks to
20 make reasonable loans with minimal loss to the state. The TWDB posts rates for comparison
21 for applicants and in August 2008 the TWDB showed its rates for a 22-year, tax exempt loan at
22 5.11 percent where the market was at 5.60 percent. Most projects have a financial package
23 with the majority of the project financed with grants. Many have received 100 percent grants.

24 The first step in the application process is to meet with TWDB staff to discuss the terms of
25 the loan and assist applicants during preparation of the application. Major components of the
26 application materials must include an engineering feasibility report, environmental information,
27 rates and customer base, operating budgets, financial statements, community information,
28 project information, and other legal information.

29 Additional information can be found online at the TWDB website under the Assistance
30 tab, Financial Assistance section, Public Works Infrastructure Construction subsection, and
31 under the link “Economically Distressed Area Program.”

32 **4.5.4.2 ORCA Funding Options**

33 Created in 2001, ORCA seeks to strengthen rural communities and assist them with
34 community and economic development and healthcare by providing a variety of rural
35 programs, services, and activities. Of their many programs and funds, the most appropriate
36 programs related to drinking water are the Community Development (CD) Fund, and Texas
37 Small Towns Environment Program (STEP). These programs offer attractive funding packages
38 to help make improvements to potable water systems to mitigate potential health concerns.

1 **Community Development Fund**

2 The CD Fund is a competitive grant program for water system improvements as well as
3 other utility services (wastewater, drainage improvements, and housing activities). Funds are
4 distributed between 24 state planning regions where funds are allocated to address each
5 region's utility priorities. Funds can be used for various types of public works projects,
6 including water system improvements. Cities with a population of less than 50,000 that are not
7 eligible for direct CDBG funding from the U.S. Department of Housing and Urban
8 Development are eligible. Funds are awarded on a competitive basis decided twice a year by
9 regional review committees using a defined scoring system (past performance with CDBG is a
10 factor). Awards are no less than \$75,000 and cannot exceed \$800,000. More information can
11 be found at the Office of Community Affairs website under Community Development Fund.

12 **Texas Small Towns Environment Program**

13 Under special occasions some communities are invited to participate in grant programs
14 when self-help is a feasible method for completing a water project, the community is
15 committed to self-help, and the community has the capacity to complete the project. The
16 purpose is to significantly reduce the cost of the project by using the communities' own human,
17 material, and financial capital. Projects typically are repair, rehabilitation, improvements,
18 service connections, and yard services. Reasonable associated administration and engineering
19 cost can be funded. A letter of interest is first submitted, and after CDBG staff determine
20 eligibility, an application may be submitted. Awards are only given twice per year on a priority
21 basis so long as the project can be fully funded (\$350,000 maximum award). Ranking criteria
22 are project impact, local effort, past performance, percent of savings, and benefit to low to
23 medium-income persons.

24 **4.5.4.3 Rural Development**

25 The RUS agency of Rural Development established a Revolving Fund Program (RFP)
26 administered by the staff of the Water and Environment Program (WEP) to assist communities
27 with water and wastewater systems. The purpose is to fund technical assistance and projects to
28 help communities bring safe drinking water and sanitary, environmentally sound, waste
29 disposal facilities to rural Americans in greatest need. WEP provides loans, grants, and loan
30 guarantees for drinking water, sanitary sewer, solid waste, and storm drainage facilities in rural
31 areas and cities and towns with a population of 10,000 or less. Recipients must be public
32 entities such as municipalities, counties, special purpose districts, Indian tribes, and
33 corporations not operated for profit. Projects include all forms of infrastructure improvement,
34 acquisition of land and water rights, and design fees. Rural Development attempts to provide
35 some level of assistance to all communities that apply. Funds are provided on a first come, first
36 serve basis; however, staff do evaluate need and assign priorities as funds are limited.
37 Grant/loan mixes vary on a case by case basis and some communities may have to wait through
38 several funding cycles until funds become available.

1 **Water and Wastewater Disposal Program**

2 The major components of the RFP are loan, loan guarantees, and grant funding for water
3 and waste disposal systems. Entities must demonstrate that they cannot obtain reasonable loans
4 at market rates, but have the capacity to repay loans, pledge security, and operate the facilities.
5 Grants can be up to 75 percent of the project costs, and loan guarantees can be up to 90 percent
6 of eligible loss. Loans are not to exceed a 40-year repayment period, require tax or revenue
7 pledges, and are offered at three rates:

- 8 • Poverty Rate - The lowest rate is the poverty interest rate of 4.5 percent. Loans must be
9 used to upgrade or construct new facilities to meet health standards, and the MHI in the
10 service area must be below the poverty line for a family of four or below 80 percent of
11 the statewide MHI for non-metropolitan communities.
- 12 • Market Rate – Where the MHI in the service exceeds the state MHI, the rate is based on
13 the average of the “Bond Buyer” 11-Bond Index over a four week period.
- 14 • Intermediate Rate – the average of the Poverty Rate and the Market Rate, but not to
15 exceed seven percent.

16

1
2

**APPENDIX A
PWS INTERVIEW FORM**

CAPACITY DEVELOPMENT ASSESSMENT FORM

Prepared By _____

Date _____

Section 1. Public Water System Information

1. PWS ID #	<input type="text"/>	2. Water System Name	<input type="text"/>
3. County	<input type="text"/>		
4. Owner	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
5. Admin	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
6. Operator	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
7. Population Served	<input type="text"/>	8. No. of Service Connections	<input type="text"/>
9. Ownership Type	<input type="text"/>	10. Metered (Yes or No)	<input type="text"/>
11. Source Type	<input type="text"/>		
12. Total PWS Annual Water Used	<input type="text"/>		
13. Number of Water Quality Violations (Prior 36 months)			
Total Coliform	<input type="text"/>	Chemical/Radiological	<input type="text"/>
Monitoring (CCR, Public Notification, etc.)	<input type="text"/>	Treatment Technique, D/DBP	<input type="text"/>

A. Basic Information

1. Name of Water System:
2. Name of Person Interviewed:
3. Position:
4. Number of years at job:
5. Number of years experience with drinking water systems:
6. Percent of time (day or week) on drinking water system activities, with current position (how much time is dedicated exclusively to the water system, not wastewater, solid waste or other activities):
7. Certified Water Operator (Yes or No):

If Yes,

 - 7a. Certification Level (water):
 - 7b. How long have you been certified?
8. Describe your water system related duties on a typical day.

B. Organization and Structure

1. Describe the organizational structure of the Utility. Please provide an organizational chart. (Looking to find out the governance structure (who reports to whom), whether or not there is a utility board, if the water system answers to public works or city council, etc.)

2. If not already covered in Question 1, to whom do you report?
3. Do all of the positions have a written job description?
 - 3a. If yes, is it available to employees?
 - 3b. May we see a copy?

C. Personnel

1. What is the current staffing level (include all personnel who spend more than 10% of their time working on the water system)?

2. Are there any vacant positions? How long have the positions been vacant?

3. In your opinion, is the current staffing level adequate? If not adequate, what are the issues or staffing needs (how many and what positions)?

4. What is the rate of employee turnover for management and operators? What are the major issues involved in the turnover (e.g., operator pay, working conditions, hours)?

5. Is the system staffed 24 hours a day? How is this handled (on-site or on-call)? Is there an alarm system to call an operator if an emergency occurs after hours?

D. Communication

1. Does the utility have a mission statement? If yes, what is it?
2. Does the utility have water quality goals? What are they?
3. How are your work priorities set?
4. How are work tasks delegated to staff?
5. Does the utility have regular staff meetings? How often? Who attends?
6. Are there separate management meetings? If so, describe.
7. Do management personnel ever visit the treatment facility? If yes, how often?
8. Is there effective communication between utility management and state regulators (e.g., NMED)?
9. Describe communication between utility and customers.

E. Planning and Funding

1. Describe the rate structure for the utility.

2. Is there a written rate structure, such as a rate ordinance? May we see it?
 - 2a. What is the average rate for 6,000 gallons of water?

3. How often are the rates reviewed?

4. What process is used to set or revise the rates?

5. In general, how often are the new rates set?

6. Is there an operating budget for the water utility? Is it separate from other activities, such as wastewater, other utilities, or general city funds?

7. Who develops the budget, how is it developed and how often is a new budget created or the old budget updated?

8. How is the budget approved or adopted?

9. In the last 5 years, how many budget shortfalls have there been (i.e., didn't collect enough money to cover expenses)? What caused the shortfall (e.g., unpaid bills, an emergency repair, weather conditions)?

9a. How are budget shortfalls handled?
10. In the last 5 years how many years have there been budget surpluses (i.e., collected revenues exceeded expenses)?

10a. How are budget surpluses handled (i.e., what is done with the money)?
11. Does the utility have a line-item in the budget for emergencies or some kind of emergency reserve account?
12. How do you plan and pay for short-term system needs?
13. How do you plan and pay for long- term system needs?
14. How are major water system capital improvements funded? Does the utility have a written capital improvements plan?
15. How is the facility planning for future growth (either new hook-ups or expansion into new areas)?
16. Does the utility have and maintain an annual financial report? Is it presented to policy makers?

17. Has an independent financial audit been conducted of the utility finances? If so, how often? When was the last one?
18. Will the system consider any type of regionalization with any other PWS, such as system interconnection, purchasing water, sharing operator, emergency water connection, sharing bookkeeper/billing or other?

F. Policies, Procedures, and Programs
--

1. Are there written operational procedures? Do the employees use them?
2. Who in the utility department has spending authorization? What is the process for obtaining needed equipment or supplies, including who approves expenditures?
3. Does the utility have a source water protection program? What are the major components of the program?
4. Are managers and operators familiar with current SDWA regulations?
5. How do the managers and operators hear about new or proposed regulations, such as arsenic, DBP, Groundwater Rule? Are there any new regulations that will be of particular concern to the utility?
6. What are the typical customer complaints that the utility receives?
7. Approximately how many complaints are there per month?

8. How are customer complaints handled? Are they recorded?
9. (If not specifically addressed in Question 7) If the complaint is of a water quality nature, how are these types of complaints handled?
10. Does the utility maintain an updated list of critical customers?
11. Is there a cross-connection control plan for the utility? Is it written? Who enforces the plan's requirements?
12. Does the utility have a written water conservation plan?
13. Has there been a water audit of the system? If yes, what were the results?
14. (If not specifically answered in 11 above) What is the estimated percentage for loss to leakage for the system?
15. Are you, or is the utility itself, a member of any trade organizations, such as AWWA or Rural Water Association? Are you an active member (i.e., attend regular meetings or participate in a leadership role)? Do you find this membership helpful? If yes, in what ways does it help you?

G. Operations and Maintenance

1. How is decision-making authority split between operations and management for the following items:
 - a. Process Control
 - b. Purchases of supplies or small equipment
 - c. Compliance sampling/reporting
 - d. Staff scheduling

2. Describe your utility's preventative maintenance program.

3. Do the operators have the ability to make changes or modify the preventative maintenance program?

4. How does management prioritize the repair or replacement of utility assets? Do the operators play a role in this prioritization process?

5. Does the utility keep an inventory of spare parts?

6. Where does staff have to go to buy supplies/minor equipment? How often?
 - 6a. How do you handle supplies that are critical, but not in close proximity (for example if chlorine is not available in the immediate area or if the components for a critical pump are not in the area)

7. Describe the system's disinfection process. Have you had any problems in the last few years with the disinfection system?

7a. Who has the ability to adjust the disinfection process?

8. How often is the disinfectant residual checked and where is it checked?

8a. Is there an official policy on checking residuals or is it up to the operators?

9. Does the utility have an O & M manual? Does the staff use it?

10. Are the operators trained on safety issues? How are they trained and how often?

11. Describe how on-going training is handled for operators and other staff. How do you hear about appropriate trainings? Who suggests the trainings – the managers or the operators? How often do operators, managers, or other staff go to training? Who are the typical trainers used and where are the trainings usually held?

12. In your opinion is the level of your on-going training adequate?

13. In your opinion is the level of on-going training for other staff members, particularly the operators, adequate?

14. Does the facility have mapping of the water utility components? Is it used on any routine basis by the operators or management? If so, how is it used? If not, what is the process used for locating utility components?
15. In the last sanitary survey, were any deficiencies noted? If yes, were they corrected?
16. How often are storage tanks inspected? Who does the inspection?
 - 16a. Have you experienced any problems with the storage tanks?

H. SDWA Compliance

1. Has the system had any violations (monitoring or MCL) in the past 3 years? If so, describe.
2. How were the violations handled?
3. Does the system properly publish public notifications when notified of a violation?
4. Is the system currently in violation of any SDWA or state regulatory requirements, including failure to pay fees, fines, or other administrative type requirements?
5. Does the utility prepare and distribute a Consumer Confidence Report (CCR)? Is it done every year? What type of response does the utility get to the CCR from customers?

I. Emergency Planning

1. Does the system have a written emergency plan to handle emergencies such as water outages, weather issues, loss of power, loss of major equipment, etc?
2. When was the last time the plan was updated?
3. Do all employees know where the plan is? Do they follow it?
4. Describe the last emergency the facility faced and how it was handled.

Attachment A

A. Technical Capacity Assessment Questions

1. Based on available information of water rights on record and water pumped has the system exceeded its water rights in the past year? YES NO

In any of the past 5 years? YES NO How many times? _____

2. Does the system have the proper level of certified operator? (Use questions a – c to answer.)
YES NO

a. What is the Classification Level of the system by NMED? _____

b. Does the system have one or more certified operator(s)? [20 NMAC 7.4.20]

YES NO

c. If YES, provide the number of operators at each New Mexico Certification Level. [20 NMAC 7.4.12]

_____ NM Small System _____ Class 2

_____ NM Small System Advanced _____ Class 3

_____ Class 1 _____ Class 4

3. Did the system correct any sanitary deficiency noted on the most recent sanitary survey within 6 months of receiving that information? [20 NMAC 7.20.504]

YES NO No Deficiencies

What was the type of deficiency? (Check all that are applicable.)

Source Storage

Treatment Distribution

Other _____

From the system’s perspective, were there any other deficiencies that were not noted on the sanitary survey?
Please describe.

4. Will the system’s current treatment process meet known future regulations?

Radionuclides YES NO Doesn’t Apply

Arsenic YES NO Doesn’t Apply

Stage 1 Disinfectants and Disinfection By-Product (DBP)

YES NO Doesn’t Apply

Surface Water Treatment Rule YES NO Doesn’t Apply

5. Does the system have a current site plan/map? [20 NMAC 7.10.302 A.1.]

YES NO

6. Has the system had a water supply outage in the prior 24 months?

YES NO

What were the causes of the outage(s)? (Include number of outages for each cause.)

Drought _____ Limited Supply _____

System Failure _____ Other _____

7. Has the system ever had a water audit or a leak evaluation?

YES NO Don't Know

If YES, please complete the following table.

Type of Investigation	Date Done	Water Loss (%)	What approach or technology was used to complete the investigation?	Was any follow-up done? If so, describe

8. Have all drinking water projects received NMED review and approval? [20 NMAC 7.10.201]

YES NO

If NO, what types of projects have not received NMED review and approval.

Source Storage

Treatment Distribution

Other _____

9. What are the typical customer complaints that the utility receives?

10. Approximately how many complaints are there per month? _____

11. How are customer complaints handled? Are they recorded?

12. What is the age and composition of the distribution system? *(Collect this information from the Sanitary Survey)*

Pipe Material	Approximate Age	Percentage of the system	Comments
			Sanitary Survey Distribution System Records Attached

13. Are there any dead end lines in the system?
 YES NO

14. Does the system have a flushing program?
 YES NO

If YES, please describe.

15. Are there any pressure problems within the system?
 YES NO

If YES, please describe.

16. Does the system disinfect the finished water?
 YES NO

If yes, which disinfectant product is used? _____

Interviewer Comments on Technical Capacity:

B. Managerial Capacity Assessment Questions

17. Has the system completed a 5-year Infrastructure Capital Improvement Plan (ICIP) plan?
 YES NO

If YES, has the plan been submitted to Local Government Division?

YES NO

18. Does the system have written operating procedures?
 YES NO

19. Does the system have written job descriptions for all staff?
 YES NO

20. Does the system have:
- A preventative maintenance plan?
YES NO
 - A source water protection plan?
YES NO N/A
 - An emergency plan?
YES NO
 - A cross-connection control program?
YES NO
 - An emergency source?
YES NO
 - System security measures?
YES NO
21. Does the system report and maintain records in accordance with the drinking water regulations concerning:
- Water quality violations
YES NO
 - Public notification
YES NO
 - Sampling exemptions
YES NO
22. Please describe how the above records are maintained:
23. Describe the management structure for the water system, including board and operations staff. Please include examples of duties, if possible.
24. Please describe type and quantity of training or continuing education for staff identified above.
25. Describe last major project undertaken by the water system, including the following: project in detail, positive aspects, negative aspects, the way in which the project was funded, any necessary rate increases, the public response to the project, whether the project is complete or not, and any other pertinent information.

26. Does the system have any debt? YES NO

If yes, is the system current with all debt payments?

YES NO

If no, describe the applicable funding agency and the default.

27. Is the system currently contemplating or actively seeking funding for any project?

YES NO

If yes, from which agency and how much?

Describe the project?

Is the system receiving assistance from any agency or organization in its efforts?

28. Will the system consider any type of regionalization with other PWS? (Check YES if the system has already regionalized.)

YES NO

If YES, what type of regionalization has been implemented/considered/discussed? (Check all that apply.)

System interconnection

Sharing operator

Sharing bookkeeper

Purchasing water

Emergency water connection

Other: _____

29. Does the system have any of the following? (Check all that apply.)

Water Conservation Policy/Ordinance Current Drought Plan

Water Use Restrictions Water Supply Emergency Plan

Interviewer Comments on Managerial Capacity:

C. Financial Capacity Assessment

30. Does the system have a budget?
 YES NO
 If YES, what type of budget?
 Operating Budget
 Capital Budget
31. Have the system revenues covered expenses and debt service for the past 5 years?
 YES NO
 If NO, how many years has the system had a shortfall? _____
32. Does the system have a written/adopted rate structure?
 YES NO
33. What was the date of the last rate increase? _____
34. Are rates reviewed annually?
 YES NO
 IF YES, what was the date of the last review? _____
35. Did the rate review show that the rates covered the following expenses? *(Check all that apply.)*
- | | |
|-------------------------------------|--------------------------|
| Operation & Maintenance | <input type="checkbox"/> |
| Infrastructure Repair & replacement | <input type="checkbox"/> |
| Staffing | <input type="checkbox"/> |
| Emergency/Reserve fund | <input type="checkbox"/> |
| Debt payment | <input type="checkbox"/> |
36. Is the rate collection above 90% of the customers?
 YES NO
37. Is there a cut-off policy for customers who are in arrears with their bill or for illegal connections?
 YES NO
 If yes, is this policy implemented?
38. What is the residential water rate for 6,000 gallons of usage in one month. _____
39. In the past 12 months, how many customers have had accounts frozen or dropped for non-payment? _____
 [Convert to % of active connections
 Less than 1% 1% - 3% 4% - 5% 6% - 10%
 11% - 20% 21% - 50% Greater than 50%]

40. The following questions refer to the process of obtaining needed equipment and supplies.

a. Can the water system operator buy or obtain supplies or equipment when they are needed?

YES NO

b. Is the process simple or burdensome to the employees?

c. Can supplies or equipment be obtained quickly during an emergency?

YES NO

d. Has the water system operator ever experienced a situation in which he/she couldn't purchase the needed supplies?

YES NO

e. Does the system maintain some type of spare parts inventory?

YES NO

If yes, please describe.

41. Has the system ever had a financial audit?

YES NO

If YES, what is the date of the most recent audit? _____

42. Has the system ever had its electricity or phone turned off due to non-payment? Please describe.

Interviewer Comments on Financial Assessment:

43. What do you think the system capabilities are now and what are the issues you feel your system will be facing in the future? In addition, are there any specific needs, such as types of training that you would like to see addressed by NMED or its contractors?

APPENDIX B COST BASIS

This section presents the basis for unit costs used to develop the conceptual cost estimates for the compliance alternatives. Cost estimates are conceptual in nature (+50%/-30%), and are intended to make comparisons between compliance options and to provide a preliminary indication of possible rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. Capital cost includes an allowance for engineering and construction management. It is assumed that adequate electrical power is available near the site. The cost estimates specifically do not include costs for the following:

- Obtaining land or easements.
- Surveying.
- Mobilization/demobilization for construction.
- Insurance and bonds

In general, unit costs are based on recent construction bids for similar work in the area; when possible, consultations with vendors or other suppliers; published construction and O&M cost data; and USEPA cost guidance. Unit costs used for the cost estimates are summarized in Table B.1.

Unit costs for pipeline components are based on 2008 RS Means Site Work & Landscape Cost Data. The number of borings and encasements and open cuts and encasements is estimated by counting the road, highway, railroad, stream, and river crossings for a conceptual routing of the pipeline. The number of air release valves is estimated by examining the land surface profile along the conceptual pipeline route. It is assumed that gate valves and flush valves would be installed, on average, every 5,000 feet along the pipeline. Pipeline cost estimates are based on the use of C-900 PVC pipe. Other pipe materials could be considered for more detailed development of attractive alternatives.

Pump station unit costs are based on experience with similar installations. The cost estimate for the pump stations include two pumps, station piping and valves, station electrical and instrumentation, minor site improvement, installation of a concrete pad, fence and building, and tools. The number of pump stations is based on calculations of pressure losses in the proposed pipeline for each alternative. Back-flow prevention is required in cases where pressure losses are negligible, and pump stations are not needed. Construction cost of a storage tank is based on consultations with vendors and 2008 R.S. Means Site Work & Landscape Cost Data.

Labor costs are estimated based on 2008 RS Means Site Work & Landscape Cost Data specific to the Nueces County region.

1 Electrical power cost is estimated to be \$0.175 per kWh, as supplied by Nueces electric
2 Co-op. The annual cost for power to a pump station is calculated based on the pumping head
3 and volume, and includes 11,800 kWh for pump building heating, cooling, and lighting, as
4 recommended in USEPA publication, *Standardized Costs for Water Supply Distribution*
5 *Systems* (1992).

6 In addition to the cost of electricity, pump stations have other maintenance costs. These
7 costs cover: materials for minor repairs to keep the pumps operating; purchase of a
8 maintenance vehicle, fuel costs, and vehicle maintenance costs; utilities; office supplies, small
9 tools and equipment; and miscellaneous materials such as safety, clothing, chemicals, and
10 paint. The non-power O&M costs are estimated based on the USEPA publication,
11 *Standardized Costs for Water Supply Distribution Systems* (1992), which provides cost curves
12 for O&M components. Costs from the 1992 report are adjusted to 2008 dollars based on the
13 ENR construction cost index.

14 Pipeline maintenance costs include routine cleaning and flushing, as well as minor repairs
15 to lines. The unit rate for pipeline maintenance is calculated based on the USEPA technical
16 report, *Innovative and Alternate Technology Assessment Manual MCD 53* (1978). Costs from
17 the 1978 report are adjusted to 2008 dollars based on the ENR construction cost index.

18 Storage tank maintenance costs include cleaning and renewal of interior lining and exterior
19 coating. Unit costs for storage tank O&M are based on USEPA publication *Standardized Costs*
20 *for Water Supply Distribution Systems* (1992). Costs from the 1992 report are adjusted to 2008
21 dollars based on the ENR construction cost index.

22 The purchase price for point-of-use (POU) water treatment units is based on vendor price
23 lists for treatment units, plus installation. O&M costs for POU treatment units are also based
24 on vendor price lists. It is assumed that a yearly water sample would be analyzed for the
25 contaminant of concern.

26 The purchase price for point-of-entry (POE) water treatment units is based on vendor price
27 lists for treatment units, plus an allowance for installation, including a concrete pad and shed,
28 piping modifications, and electrical connection. O&M costs for POE treatment units are also
29 based on vendor price lists. It is assumed that a yearly water sample would be analyzed for the
30 contaminant of concern.

31 Central treatment plant costs include pricing for buildings, utilities, and site work. Costs
32 are based on pricing given in the various R.S. Means Construction Cost Data References, as
33 well as prices obtained from similar work on other projects. Pricing for treatment equipment
34 was obtained from vendors.

35 Well installation costs are based on 2008 RS Means Site Work & Landscape Cost Data.
36 Well installation costs include drilling, a well pump, electrical and instrumentation installation,
37 well finishing, piping, and water quality testing. O&M costs for water wells include power,
38 materials, and labor. It is assumed that new wells located more than 1 mile from the intake
39 point of an existing system would require a storage tank and pump station.

1 Purchase price for the treatment unit dispenser is based on vendor price lists, plus an
2 allowance for installation at a centralized public location. The O&M costs are also based on
3 vendor price lists. It is assumed that weekly water samples would be analyzed for the
4 contaminant of concern.

5 Costs for bottled water delivery alternatives are based on consultation with vendors that
6 deliver residential bottled water. The cost estimate includes an initial allowance for set-up of
7 the program, and a yearly allowance for program administration.

8 The cost estimate for a public dispenser for trucked water includes the purchase price for a
9 water truck and construction of a storage tank. Annual costs include labor for purchasing the
10 water, picking up and delivering the water, truck maintenance, and water sampling and testing.
11 It is assumed the water truck would be required to make one trip each week, and that chlorine
12 residual would be determined for each truck load.

13

Table B.1
Summary of General Data
Riviera ISD
1370019
General PWS Information

Service Population 500	Number of Connections 7
Total PWS Daily Water Usage 0.023 (mgd)	Source Site visit list

Unit Cost Data

General Items	Unit	Unit Cost	Central Treatment Unit Costs	Unit	Unit Cost
Treated water purchase cost	<i>See alternative</i>		General		
Water purchase cost (trucked)	\$/1,000 gals	\$ 17.50	Site preparation	acre	\$ 4,000
Contingency	20%	n/a	Slab	CY	\$ 1,000
Engineering & Constr. Management	25%	n/a	Building	SF	\$ 60
Procurement/admin (POU/POE)	20%	n/a	Building electrical	SF	\$ 8.00
			Building plumbing	SF	\$ 8.00
			Heating and ventilation	SF	\$ 7.00
			Fence	LF	\$ 15
			Paving	SF	\$ 2.00
Pipeline Unit Costs	Unit	Unit Cost	General O&M		
PVC water line, Class 200, 04"	LF	\$ 12	Building power	kwh/yr	\$ 0.175
Bore and encasement, 10"	LF	\$ 240	Equipment power	kwh/yr	\$ 0.175
Open cut and encasement, 10"	LF	\$ 130	Labor, O&M	hr	\$ 40
Gate valve and box, 04"	EA	\$ 710	Analyses	test	\$ 200
Air valve	EA	\$ 2,050			
Flush valve	EA	\$ 1,025	Reject Pond		
Metal detectable tape	LF	\$ 2.00	Reject pond, excavation	CYD	\$ 3
			Reject pond, compacted fill	CYD	\$ 7
Bore and encasement, length	Feet	200	Reject pond, lining	SF	\$ 1.50
Open cut and encasement, length	Feet	50	Reject pond, vegetation	SY	\$ 1.50
			Reject pond, access road	LF	\$ 30
Pump Station Unit Costs	Unit	Unit Cost	Reject water haulage truck	EA	\$ 100,000
Pump	EA	\$ 8,000	Water haulage truck	day	\$ 250
Pump Station Piping, 04"	EA	\$ 550			
Gate valve, 04"	EA	\$ 710	Reverse Osmosis		
Check valve, 04"	EA	\$ 755	Electrical	JOB	\$ 40,000
Electrical/Instrumentation	EA	\$ 10,250	Piping	JOB	\$ 20,000
Site work	EA	\$ 2,560	RO package plant	UNIT	\$ 137,000
Building pad	EA	\$ 5,125	Transfer pumps (3 hp)	EA	\$ 3,000
Pump Building	EA	\$ 10,250	Permeate/product tank	gal	\$ 3
Fence	EA	\$ 6,150	RO materials and chemicals	kgal	\$ 0.75
Tools	EA	\$ 1,025	RO chemicals	year	\$ 2,000
5,000 gal feed tank	EA	\$ 10,000	Backwash disposal mileage cost	miles	\$ 1.50
Backflow preventer, 4"	EA	\$ 2,295	Backwash disposal fee	1,000 gal/yr	\$ 5.00
Backflow Testing/Certification	EA	\$ 105			
			EDR		
Well Installation Unit Costs	Unit	Unit Cost	Electrical	JOB	\$ 45,000
Well installation	<i>See alternative</i>		Piping	JOB	\$ 20,000
Water quality testing	EA	\$ 1,280	Product storage tank	gal	\$ 3.00
5HP Well Pump	EA	\$ 2,750	EDR package plant	UNIT	\$ 168,000
Well electrical/instrumentation	EA	\$ 5,635	EDR materials	kgal	\$ 0.48
Well cover and base	EA	\$ 3,075	EDR chemicals	kgal	\$ 0.40
Piping	EA	\$ 3,075	Backwash disposal mileage cost	miles	\$ 1.50
10,000 gal ground storage tank	EA	\$ 15,000	Backwash disposal fee	1,000 gal/yr	\$ 5.00
			Transfer pumps (3 hp)	EA	\$ 3,000
Electrical Power	\$/kWH	\$ 0.175			
Building Power	kWH	11,800	Ion Exchange		
Labor	\$/hr	\$ 60	Electrical	JOB	\$ 30,000
Materials	EA	\$ 1,540	Piping	JOB	\$ 15,000
Transmission main O&M	\$/mile	\$ 275	IX package plant	UNIT	\$ 110,000
Tank O&M	EA	\$ 1,025	Backwash tank	GAL	\$ 2.00
			Sewer connection fee	EA	\$ 15,000
POU/POE Unit Costs			Supplies and Materials	YR	\$ 4,000
POU treatment unit purchase	EA	\$ 615	Resin replacement/disposal	CF	\$ 220.00
POU treatment unit installation	EA	\$ 155			
POE treatment unit purchase	EA	\$ 5,125	Spent regenerate disposal	1000 gallons	\$ 5.00
POE - pad and shed, per unit	EA	\$ 2,050			
POE - piping connection, per unit	EA	\$ 1,025	Coagulation/filtration		
POE - electrical hook-up, per unit	EA	\$ 1,025	Electrical	JOB	\$ 30,000
			Piping	JOB	\$ 15,000
POU Treatment O&M, per unit	\$/year	\$ 230	Coagulation package plant	UNIT	\$ 108,000
POE Treatment O&M, per unit	\$/year	\$ 1,540	Backwash tank	GAL	\$ 2.00
Treatment analysis	\$/year	\$ 205	Coagulant tank	GAL	\$ 3.00
POU/POE labor support	\$/hr	\$ 40			
			Coagulation/Filtration Materials	year	\$ 4,000
Dispenser/Bottled Water Unit Costs			Chemicals, Coagulation	year	\$ 1,100
POE-Treatment unit purchase	EA	\$ 7,175	Backwash disposal/sewer discharge	kgal	\$ 5.00
POE-Treatment unit installation	EA	\$ 5,125			
Treatment unit O&M	EA	\$ 2,050			
Administrative labor	hr	\$ 45			
Bottled water cost (inc. delivery)	gallon	\$ 1.60			
Water use, per capita per day	gpcd	1.0			
Bottled water program materials	EA	\$ 5,125			
5,000 gal ground storage tank	EA	\$ 10,000			
Site improvements	EA	\$ 3,075			
Potable water truck	EA	\$ 75,000			
Water analysis, per sample	EA	\$ 205			
Potable water truck O&M costs	\$/mile	\$ 3.00			

1
2

APPENDIX C COMPLIANCE ALTERNATIVE CONCEPTUAL COST ESTIMATES

3 This appendix presents the conceptual cost estimates developed for the compliance
4 alternatives. The conceptual cost estimates are given in Tables C.1 through C.7. The cost
5 estimates are conceptual in nature (+50%/-30%), and are intended for making comparisons
6 between compliance options and to provide a preliminary indication of possible water rate
7 impacts. Consequently, these costs are pre-planning level and should not be viewed as final
8 estimated costs for alternative implementation.

Table C.1

PWS Name Riviera ISD
Alternative Name Purchase Water from Baffin Bay WSC
Alternative Number RI-1

Distance from Alternative to PWS (along pipe) 6.8 miles
Total PWS annual water usage 8.395 MG
Treated water purchase cost \$ 4.50 per 1,000 gals
Pump Stations needed w/ 1 feed tank each 1
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	13	n/a	n/a	n/a
PVC water line, Class 200, 04"	35,968	LF	\$ 12	\$ 431,616
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	650	LF	\$ 130	\$ 84,500
Gate valve and box, 04"	7	EA	\$ 710	\$ 5,107
Air valve	21	EA	\$ 2,050	\$ 43,050
Flush valve	7	EA	\$ 1,025	\$ 7,373
Metal detectable tape	35,968	LF	\$ 2	\$ 71,936
Subtotal				\$ 643,583

Pump Station(s) Installation

Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 04"	1	EA	\$ 550	\$ 550
Gate valve, 04"	4	EA	\$ 710	\$ 2,840
Check valve, 04"	2	EA	\$ 755	\$ 1,510
Electrical/Instrumentation	1	EA	\$ 10,250	\$ 10,250
Site work	1	EA	\$ 2,560	\$ 2,560
Building pad	1	EA	\$ 5,125	\$ 5,125
Pump Building	1	EA	\$ 10,250	\$ 10,250
Fence	1	EA	\$ 6,150	\$ 6,150
Tools	1	EA	\$ 1,025	\$ 1,025
5,000 gal feed tank	1	EA	\$ 10,000	\$ 10,000
10,000 gal ground storage tank	-	EA	\$ 15,000	\$ -
Backflow Preventor	-	EA	\$ 2,295	\$ -
Subtotal				\$ 66,260

Subtotal of Component Costs \$ 709,843

Contingency 20% \$ 141,969
 Design & Constr Management 25% \$ 177,461

TOTAL CAPITAL COSTS **\$ 1,029,272**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	6.8	mile	\$ 275	\$ 1,873
Subtotal				\$ 1,873
<i>Water Purchase Cost</i>				
From PWS	8,395	1,000 gal	\$ 4.50	\$ 37,778
Subtotal				\$ 37,778

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.175	\$ 2,065
Pump Power	2,590	kWH	\$ 0.175	\$ 453
Materials	1	EA	\$ 1,540	\$ 1,540
Labor	365	Hrs	\$ 60.00	\$ 21,900
Tank O&M	-	EA	\$ 1,025	\$ -
Backflow Test/Cert	0	EA	\$ 105	\$ -
Subtotal				\$ 25,958

O&M Credit for Existing Well Closure

Pump power	45,088	kWH	\$ 0.175	\$ (7,890)
Well O&M matl	1	EA	\$ 1,540	\$ (1,540)
Well O&M labor	180	Hrs	\$ 60	\$ (10,800)
Subtotal				\$ (20,230)

TOTAL ANNUAL O&M COSTS **\$ 45,379**

Table C.2

PWS Name *Riviera ISD*
Alternative Name *New Well at 10 Miles*
Alternative Number *RI-2*

Distance from PWS to new well location 10.0 miles
Estimated well depth 727 feet
Number of wells required 1
Well installation cost (location specific) \$149 per foot
Pump Stations needed w/ 1 feed tank each 2
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	19	n/a	n/a	n/a
PVC water line, Class 200, 04"	52,800	LF	\$ 12	\$ 633,600
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	950	LF	\$ 130	\$ 123,500
Gate valve and box, 04"	11	EA	\$ 710	\$ 7,498
Air valve	31	EA	\$ 2,050	\$ 63,550
Flush valve	11	EA	\$ 1,025	\$ 10,824
Metal detectable tape	52,800	LF	\$ 2	\$ 105,600
Subtotal				\$ 944,572
<i>Pump Station(s) Installation</i>				
Pump	4	EA	\$ 8,000	\$ 32,000
Pump Station Piping, 04"	2	EA	\$ 550	\$ 1,100
Gate valve, 04"	8	EA	\$ 710	\$ 5,680
Check valve, 04"	4	EA	\$ 755	\$ 3,020
Electrical/Instrumentation	2	EA	\$ 10,250	\$ 20,500
Site work	2	EA	\$ 2,560	\$ 5,120
Building pad	2	EA	\$ 5,125	\$ 10,250
Pump Building	2	EA	\$ 10,250	\$ 20,500
Fence	2	EA	\$ 6,150	\$ 12,300
Tools	2	EA	\$ 1,025	\$ 2,050
5,000 gal feed tank	2	EA	\$ 10,000	\$ 20,000
10,000 gal ground storage tank	-	EA	\$ 15,000	\$ -
Subtotal				\$ 132,520
<i>Well Installation</i>				
Well installation	727	LF	\$ 149	\$ 108,323
Water quality testing	2	EA	\$ 1,280	\$ 2,560
Well pump	1	EA	\$ 2,750	\$ 2,750
Well electrical/instrumentation	1	EA	\$ 5,635	\$ 5,635
Well cover and base	1	EA	\$ 3,075	\$ 3,075
Piping	1	EA	\$ 3,075	\$ 3,075
Subtotal				\$ 125,418

Subtotal of Component Costs \$ 1,202,510

Contingency 20% \$ 240,502
 Design & Constr Management 25% \$ 300,627

TOTAL CAPITAL COSTS **\$ 1,743,639**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	10.0	mile	\$ 275	\$ 2,750
Subtotal				\$ 2,750
<i>Pump Station(s) O&M</i>				
Building Power	23,600	kWH	\$ 0.175	\$ 4,130
Pump Power	3,802	kWH	\$ 0.175	\$ 665
Materials	2	EA	\$ 1,540	\$ 3,080
Labor	730	Hrs	\$ 60.00	\$ 43,800
Tank O&M	-	EA	\$ 1,025	\$ -
Subtotal				\$ 51,675
<i>Well O&M</i>				
Pump power	45,088	kWH	\$ 0.175	\$ 7,890
Well O&M matl	1	EA	\$ 1,540	\$ 1,540
Well O&M labor	180	Hrs	\$ 60	\$ 10,800
Subtotal				\$ 20,230
<i>O&M Credit for Existing Well Closure</i>				
Pump power	45,088	kWH	\$ 0.175	\$ (7,890)
Well O&M matl	1	EA	\$ 1,540	\$ (1,540)
Well O&M labor	180	Hrs	\$ 60	\$ (10,800)
Subtotal				\$ (20,230)

TOTAL ANNUAL O&M COSTS **\$ 54,425**

Table C.3

PWS Name *Riviera ISD*
Alternative Name *New Well at 5 Miles*
Alternative Number *RI-3*

Distance from PWS to new well location 5.0 miles
Estimated well depth 727 feet
Number of wells required 1
Well installation cost (location specific) \$149 per foot
Pump Stations needed w/ 1 feed tank each 1
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	10	n/a	n/a	n/a
PVC water line, Class 200, 04"	26,400	LF	\$ 12	\$ 316,800
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	500	LF	\$ 130	\$ 65,000
Gate valve and box, 04"	5	EA	\$ 710	\$ 3,749
Air valve	15	EA	\$ 2,050	\$ 30,750
Flush valve	5	EA	\$ 1,025	\$ 5,412
Metal detectable tape	26,400	LF	\$ 2	\$ 52,800
Subtotal				\$ 474,511

Pump Station(s) Installation

Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 04"	1	EA	\$ 550	\$ 550
Gate valve, 04"	4	EA	\$ 710	\$ 2,840
Check valve, 04"	2	EA	\$ 755	\$ 1,510
Electrical/Instrumentation	1	EA	\$ 10,250	\$ 10,250
Site work	1	EA	\$ 2,560	\$ 2,560
Building pad	1	EA	\$ 5,125	\$ 5,125
Pump Building	1	EA	\$ 10,250	\$ 10,250
Fence	1	EA	\$ 6,150	\$ 6,150
Tools	1	EA	\$ 1,025	\$ 1,025
5,000 gal feed tank	1	EA	\$ 10,000	\$ 10,000
10,000 gal ground storage tank	-	EA	\$ 15,000	\$ -
Subtotal				\$ 66,260

Well Installation

Well installation	727	LF	\$ 149	\$ 108,323
Water quality testing	2	EA	\$ 1,280	\$ 2,560
Well pump	1	EA	\$ 2,750	\$ 2,750
Well electrical/instrumentation	1	EA	\$ 5,635	\$ 5,635
Well cover and base	1	EA	\$ 3,075	\$ 3,075
Piping	1	EA	\$ 3,075	\$ 3,075
Subtotal				\$ 125,418

Subtotal of Component Costs \$ 666,189

Contingency 20% \$ 133,238
 Design & Constr Management 25% \$ 166,547

TOTAL CAPITAL COSTS \$ 965,974

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	5.0	mile	\$ 275	\$ 1,375
Subtotal				\$ 1,375

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.175	\$ 2,065
Pump Power	1,901	kWH	\$ 0.175	\$ 333
Materials	1	EA	\$ 1,540	\$ 1,540
Labor	365	Hrs	\$ 60.00	\$ 21,900
Tank O&M	-	EA	\$ 1,025	\$ -
Subtotal				\$ 25,838

Well O&M

Pump power	45,088	kWH	\$ 0.175	\$ 7,890
Well O&M matl	1	EA	\$ 1,540	\$ 1,540
Well O&M labor	180	Hrs	\$ 60	\$ 10,800
Subtotal				\$ 20,230

O&M Credit for Existing Well Closure

Pump power	45,088	kWH	\$ 0.175	\$ (7,890)
Well O&M matl	1	EA	\$ 1,540	\$ (1,540)
Well O&M labor	180	Hrs	\$ 60	\$ (10,800)
Subtotal				\$ (20,230)

TOTAL ANNUAL O&M COSTS \$ 27,213

Table C.4

PWS Name Riviera ISD
Alternative Name New Well at 1 Mile
Alternative Number RI-4

Distance from PWS to new well location	1.0 miles
Estimated well depth	727 feet
Number of wells required	1
Well installation cost (location specific)	\$149 per foot
Pump Stations needed w/ 1 feed tank each	0
On site storage tanks / pump sets needed	0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	2	n/a	n/a	n/a
PVC water line, Class 200, 04"	5,280	LF	\$ 12	\$ 63,360
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	100	LF	\$ 130	\$ 13,000
Gate valve and box, 04"	1	EA	\$ 710	\$ 750
Air valve	3	EA	\$ 2,050	\$ 6,150
Flush valve	1	EA	\$ 1,025	\$ 1,082
Metal detectable tape	5,280	LF	\$ 2	\$ 10,560
Subtotal				\$ 94,902

Pump Station(s) Installation

Pump	-	EA	\$ 8,000	\$ -
Pump Station Piping, 04"	-	EA	\$ 550	\$ -
Gate valve, 04"	-	EA	\$ 710	\$ -
Check valve, 04"	-	EA	\$ 755	\$ -
Electrical/Instrumentation	-	EA	\$ 10,250	\$ -
Site work	-	EA	\$ 2,560	\$ -
Building pad	-	EA	\$ 5,125	\$ -
Pump Building	-	EA	\$ 10,250	\$ -
Fence	-	EA	\$ 6,150	\$ -
Tools	-	EA	\$ 1,025	\$ -
5,000 gal feed tank	-	EA	\$ 10,000	\$ -
10,000 gal ground storage tank	-	EA	\$ 15,000	\$ -
Subtotal				\$ -

Well Installation

Well installation	727	LF	\$ 149	\$ 108,323
Water quality testing	2	EA	\$ 1,280	\$ 2,560
Well pump	1	EA	\$ 2,750	\$ 2,750
Well electrical/instrumentation	1	EA	\$ 5,635	\$ 5,635
Well cover and base	1	EA	\$ 3,075	\$ 3,075
Piping	1	EA	\$ 3,075	\$ 3,075
Subtotal				\$ 125,418

Subtotal of Component Costs \$ 220,320

Contingency	20%	\$ 44,064
Design & Constr Management	25%	\$ 55,080

TOTAL CAPITAL COSTS \$ 319,464

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	1.0	mile	\$ 275	\$ 275
Subtotal				\$ 275

Pump Station(s) O&M

Building Power	-	kWH	\$ 0.175	\$ -
Pump Power	-	kWH	\$ 0.175	\$ -
Materials	-	EA	\$ 1,540	\$ -
Labor	-	Hrs	\$ 60.00	\$ -
Tank O&M	-	EA	\$ 1,025	\$ -
Subtotal				\$ -

Well O&M

Pump power	45,088	kWH	\$ 0.175	\$ 7,890
Well O&M matl	1	EA	\$ 1,540	\$ 1,540
Well O&M labor	180	Hrs	\$ 60	\$ 10,800
Subtotal				\$ 20,230

O&M Credit for Existing Well Closure

Pump power	45,088	kWH	\$ 0.175	\$ (7,890)
Well O&M matl	1	EA	\$ 1,540	\$ (1,540)
Well O&M labor	180	Hrs	\$ 60	\$ (10,800)
Subtotal				\$ (20,230)

TOTAL ANNUAL O&M COSTS \$ 275

Table C.5

PWS Name *Riviera ISD*
Alternative Name *Central Treatment - Reverse Osmosis*
Alternative Number *RI-5*

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Reverse Osmosis Unit Purchase/Installation</i>				
Site preparation	0.30	acre	\$ 4,000	\$ 1,200
Slab	15	CY	\$ 1,000	\$ 15,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8	\$ 3,200
Building plumbing	400	SF	\$ 8	\$ 3,200
Heating and ventilation	400	SF	\$ 7	\$ 2,800
Fence	400	LF	\$ 15	\$ 6,000
Paving	1,500	SF	\$ 2	\$ 3,000
Electrical	1	JOB	\$ 40,000	\$ 40,000
Piping	1	JOB	\$ 20,000	\$ 20,000
Reverse osmosis package including:				
High pressure pumps - 20 hp				
Cartridge filters and vessels				
RO membranes and vessels				
Control system				
Chemical feed systems				
Freight cost				
Vendor start-up services	1	UNIT	\$ 137,000	\$ 137,000
Transfer pumps	2	EA	\$ 3,000	\$ 6,000
Permeate tank	-	gal	\$ 3	\$ -
Feed Tank	15,000	gal	\$ 3	\$ 45,000
Brine Pipeline to Sewer	1	EA	\$ 25,000	\$ 25,000
Subtotal of Design/Construction Costs				\$ 331,400
Contingency	20%		\$	66,280
Design & Constr Management	25%		\$	82,850

TOTAL CAPITAL COSTS **\$ 480,530**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Reverse Osmosis Unit O&M</i>				
Building Power	3,500	kwh/yr	\$ 0.175	\$ 613
Equipment power	49,000	kwh/yr	\$ 0.175	\$ 8,575
Labor	800	hrs/yr	\$ 40.00	\$ 32,000
RO materials and Chemicals	8,400	kgal	\$ 0.75	\$ 6,300
Analyses	24	test	\$ 200	\$ 4,800
Subtotal				\$ 52,288
<i>Reject (brine) disposal</i>				
Reject (brine) disposal fee	2,372	kgal/yr	\$ 5.00	\$ 11,860
Subtotal				\$ 11,860

TOTAL ANNUAL O&M COSTS **\$ 64,147**

Table C.6

PWS Name *Riviera ISD*
Alternative Name *Central Treatment - Coagulation filtration*
Alternative Number *RI-6*

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Coagulation/Filtration Unit Purchase/Installation</i>				
Site preparation	0.20	acre	\$ 4,000	\$ 800
Slab	11	CY	\$ 1,000	\$ 11,250
Building	300	SF	\$ 60	\$ 18,000
Building electrical	300	SF	\$ 8	\$ 2,400
Building plumbing	300	SF	\$ 8	\$ 2,400
Heating and ventilation	300	SF	\$ 7	\$ 2,100
Fence	300	LF	\$ 15	\$ 4,500
Paving	1,500	SF	\$ 2	\$ 3,000
Electrical	1	JOB	\$ 30,000	\$ 30,000
Piping	1	JOB	\$ 15,000	\$ 15,000
Coagulant/filter package including:				
Chemical feed system				
Pressure ceramic filters				
Controls & Instruments	1	UNIT	\$ 108,000	\$ 108,000
Spent Backwash Tank	3,840	GAL	\$ 2	\$ 7,680
Coagulant Tank	300	GAL	\$ 3	\$ 900
Feed Tank	12,000	gal	\$ 3	\$ 36,000
Spent BW Pipeline to Sewer	1	EA	\$ 15,000	\$ 15,000
Subtotal of Component Costs				\$ 257,030
Contingency	20%		\$	51,406
Design & Constr Management	25%		\$	64,258
TOTAL CAPITAL COSTS				\$ 372,694

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Coagulation/Filtration Unit O&M</i>				
Building Power	2,500	kwh/yr	\$ 0.175	\$ 438
Equipment power	6,078	kwh/yr	\$ 0.175	\$ 1,064
Labor	800	hrs/yr	\$ 40	\$ 32,000
Materials	1	year	\$ 4,000	\$ 4,000
Chemicals	1	year	\$ 1,100	\$ 1,100
Analyses	24	test	\$ 200	\$ 4,800
Backwash discharge to sewer		MG/yr	\$ 45,000	\$ -
Subtotal				\$ 43,401
<i>Sludge Disposal</i>				
Reject (brine) disposal fee	701	kgal	\$ 5.00	\$ 3,504
Subtotal				\$ 3,504
TOTAL ANNUAL O&M COSTS				\$ 43,401

Table C.7

PWS Name *Riviera ISD*
Alternative Name *Central Treatment - Ion Exchange*
Alternative Number *RI-7*

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Adsorption Unit Purchase/Installation</i>				
Site preparation	0.10	acre	\$ 4,000	\$ 400
Slab	10	CY	\$ 1,000	\$ 9,750
Building	300	SF	\$ 60	\$ 18,000
Building electrical	300	SF	\$ 8	\$ 2,400
Building plumbing	300	SF	\$ 8	\$ 2,400
Heating and ventilation	300	SF	\$ 7	\$ 2,100
Fence	300	LF	\$ 15	\$ 4,500
Paving	2,000	SF	\$ 3	\$ 6,000
Electrical	1	JOB	\$ 30,000	\$ 30,000
Piping	1	JOB	\$ 15,000	\$ 15,000
		Subtotal		\$ 90,550
Ion Exchange package including:				
2 - IX vessels				
anionic exchange resin				
Controls & instruments	1	UNIT	\$ 110,000	\$ 110,000
Spent Regenerate Tank	5,670	GAL	\$ 2	\$ 11,340
Spent Regenerate PL to Sewer	1	EA	\$ 15,000	\$ 15,000
Transfer/backwash pumps	2	EA	\$ 3,000	\$ 6,000
Product water tank	-	gal	\$ 3	\$ -
Feed Tank	12,000	gal	\$ 3	\$ 36,000
Subtotal of Component Costs				\$ 268,890
Contingency	20%		\$	53,778
Design & Constr Management	25%		\$	67,223

TOTAL CAPITAL COSTS **\$ 389,891**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Adsorption Unit O&M</i>				
Building Power	2,500	kwh/yr	\$ 0.175	\$ 438
Equipment power	4,558	kwh/yr	\$ 0.175	\$ 798
Labor	600	hrs/yr	\$ 40	\$ 24,000
Media replacement/disposal	21	cf	\$ 220	\$ 4,576
Analyses	24	test	\$ 200	\$ 4,800
Regeneration Salt	33,600	lbs	\$ 0.01	\$ 336
Supplies and Equipment	1	yr	\$ 4,000	\$ 4,000
		Subtotal		\$ 38,947
Reject (brine) disposal fee	235	kgal	\$ 5.00	\$ 1,177
		Subtotal		\$ 1,177

TOTAL ANNUAL O&M COSTS **\$ 40,125**

1
2
3

**APPENDIX D
EXAMPLE FINANCIAL MODEL**

Appendix D
General Inputs

Riviera ISD

Number of Alternatives 7 Selected from Results Sheet

Input Fields are Indicated by:

General Inputs		
Implementation Year	2009	
Months of Working Capital	0	
Depreciation	\$ -	
Percent of Depreciation for Replacement Fund	0%	
Allow Negative Cash Balance (yes or no)	No	
Median Household Income	\$ 30,750	Riviera ISD
Median HH Income -- Texas	\$ 39,927	
Grant Funded Percentage	0%	Selected from Results
Capital Funded from Revenues	\$ -	
	Base Year	2007
	Growth/Escalation	
Accounts & Consumption		
Metered Residential Accounts		
Number of Accounts	0.0%	500
Number of Bills Per Year		12
Annual Billed Consumption		8,395,000
Consumption per Account Per Pay Period	0.0%	1,399
Consumption Allowance in Rates		100,000
Total Allowance		600,000,000
Net Consumption Billed		(591,605,000)
Percentage Collected		100.0%
Unmetered Residential Accounts		
Number of Accounts	0.0%	0
Number of Bills Per Year		12
Percentage Collected		100.0%
Metered Non-Residential Accounts		
Number of Accounts	0.0%	0
Number of Bills Per Year		12
Non-Residential Consumption		-
Consumption per Account	0.0%	-
Consumption Allowance in Rates		-
Total Allowance		-
Net Consumption Billed		-
Percentage Collected		0.0%
Unmetered Non-Residential Accounts		
Number of Accounts	0.0%	0
Number of Bills Per Year		12
Percentage Collected		100.0%
Water Purchase & Production		
Water Purchased (gallons)	0.0%	-
Average Cost Per Unit Purchased	0.0%	\$ -
Bulk Water Purchases	0.0%	\$ -
Water Production	0.0%	8,395,000
Unaccounted for Water		-
Percentage Unaccounted for Water		0.0%

Appendix D
General Inputs

Riviera ISD

Number of Alternatives 7 Selected from Results Sheet

Input Fields are Indicated by: [Redacted]

Residential Rate Structure	Allowance within Tier	
Base Monthly Payment	-	\$ 0.83
		\$ -
Non-Residential Rate Structure		
Estimated Average Water Rate (\$/1000gallons)	-	\$ -
INITIAL YEAR EXPENDITURES	Inflation	Initial Year
Operating Expenditures:		
Salaries & Benefits	0.0%	-
Contract Labor	0.0%	-
Water Purchases	0.0%	-
Chemicals, Treatment	0.0%	-
Utilities	0.0%	-
Repairs, Maintenance, Supplies	0.0%	-
Repairs	0.0%	-
Maintenance	0.0%	-
Supplies	0.0%	-
Administrative Expenses	0.0%	-
Accounting and Legal Fees	0.0%	-
Insurance	0.0%	-
Automotive and Travel	0.0%	-
Professional and Directors Fees	0.0%	-
Bad Debts	0.0%	-
Garbage Pick-up	0.0%	-
Miscellaneous	0.0%	-
Other 3	0.0%	5,000
Other 4	0.0%	-
Incremental O&M for Alternative	0.0%	-
Total Operating Expenses		5,000
Non-Operating Income/Expenditures		
Interest Income	0.0%	-
Other Income	0.0%	-
Other Expense	0.0%	-
Transfers In (Out)	0.0%	-
Net Non-Operating		-
Esisting Debt Service		
Bonds Payable, Less Current Maturities		\$ -
Bonds Payable, Current		\$ -
Interest Expense		\$ -

1 **APPENDIX E**
2 **ANALYSIS OF SHARED SOLUTIONS FOR OBTAINING WATER FROM**
3 **BAFFIN BAY WATER SYSTEM**

4 **E.1 OVERVIEW OF METHOD USED**

5 There is a limited number of small PWSs with water quality problems located in the
6 vicinity of the Riviera ISD PWS that could benefit from joining together and cooperating to
7 share the cost for obtaining compliant drinking water. This cooperation could involve creating
8 a formal organization of individual PWSs to address obtaining compliant drinking water,
9 consolidating to form a single PWS, or having the individual PWSs taken over or bought out by
10 a larger regional entity.

11 The small PWSs with water quality problems near Riviera ISD are listed in Table E.1,
12 along with their average water consumption and estimates of the capital cost for each PWS to
13 construct an individual pipeline. It is assumed for this analysis that all the systems would
14 participate in a shared solution.

15 This analysis focuses on compliance alternatives related to obtaining water from large
16 water providers interested in providing water outside their current area, either by wholesaling
17 to PWSs, or by expanding their service areas. This type of solution is most likely to have the
18 best prospects for sustainability, and a reliable provision of compliant drinking water.

19 The purpose of this analysis is to approximate the level of capital cost savings that could
20 be expected from pursuing a shared solution versus a solution where the study PWS obtains
21 compliant drinking water on its own. Regardless of the form a group solution would take,
22 water consumers would have to pay for the infrastructure needed for obtaining compliant
23 water. To keep this analysis as straightforward and realistic as possible, it is assumed the
24 individual PWSs would remain independent, and would share the capital cost for the
25 infrastructure required. Also, to maintain simplicity, this analysis is limited to estimating
26 capital cost savings related to pipeline construction, which is likely to be by far the largest
27 component of the overall capital cost. A shared solution could also produce savings in O&M
28 expenses as a result of reduction in redundant facilities and the potential for shared O&M
29 resources, and these savings would have to be evaluated if the PWSs are interested in
30 implementing a shared solution.

31 There are many ways pipeline capital costs could be divided between participating PWSs,
32 and the final apportioning of costs would likely be based on negotiation between the
33 participating entities. At this preliminary stage of analysis it is not possible to project results
34 from negotiations regarding cost sharing. For this reason, three methods are used to allocate
35 cost between PWSs in an effort to give an approximation of the range of savings that might be
36 attainable for an individual PWS.

37 Method A is based on allocating capital cost of the shared pipeline solution proportionate
38 to the amount of water used by each PWS. In this case, the capital cost for the shared pipeline

1 and the necessary pump stations is estimated, and then this total capital cost is allocated based
2 on the fraction of the total water used by each PWS. For example, PWS #1 has an average
3 daily water use of 0.1 mgd and PWS #2 has an average daily use of 0.3 mgd. Using this
4 method, PWS #1 would be allocated 25 percent of the capital cost of the shared solution. This
5 method is a reasonable method for allocating cost when all the PWSs are different in size but
6 are relatively equidistant from the shared water source.

7 Method B is also based on allocating capital cost of the shared pipeline solution
8 proportionate to the amount of water used by the PWSs. However, rather than allocating the
9 *total* capital cost of the shared solution between each participating PWS, this approach splits
10 the shared pipeline into segments and allocates flow-proportional costs to the PWSs using each
11 segment. Costs for a pipeline segment are not shared by a PWS if the PWS does not use that
12 particular segment. For example, PWS #1 has an average daily water use of 0.3 mgd and PWS
13 #2 has an average daily use of 0.2 mgd. A 3-mile long pipeline segment is common to both
14 PWSs, while PWS #2 requires an additional 4-mile segment. Using this method, PWS #2
15 would be allocated 40 percent of the cost of the 3-mile segment and 100 percent of the cost of
16 the 4-mile segment. This method is a reasonable method for allocating cost when all the PWSs
17 are different in size and are located at different distances from the shared water source.

18 Method C is based on allocating capital cost of the shared pipeline solution proportionate
19 to the cost each PWS would have to pay to obtain compliant water if it were to implement an
20 individual solution. In this case, the total capital cost for the shared pipeline and the necessary
21 pump stations is estimated as well as the capital cost each PWS would have for obtaining its
22 own pipeline. The total capital cost for the shared solution is then allocated between the
23 participating PWSs based on what each PWS would have to pay to construct its own pipeline.
24 For example, the individual solution cost for PWS #1 is \$4 million and the individual solution
25 cost for PWS #2 is \$1 million. Using this method, PWS #1 would be allocated 80 percent of
26 the cost of the shared solution. This method is a reasonable method for allocating cost when
27 the PWS are located at different distances from the water source.

28 For any given PWS, all three of these methods should generate costs for the shared
29 solution that produce savings for the PWS over an individual solution. However, for different
30 PWSs participating in a shared solution, each of these three methods can produce savings of
31 varying magnitudes: for one PWS, Method A might show the best cost savings while for
32 another Method C might provide the best savings. For this reason, this range is considered to
33 be representative of possible savings that could result from an agreement that should be fair and
34 equitable to all parties involved.

35 **E.2 SHARED SOLUTION FOR OBTAINING WATER FROM BAFFIN BAY**

36 This alternative would consist of constructing approximately 7 miles of 4-inch joint
37 pipeline from Baffin Bay to a split where one branch would continue to Riviera ISD and the
38 other branch would continue to Riviera WSC. The pipeline routing is shown in Figure E.1 at
39 the end of this appendix. It is assumed three pump stations would be required to transfer the
40 water from Baffin Bay to the two public water systems.

1 The capital costs for each pipe segment and the total capital cost for the shared pipeline are
2 summarized in Table E.2. Table E.3 shows the capital costs allocated to each PWS using
3 Method A. Table E.4 shows the capital costs allocated to each PWS using Method B.
4 Table E.5 shows the allocation of pipeline capital costs to each of the PWSs using Method C,
5 as described above. Table E.6 provides a summary of the pipeline capital costs estimated for
6 each PWS, and the savings that could be realized compared to developing individual pipelines.
7 More detailed cost estimates for the pipe segments are shown at the end of this appendix in
8 Tables E.7 through E.10.

9 Based on these estimates, the range of pipeline capital cost savings to Riviera ISD could be
10 between \$371,300 to \$726,600 if they were to implement a shared solution like this, which
11 would be a savings between 37 to 72 percent. These estimates are hypothetical and are only
12 provided to approximate the magnitude of potential savings if this shared solution is
13 implemented as described.

14

Table E.1
Summary Information for PWSs Participating in Shared Solution

PWS	PWS #	Average Water Demand (mgd)	Water Demand as Percent of Total	Pipeline Capital Cost for Individual Solutions for Riviera ISD and Riviera WSC	Percent of Sum of Capital Costs for Individual Solutions for Riviera ISD and Riviera WSC
Riviera ISD	1370019	0.015	18%	\$ 1,002,500	41%
Riviera WSC	1370007	0.069	82%	\$ 1,451,600	59%
Totals		0.084	100%	\$ 2,454,100	100%

Table E.2
Capital cost for Shared Pipeline from East Riviera WS

Pipe Segment	Capital Cost
Pipe 1	\$ 1,401,732
Pipe A	\$ 34,543
Pipe B	\$ 108,891
Totals	\$ 1,545,166

**Table E.3
 Pipeline Capital Cost Allocation by Method A
 Shared Pipeline Assesment for Riviera ISD and Riviera WS**

PWS	PWS #	Percentage Based On Flow	Total Costs
Riviera ISD	1370019	18%	\$ 275,923
Riviera WSC	1370007	82%	\$ 1,269,244
Totals		100%	\$ 1,545,166

**Table E.4
 Pipeline Capital Cost Allocation by Method B
 Shared Pipeline Assesment for Riviera ISD and Riviera WS**

Pipeline Segment	Pipe Segment Capital Cost	Riviera ISD		Riviera WSC	
		Percent Allocation Based on Water Use	Allocated Cost	Percent Allocation Based on Water Use	Allocated Cost
Pipe 1	\$ 1,401,732	18%	\$ 250,309	82%	\$ 1,151,423
Pipe A	\$ 34,543	100%	\$ 34,543	0%	\$ -
Pipe B	\$ 108,891	0%	\$ -	100%	\$ 108,891
Totals	\$ 1,545,166		\$ 284,853		\$ 1,260,314

**Table E.5
Pipeline Capital Cost Allocation by Method C
Shared Pipeline Assessment for Lubbock**

PWS	PWS #	Cost for Individual Pipelines	Percentage based on Individual Solutions	Allocated Capital Cost
Riviera ISD	1370019	\$ 1,002,500	41%	\$ 631,201
Riviera WSC	1370007	\$ 1,451,600	59%	\$ 913,966
Totals		\$ 2,454,100	100%	\$ 1,545,166

**Table E.6
Pipeline Capital Cost Summary
Shared Pipeline Assessment for Lubbock**

PWS	Individual Pipeline Capital Costs	Shared Solution Capital Cost Allocation			Shared Solution Cost Savings			Shared Solution Percentage Savings		
		Method A	Method B	Method C	Method A	Method B	Method C	Method A	Method B	Method C
1370019	\$ 1,002,500	\$ 275,923	\$ 284,853	\$ 631,201	\$ 726,577	\$ 717,647	\$ 371,299	72%	72%	37%
1370007	\$ 1,451,600	\$ 1,269,244	\$ 1,260,314	\$ 913,966	\$ 182,356	\$ 191,286	\$ 537,634	13%	13%	37%
Totals	\$ 2,454,100	\$ 1,545,166	\$ 1,545,166	\$ 1,545,166	\$ 908,934	\$ 908,934	\$ 908,934			

Table E.7

Main Link # 1
Total Pipe Length 6.81 miles
Number of Pump Stations Needed 3
Pipe Size 04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	13	n/a	n/a	n/a
PVC water line, Class 200, 04"	35,968	LF	\$ 12	\$ 431,616
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	650	LF	\$ 130	\$ 84,500
Gate valve and box, 04"	8	EA	\$ 710	\$ 5,680
Air valve	7	EA	\$ 2,050	\$ 14,350
Flush valve	8	EA	\$ 1,025	\$ 8,200
Metal detectable tape	35,968	LF	\$ 2.00	\$ 71,936
Subtotal				\$ 616,282
<i>Pump Station(s) Installation</i>				
Pump	6	EA	\$ 8,000	\$ 48,000
Pump Station Piping, 04"	6	EA	\$ 550	\$ 3,300
Gate valve, 04"	12	EA	\$ 710	\$ 8,520
Check valve, 04"	6	EA	\$ 755	\$ 4,530
Electrical/Instrumentation	3	EA	\$ 10,250	\$ 30,750
Site work	3	EA	\$ 2,560	\$ 7,680
Building pad	3	EA	\$ 5,125	\$ 15,375
Pump Building	3	EA	\$ 10,250	\$ 30,750
Fence	3	EA	\$ 6,150	\$ 18,450
Tools	3	EA	\$ 1,025	\$ 3,075
50,000 gal ground storage tank	3	EA	\$ 60,000	\$ 180,000
Subtotal				\$ 350,430
Subtotal of Component Costs				\$ 966,712
Contingency	20%			\$ 193,342
Design & Constr Management	25%			\$ 241,678
TOTAL CAPITAL COSTS				\$ 1,401,732

Table E.8

Segment A

Riviera ISD

Private Pipe Size

04"

Total Pipe Length

0.18 miles

Total PWS annual water usage

5.5 MG

Number of Pump Stations Needed

0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	967	LF	\$ 12	\$ 11,604
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	50	LF	\$ 130	\$ 6,500
Gate valve and box, 04"	1	EA	\$ 710	\$ 710
Air valve	1	EA	\$ 2,050	\$ 2,050
Flush valve	1	EA	\$ 1,025	\$ 1,025
Metal detectable tape	967	LF	\$ 2.00	\$ 1,934
Subtotal				\$ 23,823
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 8,000	\$ -
Pump Station Piping, 04"	-	EA	\$ 550	\$ -
Gate valve, 04"	-	EA	\$ 710	\$ -
Check valve, 04"	-	EA	\$ 755	\$ -
Electrical/Instrumentation	-	EA	\$ 10,250	\$ -
Site work	-	EA	\$ 2,560	\$ -
Building pad	-	EA	\$ 5,125	\$ -
Pump Building	-	EA	\$ 10,250	\$ -
Fence	-	EA	\$ 6,150	\$ -
Tools	-	EA	\$ 1,025	\$ -
10,000 gal ground storage tank	-	EA	\$ 15,000	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 23,823
Contingency	20%			\$ 4,765
Design & Constr Management	25%			\$ 5,956
TOTAL CAPITAL COSTS				\$ 34,543

Table E.9

Segment B

Riviera WSC

Private Pipe Size

04"

Total Pipe Length

0.44 miles

Total PWS annual water usage

25.2 MG

Number of Pump Stations Needed

0

Capital Costs



Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	6	n/a	n/a	n/a
PVC water line, Class 200, 04"	2,308	LF	\$ 12	\$ 27,696
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	300	LF	\$ 130	\$ 39,000
Gate valve and box, 04"	1	EA	\$ 710	\$ 710
Air valve	1	EA	\$ 2,050	\$ 2,050
Flush valve	1	EA	\$ 1,025	\$ 1,025
Metal detectable tape	2,308	LF	\$ 2.00	\$ 4,616
Subtotal				\$ 75,097
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 8,000	\$ -
Pump Station Piping, 04"	-	EA	\$ 550	\$ -
Gate valve, 04"	-	EA	\$ 710	\$ -
Check valve, 04"	-	EA	\$ 755	\$ -
Electrical/Instrumentation	-	EA	\$ 10,250	\$ -
Site work	-	EA	\$ 2,560	\$ -
Building pad	-	EA	\$ 5,125	\$ -
Pump Building	-	EA	\$ 10,250	\$ -
Fence	-	EA	\$ 6,150	\$ -
Tools	-	EA	\$ 1,025	\$ -
50,000 gal ground storage tank	-	EA	\$ 60,000	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 75,097
Contingency	20%			\$ 15,019
Design & Constr Management	25%			\$ 18,774
TOTAL CAPITAL COSTS				\$ 108,891

Table E.10

Main Link # 1
Total Pipe Length 7.25 miles
Number of Pump Stations Needed 3
Pipe Size 04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	13	n/a	n/a	n/a
PVC water line, Class 200, 04"	38,280	LF	\$ 12	\$ 459,360
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	650	LF	\$ 130	\$ 84,500
Gate valve and box, 04"	8	EA	\$ 710	\$ 5,680
Air valve	8	EA	\$ 2,050	\$ 16,400
Flush valve	8	EA	\$ 1,025	\$ 8,200
Metal detectable tape	38,280	LF	\$ 2.00	\$ 76,560
Subtotal				\$ 650,700
<i>Pump Station(s) Installation</i>				
Pump	6	EA	\$ 8,000	\$ 48,000
Pump Station Piping, 04"	6	EA	\$ 550	\$ 3,300
Gate valve, 04"	12	EA	\$ 710	\$ 8,520
Check valve, 04"	6	EA	\$ 755	\$ 4,530
Electrical/Instrumentation	3	EA	\$ 10,250	\$ 30,750
Site work	3	EA	\$ 2,560	\$ 7,680
Building pad	3	EA	\$ 5,125	\$ 15,375
Pump Building	3	EA	\$ 10,250	\$ 30,750
Fence	3	EA	\$ 6,150	\$ 18,450
Tools	3	EA	\$ 1,025	\$ 3,075
50,000 gal ground storage tank	3	EA	\$ 60,000	\$ 180,000
Subtotal				\$ 350,430
Subtotal of Component Costs				\$ 1,001,130
Contingency	20%			\$ 200,226
Design & Constr Management	25%			\$ 250,283
TOTAL CAPITAL COSTS				\$ 1,451,639



Legend

- Study System
- PWS's
- Cities
- City Limits
- Counties
- Major Road
- Minor Road
- CRMWA Pipeline
- Lubbock Pipeline
- Grass Valley Pipeline
- RV/RI - 1




Figure E.1

**RIVIERA WSC & RIVIERA ISD
TO BAFFIN BAY WSC
Shared Pipeline Alternative**