

DRAFT FEASIBILITY REPORT FEASIBILITY ANALYSIS OF WATER SUPPLY FOR SMALL PUBLIC WATER SYSTEMS

TWIN OAKS MOBILE HOME PARK
PWS ID# 1650057, CCN# 13008

Prepared for:

THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



Prepared by:

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC GEOLOGY
AND**

PARSONS

Preparation of this report was financed by the Texas Commission on Environmental Quality through the Drinking Water State Revolving Fund Small Systems Assistance Program

AUGUST 2008

DRAFT FEASIBILITY REPORT

**FEASIBILITY ANALYSIS OF WATER SUPPLY
FOR SMALL PUBLIC WATER SYSTEMS**

**TWIN OAKS MOBILE HOME PARK
PWS ID# 1650057, CCN# 13008**

Prepared for:

THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Prepared by:

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC
GEOLOGY**

AND

PARSONS

*Preparation of this report was financed by the Texas Commission on Environmental Quality
through the Drinking Water State Revolving Fund Small Systems Assistance Program*

THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF INTERIM REVIEW UNDER THE
AUTHORITY OF ERIC J. DAWSON, P.E. 79564, ON AUGUST 31, 2008. IT IS NOT TO BE USED
FOR CONSTRUCTION, BIDDING, OR PERMIT PURPOSES.

AUGUST 2008

EXECUTIVE SUMMARY

INTRODUCTION

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Transportation Group Inc. (Parsons), was contracted by the Texas Commission on Environmental Quality (TCEQ) to conduct a project to assist with identifying and analyzing alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

The overall goal of this project was to promote compliance using sound engineering and financial methods and data for PWSs that had recently recorded sample results exceeding maximum contaminant levels (MCL). The primary objectives of this project were to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS for future implementation.

This feasibility report provides an evaluation of water supply alternatives for the Twin Oaks Mobile Home Park (MHP) PWS ID# 1650057, Certificate of Convenience and Necessity (CCN) #13008, located in Midland County. The Twin Oaks MHP PWS is located in the southern portion of Midland, Texas at 5200 South County Road. Twin Oaks PWS is a community system providing potable water to the MHP and serves a population of 234 with 78 connections. The water source comes from two wells that are 105 feet and 108 feet and completed in the Ogallala Aquifer (121OGLL). Well #1 (G1650057A) is rated at 40 gallons per minute (gpm) and Well #2 (G1650057B) is rated at 30 gpm.

During the period from February 1998 to February 2005, Twin Oaks MHP recorded arsenic concentrations that ranged from of 0.0109 milligrams per liter (mg/L) to 0.0171 mg/L. From March 1997 to May 2004, nitrate concentrations have ranged from 5.49 mg/L to 16.53 mg/L, with the majority of results exceeding 10 mg/L. These values are above the 0.01 mg/L MCL for arsenic and 10 mg/L MCL for nitrate. Therefore, Twin Oaks MHP faces compliance issues under the water quality standards for arsenic and nitrate.

Basic system information for the Twin Oaks MHP PWS is shown in Table ES.1.

**Table ES.1 Twin Oaks Mobile Home Park PWS
Basic System Information**

Population served	234
Connections	78
Average daily flow rate	0.0165 million gallons per day (mgd)
Peak demand flow rate	46 gallons per minute
Water system peak capacity	0.101 mgd
Typical arsenic range	0.0109 mg/L – to 0.0171 mg/L
Typical nitrate range	5.49 mg/L - 16.53 mg/L

STUDY METHODS

The methods used for this project were based on a pilot project performed in 2004 and 2005 by TCEQ, BEG, and Parsons. Methods for identifying and analyzing compliance options were developed in the pilot project (a decision tree approach).

The process for developing the feasibility study used the following general steps:

- Gather data from the TCEQ and Texas Water Development Board databases, from TCEQ files, and from information maintained by the PWS;
- Conduct financial, managerial, and technical (FMT) evaluations of the PWS;
- Perform a geologic and hydrogeologic assessment of the study area;
- Develop treatment and non-treatment compliance alternatives which, in general, consist of the following possible options:
 - Connecting to neighboring PWSs via new pipeline or by pumping water from a newly installed well or an available surface water supply within the jurisdiction of the neighboring PWS;
 - Installing new wells within the vicinity of the PWS into other aquifers with confirmed water quality standards meeting the MCLs;
 - Installing a new intake system within the vicinity of the PWS to obtain water from a surface water supply with confirmed water quality standards meeting the MCLs;
 - Treating the existing non-compliant water supply by various methods depending on the type of contaminant; and
 - Delivering potable water by way of a bottled water program or a treated water dispenser as an interim measure only.
- Assess each of the potential alternatives with respect to economic and non-economic criteria;
- Prepare a feasibility report and present the results to the PWS.

This basic approach is summarized in Figure ES.1.

HYDROGEOLOGICAL ANALYSIS


The Twin Oaks MHP PWS obtains groundwater from the Ogallala aquifer. Arsenic and nitrate are commonly found in area wells at concentrations greater than the MCL. Several nearby wells have nitrate levels below the MCL, but few of these have been tested for arsenic and all are located more than 2-1/2 miles from the Twin Oaks MHP PWS wells. If any of these are considered for an alternative supply, they should be resampled and tested for all constituents of concern.

Alternatively, regional analyses show that most wells deeper than about 250 feet contain acceptable levels of all constituents of concern. In contrast, the current Twin Oaks MHP PWS wells are 105 and 110 feet deep. If the solute levels above the MCLs are coming from localized contamination near the surface, deepening one or more of these wells and casing them near the surface might improve water quality, if the aquifer is thick enough.

The water quality for each of the wells should be characterized. If one of the wells is found to produce compliant water, as much production as possible should be shifted to that well as a method of achieving compliance. It may also be possible to do down-hole testing on non-compliant wells to determine the source of the contaminants. If the contaminants derive primarily from a single part of the formation, that part could be excluded by modifying the existing well, or avoided altogether by completing a new well.

1

Figure ES.1 Summary of Project Methods



COMPLIANCE ALTERNATIVES

Overall, the system had a marginal level of FMT capacity. The system had some areas that needed improvement to be able to address future compliance issues; however, the system does have many positive aspects, including a dedicated operator and on-site manager. Areas of concern for the system included lack of long term capital planning, lack of compliance with nitrate and arsenic standards, lack of knowledge of SDWA regulations, and operator not involved in budget preparation or tracking.

There are several PWSs within 10 miles of Twin Oaks MHP. Some of these nearby systems have good water quality. In general, feasibility alternatives were developed based on obtaining water from the nearest PWSs, either by directly purchasing water, or by expanding the existing well field. There is a minimum of surface water available in the area, and obtaining a new surface water source is considered through the alternatives where treated surface water is obtained from the Cities of Midland and Odessa which obtain raw surface water from the Colorado River Municipal Water District.

Centralized treatment alternatives for arsenic and nitrate removal have been developed and were considered for this report; for example, reverse osmosis and electrodialysis reversal. Point-of-use (POU) and point-of-entry treatment alternatives were also considered. Temporary solutions such as providing bottled water or providing a centralized dispenser for treated or trucked-in water, were also considered as alternatives.

If compliant water can be found, developing a new well close to Twin Oaks MHP is likely to be the best solution if compliant groundwater can be found. Having a new well close to Twin Oaks MHP is likely to be one of the lower cost alternatives since the PWS already possesses the technical and managerial expertise needed to implement this option. The cost of new well alternatives quickly increases with pipeline length, making proximity of the alternate source a key concern. A new compliant well or obtaining water from a neighboring compliant PWS has the advantage of providing compliant water to all taps in the system.

Central treatment can be cost-competitive with the alternative of new nearby wells, but would require significant institutional changes to manage and operate. Similar to obtaining an alternate compliant water source, central treatment would provide compliant water to all water taps.

POU treatment can be cost competitive, but does not supply compliant water to all taps. Additionally, significant efforts would be required for maintenance and monitoring of the POU treatment units.

Providing compliant water through a central dispenser is significantly less expensive than providing bottled water to 100 percent of the population, but a significant effort is required for clients to fill their containers at the central dispenser.

FINANCIAL ANALYSIS

A financial analysis of the various alternatives for the Twin Oaks MHP PWS was performed using actual system revenues and estimated expenses. Estimated values were used since complete financial data for the water system were not available. The estimated annual water bill of \$136 per connection represents 0.4 percent of the median household income (MHI). Estimated operating expenses for the Twin Oaks MHP PWS suggest that revenues are inadequate to sustain operations. However, because of the lack of financial data, it is difficult to determine the actual current financial condition. Even though some values were estimated, the alternative comparison generated by the financial data still provides the PWS valuable information regarding the viability and affordability of implementing a solution. Table ES.2 provides a summary of the financial impact of implementing selected compliance alternatives, including the rate increase necessary to meet current operating expenses. The alternatives were selected to highlight results for the best alternatives from each different type or category.

Some of the compliance alternatives offer potential for shared or regional solutions. A group of PWSs could work together to implement alternatives for developing a new groundwater source or expanding an existing source, obtaining compliant water from a large regional provider, or for central treatment. Sharing the cost for implementation of these alternatives could reduce the cost on a per user basis. Additionally, merging PWSs or management of several PWSs by a single entity offers the potential for reduction in administrative costs.

Table ES.2 Selected Financial Analysis Results

Alternative	Funding Option	Average Annual Water Bill	Percent of MHI
Current	NA	\$136	0.4
To meet current expenses	NA	\$276	0.8
Purchase water from City of Midland	100% Grant	\$381	1.2
	Loan/Bond	\$1,019	3.2
Central Treatment - Ion Exchange IO	100% Grant	\$944	3.0
	Loan/Bond	\$1,388	4.4
Point-of-use Treatment	100% Grant	\$1,111	3.5
	Loan/Bond	\$1,211	3.8
Public dispenser for Treated Drinking Water	100% Grant	\$720	2.3
	Loan/Bond	\$738	2.3

TABLE OF CONTENTS

LIST OF TABLES.....	iv
LIST OF FIGURES.....	v
LIST OF FIGURES.....	v
ACRONYMS AND ABBREVIATIONS	vi
SECTION 1 INTRODUCTION	1-1
1.1 Public Health and Compliance with MCLs.....	1-4
1.2 Method.....	1-4
1.3 Regulatory Perspective.....	1-5
1.4 Abatement Options.....	1-5
1.4.1 Existing Public Water Supply Systems.....	1-5
1.4.2 Potential for New Groundwater Sources	1-7
1.4.3 Potential for Surface Water Sources	1-8
1.4.4 Identification of Treatment Technologies.....	1-9
1.4.5 Treatment Technologies Description.....	1-10
1.4.6 Point-of-Entry and Point-of-Use Treatment Systems.....	1-14
1.4.7 Water Delivery or Central Drinking Water Dispensers.....	1-16
SECTION 2 EVALUATION METHOD.....	2-1
2.1 Decision Tree.....	2-1
2.2 Data Sources and Data Collection.....	2-1
2.2.1 Data Search	2-1
2.2.2 PWS Interviews.....	2-7
2.3 Alternative Development and Analysis.....	2-10
2.3.1 Existing PWS	2-10
2.3.2 New Groundwater Source.....	2-10
2.3.3 New Surface Water Source	2-11
2.3.4 Treatment	2-11
2.4 Cost of Service and Funding Analysis	2-12
2.4.1 Financial Feasibility.....	2-12
2.4.2 Median Household Income	2-12
2.4.3 Annual Average Water Bill	2-13
2.4.4 Financial Plan Development.....	2-13
2.4.5 Financial Plan Results.....	2-14

1	SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS	3-1
2	3.1 Regional Analysis.....	3-1
3	3.1.1 Overview of the Study Area	3-1
4	3.1.2 Contaminants of Concern in the Study Area	3-4
5	3.1.3 Regional Geology	3-13
6	3.2 Detailed Assessment for Twin Oaks Mobile Home Park PWS	3-14
7	3.2.1 Summary of Alternative Groundwater Sources for the Twin Oaks Mobile	
8	Home Park PWS	3-19
9	SECTION 4 ANALYSIS OF THE TWIN OAKS MOBILE HOME PARK PWS	4-1
10	4.1 Description of Existing System	4-1
11	4.1.1 Existing System	4-1
12	4.1.2 Capacity Assessment for Twin Oaks Mobile Home Park PWS	4-3
13	4.2 Alternative Water Source Development.....	4-5
14	4.2.1 Identification of Alternative Existing Public Water Supply Sources	4-5
15	4.2.2 Potential for New Groundwater Sources	4-11
16	4.2.3 Potential for New Surface Water Sources	4-13
17	4.2.4 Options for Detailed Consideration	4-14
18	4.3 Treatment Options	4-14
19	4.3.1 Centralized Treatment Systems	4-14
20	4.3.2 Point-of-Use Systems.....	4-15
21	4.3.3 Point-of-Entry Systems	4-15
22	4.4 Bottled Water.....	4-15
23	4.5 Alternative Development and Analysis.....	4-15
24	4.5.1 Alternative TO-1: Purchase Treated Water from the City of Midland	4-15
25	4.5.2 Alternative TO-2: Purchase Water from the Midland International	
26	Airport.....	4-16
27	4.5.3 Alternative TO-3: Purchase Treated Water from Odessa	4-17
28	4.5.4 Alternative TO-4: New Well at 10 miles	4-19
29	4.5.5 Alternative TO-5: New at 5 miles.....	4-19
30	4.5.6 Alternative TO-6: New Well at 1 mile	4-20
31	4.5.7 Alternative TO-7: Central RO Treatment	4-21
32	4.5.8 Alternative TO-8: Central EDR Treatment.....	4-21
33	4.5.9 Alternative TO-9: Central IX Treatment	4-22
34	4.5.10 Alternative TO-10: Point-of-Use Treatment.....	4-22
35	4.5.11 Alternative TO-11: Point-of-Entry Treatment	4-24

1	4.5.12	Alternative TO-12: Public Dispenser for Treated Drinking Water	4-25
2	4.5.13	Alternative TO-13: 100 Percent Bottled Water Delivery	4-26
3	4.5.14	Alternative TO-14: Public Dispenser for Trucked Drinking Water	4-26
4	4.5.15	Summary of Alternatives	4-27
5	4.6	Cost of Service and Funding Analysis	4-30
6	4.6.1	Twin Oak Hills Mobile Home Park Financial Data.....	4-30
7	4.6.2	Current Financial Condition	4-30
8	4.6.3	Financial Plan Results.....	4-31
9	4.6.4	Evaluation of Potential Funding Options Financial Plan Results.....	4-34
10	SECTION 5 REFERENCES		5-1
11	APPENDICES		
12	Appendix A	PWS Interview Form	
13	Appendix B	Cost Basis	
14	Appendix C	Compliance Alternative Conceptual Cost Estimates	
15	Appendix D	Example Financial Model	
16	Appendix E	Analysis of Shared Solutions for Obtaining Water from the City of	
17		Midland	

LIST OF TABLES

1		
2	Table ES.1	Twin Oaks Mobile Home Park PWS Basic System Information..... ES-2
3	Table ES.2	Selected Financial Analysis Results..... ES-6
4	Table 3.1	Summary of Wells that Exceed the MCL for Arsenic, by Aquifer3-5
5	Table 3.2	Summary of Wells that Exceed the MCL for Nitrate, by Aquifer3-7
6	Table 3.3	Summary of Wells that Exceed the MCL for Fluoride, by Aquifer3-8
7	Table 3.4	Summary of Wells that Exceed the MCL for Selenium, by Aquifer3-10
8	Table 3.5	Nitrate and Arsenic Concentrations from the Twin Oaks Mobile Home Park
9		PWS3-15
10	Table 3.6	Most recent Concentrations of Select Constituents in Potential Alternative Water
11		Sources3-18
12	Table 4.1	Selected Public Water Systems within 32 Miles of the Twin Oaks MHP
13		PWS4-6
14	Table 4.2	Public Water Systems within the Vicinity of the Twin Oaks MHP PWS Selected
15		for Further Evaluation4-8
16	Table 4.3	Summary of Compliance Alternatives for MHP PWS.....4-28
17	Table 4.4	Financial Impact on Households for MHP PWS.....4-32

LIST OF FIGURES

1		
2	Figure ES.1 Summary of Project Methods.....	ES-4
3	Figure 1.1 Twin Oaks MHP PWS Location Map.....	1-2
4	Figure 1.2 Groundwater Districts, Conservation Areas, Municipal Authorities, and Planning	
5	Groups	1-3
6	Figure 2.1 Decision Tree – Tree 1 Existing Facility Analysis.....	2-2
7	Figure 2.2 Decision Tree – Tree 2 Develop Treatment Alternatives.....	2-3
8	Figure 2.3 Decision Tree – Tree 3 Preliminary Analysis	2-4
9	Figure 2.4 Decision Tree – Tree 4 Financial and Managerial	2-5
10	Figure 3.1 Regional Study Area and Locations of the PWS Wells Assessed.....	3-1
11	Figure 3.2 Major (a) and Minor (b) Aquifers in the Study Area	3-2
12	Figure 3.3 Water Quality Zones in the Study Area	3-3
13	Figure 3.4 Spatial Distribution of Arsenic Concentrations.....	3-4
14	Figure 3.5 Arsenic Concentrations and Well Depths in the Ogallala Aquifer	3-5
15	Figure 3.6 Spatial Distribution of Nitrate Concentrations.....	3-6
16	Figure 3.7 Nitrate as N Concentrations and Well Depths in the Ogallala Aquifer within the	
17	Study Area	3-7
18	Figure 3.8 Spatial Distribution of Fluoride Concentrations	3-8
19	Figure 3.9 Fluoride Concentrations and Well Depths in the Ogallala Aquifer within the Study	
20	Area	3-9
21	Figure 3.10 Spatial Distribution of Selenium Concentrations.....	3-10
22	Figure 3.11 Selenium Concentrations and Well Depths in the Ogallala Aquifer within the	
23	Study Area	3-11
24	Figure 3.12 Spatial Distribution of Uranium Concentrations in the Study Area.....	3-12
25	Figure 3.13 Uranium Concentrations and Well Depths in the Study Area.....	3-13
26	Figure 3.14 Nitrate Concentrations within 5- and 10-km Buffers around the Twin Oaks Mobile	
27	Home Park PWS Wells.....	3-16
28	Figure 3.15 Arsenic Concentrations within 5- and 10-km Buffers around the Twin Oaks	
29	Mobile Home Park PWS Wells	3-17
30	Figure 4.1 Twin Oaks MHP PWS.....	4-2
31	Figure 4.2 Alternative Cost Summary: MHP PWS	4-33
32		

1

ACRONYMS AND ABBREVIATIONS

µg/L	Micrograms per liter
°F	Degrees Fahrenheit
ANSI	American National Standards Institute
AFY	acre-feet per year
BAT	Best available technology
BEG	Bureau of Economic Geology
CA	cellulose acetate
CCN	Certificate of Convenience and Necessity
CFR	Code of Federal Regulations
CR	county road
CRMWD	Canadian River Municipal Water District
DWSRF	Drinking Water State Revolving Fund
EDR	Electrodialysis reversal
FM	Farm-to-market
FMT	Financial, managerial, and technical
GAM	Groundwater Availability Model
gpd	gallons per day
IX	Ion exchange
MCL	Maximum contaminant level
mg/L	Milligram per liter
mgd	Million gallons per day
MHI	Median household income
MHP	Mobile Home Park
NF	nanofiltration
NMEFC	New Mexico Environmental Financial Center
NURE	National Uranium Resource Evaluation
NPDWR	National Primary Drinking Water Regulations
O&M	Operation and Maintenance
ORCA	Office of Rural Community Affairs
Parsons	Parsons Transportation Group, Inc.
POE	Point-of-entry
POU	Point-of-use
psi	pounds per square inch
PWS	Public water system
RO	Reverse osmosis
SDWA	Safe Drinking Water Act
TAC	Texas Administrative Code

TCEQ	Texas Commission on Environmental Quality
TDS	Total dissolved solids
TFC	thin film composite
TWDB	Texas Water Development Board
USEPA	United States Environmental Protection Agency
VOC	volatile organic compound
WAM	Water Availability Model

1
2
3


SECTION 1 INTRODUCTION


The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Transportation Group Inc. (Parsons), were contracted by the Texas Commission on Environmental Quality (TCEQ) to assist with identifying and analyzing compliance alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

The overall goal of this project is to promote compliance using sound engineering and financial methods and data for PWSs that have recently had sample results that exceed maximum contaminant levels (MCL). The primary objectives of this project are to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS with regard to future implementation. The feasibility studies identify a range of potential compliance alternatives, and present basic data that can be used for evaluating feasibility. The compliance alternatives addressed include a description of what would be required for implementation, conceptual cost estimates for implementation, and non-cost factors that could be used to differentiate between alternatives. The cost estimates are intended for comparing compliance alternatives, and to give a preliminary indication of potential impacts on water rates resulting from implementation.

It is anticipated the PWS will review the compliance alternatives in this report to determine if there are promising alternatives, and then select the most attractive alternative(s) for more detailed evaluation and possible subsequent implementation. This report contains a decision tree approach that guided the efforts for this project, and also contains steps to guide a PWS through the subsequent evaluation, selection, and implementation of a compliance alternative.

The feasibility report provides an evaluation of water supply compliance options for the Twin Oaks Mobile Home Park (MHP) PWS, PWS ID# 1650057, Certificate of Convenience and Necessity (CCN) #13008, located in Midland County, hereinafter referred to in this document as the “Twin Oaks MHP PWS.” Recent sample results from the Twin Oaks MHP PWS exceeded the MCL for arsenic of 0.01 milligrams per Liter (mg/L) and 10 mg/L for nitrate (USEPA 2008a; TCEQ 2004). The location of the Twin Oaks MHP PWS is shown on Figure 1.1. Various water supply and planning jurisdictions are shown on Figure 1.2. These water supply and planning jurisdictions are used in the evaluation of alternate water supplies that may be available in the area.





1.1 PUBLIC HEALTH AND COMPLIANCE WITH MCLs

The goal of this project is to promote compliance for PWSs that supply drinking water exceeding regulatory MCLs. This project only addresses those contaminants and does not address any other violations that may exist for a PWS. As mentioned above, the Twin Oaks Mobile Home Park water system had recent sample results exceeding the MCL for arsenic and nitrate. In general, contaminant(s) in drinking water above the MCL(s) can have both short-term (acute) and long-term or lifetime (chronic) effects. Health concerns related to drinking water above MCLs for these two chemicals are briefly described below.

Potential health effects from long-term ingestion of water with levels of arsenic above the MCL (0.01 µg/L) include non-cancerous effects, such as cardiovascular, pulmonary, immunological, neurological and endocrine effects, and cancerous effects, including skin, bladder, lung, kidney, nasal passage, liver and prostate cancer (USEPA 2008b).

Short-term effects of nitrate in drinking water above the MCL have caused serious illness and sometimes death. Drinking water health publications conclude that the most susceptible population to adverse nitrate health effects includes infants less than 6 months of age; women who are pregnant or nursing; and individuals with enzyme deficiencies or a lack of free hydrochloric acid in the stomach. The serious illness in infants is due to the conversion of nitrate to nitrite by the body, which can interfere with the oxygen-carrying capacity of the child's blood. Symptoms include shortness of breath and blue-baby syndrome. Lifetime exposure to nitrates at levels above the MCL has the potential to cause the following effects: diuresis, increased starchy deposits, and hemorrhaging of the spleen (USEPA 2008c).

1.2 METHOD

The method for this project follows that of a pilot project performed by TCEQ, BEG, and Parsons. The pilot project evaluated water supply alternatives for PWSs that supplied drinking water with contaminant concentrations above U.S. Environmental Protection Agency (USEPA) and Texas drinking water standards. Three PWSs were evaluated in the pilot project to develop the method (*i.e.*, decision tree approach) for analyzing options for provision of compliant drinking water. This project is performed using the decision tree approach that was developed for the pilot project, and which was also used for subsequent projects.

Other tasks of the feasibility study are as follows:

- Identifying available data sources;
- Gathering and compiling data;
- Conducting financial, managerial, and technical (FMT) evaluations of the selected PWSs;
- Performing a geologic and hydrogeologic assessment of the area;
- Developing treatment and non-treatment compliance alternatives;
- Assessing potential alternatives with respect to economic and non-economic criteria;

- Preparing a feasibility report; and
- Suggesting refinements to the approach for future studies.

The remainder of Section 1 of this report addresses the regulatory background, and provides a summary of arsenic and nitrate abatement options. Section 2 describes the method used to develop and assess compliance alternatives. The groundwater sources of arsenic and nitrate are addressed in Section 3. Findings for the Twin Oaks MHP PWS, along with compliance alternatives development and evaluation, can be found in Section 4. Section 5 references the sources used in this report.

1.3 REGULATORY PERSPECTIVE

The Utilities & Districts and Public Drinking Water Sections of the TCEQ Water Supply Division are responsible for implementing requirements of the Federal Safe Drinking Water Act (SDWA), which include oversight of PWSs and water utilities. These responsibilities include:

- Monitoring public drinking water quality;
- Processing enforcement referrals for MCL violators;
- Tracking and analyzing compliance options for MCL violators;
- Providing FMT assessment and assistance to PWSs;
- Participating in the Drinking Water State Revolving Fund program to assist PWSs in achieving regulatory compliance; and
- Setting rates for privately owned water utilities.

This project was conducted to assist in achieving these responsibilities.

1.4 ABATEMENT OPTIONS

When a PWS exceeds a regulatory MCL, the PWS must take action to correct the violation. The MCL exceedances at the Twin Oaks MHP PWS involve arsenic and nitrate. The following subsections explore alternatives considered as potential options for obtaining/providing compliant drinking water.

1.4.1 Existing Public Water Supply Systems

A common approach to achieving compliance is for the PWS to make arrangements with a neighboring PWS for water supply. For this arrangement to work, the PWS from which water is being purchased (supplier PWS) must have water in sufficient quantity and quality, the political will must exist, and it must be economically feasible.

1.4.1.1 Quantity

For purposes of this report, quantity refers to water volume, flowrate, and pressure. Before approaching a potential supplier PWS, the non-compliant PWS should determine its water demand on the basis of average day and maximum day. Peak instantaneous demands can be met through proper sizing of storage facilities. Further, the potential for obtaining the appropriate quantity of water to blend to achieve compliance should be considered. The concept of blending involves combining water with low levels of contaminants with non-compliant water in sufficient quantity that the resulting blended water is compliant. The exact blend ratio would depend on the quality of the water a potential supplier PWS can provide, and would likely vary over time. If high quality water is purchased, produced or otherwise obtained, blending can reduce the amount of high quality water required. Implementation of blending will require a control system to ensure the blended water is compliant.

If the supplier PWS does not have sufficient quantity, the non-compliant community could pay for the facilities necessary to increase the quantity to the extent necessary to supply the needs of the non-compliant PWS. Potential improvements might include, but are not limited to:

- Additional wells;
- Developing a new surface water supply,
- Additional or larger-diameter piping;
- Increasing water treatment plant capacity
- Additional storage tank volume;
- Reduction of system losses,
- Higher-pressure pumps; or
- Upsized, or additional, disinfection equipment.

In addition to the necessary improvements, a transmission pipeline would need to be constructed to tie the two PWSs together. The pipeline must tie-in at a point in the supplier PWS where all the upstream pipes and appurtenances are of sufficient capacity to handle the new demand. In the non-compliant PWS, the pipeline must tie in at a point where no down stream bottlenecks are present. If blending is the selected method of operation, the tie-in point must be selected to ensure all the water in the system is blended to achieve regulatory compliance.

1.4.1.2 Quality

If a potential supplier PWS obtains its water from the same aquifer (or same portion of the aquifer) as the non-compliant PWS, the quality of water may not be significantly better. However, water quality can vary significantly due to well location, even within the same aquifer. If localized areas with good water quality cannot be identified, the non-compliant PWS would need to find a potential supplier PWS that obtains its water from a different aquifer

or from a surface water source. Additionally, a potential supplier PWS may treat non-compliant raw water to an acceptable level.

Surface water sources may offer a potential higher-quality source. Since there are significant treatment requirements, utilization of surface water for drinking water is typically most feasible for larger local or regional authorities or other entities that may provide water to several PWSs. Where PWSs that obtain surface water are neighbors, the non-compliant PWS may need to deal with those systems as well as with the water authorities that supply the surface water.

1.4.2 Potential for New Groundwater Sources

1.4.2.1 Existing Non-Public Supply Wells

Often there are wells not associated with PWSs located in the vicinity of the non-compliant PWS. The current use of these wells may be for irrigation, industrial purposes, domestic supply, stock watering, and other purposes. The process for investigating existing wells is as follows:

- Existing data sources (see below) will be used to identify wells in the areas that have satisfactory quality. For the Twin Oaks MHP PWS, the following standards could be used in a rough screening to identify compliant groundwater in surrounding systems:
 - o Nitrate (measured as nitrogen) concentrations less than 8 mg/L (below the MCL of 10 mg/L);
 - o Fluoride concentration less than 2.0 mg/L (below the Secondary MCL of 2 mg/L);
 - o Arsenic concentration less than 0.008 mg/L (below the MCL of 0.01 mg/L);
 - o Uranium concentration less than 0.024 mg/L (below the MCL of 0.030 mg/L; and
 - o Selenium concentration less than 0.04 mg/L (below the MCL of 0.05 mg/L).
- The recorded well information will be reviewed to eliminate those wells that appear to be unsuitable for the application. Often, the “Remarks” column in the Texas Water Development Board (TWDB) hard-copy database provides helpful information. Wells eliminated from consideration generally include domestic and stock wells, dug wells, test holes, observation wells, seeps and springs, destroyed wells, wells used by other communities, etc.
- Wells of sufficient size are identified. Some may be used for industrial or irrigation purposes. Often the TWDB database will include well yields, which may indicate the likelihood that a particular well is a satisfactory source.
- At this point in the process, the local groundwater control district (if one exists) should be contacted to obtain information about pumping restrictions. Also, preliminary cost

estimates should be made to establish the feasibility of pursuing further well development options.

- If particular wells appear to be acceptable, the owner(s) should be contacted to ascertain their willingness to work with the PWS. Once the owner agrees to participate in the program, questions should be asked about the wells. Many owners have more than one well, and would probably be the best source of information regarding the latest test dates, who tested the water, flowrates, and other well characteristics.
- After collecting as much information as possible from cooperative owners, the PWS would then narrow the selection of wells and sample and analyze them for quality. Wells with good quality water would then be potential candidates for test pumping. In some cases, a particular well may need to be refurbished before test pumping. Information obtained from test pumping would then be used in combination with information about the general characteristics of the aquifer to determine whether a well at that location would be suitable as a supply source.
- It is recommended that new wells be installed instead of using existing wells to ensure the well characteristics are known and the well meets construction standards.
- Permit(s) would then be obtained from the groundwater control district or other regulatory authority, and an agreement with the owner (purchase or lease, access easements, etc.) would then be negotiated.

1.4.2.2 Develop New Wells

If no existing wells are available for development, the PWS or group of PWSs has an option of developing new wells. Records of existing wells, along with other hydrogeologic information and modern geophysical techniques, should be used to identify potential locations for new wells. In some areas, the TWDB's Groundwater Availability Model (GAM) may be applied to indicate potential sources. Once a general area is identified, land owners and regulatory agencies should be contacted to determine an exact location for a new well or well field. Pump tests and water quality tests would be required to determine if a new well will produce an adequate quantity of good quality water. Permits from the local groundwater control district or other regulatory authority could also be required for a new well.

1.4.3 Potential for Surface Water Sources

Water rights law dominates the acquisition of water from surface water sources. For a PWS, 100 percent availability of water is required, except where a back-up source is available. For PWSs with an existing water source, although it may be non-compliant because of elevated concentrations of one or more parameters, water rights may not need to be 100 percent available.

1.4.3.1 Existing Surface Water Sources

"Existing surface water sources" of water refers to municipal water authorities and cities that obtain water from surface water sources. The process of obtaining water from such a

source is generally less time consuming and less costly than the process of developing a new source; therefore, it should be a primary course of investigation. An existing source would be limited by its water rights, the safe yield of a reservoir or river, or by its water treatment or water conveyance capability. The source must be able to meet the current demand and honor contracts with communities it currently supplies. In many cases, the contract amounts reflect projected future water demand based on population or industrial growth.

A non-compliant PWS would look for a source with sufficient spare capacity. Where no such capacity exists, the non-compliant PWS could offer to fund the improvements necessary to obtain the capacity. This approach would work only where the safe yield could be increased (perhaps by enlarging a reservoir) or where treatment capacity could be increased. In some instances water rights, where they are available, could possibly be purchased.

In addition to securing the water supply from an existing source, the non-compliant PWS would need to arrange for transmission of the water to the PWS. In some cases, that could require negotiations with, contracts with, and payments to an intermediate PWS (an intermediate PWS is one where the infrastructure is used to transmit water from a “supplier” PWS to a “supplied” PWS, but does not provide any additional treatment to the supplied water). The non-compliant PWS could be faced with having to fund improvements to the intermediate PWS in addition to constructing its own necessary transmission facilities.

1.4.3.2 New Surface Water Sources

Communication with the TCEQ and relevant planning groups from the beginning is essential in the process of obtaining a new surface water source. Preliminary assessment of the potential for acquiring new rights may be based on surface water availability maps located on the TWDB website. Where water rights appear to be available, the following activities need to occur:

- Discussions with TCEQ to indicate the likelihood of obtaining those rights. The TCEQ may use the Water Availability Model (WAM) to assist in the determination.
- Discussions with land owners to indicate potential treatment plant locations.
- Coordination with U.S. Army Corps of Engineers and local river authorities.
- Preliminary engineering design to determine the feasibility, costs, and environmental issues of a new treatment plant.

Should these discussions indicate that a new surface water source is the best option, the community would proceed with more intensive planning (initially obtaining funding), permitting, land acquisition, and detailed designs.

1.4.4 Identification of Treatment Technologies

Various treatment technologies were also investigated as compliance alternatives for treatment of nitrate and arsenic to regulatory levels (*i.e.*, MCLs). Numerous options have been

identified by the USEPA as best available technologies (BAT) for non-compliant constituents. Identification and descriptions of the various BATs are provided in the following sections.

1.4.4.1 Treatment Technologies for Nitrate

The MCL for nitrate (as nitrogen) was set at 10 mg/L by the USEPA on January 30, 1992, as part of the Phase II Rules, and became effective on July 30, 1992 (USEPA 2008a). This MCL applies to all community water systems, regardless of size.

BATs identified by USEPA for removal of nitrates include:

- Reverse Osmosis (RO);
- Ion Exchange (IX); and
- Electrodialysis Reversal (EDR).

1.4.4.2 Treatment Technologies for Arsenic

In January 2001, the USEPA published a final rule in the Federal Register that established an MCL for arsenic of 0.010 mg/L (USEPA 2008b). The regulation applies to all community water systems and non-transient, non-community water systems, regardless of size.

The new arsenic MCL of 0.010 mg/L became effective January 23, 2006, after which time the running average annual arsenic level must be at or below 0.010 mg/L at each entry point to the distribution system, although point-of-use (POU) treatment can be instituted in place of centralized treatment.

Various treatment technologies were investigated as compliance alternatives for treatment of arsenic to regulatory levels (*i.e.*, MCL). According to a recent USEPA report for small water systems with less than 10,000 customers (EPA/600/R-05/001) a number of drinking water treatment technologies are available to reduce arsenic concentrations in source water to below the new MCL of 0.010 mg/L, including:

- IX;
- RO;
- EDR;
- Adsorption; and
- Coagulation/filtration.

1.4.5 Treatment Technologies Description

Reverse Osmosis, IX, and EDR are identified by USEPA as BATs for removal of nitrates. These three treatment technologies are also applicable to arsenic, and are the only three technologies common to both nitrate and arsenic treatment. In this case, IX is not a feasible

technology because of the high total dissolved solids (TDS) of the groundwater. A description of these technologies follows

1.4.5.1 Reverse Osmosis

Process. RO is a physical process in which contaminants are removed by applying pressure on the feed water to force it through a semi-permeable membrane. RO membranes reject ions based on size and electrical charge. The raw water is typically called feed; the product water is called permeate; and the concentrated reject is called concentrate. Common RO membrane materials include asymmetric cellulose acetate (CA) or polyamide thin film composite (TFC). The TFC membrane operates at much lower pressure and can achieve higher salt rejection than the CA membranes but is less chlorine resistant. Each material has specific benefits and limitations depending on the raw water characteristics and pre-treatment. A newer, lower pressure type membrane that is similar in operation to spiral wound RO, is nanofiltration (NF), which has higher rejection for divalent ions than mono-valent ions. NF is sometimes used instead of RO for treating water with high hardness and sulfate concentrations. A typical RO installation includes a high pressure feed pump; parallel first and second stage membrane elements (in pressure vessels); and valves and piping for feed, permeate, and concentrate streams. Factors influencing membrane selection are cost, recovery, rejection, raw water characteristics, and pre-treatment. Factors influencing performance are raw water characteristics, pressure, temperature, and regular monitoring and maintenance. Depending on the membrane type and operating pressure, RO is capable of removing 85-95 percent of fluoride, and over 95 percent of nitrate and arsenic. The treatment process is relatively insensitive to pH. Water recovery is 60-80 percent, depending on raw water characteristics. The concentrate volume for disposal can be significant. The conventional RO treatment train for well water uses anti-scalant addition, cartridge filtration, RO membranes, chlorine disinfection, and clearwell storage.

Pre-treatment. RO requires careful review of raw water characteristics, and pre-treatment needs to prevent membranes from fouling, scaling, or other membrane degradation. Removal or sequestering of suspended solids is necessary to prevent colloidal and bio-fouling, and removal of sparingly soluble constituents such as calcium, magnesium, silica, sulfate, barium, etc., may be required to prevent scaling. Pretreatment can include media filters to remove suspended particles; IX softening to remove hardness; antiscalant feed; temperature and pH adjustment to maintain efficiency; acid to prevent scaling and membrane damage; activated carbon or bisulfite to remove chlorine (post-disinfection may be required); and cartridge filters to remove any remaining suspended particles to protect membranes from upsets.

Maintenance. Rejection percentages must be monitored to ensure contaminant removal below MCLs. Regular monitoring of membrane performance is necessary to determine fouling, scaling, or other membrane degradation. Use of monitoring equipment to track membrane performance is recommended. Acidic or caustic solutions are regularly flushed through the system at high volume/low pressure with a cleaning agent to remove fouling and scaling. The system is flushed and returned to service. RO stages are cleaned sequentially.

Frequency of membrane replacement is dependent on raw water characteristics, pre-treatment, and maintenance.

Waste Disposal. Pre-treatment waste streams, concentrate flows, and spent filters and membrane elements all require approved disposal methods. Disposal of the significant volume of the concentrate stream is a problem for many utilities.

Advantages (RO)

- Produces the highest water quality.
- Can effectively treat a wide range of dissolved salts and minerals, turbidity, health and aesthetic contaminants, and certain organics. Some highly maintained units are capable of treating biological contaminants.
- Low pressure - less than 100 pounds per square inch (psi), compact, self-contained, single membrane units are available for small installations.

Disadvantages (RO)

- Relatively expensive to install and operate.
- Frequent membrane monitoring and maintenance; pressure, temperature, and pH requirements to meet membrane tolerances. Membranes can be chemically sensitive.
 - Additional water usage depending on rejection rate.
 - Concentrate disposal required.

A concern with RO for treatment of inorganics is that if the full stream is treated, then most of the alkalinity and hardness would also be removed. In that event, post-treatment may be necessary to avoid corrosion problems. If feasible, a way to avoid this issue is to treat a slip stream of raw water and blend the slip stream back with the raw water rather than treat the full stream. The amount of water rejected is also an issue with RO. Discharge concentrate flow can be between 10 and 50 percent of the influent flow.

1.4.5.2 Electrodialysis Reversal

Process. EDR is an electrochemical process in which ions migrate through ion-selective semi-permeable membranes as a result of their attraction to two electrically charged electrodes. A typical EDR system includes a membrane stack with a number of cell pairs, each consisting of a cation transfer membrane, a demineralized flow spacer, an anion transfer membrane, and a concentrate flow spacer. Electrode compartments are at opposite ends of the stack. The influent feed water (chemically treated to prevent precipitation) and the concentrated reject flow in parallel across the membranes and through the demineralized and concentrate flow spacers, respectively. The electrodes are continually flushed to reduce fouling or scaling. Careful consideration of flush feed water is required. Typically, the membranes are cation or anion exchange resins cast in sheet form; the spacers are high density polyethylene; and the electrodes are inert metal. EDR stacks are tank-contained and often staged. Membrane

selection is based on review of raw water characteristics. A single-stage EDR system usually removes 40-50 percent of fluoride, nitrate, arsenic, and TDS. Additional stages are required to achieve higher removal efficiency (85-95% for fluoride). EDR uses the technique of regularly reversing the polarity of the electrodes, thereby freeing accumulated ions on the membrane surface. This process requires additional plumbing and electrical controls, but it increases membrane life, may require less added chemicals, and eases cleaning. The conventional EDR treatment train typically includes EDR membranes, chlorine disinfection, and clearwell storage. Treatment of surface water may also require pre-treatment steps such as raw water pumps, debris screens, rapid mix with addition of an anti-scalant, slow mix flocculator, sedimentation basin or clarifier, and gravity filters. Microfiltration could be used in place of flocculation, sedimentation, and filtration. Additional treatment or management of the concentrate and the removed solids would be necessary prior to disposal.

Pre-treatment. There are pretreatment requirements for pH, organics, turbidity, and other raw water characteristics. EDR typically requires chemical feed to prevent scaling, acid addition for pH adjustment, and a cartridge filter for prefiltration. If arsenite [As(III)] occurs, oxidation via pre-chlorination is required since the arsenite specie at pH below 9 has no ionic charge and will not be removed by EDR.

Maintenance. EDR membranes are durable, can tolerate a pH range from 1 to 10, and temperatures to 115 degrees Fahrenheit (°F) for cleaning. They can be removed from the unit and scrubbed. Solids can be washed off by turning the power off and letting water circulate through the stack. Electrode washes flush out byproducts of electrode reaction. The byproducts are hydrogen, formed in the cathode space, and oxygen and chlorine gas, formed in the anode space. If the chlorine is not removed, toxic chlorine gas may form. Depending on raw water characteristics, the membranes would require regular maintenance or replacement. EDR requires reversing the polarity. Flushing at high volume/low pressure continuously is required to clean electrodes. If used, pre-treatment filter replacement and backwashing would be required. The EDR stack must be disassembled, mechanically cleaned, and reassembled at regular intervals.

Waste Disposal. Highly concentrated reject flows, electrode cleaning flows, and spent membranes require approved disposal methods. Pre-treatment processes and spent materials also require approved disposal methods.

Advantages (EDR)

- EDR can operate with minimal fouling or scaling, or chemical addition.
- Low pressure requirements; typically quieter than RO.
- Long membrane life expectancy; EDR extends membrane life and reduces maintenance.
- More flexible than RO in tailoring treated water quality requirements.

Disadvantages (EDR)

- Not suitable for high levels of iron, manganese, and hydrogen sulfide.

- High energy usage for high TDS water.
- Waste of water because of the significant concentrate flows.
- Generates relatively large saline waste stream requiring disposal.
- Pre-oxidation required for arsenite (if present).

EDR can be quite expensive to run because of the energy it uses. However, because it is generally automated and allows for part-time operation, it may be an appropriate technology for small systems. It can be used to simultaneously reduce fluoride, selenium, nitrate, arsenic and TDS.

1.4.6 Point-of-Entry and Point-of-Use Treatment Systems

Point-of-entry (POE) and POU treatment devices or systems rely on many of the same treatment technologies used in central treatment plants. However, while central treatment plants treat all water distributed to consumers to the same level, POU and POE treatment devices are designed to treat only a portion of the total flow. POU devices treat only the water intended for direct consumption, typically at a single tap or limited number of taps, while POE treatment devices are typically installed to treat all water entering a single home, business, school, or facility. POU and POE treatment systems may be an option for PWSs where central treatment is not affordable. Updated USEPA guidance on use of POU and POE treatment devices is provided in “*Point-of-Use or Point-of-Entry Treatment Options for Small Drinking Water Systems*,” EPA 815-R-06-010, April 2006 (USEPA 2006).

Point-of-entry and POU treatment systems can be used to provide compliant drinking water. These systems typically use small adsorption or reverse osmosis treatment units installed “under the sink” in the case of POU, and where water enters a house or building in the case of POE. It should be noted that the POU treatment units would need to be more complex than units typically found in commercial retail outlets to meet regulatory requirements, making purchase and installation more expensive. Point-of-entry and POU treatment units would be purchased and owned by the PWS. These solutions are decentralized in nature, and require utility personnel entry into houses or at least onto private property for installation, maintenance, and testing. Due to the large number of treatment units that would be employed and would be largely out of the control of the PWS, it is very difficult to ensure 100 percent compliance. Prior to selection of a POE or POU program for implementation, consultation with TCEQ would be required to address measurement and determination of level of compliance.

The National Primary Drinking Water Regulations (NPDWR), 40 CFR Section 141.100, covers criteria and procedures for PWSs using POE devices and sets limits on the use of these devices. According to the regulations (July 2005 Edition), the PWS must develop and obtain TCEQ approval for a monitoring plan before POE devices are installed for compliance with an MCL. Under the plan, POE devices must provide health protection equivalent to central water treatment meaning the water must meet all NPDWR and would be of acceptable quality similar to water distributed by a well-operated central treatment plant. In addition, monitoring must

include physical measurements and observations such as total flow treated and mechanical condition of the treatment equipment. The system would have to track the POE flow for a given time period, such as monthly, and maintain records of device inspection. The monitoring plan should include frequency of monitoring for the contaminant of concern and number of units to be monitored. For instance, the system may propose to monitor every POE device during the first year for the contaminant of concern and then monitor one-third of the units annually, each on a rotating schedule, such that each unit would be monitored every three years. To satisfy the requirement that POE devices must provide health protection, the water system may be required to conduct a pilot study to verify the POE device can provide treatment equivalent to central treatment. Every building connected to the system must have a POE device installed, maintained, and properly monitored. Additionally, TCEQ must be assured that every building is subject to treatment and monitoring, and that the rights and responsibilities of the PWS customer convey with title upon sale of property.

Effective technology for POE devices must be properly applied under the monitoring plan approved by TCEQ and the microbiological safety of the water must be maintained. TCEQ requires adequate certification of performance, field testing, and, if not included in the certification process, a rigorous engineering design review of the POE devices. The design and application of the POE devices must consider the tendency for increase in heterotrophic bacteria concentrations in water treated with activated carbon. It may be necessary to use frequent backwashing, post-contactor disinfection, and Heterotrophic Plate Count monitoring to ensure that the microbiological safety of the water is not compromised.

The SDWA [§1412(b)(4)(E)(ii)] regulates the design, management and operation of POU and POE treatment units used to achieve compliance with an MCL. These restrictions, relevant to MCL compliance are:

- POU and POE treatment units must be owned, controlled, and maintained by the water system, although the utility may hire a contractor to ensure proper operation and maintenance (O&M) and MCL compliance. The water system must retain unit ownership and oversight of unit installation, maintenance and sampling; the utility ultimately is the responsible party for regulatory compliance. The water system staff need not perform all installation, maintenance, or management functions, as these tasks may be contracted to a third party-but the final responsibility for the quality and quantity of the water supplied to the community resides with the water system, and the utility must monitor all contractors closely. Responsibility for O&M of POU or POE devices installed for SDWA compliance may not be delegated to homeowners.
- POU and POE units must have mechanical warning systems to automatically notify customers of operational problems. Each POU or POE treatment device must be equipped with a warning device (e.g., alarm, light) that would alert users when their unit is no longer adequately treating their water. As an alternative, units may be equipped with an automatic shut-off mechanism to meet this requirement.
- If the American National Standards Institute (ANSI) issued product standards for a specific type of POU or POE treatment unit, only those units that have been

independently certified according to those standards may be used as part of a compliance strategy.

The following observations with regard to using POE and POU devices for SDWA compliance were made by Raucher, *et al.* (2004):

- If POU devices are used as an SDWA compliance strategy, certain consumer behavioral changes will be necessary (e.g., encouraging people to drink water only from certain treated taps) to ensure comprehensive consumer health protection.
- Although not explicitly prohibited in the SDWA, USEPA indicates that POU treatment devices should not be used to treat for radon or for most volatile organic contaminants (VOC) to achieve compliance, because POU devices do not provide 100 percent protection against inhalation or contact exposure to those contaminants at untreated taps (e.g., shower heads).
- Liability – PWSs considering unconventional treatment options (POU, POE, or bottled water) must address liability issues. These could be meeting drinking water standards, property entry and ensuing liabilities, and damage arising from improper installation or improper function of the POU and POE devices.

1.4.7 Water Delivery or Central Drinking Water Dispensers

Current USEPA regulations 40 Code of Federal Regulations (CFR) 141.101 prohibit the use of bottled water to achieve compliance with an MCL, except on a temporary basis. State regulations do not directly address the use of bottled water. Use of bottled water at a non-compliant PWS would be on a temporary basis. Every 3 years, the PWSs that employ interim measures are required to present the TCEQ with estimates of costs for piping compliant water to their systems. As long as the projected costs remain prohibitively high, the bottled water interim measure is extended. Until USEPA amends the noted regulation, the TCEQ is unable to accept water delivery or central drinking water dispensers as compliance solutions.

Central provision of compliant drinking water would consist of having one or more dispensers of compliant water where customers could come to fill containers with drinking water. The centralized water source could be from small to medium-sized treatment units or could be compliant water delivered to the central point by truck.

Water delivery is an interim measure for providing compliant water. As an interim measure for a small impacted population, providing delivered drinking water may be cost effective. If the susceptible population is large, the cost of water delivery would increase significantly.

- Water delivery programs require consumer participation to a varying degree. Ideally, consumers would have to do no more than they currently do for a piped-water delivery system. Least desirable are those systems that require maximum effort on the part of the customer (e.g., customer has to travel to get the water, transport the water, and physically handle the bottles).

SECTION 2 EVALUATION METHOD

2.1 DECISION TREE

The decision tree is a flow chart for conducting feasibility studies for a non-compliant PWS. The decision tree is shown in Figures 2.1 through 2.4. The tree guides the user through a series of phases in the design process. Figure 2.1 shows Tree 1, which outlines the process for defining the existing system parameters, followed by optimizing the existing treatment system operation. If optimizing the existing system does not correct the deficiency, the tree leads to six alternative preliminary branches for investigation. The groundwater branch leads through investigating existing wells to developing a new well field. The treatment alternatives address centralized and on-site treatment. The objective of this phase is to develop conceptual designs and cost estimates for the six types of alternatives. The work done for this report follows through Tree 1 and Tree 2, as well as a preliminary pass through Tree 4.

Tree 3, which begins at the conclusion of the work for this report, starts with a comparison of the conceptual designs, selecting the two or three alternatives that appear to be most promising, and eliminating those alternatives that are obviously infeasible. It is envisaged that a process similar to this would be used by the study PWS to refine the list of viable alternatives. The selected alternatives are then subjected to intensive investigation, and highlighted by an investigation into the socio-political aspects of implementation. Designs are further refined and compared, resulting in the selection of a preferred alternative. The steps for assessing the financial and economic aspects of the alternatives (one of the steps in Tree 3) are given in Tree 4 in Figure 2.4.

2.2 DATA SOURCES AND DATA COLLECTION

2.2.1 Data Search

2.2.1.1 Water Supply Systems

The TCEQ maintains a set of files on public water systems, utilities, and districts at its headquarters in Austin, Texas. The files are organized under two identifiers: a PWS identification number and a CCN number. The PWS identification number is used to retrieve four types of files:

- CO – Correspondence,
- CA – Chemical analysis,
- MOR – Monthly operating reports (quality/quantity), and
- FMT – Financial, managerial and technical issues.

Figure 2.1
TREE 1 – EXISTING FACILITY ANALYSIS




Figure 2.2
TREE 2 – DEVELOP TREATMENT ALTERNATIVES




Figure 2.3

Tree 3 – PRELIMINARY ANALYSIS





Figure 2.4
TREE 4 – FINANCIAL



The CCN files generally contain a copy of the system's Certificate of Convenience and Necessity, along with maps and other technical data.

These files were reviewed for the PWS and surrounding systems.

The following websites were consulted to identify the water supply systems in the area:

- Texas Commission on Environmental Quality
www3.tceq.state.tx.us/iwud/.
- USEPA Safe Drinking Water Information System
www.epa.gov/safewater/data/getdata.html

Groundwater Control Districts were identified on the TWDB web site, which has a series of maps covering various groundwater and surface water subjects. One of those maps shows groundwater control districts in the State of Texas.

2.2.1.2 Existing Wells

The TWDB maintains a groundwater database available at www.twdb.state.tx.us that has two tables with helpful information. The "Well Data Table" provides a physical description of the well, owner, location in terms of latitude and longitude, current use, and for some wells, items such as flowrate, and nature of the surrounding formation. The "Water Quality Table" provides information on the aquifer and the various chemical concentrations in the water. For this project, it was assumed the nitrate concentration given in this database was the concentration of nitrate, with a molecular weight of 62. To convert to the same basis used for the MCL (Nitrate-N), the value given in the TWDB database was divided by 4.5.

2.2.1.3 Surface Water Sources

Regional planning documents were consulted for lists of surface water sources.

2.2.1.4 Groundwater Availability Model

GAMs, developed by the TWDB, are planning tools and should be consulted as part of a search for new or supplementary water sources. GAMs for the Ogallala Aquifer and Edwards-Trinity Plateau Aquifer were investigated as potential tools for identifying available and suitable groundwater resources.

2.2.1.5 Water Availability Model

The WAM is a computer-based simulation predicting the amount of water that would be in a river or stream under a specified set of conditions. WAMs are used to determine whether water would be available for a newly requested water right or amendment. If water is available, these models estimate how often the applicant could count on water under various conditions (*e.g.*, whether water would be available only one month out of the year, half the

year, or all year, and whether that water would be available in a repeat of the drought of record).

WAMs provide information that assist TCEQ staff in determining whether to recommend the granting or denial of an application.

2.2.1.6 Financial Data

An evaluation of existing data will yield an up-to-date assessment of the financial condition of the water system. As part of a site visit, financial data were collected in various forms such as electronic files, hard copy documents, and focused interviews. Data sought included:

- Annual Budget
- Audited Financial Statements
 - o Balance Sheet
 - o Income & Expense Statement
 - o Cash Flow Statement
 - o Debt Schedule
- Water Rate Structure
- Water Use Data
 - o Production
 - o Billing
 - o Customer Counts

2.2.1.7 Demographic Data

Basic demographic data were collected from the 2000 Census to establish incomes and eligibility for potential low cost funding for capital improvements. Median household income (MHI) and number of families below poverty level were the primary data points of significance. If available, MHI for the customers of the PWS should be used. In addition, unemployment data were collected from current U.S. Bureau of Labor Statistics. These data were collected for the following levels: national, state, and county.

2.2.2 PWS Interviews

2.2.2.1 PWS Capacity Assessment Process

Capacity assessment is the industry standard term for evaluation of a water system's FMT capacity to effectively deliver safe drinking water to its customers now and in the future at a reasonable cost, and to achieve, maintain and plan for compliance with applicable regulations.

The assessment process involves interviews with staff and management who have a responsibility in the operations and management of the system.

Financial, managerial, and technical capacity are individual yet highly interrelated components of a system's capacity. A system cannot sustain capacity without maintaining adequate capability in all three components.

Financial capacity is a water system's ability to acquire and manage sufficient financial resources to allow the system to achieve and maintain compliance with SDWA regulations. Financial capacity refers to the financial resources of the water system, including but not limited to, revenue sufficiency, credit worthiness, and fiscal controls.

Managerial capacity is the ability of a water system to conduct its affairs so the system is able to achieve and maintain compliance with SDWA requirements. Managerial capacity refers to the management structure of the water system, including but not limited to, ownership accountability, staffing and organization, and effective relationships with customers and regulatory agencies.

Technical capacity is the physical and operational ability of a water system to achieve and maintain compliance with SDWA regulations. It refers to the physical infrastructure of the water system, including the adequacy of the source water, treatment, storage and distribution infrastructure. It also refers to the ability of system personnel to effectively operate and maintain the system and to otherwise implement essential technical knowledge.

Many aspects of water system operations involve more than one component of capacity. Infrastructure replacement or improvement, for example, requires financial resources, management planning and oversight, and technical knowledge. A deficiency in any one area could disrupt the entire operation. A system that is able to meet both its immediate and long-term challenges demonstrates that it has sufficient FMT capacity.

Assessment of FMT capacity of the PWS was based on an approach developed by the New Mexico Environmental Finance Center (NMEFC), which is consistent with the TCEQ FMT assessment process. This method was developed from work the NMEFC did while assisting USEPA Region 6 in developing and piloting groundwater comprehensive performance evaluations. The NMEFC developed a standard list of questions that could be asked of water system personnel. The list was then tailored slightly to have two sets of questions – one for managerial and financial personnel, and one for operations personnel (the questions are included in Appendix A). Each person with a role in the FMT capacity of the system was asked the applicable standard set of questions individually. The interviewees were not given the questions in advance and were not told the answers others provided. Also, most of the questions are open ended type questions so they were not asked in a fashion to indicate what would be the "right" or "wrong" answer. The interviews lasted between 45 minutes to 75 minutes depending on the individual's role in the system and the length of the individual's answers.

In addition to the interview process, visual observations of the physical components of the system were made. A technical information form was created to capture this information. This form is also contained in Appendix A. This information was considered supplemental to the interviews because it served as a check on information provided in the interviews. For example, if an interviewee stated he or she had an excellent preventative maintenance schedule and the visit to the facility indicated a significant amount of deterioration (more than would be expected for the age of the facility) then the preventative maintenance program could be further investigated or the assessor could decide that the preventative maintenance program was inadequate.

Following interviews and observations of the facility, answers that all personnel provided were compared and contrasted to provide a clearer picture of the true operations at the water system. The intent was to go beyond simply asking the question, “Do you have a budget?” to actually finding out if the budget was developed and being used appropriately. For example, if a water system manager was asked the question, “Do you have a budget?” he or she may say, “yes” and the capacity assessor would be left with the impression that the system is doing well in this area. However, if several different people are asked about the budget in more detail, the assessor may find that although a budget is present, operations personnel do not have input into the budget, the budget is not used by the financial personnel, the budget is not updated regularly, or the budget is not used in setting or evaluating rates. With this approach, the inadequacy of the budget would be discovered and the capacity deficiency in this area would be noted.

Following the comparison of answers, the next step was to determine which items noted as a potential deficiency truly had a negative effect on the system’s operations. If a system had what appeared to be a deficiency, but this deficiency was not creating a problem in terms of the operations or management of the system, it was not considered critical and may not have needed to be addressed as a high priority. As an example, the assessment may have revealed an insufficient number of staff members to operate the facility. However, it may also have been revealed that the system was able to work around that problem by receiving assistance from a neighboring system, so no severe problems resulted from the number of staff members. Although staffing may not be ideal, the system does not need to focus on this particular issue. The system needs to focus on items that are truly affecting operations. As an example of this type of deficiency, a system may lack a reserve account which can then lead the system to delay much-needed maintenance or repair on its storage tank. In this case, the system needs to address the reserve account issue so that proper maintenance can be completed.

The intent was to develop a list of capacity deficiencies with the greatest impact on the system’s overall capacity. Those were the most critical items to address through follow-up technical assistance or by the system itself.

2.2.2.2 Interview Process

PWS personnel were interviewed by the project team, and each was interviewed separately. Interview forms were completed during each interview.

2.3 ALTERNATIVE DEVELOPMENT AND ANALYSIS

The initial objective for developing alternatives to address compliance issues is to identify a comprehensive range of possible options that can be evaluated to determine the most promising for implementation. Once the possible alternatives are identified, they must be defined in sufficient detail so a conceptual cost estimate (capital and O&M costs) can be developed. These conceptual cost estimates are used to compare the affordability of compliance alternatives, and to give a preliminary indication of rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. The basis for the unit costs used for the compliance alternative cost estimates is summarized in Appendix B. Other non-economic factors for the alternatives, such as reliability and ease of implementation, are also addressed

2.3.1 Existing PWS

The neighboring PWSs were identified, and the extents of their systems were investigated. PWSs farther than 30 miles from the non-compliant PWSs were not considered because the length of the pipeline required would make the alternative cost prohibitive. The quality of water provided was also investigated. For neighboring PWSs with compliant water, options for water purchase and/or expansion of existing well fields were considered. The neighboring PWSs with non-compliant water were considered as possible partners in sharing the cost for obtaining compliant water either through treatment or developing an alternate source.

The neighboring PWSs were investigated to get an idea of the water sources in use and the quantity of water that might be available for sale. They were contacted to identify key locations in their systems where a connection might be made to obtain water, and to explore on a preliminary basis their willingness to partner or sell water. Then, the major system components that would be required to provide compliant water were identified. The major system components included treatment units, wells, storage tanks, pump stations, and pipelines.

Once the major components were identified, a preliminary design was developed to identify sizing requirements and routings. A capital cost estimate was then developed based on the preliminary design of the required system components. An annual O&M cost was also estimated to reflect the change in O&M expenditures that would be needed if the alternative was implemented.

Non-economic factors were also identified. Ease of implementation was considered, as well as the reliability for providing adequate quantities of compliant water. Additional factors were whether implementation of an alternative would require significant increase in the management or technical capability of the PWS, and whether the alternative had the potential for regionalization.

2.3.2 New Groundwater Source

It was not possible in the scope of this project to determine conclusively whether new wells could be installed to provide compliant drinking water. To evaluate potential new

groundwater source alternatives, three test cases were developed based on distance from the PWS intake point. The test cases were based on distances of 10 miles, 5 miles, and 1 mile. It was assumed that a pipeline would be required for all three test cases, and a storage tank and pump station would be required for the 10-mile and 5-mile alternatives. It was also assumed that new wells would be installed, and that their depths would be similar to the depths of the existing wells, or other existing drinking water wells in the area.

A preliminary design was developed to identify sizing requirements for the required system components. A capital cost estimate was then developed based on the preliminary design of the required system components. An annual O&M cost was also estimated to reflect the change (*i.e.*, from current expenditures) in O&M expenditures that would be needed if the alternative was implemented.

Non-economic factors were also identified. Ease of implementation was considered, as well as the reliability for providing adequate quantities of compliant water. Additional factors were whether implementation of an alternative would require significant increase in the management or technical capability of the PWS, and whether the alternative had the potential for regionalization.

2.3.3 New Surface Water Source

New surface water sources were investigated. Availability of adequate quality water was investigated for the main rivers in the area, as well as the major reservoirs. TCEQ WAMs were inspected, and the WAM was run, where appropriate.

2.3.4 Treatment

Treatment technologies considered potentially applicable to both nitrate and arsenic removal are RO, IX, and EDR since they are proven technologies with numerous successful installations. However, the system has TDS higher than 1,000 mg/L and thus, IX is not economically feasible. RO treatment is considered for central treatment alternatives. EDR treatment is considered for central treatment alternatives only. Both RO and EDR treatment produce a liquid waste: a reject stream from RO treatment and a concentrate stream from EDR treatment. As a result, the treated volume of water is less than the volume of raw water that enters the treatment system. The amount of raw water used increases to produce the same amount of treated water if RO or EDR treatment is implemented. If significant concentrations of arsenite are present, pre-oxidation may be required for EDR. The treatment units were sized based on flow rates, and capital and annual O&M cost estimates were made based on the size of the treatment equipment required. Neighboring non-compliant PWSs were identified to look for opportunities where the costs and benefits of central treatment could be shared between systems.

Non-economic factors were also identified. Ease of implementation was considered, as well as reliability for providing adequate quantities of compliant water. Additional factors were whether implementation of an alternative would require significant increase in the

management or technical capability of the PWS, and whether the alternative had the potential for regionalization.

2.4 COST OF SERVICE AND FUNDING ANALYSIS

The primary purpose of the cost of service and funding analysis is to determine the financial impact of implementing compliance alternatives, primarily by examining the required rate increases, and also the fraction of household income that water bills represent. The current financial situation is also reviewed to determine what rate increases are necessary for the PWS to achieve or maintain financial viability.

2.4.1 Financial Feasibility

A key financial metric is the comparison of an average annual household water bill for a PWS customer to the MHI for the area. MHI data from the 2000 census are used at the most detailed level available for the community. Typically, county level data are used for small rural water utilities due to small population sizes. Annual water bills are determined for existing base conditions, including consideration of additional rate increases needed under current conditions. Annual water bills are also calculated after adding incremental capital and operating costs for each of the alternatives to determine feasibility under several potential funding sources. It has been suggested by agencies such as USEPA that federal and state programs consider several criteria to determine “disadvantaged communities” with one based on the typical residential water bill as a percentage of MHI.

Additionally, the use of standard ratios provides insight into the financial condition of any business. Three ratios are particularly significant for water utilities:

- Current Ratio = current assets (items that could be converted to cash) divided by current liabilities (accounts payable, accrued expenses, and debt) provides insight into the ability to meet short-term payments. For a healthy utility, the value should be greater than 1.0.
- Debt to Net Worth Ratio = total debt (total amount of money borrowed) divided by net worth (total assets minus total liabilities) shows to what degree assets of the company have been funded through borrowing. A lower ratio indicates a healthier condition.
- Operating Ratio = total operating revenues divided by total operating expenses show the degree to which revenues cover ongoing expenses. The value is greater than 1.0 if the utility is covering its expenses.

2.4.2 Median Household Income

The 2000 U.S. Census is used as the basis for MHI. In addition to consideration of affordability, the annual MHI may also be an important factor for sources of funds for capital programs needed to resolve water quality issues. Many grant and loan programs are available to lower income rural areas, based on comparisons of local income to statewide incomes. In the 2000 Census, MHI for the State of Texas was \$39,927, compared to the U.S. level of

\$41,994. The census broke down MHIs geographically by block group and ZIP code. The MHIs can vary significantly for the same location, depending on the geographic subdivision chosen. The MHI for each PWS was estimated by selecting the most appropriate value based on block group or ZIP code based on results of the site interview and a comparison with the surrounding area.

2.4.3 Annual Average Water Bill

The annual average household water bill was calculated for existing conditions and for future conditions incorporating the alternative solutions. Average residential consumption is estimated and applied to the existing rate structure to estimate the annual water bill. The estimates are generated from a long-term financial planning model that details annual revenue, expenditure, and cash reserve requirements over a 30-year period.

2.4.4 Financial Plan Development

The financial planning model uses available data to establish base conditions under which the system operates. The model includes, as available:

- Accounts and consumption data
- Water tariff structure
- Beginning available cash balance
- Sources of receipts:
 - Customer billings
 - Membership fees
 - Capital Funding receipts from:
 - ❖ Grants
 - ❖ Proceeds from borrowing
- Operating expenditures:
 - Water purchases
 - Utilities
 - Administrative costs
 - Salaries
- Capital expenditures
- Debt service:
 - Existing principal and interest payments
 - Future principal and interest necessary to fund viable operations

- Net cash flow
- Restricted or desired cash balances:
 - o Working capital reserve (based on 1-4 months of operating expenses)
 - o Replacement reserves to provide funding for planned and unplanned repairs and replacements

From the model, changes in water rates are determined for existing conditions and for implementing the compliance alternatives.

2.4.5 Financial Plan Results

Results from the financial planning model are summarized in two areas: percentage of household income and total water rate increase necessary to implement the alternatives and maintain financial viability.

2.4.5.1 Funding Options

Results are summarized in a table that shows the following according to alternative and funding source:

- Percentage of the median annual household income the average annual residential water bill represents.
- The first year in which a water rate increase would be required
- The total increase in water rates required, compared to current rates

Water rates resulting from the incremental capital costs of the alternative solutions are examined under a number of funding options. The first alternative examined is always funding from existing reserves plus future rate increases. Several funding options were analyzed to frame a range of possible outcomes.

- Grant funds for 100 percent of required capital. In this case, the PWS is only responsible for the associated O&M costs.
- Grant funds for 75 percent of required capital, with the balance treated as if revenue bond funded.
- Grant funds for 50 percent of required capital, with the balance treated as if revenue bond funded.
- State revolving fund loan at the most favorable available rates and terms applicable to the communities.
- If local MHI > 75 percent of state MHI, standard terms, currently at 3.8 percent interest for non-rated entities. Additionally:
 - o If local MHI = 70-75 percent of state MHI, 1 percent interest rate on loan.
 - o If local MHI = 60-70 percent of state MHI, 0 percent interest rate on loan.

- o If local MHI = 50-60 percent of state MHI, 0 percent interest and 15 percent forgiveness of principal.
- o If local MHI less than 50 percent of state MHI, 0 percent interest and 35 percent forgiveness of principal.
- Terms of revenue bonds assumed to be 25-year term at 6.0 percent interest rate.

2.4.5.2 General Assumptions Embodied in Financial Plan Results

The basis used to project future financial performance for the financial plan model includes:

- No account growth (either positive or negative).
- No change in estimate of uncollectible revenues over time.
- Average consumption per account unchanged over time.
- No change in unaccounted for water as percentage of total (more efficient water use would lower total water requirements and costs).
- No inflation included in the analyses (although the model has provisions to add escalation of O&M costs, doing so would mix water rate impacts from inflation with the impacts from the alternatives being examined).
- Minimum working capital fund established for each district, based on specified months of O&M expenditures.
- O&M for alternatives begins 1 year after capital implementation.
- Balance of capital expenditures not funded from primary grant program is funded through debt (bond equivalent).
- Cash balance drives rate increases, unless provision chosen to override where current net cash flow is positive.

2.4.5.3 Interpretation of Financial Plan Results

Results from the financial plan model are presented in a Table 4.4 which shows the percentage of MHI represented by the annual water bill that results from any rate increases necessary to maintain financial viability over time. In some cases, this may require rate increases even without implementing a compliance alternative (the no action alternative). The table shows any increases such as these separately. The results table shows the total increase in rates necessary, including both the no-action alternative increase and any increase required for the alternative. For example, if the no action alternative requires a 10 percent increase in rates and the results table shows a rate increase of 25 percent, then the impact from the alternative is an increase in water rates of 15 percent. Likewise, the percentage of household income in the table reflects the total impact from all rate increases.

2.4.5.4 Potential Funding Sources

A number of potential funding sources exist for rural utilities, which typically provide service to less than 50,000 people. Both state and federal agencies offer grant and loan programs to assist rural communities in meeting their infrastructure needs. Most are available to “political subdivisions” such as counties, municipalities, school districts, special districts, or authorities of the state with some programs providing access to private individuals. Grant funds and lower interest rates are made more available with demonstration of economic stress, typically indicated with MHI below 80 percent that of the state. The funds may be used for planning, design, and construction of water supply construction projects including, but not limited to, line extensions, elevated storage, purchase of well fields, and purchase or lease of rights to produce groundwater. Interim financing of water projects and water quality enhancement projects such as wastewater collection and treatment projects are also eligible. Some funds are used to enable a rural water provider to obtain water or wastewater service supplied by a larger utility or to finance the consolidation or regionalization of neighboring utilities. Of the three Texas agencies that offer financial assistance for water infrastructure the TWDB is the primary agencies that offers financing for privately owned water systems.

TWDB has several programs that offer loans at interest rates lower than the market offers to finance projects for drinking water systems that facilitate compliance with primary drinking water regulations. Additional subsidies may be available for disadvantaged communities. Low interest rate loans with short and long-term finance options at tax exempt rates for water or water-related projects give an added benefit by making construction purchases qualify for a sales tax exemption. Generally, the program targets customers with eligible water supply projects for all political subdivisions of the state and Water Supply Corporations with projects, but Drinking Water State Revolving Fund (DWSRF) is available to privately owned systems.

Other programs with agencies such as Office of Rural Community Affairs (ORCA) and the U.S. Department of Agriculture Rural Development Texas (Texas Rural Development) coordinates federal assistance to rural Texas to help rural Americans improve their quality of life. Although, the programs with these agencies are for public systems special cases have been addressed where in need communities can receive funds by way of public entities (e.g., county). A public entity can apply for state funds and private water system be the recipient of the services (all agency criteria would still have to be met by the benefiting community).

The application process, eligibility requirements, and funding structure vary for each of these programs. There are many conditions that must be considered by each agency to determine eligibility and ranking of projects. The principal factors that affect this choice are population, percent of the population under the state MHI, health concerns, compliance with standards, Colonia status, and compatibility with regional and state plans.


SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS

3.1 REGIONAL ANALYSIS

3.1.1 Overview of the Study Area

The regional analysis described below includes data from 23 counties in the High Plains within Texas: Andrews, Bailey, Borden, Cochran, Crosby, Dawson, Ector, Floyd, Gaines, Garza, Glasscock, Hale, Hockley, Howard, Lamb, Lubbock, Lynn, Martin, Midland, Sterling, Terry, Winkler, and Yoakum (Figure 3.1).


Figure 3.1 Regional Study Area and Locations of the PWS Wells Assessed



The major and minor aquifers within the region are shown in Figure 3.2. Most of the PWS wells of concern are drilled within the Tertiary sediments of the Ogallala aquifer. Other aquifers in the region that may locally be hydraulically connected to the Ogallala aquifer include younger alluvial and fluvial deposits of Quaternary age (Blackwater Draw Formation, not shown) and underlying older aquifers, including the Cretaceous-age Edwards-Trinity (Plateau) aquifer, the Edwards-Trinity (High Plains) aquifer of Cretaceous age, the Dockum

1 aquifer of Triassic age, and undifferentiated Permian aquifers (not shown). Other aquifers in
2 the area, including the Capitan Reef, Lipan, Pecos Valley, Rustler, and Seymour aquifers, are
3 not located near any of the wells in this analysis.


Figure 3.2 Major (a) and Minor (b) Aquifers in the Study Area



"Subsurface" indicates a portion of an aquifer that underlies other formations. All other labels indicate a portion of an aquifer that lies at the land surface.

6 Water quality in the Ogallala aquifer is distinctively different in the northern portion of the
7 study area. Thus, this study analyzes the Ogallala aquifer in two parts: Ogallala-North (TDS $\leq$
8 500 mg/L) and Ogallala-South (TDS $>$ 500 mg/L) (Figure 3.3).

Figure 3.3 Water Quality Zones in the Study Area



Data used for this study include information from three sources:

- Texas Water Development Board groundwater database available at www.twdb.state.tx.us. The database includes information on the location and construction of wells throughout the state as well as historical measurements of water chemistry and levels in the wells.
- Texas Commission on Environmental Quality Public Water Supply database (not publicly available). The database includes information on the location, type, and construction of water sources used by PWS in Texas, along with historical measurements of water levels and chemistry.
- National Uranium Resource Evaluation (NURE) database available at: tin.er.usgs.gov/nure/water. The NURE dataset includes groundwater quality data collected between 1975 and 1980. The database provides well locations and depths with an array of analyzed chemical data. The NURE dataset covers only the eastern part of the study area.


3.1.2 Contaminants of Concern in the Study Area

Contaminants addressed include arsenic, fluoride, nitrate, selenium, and uranium. In PWSs in the area, water sampling shows that one or more of these solutes exceeds the USEPA's MCL.

Arsenic

Arsenic concentrations exceed the USEPA's MCL (10 µg/L) throughout the study area, especially in the Ogallala-South area (Figure 3.4). Half of the wells in the Ogallala-South aquifer and one-fifth of wells in the Edwards-Trinity (High Plains) aquifer contain arsenic levels above the MCL. In contrast, only 10 percent or less of wells in the Ogallala-North, Edwards-Trinity (Plateau), and Dockum aquifers exceed the MCL for arsenic.

Figure 3.4 Spatial Distribution of Arsenic Concentrations




Data presented here are from the TWDB database. The most recent sample for each well is shown. Table 3.1 gives the percentage of wells with arsenic exceeding the MCL (10 µg/L) in each of the major aquifers in the study area.

Table 3.1 Summary of Wells that Exceed the MCL for Arsenic, by Aquifer

Aquifer	Wells with measurements	Wells that exceed 10 µg/L	Percentage of wells that exceed 10 µg/L
Ogallala-North	228	15	7%
Ogallala-South	642	323	50%
Edwards-Trinity (Plateau)	127	13	10%
Edwards-Trinity (High Plains)	16	3	19%
Dockum	70	4	6%
Other	5	0	0%

There is a clear stratification of arsenic concentrations with depth in the study area (Figure 3.5), with arsenic concentrations decreasing with depth. This suggests that tapping deeper water by deepening shallow wells or casing off shallower parts of wells might decrease arsenic concentrations.


Figure 3.5 Arsenic Concentrations and Well Depths in the Ogallala Aquifer



Nitrate

Nitrate concentrations exceed the MCL (10 mg/L) throughout the study area, especially in the eastern part of the Ogallala-South aquifer (Figure 3.6). In the Ogallala-North, only one percent of wells have nitrate concentrations above the MCL.

Figure 3.6 Spatial Distribution of Nitrate Concentrations




Data presented here are from the TWDB database. The most recent measurement from each well is shown. Table 3.2 shows the percentage of wells with nitrate as N exceeding the MCL (10 mg/L).

Table 3.2 Summary of Wells that Exceed the MCL for Nitrate, by Aquifer

Aquifer	Wells with measurements	Wells that exceed 10 mg/L	Percentage of wells that exceed 10 mg/L
Ogallala-North	590	6	1%
Ogallala-South	2826	370	13%
Edwards-Trinity (Plateau)	642	39	6%
Edwards-Trinity (High Plains)	76	3	4%
Dockum	149	9	6%
Seymour	1	1	100%
other	40	5	13%

Within the study area, the concentration of nitrate as N tends to decrease with well depth (Figure 3.7). Nearly all wells in the Ogallala aquifer deeper than 250 feet have acceptable nitrate levels. Therefore, deepening shallow wells or casing the upper portions of problematic wells might decrease nitrate concentrations.


Figure 3.7 Nitrate as N Concentrations and Well Depths in the Ogallala Aquifer within the Study Area



Fluoride

Fluoride concentrations above the MCL (4 mg/L) are widespread in the Ogallala-South area (42% of wells) and relatively rare in the Ogallala-North area (2% of wells) (Figure 3.8, Table 3.3). Fluoride levels are also high in the Edwards-Trinity (High Plains) aquifer, with over half of wells in the aquifer containing fluoride in excess of the MCL.

Figure 3.8 Spatial Distribution of Fluoride Concentrations




Data presented here are from the TWDB database. The most recent measurement from each well is shown. Table 3.3 shows the percentage of wells with fluoride exceeding the MCL (4 mg/L).

Table 3.3 Summary of Wells that Exceed the MCL for Fluoride, by Aquifer

Aquifer	Wells with measurements	Wells that exceed 4 mg/L	Percentage of wells that exceed 4 mg/L
Ogallala-North	588	13	2%
Ogallala-South	2622	1098	42%
Edwards-Trinity (Plateau)	626	5	1%
Edwards-Trinity (High Plains)	76	40	53%
Dockum	144	10	7%
other	29	5	17%

Comparing fluoride levels with well depth, it is clear that the highest fluoride concentrations occur in wells shallower than about 100 feet and that concentrations tend to decrease with well depth (Figure 3.9). However, fluoride levels above the MCL are common in wells 100–200 feet deep. Based on this trend, deepening shallow wells or casing the shallower portions of wells could lead to decreased fluoride concentrations in produced groundwater.


Figure 3.9 Fluoride Concentrations and Well Depths in the Ogallala Aquifer within the Study Area



Selenium

Selenium concentrations in the study area are generally below the MCL (50 µg/L). However, some wells with excess selenium occur in the Dockum and Ogallala-South aquifers, particularly in the eastern part of the study area (Figure 3.10, Table 3.4).

Figure 3.10 Spatial Distribution of Selenium Concentrations




Data presented here are from the TWDB database. The most recent sample for each well is shown. Table 3.4 shows the percentage of wells with selenium concentrations exceeding the selenium MCL (50 µg/L).

Table 3.4 Summary of Wells that Exceed the MCL for Selenium, by Aquifer

Aquifer	Wells with measurements	Wells that exceed 50 µg/L	Percentage of wells that exceed 50 µg/L
Ogallala-North	233	0	0%
Ogallala-South	693	84	12%
Edwards-Trinity (Plateau)	104	1	1%
Edwards-Trinity (High Plains)	16	1	6%
Dockum	74	10	14%
Other	5	1	20%

Selenium shows a trend with well depth similar to that of the other constituents discussed (Figure 3.11). Most wells with selenium concentrations above the MCL are shallower than 200 feet. Thus, deepening a well to more than 200 feet or casing the shallower portion of deeper wells could lead to reduced selenium concentrations.


Figure 3.11 Selenium Concentrations and Well Depths in the Ogallala Aquifer within the Study Area



Uranium


The TWDB rarely tests wells for uranium content in water samples, but the NURE database provides a large dataset of uranium levels in the area. This database only includes wells from part of the study area, as shown in Figure 3.12. Even with this limited distribution of measurements, it is clear that uranium concentrations are much higher in the Ogallala-South aquifer than the Ogallala-North aquifer. However, the NURE database does not include information about which aquifer the sampled wells are from, so a quantitative comparison of uranium levels by aquifer is not available.

Figure 3.12 Spatial Distribution of Uranium Concentrations in the Study Area



A comparison of uranium concentrations and well depths shows that nearly all wells with uranium levels above the MCL are less than about 150 feet deep (Figure 3.13). Therefore, deepening or casing wells to access water from greater depths might reduce uranium levels.

Figure 3.13 Uranium Concentrations and Well Depths in the Study Area



3.1.3 Regional Geology

The major aquifer in the study area is the Ogallala aquifer, which is equivalent to the Ogallala Formation, the predominant geologic unit that makes up the High Plains aquifer. The Ogallala Formation is late Tertiary (Miocene–Pliocene, or about 2–12 million years ago) (Nativ 1988). It consists of coarse fluvial sandstone and conglomerates that were deposited in the paleovalleys of a mid-Tertiary erosional surface and eolian sand deposited in intervening upland areas (Gustavson and Holliday 1985). In the Ogallala-North area, the Ogallala Formation consists largely of sediments within a paleovalley. In this region, the saturated thickness of the aquifer is greater and the water table is deeper. In contrast, the formation is composed of deposition on top of a paleoupland in the Ogallala-South area. Here the formation is thinner, resulting in a smaller saturated thickness and shallower water table. The top of the Ogallala Formation is marked in many places by a resistant calcite layer known as the “caprock caliche.”

Within much of the study area, the Ogallala Formation is overlain by Quarternary-age (Pleistocene–Holocene) eolian, fluvial, and lacustrine sediments, collectively called the Blackwater Draw Formation (Holliday 1989). The texture of the formation ranges from sands and gravels along riverbeds to clay-rich sediments in playa floors.

In much of the southern High Plains, the Ogallala Formation lies on top of Lower Cretaceous (Comanchean) strata. The top of the Cretaceous sediments is marked by an uneven erosional surface that represents the end of the Laramide orogeny. Cretaceous strata are absent beneath the thick Ogallala paleovalley fill deposits because they were removed by prior

erosion. The Cretaceous sediments were deposited in a subsiding shelf environment and consist of the Trinity Group (including the basal sandy, permeable Antlers Formation); the Fredericksburg Group (limey to shaley formations, including the Walnut, Comanche Peak, and Edwards Formations, as well as the Kiamichi Formation); and the Washita Group (low-permeability, shaley sediments of Duck Creek Formation) (Nativ 1988). The sequence results in two main aquifer units: the Antlers Sandstone (also termed the Trinity or Paluxy sandstone, about 49 feet thick) and the Edwards Limestone (about 98 feet thick). These aquifer units constitute the Edwards-Trinity (High Plains) aquifer (Ashworth and Flores 1991). The limestone decreases in thickness to the northwest and transitions into the Kiamichi and Duck Creek formations.

The Ogallala Formation also overlies the Triassic Dockum Group in much of the southern High Plains. The Dockum Group is generally about 492 feet thick and is exposed along the margins of the High Plains. The uppermost sediments consist of red mudstones that generally form an aquitard. Underlying units (Trujillo Sandstone [Upper Dockum] and Santa Rosa Sandstone [lower Dockum]) form the Dockum aquifer. Water quality in the Dockum is generally poor (Dutton and Simpkins 1986). The sediments of the Dockum were deposited in a continental fluvio-lacustrine environment that included streams, deltas, lakes, and mud flats (McGowen et al. 1977) and included alternating arid and humid climatic conditions. The Triassic rocks reach up to 1,956 feet thick in the Midland Basin.

3.2 DETAILED ASSESSMENT FOR TWIN OAKS MOBILE HOME PARK PWS

The Twin Oaks Mobile Home Park PWS has two wells, G1650057A and G1650057B, that are 105 and 110 feet deep, respectively. Both wells are reported to be in the Ogallala aquifer. These wells share a single sample tap, so water analyses from this water supply system reflect the chemistry in both wells. Past measurements of nitrate and arsenic concentrations in the Twin Oaks Mobile Home Park PWS wells are listed in Table 3.5.

Table 3.5 Nitrate and Arsenic Concentrations from the Twin Oaks Mobile Home Park PWS

Date	Nitrate (mg/L)	Arsenic (µg/L)	Wells sampled
3/18/97	7.7	-	G1650057A-B
6/26/97	5.5	-	G1650057A-B
2/3/98	-	14.4	G1650057A-B
8/11/98	11.5	-	G1650057A-B
9/30/99	<0.01	-	G1650057A-B
11/1/99	12.2	-	G1650057A-B
3/9/00	12.0	-	G1650057A-B
5/4/00	12.1	-	G1650057A-B
7/26/00	12.8	-	G1650057A-B
11/16/00	12.6	-	G1650057A-B
4/18/01	11.2	-	G1650057A-B
4/18/01	11.2	15.9	G1650057A-B
9/25/01	11.7	-	G1650057A-B
12/4/01	11.2	-	G1650057A-B
2/20/02	10.7	-	G1650057A-B
6/24/02	-	-	G1650057A-B
8/29/02	12.1	-	G1650057A-B
11/25/02	10.8	-	G1650057A-B
7/24/03	12.4	-	G1650057A-B
11/6/03	-	-	G1650057A-B
12/8/03	12.1	-	G1650057A-B
12/8/03	16.5	-	raw sample, unknown well
2/11/04	11.7	17.1	G1650057A-B
5/4/04	11.9	-	G1650057A-B
9/22/04	12.5	-	G1650057A-B
11/30/04	12.6	-	G1650057A-B
2/28/05	12.9	10.9	G1650057A-B
5/17/05	13.3	12.7	G1650057A-B
7/18/05	13.2	14.4	G1650057A-B
12/29/05	-	13.8	G1650057A-B
1/17/06	14.5	14.4	G1650057A-B
4/19/06	13.2	-	G1650057A-B
7/26/06	13.3	-	G1650057A-B
10/17/06	13.5	11.9	G1650057A-B
12/29/06	11.2	-	G1650057A-B
2/7/07	12.9	11.0	G1650057A-B

Data from TCEQ PWS Database.

Of 32 historical nitrate measurements, taken between 1997 and 2007, 29 exceed the MCL (10 mg/L). Over this same period, all 10 arsenic measurements exceed the MCL (10 µg/L). The distributions of measured nitrate and arsenic levels in nearby wells are shown in Figures 3.14 and 3.15, respectively.

Figure 3.14 Nitrate Concentrations within 5- and 10-km Buffers around the Twin Oaks Mobile Home Park PWS Wells





Figure 3.15 Arsenic Concentrations within 5- and 10-km Buffers around the Twin Oaks Mobile Home Park PWS Wells



Data are from the TCEQ and TWDB databases. Two types of samples were included in the analysis. Samples from the TCEQ database (shown as squares on the map) represent the most recent sample taken at a PWS, which can be raw samples from a single well or entry point samples that may combine water from multiple sources. Samples from the TWDB database are taken from single wells (shown as circles in the map). Where more than one measurement has been made in a well, the most recent concentration is shown.

Several wells, located about 2-1/2 to 4 miles to the west of the Twin Oaks Mobile Home Park PWS wells, have shown acceptable levels of nitrate and a few have shown acceptable levels of arsenic (many have never been tested for arsenic). Additional information about these wells is listed in Table 3.6. Of these, the wells from the Westgate Manufactured Townhome Com PWS (G1650047A–J) were measured most recently and are the only wells tested for all constituents of concern. However, these wells produce water with elevated TDS. Well 4508301 is the only one listed as currently unused, but has not been tested since 1958.

Table 3.6 Most recent Concentrations of Select Constituents in Potential Alternative Water Sources

Well	Owner	Depth (ft)	Aquifer	Use	Date	Arsenic (µg/L)	Fluoride (mg/L)	Nitrate as N (mg/L)	Selenium (µg/L)	Uranium (µg/L)
G1650047A– G1650047J	Westgate Manufactured Townhome Com	80-110	Ogallala (8) Edwards- Trinity (Plateau) (2) Antlers Sand (1)		8/11/2004	0.007	1.7	4.37	0.009	23.73
4507602	Scharbauer Ranch Gary Van Winkle	89	Ogallala	domestic stock	7/13/2000	8.64	1.3	5.87	7.03	-
4508301	J Baker	129	Ogallala	unused	11/14/1958	-	3.5	2.891	-	-
4508310	Onita Boyd	100	Ogallala	domestic	6/21/1973	-	3.4	8.809	-	-
4516102	Wilson Bryant	95	Edwards- Trinity (Plateau)	stock	2/15/1967	-	3.1	3.614	-	-
4516302	Wilson Bryant	135	Edwards- Trinity (Plateau)	stock	2/15/1967	-	2.8	2.936	-	-
4508403	J.A. Baze	85	Ogallala	domestic	10/12/1990	<10	1.71	0.56	8	-
4508404	Ray Merworth	71	Ogallala	irrigation	7/19/1979	-	2	5.059	-	-
4508405	Melvin Jones	92	Ogallala	domestic	7/19/1979	-	1.3	1.558	-	-
4508406	Pete Haman	97	Ogallala	domestic	8/11/1975	-	2.2	4.969	-	-
4508407	Jerry Kandel	92	Ogallala	domestic	8/12/1975	-	1	3.162	-	-
4508408	Roscoe Lewis	97	Ogallala	industrial	8/12/1975	-	1.7	4.969	-	-
4508409	Don Dagenhart	90	Ogallala	domestic	8/12/1975	-	1	2.258	-	-
4508410	Don Murphree	97	Ogallala	domestic	8/12/1975	-	1	3.614	-	-

3.2.1 Summary of Alternative Groundwater Sources for the Twin Oaks Mobile Home Park PWS

Several nearby wells have been shown to contain nitrate levels below the MCL, but few of these have been tested for arsenic and all are located more than 2-1/2 miles from the Twin Oaks Mobile Home Park PWS wells. If any of these are considered for an alternative supply, they should be resampled and tested for all constituents of concern.

Alternatively, regional analyses show that most wells deeper than about 250 feet contain acceptable levels of all constituents of concern. In contrast, the current Twin Oaks Mobile Home Park PWS wells are 105 and 110 feet deep. If the solute levels above the MCLs are coming from localized contamination near the surface, deepening one or more of these wells and casing them near the surface might improve water quality.

SECTION 4 ANALYSIS OF THE TWIN OAKS MOBILE HOME PARK PWS

4.1 DESCRIPTION OF EXISTING SYSTEM

4.1.1 Existing System


The location of Twin Oaks MHP is shown in Figure 4.1. The Twin Oaks MHP is located in the southern portion of Midland, Texas at 5200 South County Road in Midland County. Twin Oaks MHP PWS is a community system providing potable water to the MHP and serves a population of 234 with 78 connections. The water sources for this community water system are two wells, completed in the Ogallala Aquifer, that are 105 feet and 108 feet deep. Well #1 (G1650057A) is rated at 40 gallons per minute (gpm) and Well #2 (G1650057B) is rated at 30 gpm.

The wells are located near the MHP just north and south of the ground storage tanks. The wells pump groundwater into the two ground storage tanks (0.046 million gallon capacity). Three service pumps feed the distribution system from the ground storage tanks, and eight pressure tanks float on the system. Chlorine for disinfection is injected up stream of the ground storage tanks.

The treatment employed for disinfection is not appropriate or effective for removal of nitrate and arsenic, so optimization is not expected to be effective for increasing removal of these contaminants. However, there is a potential opportunity for system optimization to reduce nitrate and arsenic concentrations. The system has more than one well, and since contaminant concentrations can vary significantly between wells, concentrations should be determined for each well. If one or more wells happens to produce water with acceptable contaminant levels, as much production as possible should be shifted to that well. It may also be possible to identify contaminant-producing strata through comparison of well logs or through sampling of water produced by various strata intercepted by the well screen.

During the period from February 1998 to February 2005, Twin Oaks MHP recorded arsenic concentrations that ranged from 0.0109 mg/L to 0.0171 mg/L. From March 1997 to May 2004, nitrate concentrations have ranged from 5.49 mg/L to 16.53 mg/L, with the majority of results exceeding 10 mg/L. These values are above the 0.01 mg/L MCL for arsenic and 10 mg/L MCL for nitrate. Therefore, Twin Oaks MHP PWS faces compliance issues under the water quality standards for arsenic and nitrate. Basic system information is as follows:

- Population served: 234
- Connections: 78
- Average daily flow: 0.0165 mgd
- Total production capacity: 0.101 mgd



Basic system raw water quality data are as follows

- Typical arsenic range: 0.0109 to 0.0171 mg/L
- Typical nitrate range: 5.49 to 16.5317 mg/L
- Typical calcium range: 211 to 225 mg/L
- Typical chloride range: 402 to 482 mg/L
- Typical fluoride range: 1.7 to 2.6 mg/L
- Typical iron range: <0.01 to 0.029 mg/L
- Typical magnesium range: 79 to 91 mg/L
- Typical manganese: <0.008 mg/L
- Typical selenium range: 0.032 to 0.0465 mg/L
- Typical sodium range: 190 to 202 mg/L
- Total hardness as CaCO₃ range: 852 to 925 mg/L
- Typical pH range: 7.1 to 7.4
- Total alkalinity as CaCO₃ range: 176 to 194 mg/L
- Typical bicarbonate range: 215 to 237 mg/L
- Typical total dissolved solids range: 1,480 to 1,844 mg/L

The typical ranges for water quality data listed above are based on a TCEQ database that contains data updated through the beginning of 2005.

4.1.2 Capacity Assessment for Twin Oaks Mobile Home Park PWS

The project team conducted a capacity assessment of the Twin Oaks Mobile Home Park water system on July 17, 2008. Results of this evaluation are separated into four categories: general assessment of capacity, positive aspects of capacity, capacity deficiencies, and capacity concerns. The general assessment of capacity describes the overall impression of FMT capability of the water system. The positive aspects of capacity describe the strengths of the system. These factors can provide the building blocks for the system to improve capacity deficiencies. The capacity deficiencies noted are those aspects creating a particular problem for the system related to long-term sustainability. Primarily, those problems are related to the system's ability to meet current or future compliance, ensure proper revenue to pay the expenses of running the system, and ensure proper operation of the system. The last category, capacity concerns, consists of items not causing significant problems for the system at this time. However, the system may want to address them before they become problematic.

Because of the challenges facing very small water systems, it is increasingly important for them to develop the internal capacity to comply with all state and federal requirements for public drinking water systems. For example, it is especially important for very small water

systems to develop long-term plans, set aside money in reserve accounts, and track system expenses and revenues because they cannot rely on increased growth and economies of scale to offset their costs. In addition, it is crucial for the owner, manager, and operator of a very small water system to understand the regulations and participate in appropriate training. Providing safe drinking water is the responsibility of every public water system, including those very small water systems that face increased challenges with compliance.

The project team interviewed Shawanna Self-Aaron, certified operator and manager, and Paul Self, assistant manager.

4.1.2.1 General Structure of the Water System

The Twin Oaks Mobile Home Park is owned by George and Laura Thomas of Las Cruces, New Mexico. Ms. Self-Aaron is the system manger and operator and holds a Level D Certification. Her father, Paul Self is the onsite manager at the MHP. The water system has a total of 78 metered connections and serves a population of 234. In addition to water, the MHP also provides septic and trash services. The owners in Las Cruces handle all billing and collections. The monthly water rates are \$7.50 for 3,000 gallons and \$1.25 for each additional 1,000 gallons. The water system exceeds the standards for nitrate and arsenic and is under a Compliance Agreement with TCEQ for both contaminants. Bottled water is provided to anyone that requests it. .

4.1.2.2 General Assessment of Capacity

Based on the team's assessment, this system has a marginal level of capacity. Although there is a positive aspect of capacity, there are some areas that need improvement, such as the FMT aspects of the water system.

4.1.2.3 Positive Aspects of Capacity

In assessing a system's overall capacity, it is important to look at all aspects – positive and negative. It is important for systems to understand those characteristics that are working well, so those activities can be continued or strengthened. In addition, these positive aspects can assist the system in addressing the capacity deficiencies or concerns. The factors particularly important for Twin Oaks MHP are listed below.

- **Dedicated Operator and On-Site Manager** – The licensed operator and her father appear to jointly operate the water system. Mr. Self lives at the MHP and has worked for owners for the past 10 years. In addition, he is on is on call 24 hours a day.

4.1.2.4 Capacity Deficiencies

The following capacity deficiencies were noted in conducting the assessment and seriously impact the ability of the water system to comply with current and future regulations and to ensure long-term sustainability.

- **Lack of Long Term Capital Planning for Compliance and Sustainability** – There appears to be no long term plan in place to achieve and maintain compliance and ensure long-term sustainability of the water system. System needs appear to be assessed as needed, rather than on a multi-year basis. Although the system has been aware of the nitrate and arsenic compliance problem, the owners have not developed a long-term plan for achieving compliance at some point into the future. Without some type of planning process, the owners are not able to plan for the revenue needed to make system improvements or add treatment processes. The system can also use the long-term planning process to help identify funding options.
- **Lack of Compliance with Nitrate and Arsenic Standards** – The water system is not in compliance with the nitrate and arsenic standards and is under a Compliance Agreement with TCEQ for both contaminants.

4.1.2.5 Potential Capacity Concerns

The following items were concerns regarding capacity but no specific operational, managerial, or financial problems can be attributed to these items at this time. The system should address the items listed below to further improve FMT capabilities to improve the system's long-term sustainability.

- **Lack of Knowledge of SDWA Regulations** – The owners indicated they are not familiar with the SDWA regulations, and that they rely on the operator to operate the system in compliance with TCEQ regulations. Although the contract operator is certified and trained, it is still a good practice for the system owners to be familiar with the SDWA requirements that apply to their system, because the owners are ultimately responsible for regulatory compliance.
- **Operator Not Involved in Budget Preparation or Tracking** – The operator stated she is not involved in the finances of the water system or the MHP. She keeps a supply of spare parts and generally is able to cover expenses for the water system by using a credit card or by sending invoices to the owners. She contacts the owners for approval for any major expenses. While it appears that all expenses have been covered, the operator could provide the owners with important information on revenues needed for repairs and replacement, as well as treatment needed to comply with regulations.

4.2 ALTERNATIVE WATER SOURCE DEVELOPMENT

4.2.1 Identification of Alternative Existing Public Water Supply Sources

Using data drawn from the TCEQ drinking water and TWDB groundwater well databases, the PWSs surrounding the Twin Oaks MHP PWS were reviewed with regard to their reported drinking water quality and production capacity. PWSs that appeared to have water supplies with water quality issues were ruled out from evaluation as alternative sources, while those without identified water quality issues were investigated further. Small systems were only considered if they were within 15 miles of the Twin Oaks MHP PWS. Large systems or systems capable of producing greater than four times the daily volume produced by the study

system were considered if they were within 30 miles of the study system. A distance of 30 miles was considered to be the upper limit of economic feasibility for constructing a new water line. Table 4.1 is a list of the selected PWSs based on these criteria for large and small PWSs within 30 miles of the Twin Oaks MHP. If it was determined these PWSs had excess supply capacity and might be willing to sell the excess, or might be a suitable location for a new groundwater well, the system was taken forward for further consideration and identified with “EVALUATE FURTHER” in the comments column of Table 4.1.

Table 4.1 Selected Public Water Systems within 32 Miles of the Twin Oaks MHP PWS

PWS ID	PWS Name	Distance from Twin Oaks MHP (miles)	Comments/Other Issues
1650084	WARREN ROAD DEVELOPMENT	0.87	Larger GW system. WQ issues: arsenic, nitrate and sulfate
1650043	JOHNS MOBILE HOME PARK	1.88	Smaller GW system. WQ issues: arsenic, nitrate and sulfate
1650077	SOUTH MIDLAND COUNTY WATER SYSTEM	2.06	Larger GW system. WQ issues: arsenic, nitrate and sulfate
1650111	COUNTRY VILLAGE MOBILE HOME ESTATE	2.89	Larger GW system. WQ issues: arsenic, nitrate and sulfate
1650047	WESTGATE MOBILE HOME PARK	3.36	Larger GW system. WQ issue: High TDS
1650001	CITY OF MIDLAND	4.0	Larger SW/GW system. No WQ issue. Evaluate Further
1650003	AIRLINE MOBILE HOME PARK LTD	5.57	Larger GW system. WQ issues: arsenic, gross alpha, and sulfate
1650007	VALLEY VIEW MOBILE HOME PARK	5.6	Larger GW system. WQ issues: arsenic, combined uranium, gross alpha, nitrate, sulfate and selenium
1650066	SPRING MEADOW MOBILE HOME PARK	5.61	Larger GW system. WQ issues: arsenic, nitrate and sulfate
1650086	KENT KWIK CONVENIENCE STORE 312	5.87	Larger GW system. WQ issue: nitrate
1650002	MIDLAND INTERNATIONAL AIRPORT	8.1	Larger GW system. No WQ issues. Evaluate Further
1650022	SHERWOOD MOBILE HOME ESTATES	8.37	Larger GW system. WQ issues: arsenic, nitrate, selenium and sulfate
1650048	GREENWOOD TERRACE M H SUBDIV	8.73	Larger GW system. WQ issues: arsenic, nitrate and sulfate
1650029	MIDESSA OILPATCH RV PARK	9.08	Larger GW system. WQ issue: nitrate
1650024	PECAN GROVE MOBILE HOME PARK	9.15	Larger GW system. WQ issues: arsenic, nitrate and sulfate
1650113	WATER RUNNERS INC	10.19	Smaller GW system. Use treatment to overcome WQ issues
1650070	PECAN ACRES HOMEOWNERS ASSN	10.27	Larger GW system. WQ issues: arsenic, gross alpha and sulfate
1650114	BLUE NILE WATER CO	10.37	Smaller GW system. WQ issues: arsenic, nitrate and sulfate
0680072	ODESSA COUNTRY CLUB	12.54	Larger GW system. WQ issues: nitrate and sulfate

PWS ID	PWS Name	Distance from Twin Oaks MHP (miles)	Comments/Other Issues
1650112	RANGER STATION CAFE	12.61	Smaller GW system. WQ issues: arsenic, fluoride, selenium, nitrate and sulfate
1650035	GREENWOOD ISD	12.79	Larger GW system. WQ issues: arsenic, fluoride, nitrate, selenium and sulfate
1650006	GREENWOOD VENTURES INC	12.82	Small GW system. WQ issues: arsenic, combined uranium, fluoride, gross alpha, nitrate, sulfate and selenium
1650078	GREENWOOD WATER SYSTEM	13.05	Larger GW system. WQ issues: arsenic and fluoride
1650096	KENT KWIK CONV STORE 315	14.32	Small GW system. WQ issues: No WQ issues
0680002	CITY OF ODESSA	14.6	Larger SW/GW system. No WQ issue. Evaluate Further
0680202	CENTRIFLO PUMP & MACHINE CO	16	Smaller GW system. WQ issues: arsenic, nitrate and sulfate
0680051	CANYON DAM MOBILE HOME PARK	17.85	Larger GW system. WQ issues: No WQ issues.
0680013	NORTHGATE MOBILE HOME PARK 1	17.9	Larger GW system. WQ issues: gross alpha, nitrate and sulfate
1650026	DEFS-SPRAYBERRY PLT	17.9	Larger non resid. GW system. Use treatment to overcome WQ issues
0680069	DE VILLA MOBILE HOME PARK	18.04	Larger GW system. WQ issues: gross alpha, nitrate and sulfate
0680005	ORCHARD WATER SUPPLY	18.42	Larger GW system. WQ issues: arsenic and fluoride
0680195	GARDENDALE COUNTRY WATER INC	19.13	Small GW system. WQ issue: nitrate
0680198	DEPOT WATER STORE	19.13	Smaller GW system. WQ issue: sulfate
0680155	SUNSET COUNTRY CLUB	19.29	Small GW system. WQ issues: arsenic (M)
0680163	HUBER GARDENS ESTATES	19.38	Larger GW system. WQ issues: arsenic, nitrate and sulfate
0680126	WILLIAMS TRAILER COURT	20	Larger GW system. WQ issues: arsenic, combined uranium, gross alpha, nitrate and sulfate
0680057	RICHEYS MOBILE HOME PARK	20.03	Larger GW system. WQ issues: gross alpha, nitrate and sulfate

WQ = water quality

GW = groundwater

After the PWSs in Table 4.1 with water quality problems were eliminated from further consideration, the remaining PWSs were screened by proximity to Twin Oaks MHP PWS and sufficient total production capacity for selling or sharing water. Based on the initial screening summarized in Table 4.1, three alternatives were selected for further evaluation. These alternatives are summarized in Table 4.2. The alternatives are connections to the Cities of Odessa and Midland, and Midland International Airport systems. Descriptions of the potential water provider systems follow Table 4.2.

**Table 4.2 Public Water Systems within the Vicinity of the
Twin Oaks MHP PWS Selected for Further Evaluation**

PWS ID	PWS Name	Pop	Connections	Total Production (mgd)	Avg Daily Usage (mgd)	Approx. Dist. from Twin Oaks MHP	Comments/Other Issues
1650001	CITY OF MIDLAND	100387	38677	98.584	21.2	4	Larger GW/SW system. No WQ issues
1650002	MIDLAND INTERNATIONAL AIRPORT	1000	166	1.529	0.281	8	Larger GW system. No WQ issues
0680002	CITY OF ODESSA	100719	43244	80.8	16.42	14.6	Larger GW/SW system. WQ issues: sulfate

WQ = water quality

GW = groundwater

SW - surface water

4.2.1.1 Colorado River Municipal Water District

The Colorado River Municipal Water District (CRMWD) supplies raw water to the Cities of Midland and Odessa and, while it would not supply water directly to the Twin Oaks PWS, a brief description is included here because of its role in supplying water to these two cities. The CRMWD was authorized in 1949 by the 51st Legislature of the State of Texas for the purpose of providing water to the District's Member cities of Odessa, Big Spring, and Snyder. The CRMWD also has contracts to provide specified quantities of water to the Cities of Midland, San Angelo, Stanton, Robert Lee, Grandfalls, Pyote, and Abilene (through the West Central Texas Municipal Water District).

The CRMWD owns and operates three major surface water supplies on the Colorado River in west Texas. These are Lake J.B. Thomas, the E.V. Spence Reservoir, and the O.H. Ivie Reservoir. Together, the combined capacity of these reservoirs is 1.272 million acre-feet. Additionally, CRMWD operates five well fields for water supply. Three of those fields were developed by the Member Cities prior to 1949. The fourth field, located in Martin County, began delivering water in 1952. The fifth field, located in Ward County southwest of Monahans, can supply up to 28 million gallons per day (mgd). CRMWD primarily uses these well fields to supplement surface water deliveries during the summer months.

4.2.1.2 City of Midland

The center of the City of Midland is located approximately 4 miles north of Twin Oaks MHP. The City of Midland purchases approximately 75 to 80 percent of its water from the CRMWD through a 1966 contract agreement. This purchased water comprises mainly untreated surface water from several reservoirs, including Lake J.B. Thomas, Lake E.V. Spence, and Lake O.H. Ivie, although the CRMWD may also supplement the supply with groundwater during the high demand summer months. The City of Midland gets the other 20 to 25 percent of its water from various City-owned well fields, which contain lower quality

1 water. Midland is classified as a customer city of the CRMWD and is allowed to use alternate
2 water supplies, unlike Odessa whose water can only be provided by CRMWD.

3 As part of Midland's primary water sources, raw water from the CRMWD is delivered to
4 one of three reservoirs. Two of the three reservoirs are owned by CRMWD and include a
5 15 million gallon reservoir located at the water treatment plant and the 100 million gallon
6 Terminal Reservoir located on FM 1788, approximately 2 miles south of Highway 191. The
7 Terminal Reservoir is shared by both Midland and Odessa. The third reservoir, Lake Peggy
8 Sue, is owned by Midland and is located approximately 2 miles west of the City's water
9 treatment plant. In addition to the surface water provided by the CRMWD, Midland owns
10 16.54 percent of Lake Ivie, located approximately 170 miles southwest of Midland. Each day,
11 15 million gallons from Lake Ivie and 16 million gallons from CRMWD reservoirs are
12 delivered via pipeline from Ballinger to San Angelo, and then to one of the three reservoirs
13 around Midland.

14 In addition to CRMWD surface water, the city owns or leases water rights in two well
15 fields. The Paul Davis well field, located 30 miles north of Midland, was developed in the late
16 1950s and is used during peak periods to offset the demand exceeding the 31 mgd provided by
17 the CRMWD reservoirs. The well field can sustain a pumping rate of 18 to 19 mgd, but
18 normally averages 10 mgd annually. The well field uses 29 wells that pump water to two
19 2.5 million gallon aboveground storage tanks. These wells are installed between 150 and
20 200 feet deep in the Ogallala aquifer (Code 121OGLL). Since arsenic, fluoride, perchlorate,
21 and radionuclides were reported in samples from the well field, the City of Midland carefully
22 monitors the blending of surface water with groundwater to avoid exceeding the MCLs for
23 these four constituents. The second well field is the T-Bar Ranch, which is located in western
24 Winkler County approximately 70 miles west of Midland. This well field is still being
25 developed and will be brought online as the Paul Davis well field is depleted.

26 The City of Midland operates two water treatment plants to treat the surface water and
27 provide water to a service population of approximately 100,000. The city has a total of
28 approximately 35,000 connections, about 32,000 of which are metered. The major users of
29 water in Midland include the college, parks, and schools, which use the water for irrigation.
30 The current monthly rates per connection are a \$12 base charge for the first 2,000 gallons and
31 \$2.75 for each additional 1,000 gallons.

32 In the fall of 2003, the Midland City Council decided that water can only be provided to
33 areas annexed by the City of Midland. Consequently, while the City of Midland does have
34 sufficient excess drinking water capacity, any location to receive water from the city would
35 have to agree to be annexed. To be annexed, a commission representing the town to be
36 annexed must submit a petition signed by at least 50 percent of the community residents
37 wanting to be annexed. The commission representing the community then appoints a Public
38 Improvement District to build a water line from a Midland supply line to the community. In
39 the past, Midland has financed the Public Improvement District through the sale of bonds. The
40 community would be subject to the same rates as other residences in Midland.

The City of Midland appreciates the issues faced by poor communities south of the Interstate Highway 20, as many were left abandoned by the original owner as water quality became bad. However, the City of Midland does not have infrastructure in the area to provide service to this area, and crossing under Interstate Highway 20 with a pipeline would be expensive. If funds can be made available to assist the City of Midland to expand its infrastructure to this area, the city would be interested in providing services to the communities in need. However, these communities would need to be annexed or at least be limited to small communities on small tracts of land such as mobile home parks. The City of Midland does have excess water and, with financial assistance for projects in poor areas outside the city, Midland may be an alternative water source for small communities.

4.2.1.3 Midland International Airport

Midland International Airport is located approximately 8 miles west of Twin Oaks MHP. The Midland International Airport is supplied by 10 groundwater wells that are completed in the Antler Sands aquifer (Code 218ALRS), range in depth from 85 to 130 feet, and are rated from 61 to 203 gpm. These wells are maintained and operated by the City of Midland Utility Department. Water from the wells is chlorinated and piped to an elevated 500,000-gallon storage tank before entering the airport's distribution system. The system is capable of producing up to 1.5 mgd, and average daily consumption is approximately 0.5 mgd.

Currently the operators of the PWS do not consider there to be sufficient excess capacity to provide water to offsite facilities or areas. However, the Twin Oaks MHP PWS is relatively small, and it appears the Midland International Airport has sufficient excess capacity.

4.2.1.4 City of Odessa

The connection point for the City of Odessa is located approximately 15 miles west of Twin Oaks MHP. The City of Odessa is one of three original members of CRMWD and, by contract, may only obtain its water supply through them. Being an original member allows them first access to available water to meet its needs. This access assures it has as much water as needed based on existing supply. The water supplied to the City of Odessa originates in a network of three reservoirs (Lake Ivie, Lake Spence, and Lake Thomas), but this water may be supplemented with groundwater during the high-demand summer months. The untreated water from the reservoirs is pumped from Ballinger, Texas to San Angelo, Texas, via a 60-inch pipeline and then through a 53-inch pipeline from San Angelo to Odessa.

Raw water is delivered to a treatment facility, where it is filtered and chlorinated, and then stored in a 4.3 million gallon concrete ground storage tank prior to distribution to the City of Odessa. In addition to the water delivered via CRMWD pipeline, a relatively small amount of water (less than 10%) is also delivered by a second pipeline from the Ward County Well Field located approximately 60 miles west of Odessa. This water is pH-adjusted and chlorinated prior to being pumped to the 4.3 million gallon storage tank. Typically this well field is used for emergencies to supplement supply under extreme need. In 2007, no well was used.

Average usage by the City of Odessa ranges from 12 to 15 mgd in the winter to 35 to 36 mgd in the summer. The City of Odessa provides water to a population of approximately 108,000 and approximately 42,000 connections. The current customer rate is \$2.50 per 1,000 gallons.

The City of Odessa does have excess capacity of treated water and may be willing to sell water to other PWSs. A community wanting to purchase treated water from the City of Odessa must submit a formal request to the City for review by the five-member city council. The community does not have to be annexed to receive treated water via pipeline, but it would have to fund the cost of the connecting pipeline. Although, no one has approached them, it is likely that City Council would be open to a discussion about providing water. Consideration would have to be on who is providing services, operation, and ownership. Past wholesale prices were typically around \$3 per thousand gallons. Odessa would consult with the CRMWD if the customers would need a substantial quantity of water.

4.2.2 Potential for New Groundwater Sources

4.2.2.1 Installing New Compliant Wells

Developing new wells or well fields is recommended, provided good quality groundwater available in sufficient quantity can be identified. Since a number of water systems in the area have water quality problems, it should be possible to share in the cost and effort of identifying compliant groundwater and constructing well fields.

Installation of a new well in the vicinity of the system intake point is likely to be an attractive option provided compliant groundwater can be found, since the PWS is already familiar with operation of a water well. As a result, existing nearby wells with good water quality should be investigated. Re-sampling and test pumping would be required to verify and determine the quality and quantity of water at those wells.

The use of existing wells should probably be limited to use as indicators of groundwater quality and availability. If a new groundwater source is to be developed, it is recommended that a new well or wells be installed instead of using existing wells. This would ensure well characteristics are known and meet standards for drinking water wells.

Some of the alternatives suggest new wells be drilled in areas where existing wells have acceptable water quality. In developing the cost estimates, Parsons assumed the aquifer in these areas would produce the required amount of water with only one well. Site investigations and geological research, which are beyond the scope of this study, could indicate whether the aquifer at a particular site and depth would provide the amount of water needed or if more than one well would need to be drilled in separate areas.

4.2.2.2 Results of Groundwater Availability Modeling

In northern Midland County, where the PWS is located, two aquifers are potential groundwater sources for public supplies: the Ogallala aquifer, and the subsurface section of the

1 Edwards-Trinity Plateau aquifer. The Ogallala provides drinking water to most of the
2 communities in the Texas panhandle, as well as irrigation water. The Edwards-Trinity Plateau
3 is also a major aquifer extending across the southwestern part of the state. More than two-
4 thirds of pumped groundwater is used for irrigation.

5 Two wells operated by the PWS are completed in the southern Ogallala Aquifer, at depths
6 of 105 and 110 feet. A search of registered wells was conducted using TCEQ's Public Water
7 Supply database to assess groundwater sources utilized within a 10-mile radius of the PWS.
8 The search indicated that domestic and public supply wells located within a 10 miles from the
9 PWS also withdraw groundwater from the Ogallala; this aquifer is also extensively used in the
10 PWS vicinity as a source of irrigation water. Within the same database search area, there are
11 numerous active wells that obtain groundwater from the Edwards-Trinity Plateau Aquifer for
12 stock watering and, to a lesser extent, domestic and industrial use.

13 **Groundwater Supply**

14 The Ogallala is the largest aquifer in the United States. The aquifer outcrop underlies
15 eastern New Mexico and much of the Texas High Plains region, extending eastward over the
16 entire Midland County. The Ogallala provides significantly more water for users than any
17 other aquifer in the state, and is used primarily for irrigation. The aquifer saturated thickness
18 ranges up to an approximate depth of 600 feet. Supply wells have an average yield of
19 approximately 500 gal/min, but higher yields, up to 2,000 gal/min, are found in previously
20 eroded drainage channels filled with coarse-grained sediments (TWDB 2007).

21 Water level declines in excess of 300 feet have occurred in several aquifer areas over the
22 last decades. Over a 50-year planning period, the 2007 Texas Water Plan anticipates a water
23 supply depletion of more than 40 percent, from 5,968,260 AFY projected for the year 2010, to
24 3,534,124 AFY by the year 2060. Nearly 95 percent of the groundwater pumped from the
25 Ogallala Aquifer is used for irrigated agriculture.

26 Throughout northern Midland County, where the PWS is located, the subsurface section of
27 the Edwards-Trinity Plateau Aquifer underlays the Ogallala aquifer. Wells in this region are
28 supplied by both the Antlers Sands formation of the Trinity Group, and the Edwards and
29 Comanche Peak formations of Fredericksburg Group.

30 **Groundwater Availability**

31 Regional groundwater withdrawal in the Texas High Plains region is extensive and likely
32 to remain near current levels over the next decades. The 2007 State Water Plan indicates that
33 in Midland County, without implementation of additional water management strategies, the
34 increasing water demand will exceed projected water supply estimates. For the 50-year
35 planning period ending in 2060, the additional water need will be 38,599 AFY by the year
36 2060. Over fifty percent of this deficit, 22,606 AFY, results from a rapidly increasing demand
37 for municipal supplies. Irrigation water needs are expected to remain near current levels over
38 the 50-year planning period.

A GAM for the Ogallala aquifer was developed by the TWDB (Blandford et al., 2003). Modeling was performed to simulate historical conditions and to develop long-term groundwater projections. Predictive simulations using the GAM model indicated that, if estimated future withdrawals are realized, aquifer water levels could decline to a point at which significant regions currently practicing irrigated agriculture could be essentially dewatered by 2050 (Blandford et al., 2003). The 2007 State Water Plan, however, indicates that the rate of decline has slowed relative to previous decades, and water levels have risen in a few areas.

The GAM model predicted the most critical conditions for Cochran, Hockley, Lubbock, Yoakum, Terry, and Gaines Counties where the simulated drawdown could exceed 100 feet. For northern Midland County, the simulated drawdown by the year 2050 would be more moderate, within the 0 to 25 feet range (Blandford et al., 2003). The Ogallala Aquifer GAM was not run for the PWS. Water use by the system would represent a minor addition to regional withdrawal conditions, making potential changes in aquifer levels beyond the spatial resolution of the regional GAM model.

Wells completed in the Edwards-Trinity Plateau Aquifer in this region are supplied by both the Antlers Sands formation of the Trinity Group, and the Edwards and Comanche Peak formations of the Fredericksburg Group. A GAM for the Edwards-Trinity Plateau Aquifer was prepared by Anaya and Jones (2004) for the TWDB. GAM data for the aquifer indicate that total withdrawal in Midland County had a steady decline in recent years, from a peak annual use of 21,127 acre-feet in 1995 to 13,484 acre-feet in 2000. This reduced water withdrawal from the Edwards-Trinity Plateau aquifer is expected to remain nearly constant over a 50-year simulation period ending in the year 2050 (Anaya and Jones 2004).

4.2.3 Potential for New Surface Water Sources

There is a minimum potential for development of new surface water sources for the PWS system because water availability is very limited over the entire river basin, at the county level, and within the site vicinity.

The PWS is located in the upper reach of the Colorado Basin, within a relatively arid region of Texas that has a low surface water yield. The State Water Plan, updated in 2007 by the TWDB, estimates that the average yield over the entire basin is 1.2 inches per year. Surface water rights are assigned primarily to municipal use and irrigation (66% and 25%, respectively). Over a 50-year planning period, the plan anticipates that availability will steadily decrease as a result of an increasing water demand. A projected 2010 surface water supply value of 1,110,000 acre-feet per year (AFY) for the Colorado Basin is expected to decrease over 10 percent by the year 2060. This decrease takes into account the implementation of various long-term water management strategies proposed in the State Water Plan.

In Midland County, where the PWS is located, irrigation accounts for 74 percent of the current water use, with the remainder allocated for municipal use. The 2007 State Water Plan indicates that, without implementation of additional water management strategies, the increasing water demand in the county will exceed projected water supply estimates. For the

50-year planning period ending in 2060, the additional water need will be 38,599 AFY by the year 2060. Over fifty percent of this deficit, 22,606 AFY, would a rapidly increasing demand for municipal supplies. Irrigation water needs are expected to remain near current levels over the 50-year planning period.

The TWDB developed a surface water availability model for the Colorado Basin as a tool to determine, at a regional level, the maximum amount of water available during the drought of record over the simulation period, regardless of whether the supply is physically or legally available. For the PWS vicinity, simulation data indicate that there is a minimum availability of surface water for new uses. Surface water availability maps were developed by TCEQ for the Colorado Basin, illustrating percent of months of flow per year. Availability maps indicate that within a 20-mile radius of the PWS, and over all of Midland County, unappropriated flows for new applications are typically available 25 to 50 percent of the time. This availability is inadequate for development of new municipal water supplies as a 100 percent year-round availability is required by TCEQ for new surface water source permit applications.

4.2.4 Options for Detailed Consideration

The initial review of alternative sources of water results in the following options for more-detailed consideration:

1. City of Midland. Treated water would be purchased from the City of Midland to be used by the Twin Oaks MHP. A pipeline would be constructed to convey water from the City of Midland to Twin Oaks MHP (Alternative TO-1).
2. Midland International Airport. Treated water would be purchased from the Midland International Airport, and a pipeline would be constructed to convey water from to Twin Oaks MHP (Alternative TO-2).
3. City of Odessa. Treated water would be purchased from the City of Odessa to be used by Twin Oaks MHP PWS. A pipeline would be constructed to convey water from the City of Odessa to Twin Oaks MHP PWS (Alternative TO-3).
4. New Wells at 10, 5, and 1 mile. Installing a new well within 10, 5, or 1 mile of the Twin Oaks MHP PWS may produce compliant water in place of the water produced by the existing active well. A pipeline and pump station would be constructed to transfer the water to the Twin Oaks MHP PWS (Alternatives TO-4, TO-5, and TO-6).

4.3 TREATMENT OPTIONS

4.3.1 Centralized Treatment Systems

Centralized treatment of the well water is identified as a potential option. Reverse osmosis, EDR, and IX could be potentially applicable. The central RO treatment alternative is

Alternative TO-7, the central EDR treatment alternative is Alternative TO-8, and the central IX alternative is TO-9.

4.3.2 Point-of-Use Systems

POU treatment using RO technology is valid for arsenic and nitrate removal. The POU treatment alternative is TO-10.

4.3.3 Point-of-Entry Systems

POE treatment using RO technology is valid for arsenic and nitrate removal. The POE treatment alternative is TO-11.

4.4 BOTTLED WATER

Providing bottled water is considered an interim measure to be used until a compliance alternative is implemented. Even though the community is small and people know each other; it would be reasonable to require a quarterly communication advising customers of the need to take advantage of the bottled water program. An alternative to providing delivered bottled water is to provide a central, publicly accessible dispenser for treated drinking water. Alternatives addressing bottled water are TO-12, TO-13, and TO-14.

4.5 ALTERNATIVE DEVELOPMENT AND ANALYSIS

A number of potential alternatives for compliance with the MCL for arsenic and nitrate have been identified. Each of the potential alternatives is described in the following subsections. It should be noted that the cost information given is the capital cost and change in O&M costs associated with implementing the particular alternative. Appendix C contains cost estimates for the compliance alternatives. These compliance alternatives represent a range of possibilities, and a number of them are likely not feasible. However, all have been presented to provide a complete picture of the range of alternatives considered. It is anticipated that a PWS will be able to use the information contained herein to select the most attractive alternative(s) for more detailed evaluation and possible subsequent implementation.

4.5.1 Alternative TO-1: Purchase Treated Water from the City of Midland

This alternative involves purchasing treated water from the City of Midland, which will be used to supply the Twin Oaks MHP PWS. The City of Midland currently has sufficient excess capacity for this alternative to be feasible. It is assumed that Twin Oaks MHP would obtain all its water from the City of Midland.

This alternative would require constructing a pipeline from a City of Midland water main to the existing storage tank for the Twin Oaks MHP system. A pump station and 5,000 gallon feed tank would also be required to overcome pipe friction and the elevation differences between Midland and Twin Oaks MHP. The required pipeline would be 4-inches in diameter and would follow Highway 349 south from the connection to the waterline at Interstate

1 Highway 20, then west on County Road (CR) 130, and south on CR 1200 to the Twin Oaks
2 MHP. Using this route, the length of pipe required would be approximately 4 miles.

3 The pump station would include two pumps, including one standby, and would be housed
4 in a building. A 5,000 gallon feed tank would also be constructed for the pumps to draw from.
5 It is assumed the pumps and piping would be installed with capacity to meet all water demand
6 for the Twin Oaks MHP, since the incremental cost would be relatively small, and would
7 provide operational flexibility.

8 By definition this alternative involves regionalization, since Twin Oaks MHP would be
9 obtaining drinking water from an existing larger supplier. Also, other PWSs near Twin Oaks
10 MHP are in need of compliant drinking water and could share in implementation of this
11 alternative.

12 The estimated capital cost for this alternative includes constructing the pipeline, pump
13 station, feed tank, and pump house. The estimated O&M cost for this alternative includes the
14 purchase price for the treated water minus the cost related to current operation of the Twin
15 Oaks MHP wells, plus maintenance cost for the pipeline, and power and O&M labor and
16 materials for the pump station. The estimated capital cost for this alternative is \$635,500, with
17 an estimated annual O&M cost of \$8,200. If the purchased water was used for blending rather
18 than for the full water supply, the annual O&M cost for this alternative could be reduced
19 because of reduced pumping costs and reduced water purchase costs. However, additional
20 costs would be incurred for equipment to ensure proper blending, and additional monitoring to
21 ensure the finished water is compliant.

22 The reliability of adequate amounts of compliant water under this alternative should be
23 good. City of Midland provides treated surface water on a large scale, facilitating adequate
24 O&M resources. From Twin Oaks MHP's perspective, this alternative would be characterized
25 as easy to operate and repair, since O&M and repair of pipelines and pump stations is well
26 understood. If the decision was made to perform blending then the operational complexity
27 would increase.

28 The feasibility of this alternative is dependent on an agreement being reached with the City
29 of Midland to purchase treated drinking water. There are several small PWSs relatively close
30 to the Twin Oaks MHP PWS that have water quality problems that would be good candidates
31 for sharing the cost for obtaining water from the City of Midland. The cost to the Twin Oaks
32 MHP supply system for this alternative could be reduced if the other PWSs would be willing to
33 share the costs. The analysis for a shared solution is presented in Appendix E. This analysis
34 shows that the Twin Oaks MHP could expect to save between \$287,900 to \$413,300 if they
35 were to implement a shared solution like this, which would be a savings between 45 to
36 65 percent.

37 **4.5.2 Alternative TO-2: Purchase Water from the Midland International Airport**

38 This alternative involves purchasing compliant water from the Midland International
39 Airport, which would be used to supply Twin Oaks MHP. The City of Midland currently has

sufficient excess capacity for this alternative to be feasible. It is assumed that Twin Oaks MHP would obtain all its water from the Midland International Airport.

This alternative would require constructing a pipeline from the Midland International Airport wells to the existing storage tank for the Twin Oaks MHP system. A pump station and 5,000 gallon feed tank would be required to overcome pipe friction and elevation differences between the Midland International Airport and Twin Oaks MHP. The required pipeline would be 4-inches in diameter and would follow Farm-to-Market (FM) road 1788 south to West CR 140 east, crossing South County Highway 1210, then to CR 1200 north to the Twin Oaks MHP. Using this route, the length of pipe required would be approximately 11.3 miles.

The pump station would include two pumps, including one standby, and would be housed in a building. A 5,000 gallon feed tank would also be constructed for the pumps to draw from. It is assumed the pumps and piping would be installed with capacity to meet all water demand for the Twin Oaks MHP, since the incremental cost would be relatively small, and would provide operational flexibility.

By definition this alternative involves regionalization, since Twin Oaks MHP would be obtaining drinking water from an existing larger supplier. Also, other PWSs near Twin Oaks MHP are in need of compliant drinking water and could share in implementation of this alternative.

The estimated capital cost for this alternative includes constructing the pipeline, pump station, feed tank, and pump house. The estimated O&M cost for this alternative includes the purchase price for the treated water minus the cost related to current operation of the Twin Oaks MHP wells, plus maintenance cost for the pipeline, and power and O&M labor and materials for the pump station. The estimated capital cost for this alternative is \$1.7 million, with an estimated annual O&M cost of \$10,000. If the purchased water was used for blending rather than for the full water supply, the annual O&M cost for this alternative could be reduced because of reduced pumping costs and reduced water purchase costs. However, additional costs would be incurred for equipment to ensure proper blending, and additional monitoring to ensure the finished water is compliant.

The reliability of adequate amounts of compliant water under this alternative should be good. Midland International Airport has adequate resources for operations and maintenance. From Twin Oaks MHP's perspective, this alternative would be characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations is well understood. If the decision was made to perform blending then the operational complexity would increase.

The feasibility of this alternative is dependent on an agreement being reached with the Midland International Airport to purchase treated drinking water.

4.5.3 Alternative TO-3: Purchase Treated Water from Odessa

This alternative involves purchasing compliant water from the City of Odessa, which would be used to supply Twin Oaks MHP. The City of Odessa currently has sufficient excess

1 capacity for this alternative to be feasible. For purposes of this report, to allow direct and
2 straightforward comparison with other alternatives, this alternative assumes that water would
3 be purchased from the City. Also, it is assumed that Twin Oaks MHP would obtain all its
4 water from the City of Odessa.

5 This alternative would require constructing a pipeline from the City of Odessa water main
6 to the existing storage tank for the Twin Oaks MHP system. A pump station and 5,000 gallon
7 feed tank would be required to overcome pipe friction and elevation differences between the
8 City and Twin Oaks MHP. The required pipeline would be 4-inches in diameter and would
9 follow W CR 123 east from Odessa to FM 1788 south to West CR 140 east, crossing South
10 County Highway 1210, then to CR 1200 north to the Twin Oaks MHP. Using this route, the
11 length of pipe required would be approximately 14.6 miles.

12 The pump station would include two pumps, including one standby, and would be housed
13 in a building. A 5,000 gallon feed tank would also be constructed for the pumps to draw from.
14 It is assumed the pumps and piping would be installed with capacity to meet all water demand
15 for the Twin Oaks MHP, since the incremental cost would be relatively small, and would
16 provide operational flexibility.

17 By definition this alternative involves regionalization, since Twin Oaks MHP would be
18 obtaining drinking water from an existing larger supplier. Also, other PWSs near Twin Oaks
19 MHP are in need of compliant drinking water and could share in implementation of this
20 alternative.

21 The estimated capital cost for this alternative includes constructing the pipeline pump
22 station, feed tank, and pump house. The estimated O&M cost for this alternative includes the
23 purchase price for the treated water minus the cost related to current operation of the Twin
24 Oaks MHP wells, plus maintenance cost for the pipeline, and power and O&M labor and
25 materials for the pump station. The estimated capital cost for this alternative is \$2.07 million,
26 with an estimated annual O&M cost of \$34,900. If the purchased water was used for blending
27 rather than for the full water supply, the annual O&M cost for this alternative could be reduced
28 because of reduced pumping costs and reduced water purchase costs. However, additional
29 costs would be incurred for equipment to ensure proper blending, and additional monitoring to
30 ensure the finished water is compliant.

31 The reliability of adequate amounts of compliant water under this alternative should be
32 good. City of Odessa provides treated surface water on a large scale, facilitating adequate
33 O&M resources. From Twin Oaks MHP's perspective, this alternative would be characterized
34 as easy to operate and repair, since O&M and repair of pipelines and pump stations is well
35 understood. If the decision was made to perform blending then the operational complexity
36 would increase.

37 The feasibility of this alternative is dependent on an agreement being reached with the City
38 of Odessa to purchase treated drinking water.

4.5.4 Alternative TO-4: New Well at 10 miles

This alternative consists of installing one new well within 10 miles of the Twin Oaks MHP that would produce compliant water in place of the water produced by the existing wells. At this level of study, it is not possible to positively identify an existing well or the location where a new well could be installed.

This alternative would require constructing one new 110-foot well, a new pump station with a 5,000-gallon feed tank near the new well and a pipeline from the new well/feed tank to the existing intake point for the Twin Oaks MHP system. An additional pump station and feed tank would be necessary to overcome pipe friction and changes in land elevation. For this alternative, the pipeline is assumed to be approximately 10 miles long, and would be a 4-inches in diameter and discharge to the existing storage tank at the Twin Oaks MHP. Each pump station would include a feed tank, two transfer pumps, including one standby, and would be housed in a building.

Depending on well location and capacity, this alternative could present some options for a more regional solution. It may be possible to share water and costs with another nearby system.

The estimated capital cost for this alternative includes installing the well, constructing the pipeline, the pump station, the feed tank, service pumps and pump house. The estimated O&M cost for this alternative includes O&M for the pipeline and pump stations. The estimated capital cost for this alternative is \$1.64 million, and the estimated annual O&M cost for this alternative is \$41,600.

The reliability of adequate amounts of compliant water under this alternative should be good, since water wells, pump stations and pipelines are commonly employed. From the perspective of the Twin Oaks MHP PWS, this alternative would be similar to operate as the existing system. Twin Oaks MHP personnel have experience with O&M of wells, pipelines, and pump stations.

The feasibility of this alternative is dependent on the ability to find an adequate existing well or success in installing a well that produces an adequate supply of compliant water. It is likely that an alternate groundwater source would not be found on land owned by Twin Oaks MHP, so landowner cooperation would likely be required.

4.5.5 Alternative TO-5: New at 5 miles

This alternative consists of installing one new well within 5 miles of the Twin Oaks MHP that would produce compliant water in place of the water produced by the existing wells. At this level of study, it is not possible to positively identify an existing well or the location where new wells could be installed.

This alternative would require constructing one new 110-foot well, a new pump station with a 5,000 gallon feed tank near the new well, and a pipeline from the new well/feed tank to

the existing intake point for the Twin Oaks MHP system. The pump station and feed tank would be necessary to overcome pipe friction and changes in land elevation. For this alternative, the pipeline is assumed to be 4-inches in diameter, approximately 5 miles long, and would discharge to the existing storage tank at the Twin Oaks PWS. The pump station near the well would include two transfer pumps, including one standby, and would be housed in a building.

Depending on well location and capacity, this alternative could present some options for a more regional solution. It may be possible to share water and costs with another nearby system.

The estimated capital cost for this alternative includes installing the well, and constructing the pipeline and pump station. The estimated O&M cost for this alternative includes O&M for the pipeline and pump station. The estimated capital cost for this alternative is \$846,600, and the estimated annual O&M cost for this alternative is \$14,600.

The reliability of adequate amounts of compliant water under this alternative should be good, since water wells, pump stations and pipelines are commonly employed. From the perspective of the Twin Oaks PWS, this alternative would be similar to operate as the existing system. Twin Oaks MHP personnel have experience with O&M of wells, pipelines and pump stations.

The feasibility of this alternative is dependent on the ability to find an adequate existing well or success in installing a well that produces an adequate supply of compliant water. It is likely an alternate groundwater source would not be found on land owned by Twin Oaks MHP, so landowner cooperation would likely be required.

4.5.6 Alternative TO-6: New Well at 1 mile

This alternative consists of installing one new well within 1 mile of the Twin Oaks PWS that would produce compliant water in place of the water produced by the existing wells. At this level of study, it is not possible to positively identify an existing well or the location where a new well could be installed.

This alternative would require constructing one new 110-foot well and a pipeline from the new well to the existing intake point for the Twin Oaks system. Since the new well is relatively close, a pump station would not be necessary. For this alternative, the pipeline is assumed to be 4 inches in diameter, approximately 1 mile long, and would discharge to the existing storage tank at the Twin Oaks PWS.

Depending on well location and capacity, this alternative could present some options for a more regional solution. It may be possible to share water and costs with another nearby system.

The estimated capital cost for this alternative includes installing the well, and constructing the pipeline. The estimated O&M cost for this alternative includes O&M for the pipeline. The

estimated capital cost for this alternative is \$173,600, and the estimated annual O&M cost for this alternative is \$700.

The reliability of adequate amounts of compliant water under this alternative should be good, since water wells and pipelines are commonly employed. From the perspective of the Twin Oaks PWS, this alternative would be similar to operate as the existing system. Twin Oaks MHP personnel have experience with O&M of wells, pipelines and pump stations.

The feasibility of this alternative is dependent on the ability to find an adequate existing well or success in installing a well that produces an adequate supply of compliant water. It is possible an alternate groundwater source would not be found on land owned by Twin Oaks MHP, so landowner cooperation may be required.

4.5.7 Alternative TO-7: Central RO Treatment

This system would continue to pump water from the existing wells, and would treat the water through an RO system prior to distribution. For this option, 100 percent of the raw water would be treated to obtain compliant water. The RO process concentrates impurities in the reject stream which would require disposal. It is estimated the RO reject generation would be approximately 5,600 gallons per day (gpd) when the system is operated at an average daily flow rate of 0.0165 mgd.

This alternative consists of constructing the RO treatment plant near the existing storage tank. The plant is composed of a 600 square foot building with a paved driveway; a skid with the pre-constructed RO plant and a 166,000-gallon pond for storing reject water. The treated water would be chlorinated and stored in the existing water storage tank prior to being pumped into the distribution system. The entire facility is fenced.

The estimated capital cost for this alternative is \$687,200, and the estimated annual O&M cost is \$77,300.

The reliability of adequate amount of compliant water under this alternative is good, since RO treatment is a common and well-understood treatment technology. However, O&M efforts required for the central RO treatment plant may be significant, and O&M personnel would require training with RO. The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other water supply entities.

4.5.8 Alternative TO-8: Central EDR Treatment

The system would continue to pump water from the existing wells, and would treat the water through an EDR system prior to distribution. For this option the EDR would treat the full flow without bypass as the EDR operation can be tailored for desired removal efficiency. It is estimated the EDR reject generation would be approximately 4,100 gpd when the system is operated at an average daily flow rate of 0.0165 mgd.

This alternative consists of constructing the EDR treatment plant near the existing storage tank. The plant is composed of a 500 square foot building with a paved driveway; a skid with the pre-constructed EDR system; and a 124,000-gallon pond for storing concentrated water. The treated water would be chlorinated and stored in the existing water storage tank prior to being pumped into the distribution system. The entire facility is fenced.

The estimated capital cost for this alternative is \$709,800 and the estimated annual O&M cost is \$74,100.

The reliability of adequate amounts of compliant water under this alternative is good, since EDR treatment is a common and well-understood treatment technology. However, O&M efforts required for the central EDR treatment plant may be significant, and O&M personnel would require training with EDR. The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other water supply entities.

4.5.9 Alternative TO-9: Central IX Treatment

The system would continue to pump water from Twin Oaks MHP PWS wells, and would treat the water through an IX system prior to distribution. For this option, the entire flow of raw water would be treated to obtain compliant water. Water in excess of that currently being produced would be required for backwashing and regeneration of the resin beds.

The IX treatment plant would be located near the existing Twin Oaks MHP PWS storage tanks, and would feature a 400 square foot (ft²) building with a paved driveway; the pre-constructed IX equipment on a skid, a commercial brine drum with regeneration equipment, two transfer pumps, a 5,000-gallon tank for storing the treated water, a 14,400-gallon tank for storing regenerant waste. The spent backwash water and regenerant waste would be trucked off-site for disposal. The treated water would be chlorinated and stored in the existing storage tanks prior to being pumped into the distribution system. The entire facility is fenced.

The estimated capital cost for this alternative is \$436,200, and the estimated annual O&M cost is \$52,000.

Reliability of supply of adequate amounts of compliant water under this alternative is good, since IX treatment is a common and well-understood treatment technology. IX treatment does not require high pressure, but can be affected by interfering constituents in the water. The O&M efforts required for the central IX treatment plant may be significant, and operating personnel would require training with ion exchange.

4.5.10 Alternative TO-10: Point-of-Use Treatment

This alternative consists of the continued operation of the Twin Oaks MHP well field, plus treatment of water to be used for drinking or food preparation at the point of use to remove nitrate and arsenic. The purchase, installation, and maintenance of POU treatment systems to be installed “under the sink” would be necessary for this alternative. Blending is not an option in this case.

1 This alternative would require installing the POU treatment units in residences and other
2 buildings that provide drinking or cooking water. Twin Oaks MHP staff would be responsible
3 for purchase and maintenance of the treatment units, including membrane and filter
4 replacement, periodic sampling, and necessary repairs. In houses, the most convenient point
5 for installation of the treatment units is typically under the kitchen sink, with a separate tap
6 installed for dispensing treated water. Installation of the treatment units in kitchens will require
7 the entry of Twin Oaks MHP or contract personnel into the houses of customers. As a result,
8 cooperation of customers would be important for success implementing this alternative. The
9 treatment units could be installed for access without house entry, but that would complicate the
10 installation and increase costs.

11 Treatment processes would involve RO. Treatment processes produce a reject waste
12 stream. The reject waste streams result in a slight increase in the overall volume of water used.
13 POU systems have the advantage that only a minimum volume of water is treated (only that for
14 human consumption). This minimizes the size of the treatment units, the increase in water
15 required, and the waste for disposal. For this alternative, it is assumed the increase in water
16 consumption is insignificant in terms of supply cost, and that the reject waste stream can be
17 discharged to the house septic or sewer system.

18 This alternative does not present options for a regional solution.

19 The estimated capital cost for this alternative includes purchasing and installing the POU
20 treatment systems. The estimated O&M cost for this alternative includes the purchase and
21 replacement of filters and membranes, as well as periodic sampling and record keeping as
22 required by the Texas Administrative Code (TAC) (Title 30, Part I, Chapter 290, Subchapter F,
23 Rule 290.106). The estimated capital cost for this alternative is \$99,100, and the estimated
24 annual O&M cost for this alternative is \$65,100. For the cost estimate, it is assumed that one
25 POU treatment unit will be required for each of the 78 connections in the Twin Oaks MHP
26 system. It should be noted that the POU treatment units would need to be more complex than
27 units typically found in commercial retail outlets in order to meet regulatory requirements,
28 making purchase and installation more expensive. Additionally, capital cost would increase if
29 POU treatment units are placed at other taps within a home, such as refrigerator water
30 dispensers, ice makers, and bathroom sinks. In school settings, all taps where children and
31 faculty receive water may need POU treatment units or clearly mark those taps suitable for
32 human consumption. Additional considerations may be necessary for preschools or other
33 establishments where individuals cannot read.

34 The reliability of adequate amounts of compliant water under this alternative is fair, since
35 it relies on the active cooperation of the customers for system installation, use, and
36 maintenance, and only provides compliant water to single tap within a house. Additionally, the
37 O&M efforts (including monitoring of the devices to ensure adequate performance) required
38 for the POU systems will be significant, and the current personnel are inexperienced in this
39 type of work. From the perspective of the Twin Oaks MHP PWS, this alternative would be
40 characterized as more difficult to operate owing to the in-home requirements and the large
41 number of individual units.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other water supply entities.

4.5.11 Alternative TO-11: Point-of-Entry Treatment

This alternative consists of the continued operation of the Twin Oaks MHP well field, plus treatment of water as it enters residences to remove nitrate and arsenic. The purchase, installation, and maintenance of the treatment systems at the point of entry to a household would be necessary for this alternative. Blending is not an option in this case.

This alternative would require the installation of the POE treatment units at houses and other buildings that provide drinking or cooking water. Every building connected to the system must have a POE device installed, maintained, and adequately monitored. TCEQ must be assured the system has 100 percent participation of all property and or building owners. A way to achieve 100 percent participation is through a public announcement and education program. Example public programs are provided in the document “*Point-of-Use or Point-of-Entry Treatment Options for Small Drinking Water Systems*” published by USEPA. The property owner’s responsibilities for the POE device must also be contained in the title to the property and “run with the land” so subsequent property owners understand their responsibilities (USEPA 2006).

Twin Oaks MHP would be responsible for purchase, operation, and maintenance of the treatment units, including membrane and filter replacement, periodic sampling, and necessary repairs. It may also be desirable to modify piping so water for non-consumptive uses can be withdrawn upstream of the treatment unit. The POE treatment units would be installed outside the residences, so entry would not be necessary for O&M. Some cooperation from customers would be necessary for installation and maintenance of the treatment systems.

POE treatment for nitrate and arsenic would involve RO. Treatment processes produce a reject stream that requires disposal. The reject water stream results in a slight increase in overall volume of water used. POE systems treat a greater volume of water than POU systems. For this alternative, it is assumed the increase in water consumption is insignificant in terms of supply cost, and that the backwash reject waste stream can be discharged to the house septic or sewer system.

This alternative does not present options for a regional solution.

The estimated capital cost for this alternative includes purchasing and installing the POE treatment systems. The estimated O&M cost for this alternative includes the purchase and replacement of filters and membranes, as well as periodic sampling and record keeping. The estimated capital cost for this alternative is \$1.19 million, and the estimated annual O&M cost for this alternative is \$167,300. For the cost estimate, it is assumed that one POE treatment unit will be required for each of the 78 existing connections to the Twin Oaks MHP system.

The reliability of adequate amounts of compliant water under this alternative are fair, but better than POU systems since it relies less on the active cooperation of the customers for

1 system installation, use, and maintenance, and compliant water is supplied to all taps within a
2 house. Additionally, the O&M efforts required for the POE systems will be significant, and the
3 current personnel are inexperienced in this type of work. From the perspective of the Twin
4 Oaks MHP PWS, this alternative would be characterized as more difficult to operate owing to
5 the on-property requirements and the large number of individual units.

6 The feasibility of this alternative is not dependent on the cooperation, willingness, or
7 capability of other water supply entities.

8 **4.5.12 Alternative TO-12: Public Dispenser for Treated Drinking Water**

9 This alternative consists of the continued operation of the Twin Oaks MHP wells, plus
10 dispensing treated water for drinking and cooking at a publicly accessible location.
11 Implementing this alternative would require purchasing and installing one treatment unit where
12 customers would be able to come and fill their own containers. This alternative also includes
13 notifying customers of the importance of obtaining drinking water from the dispenser. In this
14 way, only a relatively small volume of water requires treatment, but customers would be
15 required to pick up and deliver their own water. Blending is not an option in this case. It
16 should be noted that this alternative would be considered an interim measure until a compliance
17 alternative is implemented.

18 Twin Oaks MHP personnel would be responsible for maintenance of the treatment unit,
19 including media or membrane replacement, periodic sampling, and necessary repairs. The
20 spent media or membranes will require disposal. This alternative relies on a great deal of
21 cooperation and action from the customers in order to be effective.

22 This alternative does not present options for a regional solution.

23 The estimated capital cost for this alternative includes purchasing and installing the
24 treatment system to be used for the drinking water dispenser. The estimated O&M cost for this
25 alternative includes purchasing and replacing filters and media or membranes, as well as
26 periodic sampling and record keeping. The estimated capital cost for this alternative is
27 \$17,800, and the estimated annual O&M cost for this alternative is \$34,600.

28 The reliability of adequate amounts of compliant water under this alternative is fair,
29 because of the large amount of effort required from the customers and the associated
30 inconvenience. Twin Oaks MHP PWS has not provided this type of service in the past. From
31 Twin Oaks MHP's perspective this alternative would be characterized as relatively easy to
32 operate, since these types of treatment units are highly automated, and there is only one unit.

33 The feasibility of this alternative is not dependent on the cooperation, willingness, or
34 capability of other water supply entities.

4.5.13 Alternative TO-13: 100 Percent Bottled Water Delivery

This alternative consists of the continued operation of the Twin Oaks MHP wells, but compliant drinking water will be delivered to customers in containers. This alternative involves setting up and operating a bottled water delivery program to serve all customers in the system. It is expected that Twin Oaks MHP would find it most convenient and economical to contract a bottled water service. The bottle delivery program would have to be flexible enough to allow the delivery of smaller containers should customers be incapable of lifting and manipulating 5-gallon bottles. Blending is not an option in this case. It should be noted that this alternative would be considered an interim measure until a compliance alternative is implemented.

This alternative does not involve capital cost for construction, but would require some initial costs for system setup, and then ongoing costs to have the bottled water furnished. It is assumed for this alternative that bottled water is provided to 100 percent of the Twin Oaks MHP PWS customers.

This alternative does not present options for a regional solution.

The estimated initial capital cost is for setting up the program. The estimated O&M cost for this alternative includes program administration and purchase of the bottled water. The estimated capital cost for this alternative is \$27,000, and the estimated annual O&M cost for this alternative is \$111,600. For the cost estimate, it is assumed that each person requires one gallon of bottled water per day.

The reliability of adequate amounts of compliant water under this alternative is fair, since it relies on the active cooperation of customers to order and utilize the water. Management and administration of the bottled water delivery program will require attention from Twin Oaks MHP.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other water supply entities.

4.5.14 Alternative TO-14: Public Dispenser for Trucked Drinking Water

This alternative consists of continued operation of the Twin Oaks MHP wells, plus dispensing compliant water for drinking and cooking at a publicly accessible location. The compliant water would be purchased from the City of Midland, and delivered by truck to a tank at a central location where customers would be able to fill their own containers. This alternative also includes notifying customers of the importance of obtaining drinking water from the dispenser. In this way, only a relatively small volume of water requires treatment, but customers are required to pick up and deliver their own water. Blending is not an option in this case. It should be noted that this alternative would be considered an interim measure until a compliance alternative is implemented.

1 Twin Oaks MHP would purchase a truck suitable for hauling potable water, and install a
2 storage tank. It is assumed the storage tank would be filled once a week, and that the chlorine
3 residual would be tested for each truckload. The truck would have to meet requirements for
4 potable water, and each load would be treated with bleach. This alternative relies on a great
5 deal of cooperation and action from the customers for it to be effective.

6 This alternative presents limited options for a regional solution if two or more systems
7 share the purchase and operation of the water truck.

8 The estimated capital cost for this alternative includes purchasing a water truck and
9 construction of the storage tank to be used for the drinking water dispenser. The estimated
10 O&M cost for this alternative includes O&M for the truck, maintenance for the tank, water
11 quality testing, record keeping, and water purchase. The estimated capital cost for this
12 alternative is \$127,700, and the estimated annual O&M cost for this alternative is \$30,700.

13 The reliability of adequate amounts of compliant water under this alternative is fair
14 because of the large amount of effort required from the customers and the associated
15 inconvenience. Current personnel have not provided this type of service in the past. From the
16 perspective of Twin Oaks MHP, this alternative would be characterized as relatively easy to
17 operate, but the water hauling and storage would have to be done with care to ensure sanitary
18 conditions.

19 The feasibility of this alternative is not dependent on the cooperation, willingness, or
20 capability of other water supply entities.

21 **4.5.15 Summary of Alternatives**

22 Table 4.3 provides a summary of the key features of each alternative for Twin Oaks MHP
23 PWS.

1 **Table 4.3 Summary of Compliance Alternatives for MHP PWS**

Alt No.	Alternative Description	Major Components	Capital Cost ¹	Annual O&M Cost	Total Annualized Cost	Reliability	System Impact	Remarks
TO-1	Purchase Water from City of Midland	- 1 new pump station / feed tank - 4.1-mile pipeline	\$635,500	\$8,200	\$63,600	Good	N	Agreement must be successfully negotiated with City of Midland. Blending may be possible. Costs could possibly be shared with small systems along pipeline route.
TO-2	Purchase Water from Midland International Airport	- 1 new pump station / feed tank - 11.3-mile pipeline	\$1,695,900	\$10,000	\$157,900	Good	N	Agreement must be successfully negotiated with Midland International Airport. Blending may be possible. Costs could possibly be shared with small systems along pipeline route.
TO-3	Purchase Water from Odessa	- Pump station - 14.6-mile pipeline	\$2,071,700	\$34,900	\$215,500	Good	N	Agreement must be successfully negotiated with City of Odessa. Blending may be possible. Costs could possibly be shared with small systems along pipeline route.
TO-4	Install new compliant well at 10 Miles	- New well - Two new pump stations / feed tanks - 10-mile pipeline	\$1,641,800	\$41,600	\$184,700	Good	N	May be difficult to find well with good water quality. Costs could possibly be shared with small systems along pipeline route.
TO-5	Install new compliant well at 5 Miles	- New well - New pump station / feed tank - 5-mile pipeline	\$846,600	\$14,600	\$88,400	Good	N	May be difficult to find well with good water quality. Costs could possibly be shared with small systems along pipeline route.
TO-6	Install new compliant well at 1 Mile	- New well - 1-mile pipeline	\$173,600	\$700	\$15,800	Good	N	May be difficult to find well with good water quality.
TO-7	Continue operation of Twin Oaks MHP well field with central RO treatment	- Central RO treatment plant	\$687,200	\$77,300	\$137,200	Good	N	Costs could possibly be shared with nearby small systems.
TO-8	Continue operation of Twin Oaks MHP well field with central EDR Treatment	- Central EDR treatment plant	\$709,800	\$74,100	\$136,000	Good	T	Costs could possibly be shared with nearby small systems.
TO-9	Continue operation of Twin Oaks MHP well field with central IX Treatment	- Central IX treatment plant	\$436,200	\$52,000	\$90,100	Good	T	Costs could possibly be shared with nearby small systems.
TO-11	Continue operation of Twin Oaks MHP well field, and POU treatment	- POU treatment units	\$99,100	\$65,100	\$73,800	Fair	T, M	Only one compliant tap in home. Cooperation of residents required for installation, maintenance, and testing.
TO-12	Continue operation of Twin Oaks MHP well field, and POE treatment	- POE treatment units	\$1,187,300	\$167,300	\$270,800	Fair (better than POU)	T, M	All home taps compliant and less resident cooperation required.

Alt No.	Alternative Description	Major Components	Capital Cost ¹	Annual O&M Cost	Total Annualized Cost	Reliability	System Impact	Remarks
TO-13	Continue operation of Twin Oaks MHP well field, but furnish public dispenser for treated drinking water	- Water treatment and dispenser unit	\$17,800	\$34,600	\$36,200	Fair/interim measure	T	Does not provide compliant water to all taps, and requires a lot of effort by customers.
TO-14	Continue operation of Twin Oaks MHP well field, but furnish bottled drinking water for all customers	- Set up bottled water system	\$27,000	\$111,600	\$113,900	Fair/interim measure	M	Does not provide compliant water to all taps, and requires customers to order and use. Management of program may be significant.
TO-15	Continue operation of Twin Oaks MHP well field, but furnish public dispenser for trucked drinking water.	- Construct storage tank and dispenser - Purchase potable water truck	\$127,700	\$30,700	\$41,900	Fair/interim measure	M	Does not provide compliant water to all taps, and requires a lot of effort by customers.

Notes:

N – No significant increase required in technical or management capability
T – Implementation of alternative will require increase in technical capability
M – Implementation of alternative will require increase in management capability
1 – See cost breakdown in Appendix C
2 – 20-year return period and 6 percent interest

4.6 COST OF SERVICE AND FUNDING ANALYSIS

To evaluate the financial impact of implementing the compliance alternatives, a 30-year financial planning model was developed. This model can be found in Appendix D. The financial model is based on cash flows, with and without implementation of the compliance alternatives. Data for such models are typically derived from established budgets, audited financial reports, published water tariffs, and consumption data. Twin Oaks MHP has 78 metered connections, serving a population of approximately 234.

This analysis will need to be performed in a more detailed fashion and applied to alternatives deemed attractive and worthy of more detailed evaluation. A more detailed analysis should include additional factors such as:

- Cost escalation,
- Price elasticity effects where increased rates may result in lower water consumption,
- Costs for other system upgrades and rehabilitation needed to maintain compliant operation.

4.6.1 Twin Oak Hills Mobile Home Park Financial Data

Financial records and statements for Twin Oaks MHP were used to determine the revenues for the Twin Oaks MHP PWS. According to the available financial data, approximately 6.02 million gallons of water was used in fiscal year 2007, generating an annual income of \$10,623. Expenses were estimated based on expenses for similar size systems.

4.6.2 Current Financial Condition

4.6.2.1 Cash Flow Needs

The average annual water bill is estimated to be \$136, or approximately 0.4 per cent of the annual household income of \$31,847. Based on the estimated expenses, it appears that revenues are not sufficient to maintain operations.

4.6.2.2 Ratio Analysis

Current Ratio

The Current Ratio for the Twin Oak Hills MHP water system could not be determined due to lack of necessary financial data to determine this ratio.

Debt to Net Worth Ratio

A Debt-to-Net-Worth Ratio also could not be determined owing to lack of the necessary financial data to determine this ratio.

Operating Ratio

Because of the lack of complete separate financial data on expenses specifically related to the Twin Oak Hills MHP, the Operating Ratio could not be accurately determined.

4.6.3 Financial Plan Results

Each compliance alternative for the Twin Oaks PWS was evaluated, with emphasis on the impact on affordability (expressed as a percentage of household income), and the overall increase in water rates necessary to pay for the improvements. Each alternative was examined under the various funding options described in Section 2.4.

Results of the financial impact analysis are provided in Table 4.4 and Figure 4.2. Table 4.4 and Figure 4.2 present rate impacts assuming that revenues match expenses, without funding reserve accounts, and that operations and implementation of compliance alternatives are funded with revenue and are not paid for from reserve accounts. Figure 4.2 provides a bar chart that, in terms of the yearly billing to an average customer, shows the following:


- Current annual average bill,
- Projected annual average bill including rate increase, if needed, to match existing expenditures, and
- Projected annual bill including rate increases needed to fund implementation of a compliance alternative (this does not include funding for reserve accounts).

The two bars shown for each compliance alternative represent the rate changes necessary for revenues to match total expenditures assuming 100 percent grant funding and 100 percent loan/bond funding. Most funding options will fall between 100 percent grant and 100 percent loan/bond funding, with the exception of 100 percent revenue financing. Establishing or increasing reserve accounts would require an increase in rates. If existing reserves are insufficient to fund a compliance alternative, rates would need to be raised before implementing the compliance alternative. This would allow for accumulation of sufficient reserves to avoid larger but temporary rate increases during the years the compliance alternative was being implemented.

Twin Oaks MHP
Table 4.4 Financial Impact on Households

Alternative	Description		All Revenue	100% Grant	75% Grant	50% Grant	SRF	Bond
1	Purchase Water from City of Midland	Maximum % of MHI	26.4%	1.2%	1.7%	2.2%	2.9%	3.2%
		Percentage Rate Increase Compared to Current	6085%	180%	297%	414%	578%	648%
		Average Annual Water Bill	\$8,423	\$381	\$541	\$700	\$924	\$1,019
2	Purchase Water from Midland International Airport	Maximum % of MHI	69.1%	1.3%	2.6%	3.9%	5.8%	6.6%
		Percentage Rate Increase Compared to Current	16067%	197%	509%	822%	1260%	1446%
		Average Annual Water Bill	\$22,019	\$405	\$830	\$1,255	\$1,853	\$2,106
3	Purchase Water from Odessa	Maximum % of MHI	84.3%	2.3%	3.9%	5.5%	7.8%	8.8%
		Percentage Rate Increase Compared to Current	19604%	431%	812%	1194%	1730%	1957%
		Average Annual Water Bill	\$26,836	\$723	\$1,243	\$1,762	\$2,492	\$2,801
4	New Well at 10 Miles	Maximum % of MHI	67.0%	2.5%	3.8%	5.1%	6.9%	7.7%
		Percentage Rate Increase Compared to Current	15558%	494%	796%	1099%	1523%	1703%
		Average Annual Water Bill	\$21,325	\$809	\$1,221	\$1,632	\$2,211	\$2,456
5	New Well at 5 Miles	Maximum % of MHI	34.9%	1.5%	2.1%	2.8%	3.7%	4.1%
		Percentage Rate Increase Compared to Current	8072%	241%	396%	552%	771%	864%
		Average Annual Water Bill	\$11,130	\$464	\$676	\$888	\$1,187	\$1,313
6	New Well at 1 Mile	Maximum % of MHI	7.9%	0.9%	1.0%	1.1%	1.3%	1.4%
		Percentage Rate Increase Compared to Current	1737%	103%	135%	167%	212%	231%
		Average Annual Water Bill	\$2,502	\$276	\$320	\$363	\$425	\$450
7	Central Treatment -RO	Maximum % of MHI	28.5%	4.0%	4.5%	5.1%	5.8%	6.1%
		Percentage Rate Increase Compared to Current	6572%	831%	957%	1084%	1262%	1337%
		Average Annual Water Bill	\$9,086	\$1,268	\$1,440	\$1,612	\$1,855	\$1,957
8	Central Treatment - ED	Maximum % of MHI	29.4%	3.8%	4.4%	5.0%	5.8%	6.1%
		Percentage Rate Increase Compared to Current	6784%	800%	931%	1061%	1245%	1323%
		Average Annual Water Bill	\$9,376	\$1,226	\$1,404	\$1,582	\$1,832	\$1,938
9	Central Treatment - Ion Exchange IO	Maximum % of MHI	18.7%	3.0%	3.3%	3.7%	4.1%	4.4%
		Percentage Rate Increase Compared to Current	4270%	593%	674%	756%	870%	919%
		Average Annual Water Bill	\$5,952	\$944	\$1,055	\$1,166	\$1,322	\$1,388
10	Point-of-Use Treatment	Maximum % of MHI	4.9%	3.5%	3.6%	3.6%	3.8%	3.8%
		Percentage Rate Increase Compared to Current	1036%	716%	734%	752%	778%	789%
		Average Annual Water Bill	\$1,547	\$1,111	\$1,136	\$1,161	\$1,196	\$1,211
11	Point-of-Entry Treatment	Maximum % of MHI	48.7%	7.6%	8.5%	9.5%	10.8%	11.3%
		Percentage Rate Increase Compared to Current	11279%	1678%	1896%	2115%	2422%	2552%
		Average Annual Water Bill	\$15,498	\$2,421	\$2,719	\$3,017	\$3,435	\$3,612
12	Public Dispenser for Treated Drinking Water	Maximum % of MHI	2.3%	2.3%	2.3%	2.3%	2.3%	2.3%
		Percentage Rate Increase Compared to Current	429%	429%	432%	435%	440%	442%
		Average Annual Water Bill	\$720	\$720	\$724	\$729	\$735	\$738
13	Supply Bottled Water to 100% of Population	Maximum % of MHI	5.4%	5.4%	5.4%	5.4%	5.4%	5.4%
		Percentage Rate Increase Compared to Current	1153%	1153%	1158%	1163%	1170%	1173%
		Average Annual Water Bill	\$1,707	\$1,707	\$1,714	\$1,721	\$1,730	\$1,734
14	Central Trucked Drinking Water	Maximum % of MHI	6.0%	2.1%	2.2%	2.3%	2.4%	2.5%
		Percentage Rate Increase Compared to Current	1305%	392%	416%	439%	472%	486%
		Average Annual Water Bill	\$1,914	\$670	\$702	\$734	\$779	\$798

Figure 4.2
Alternative Cost Summary: Twin Oaks MHP



Current Average Monthly Bill = \$11.35
 Median Household Income = \$31,847
 Average Monthly Residential Usage = 6,434 gallons

■ Current
 ■ Needed
 ■ With 100% Grant Funding
 ■ With 100% Loan/Bond Funding

4.6.4 Evaluation of Potential Funding Options Financial Plan Results

There are limited funding programs available to entities as described in Section 2.4. Twin Oaks MHP PWS is most likely to obtain funding from programs administered by the TWDB. This report contains information that would be used for an application for funding. Information such as financial analyses, water supply assessment, and records demonstrating health concerns, failing infrastructure, and financial need, may be required by these agencies. This section describes the candidate funding agencies and their appropriate programs as well as information and steps needed to begin the application process.

This report should serve to document the existing water quality issues, infrastructure need and costs, and water system information needed to begin the application process with the TWDB. Although this report is at the conceptual level, it demonstrates that significant funding will be needed to meet Safe Drinking Water Standards. The information provided in this report may serve as the needed documentation to justify a project that may only be possible with significant financial assistance.

The program most available to the privately owned system is the DWSRF. The DWSRF offers net long-term interest lending rates below the rate the borrower would receive on the open market for a period of 20 years. A cost-recovery loan origination charge is imposed to cover the administrative costs of operating the DWSRF, but an additional interest rate subsidy is offered to offset the charge. The terms of the loan typically require a revenue or tax pledge. Depending on how the origination charge is handled, interest rates can be as low as 0.95 percent below market rates with the possibility of additional federal subsidies for total interest rates 1.95 percent below market rates. Disadvantaged communities may obtain loans at interest rates between 0 percent and 1 percent.

The loan application process has several steps: pre-application, application and commitment, loan closing, funding and construction monitoring, and any other special requirements. In the pre-application phase, prospective loan applicants are asked to submit a brief DWSRF Information Form to the TWDB that describes the applicant's existing water facilities, additional facility needs and the nature of projects being considered for meeting those needs, project cost estimates, and "disadvantaged community" status. The TCEQ assigns a priority rating that includes an applicant's readiness to proceed. TWDB staff notify prospective applicants of their priority rating and encourage them to schedule a pre-planning conference for guidance in preparing the engineering, planning, environmental, financial, and water conservation portions of the DWSRF application.

Additional information can be found online at the TWDB website under the Assistance tab, Financial Assistance section, Public Works Infrastructure Construction subsection, and under the links "Clean Water State Revolving Fund Loan Program."

SECTION 5 REFERENCES

- Anaya, R. and I. Jones, 2004. Groundwater Availability Model for the Edwards-Trinity (Plateau) and Cenozoic Pecos Alluvium Aquifer Systems, Texas. Texas Water Development Board GAM Report. Available online at <http://www.twdb.state.tx.us/gam/index.htm>.
- Ashworth, J.B., and R.R. Flores. 1991. Delineation criteria for the major and minor aquifer maps of Texas. Texas Water Development Board Report LP-212, 27 p.
- Blandford, T.N., D.J. Blazer, K.C. Calhoun, A.R. Dutton, T. Naing, R.C. Reedy, and B.R. Scanlon. 2003. Groundwater Availability Model of the Southern Ogallala Aquifer in Texas and New Mexico: Numerical Simulations Through 2050. Available online at: <http://www.twdb.state.tx.us/gam/index.htm>
- Dutton, A.R., and W.W. Simpkins. 1986. Hydrogeochemistry and water resources of the Triassic lower Dockum Group in the Texas Panhandle and eastern New Mexico. University of Texas, Bureau of Economic Geology Report of Investigations No 161, 51p.
- Gustavson, T.C., and V.T. Holliday. 1985. Depositional architecture of the Quaternary Blackwater Draw and Tertiary Ogallala Formations, Texas Panhandle and eastern New Mexico. The University of Texas at Austin Bureau of Economic Geology Open File Report of West Texas Waste Isolation 1985-23, 60 p.
- Holliday, V.T. 1989. The Blackwater Draw Formation (Quaternary): a 1.4-plus-m.y. record of eolian sedimentation and soil formation on the Southern High Plains. Geological Society of America Bulletin 101:1598-1607.
- McGowen, J.H., G.E. Granata, and S.J. Seni. 1977. Depositional systems, uranium occurrence and postulated ground-water history of the Triassic Dockum Group, Texas Panhandle-Eastern New Mexico. The University of Texas at Austin, Bureau of Economic Geology, report prepared for the U.S. Geological Survey under grant number 14-08-0001-G410, 104 p.
- Nativ, R. 1988. Hydrogeology and hydrochemistry of the Ogallala Aquifer, Southern High Plains, Texas Panhandle and Eastern New Mexico. The University of Texas, Bureau of Economic Geology Report of Investigations No. 177, 64 p.
- Raucher, Robert S., Marca Hagenstad, Joseph Cotruvo, Kate Martin, and Harish Arora. 2004. Conventional and Unconventional Approaches to Water Service Provision. AWWA Research Foundation and American Water Works Association.
- TCEQ 2004. Drinking Quality and Reporting Requirements for PWSs: 30 TAC 290 Subchapter F (290.104. Summary of Maximum Contaminant levels, Maximum Residual Disinfectant Levels, Treatment Techniques, and Action Levels). Revised February 2004.

- 1 Texas Administrative Code. Title 30, Part I, Chapter 290, Subchapter F, Rule 290.106. Can
2 be viewed at:
3 [http://info.sos.state.tx.us/pls/pub/readtac\\$ext.TacPage?sl=R&app=9&p_dir=&p_rloc](http://info.sos.state.tx.us/pls/pub/readtac$ext.TacPage?sl=R&app=9&p_dir=&p_rloc)
4 [=&p_tloc=&p_ploc=&pg=1&p_tac=&ti=30&pt=1&ch=290&rl=106](http://info.sos.state.tx.us/pls/pub/readtac$ext.TacPage?sl=R&app=9&p_dir=&p_rloc=&p_tloc=&p_ploc=&pg=1&p_tac=&ti=30&pt=1&ch=290&rl=106)
- 5 TWDB 2007. Water for Texas 2007, State Water Plan. Texas Water Development Board.
6 Available online at: <http://www.twdb.state.tx.us/wrpi/swp/swp.htm> USEPA 2006,
7 “Point-of-Use or Point-of-Entry” Treatment Options for Small Drinking Water
8 Systems” published by USEPA.
- 9 USEPA 2008a. List of Drinking Water Contaminants & MCLs. Online. Last updated on
10 Thursday, June 5th, 2008. <http://www.epa.gov/safewater/mcl.html>.
- 11 USEPA 2008b. United States Environmental Protection Agency Drinking Water
12 Contaminants for Arsenic. Last updated on Tuesday, November 28th, 2006. Website
13 accessed on June 5, 2008, <http://www.epa.gov/safewater/hfacts.html#Radioactive>
- 14 USEPA 2008c. United States Environmental Protection Agency Drinking Water
15 Contaminants for Fluoride. Last updated on Tuesday, November 28th, 2006. Website
16 accessed on June 5, 2008, <http://www.epa.gov/safewater/hfacts.html>

1
2

**APPENDIX A
PWS INTERVIEW FORM**

CAPACITY DEVELOPMENT ASSESSMENT FORM

Prepared By _____

Date _____

Section 1. Public Water System Information

1. PWS ID #		2. Water System Name	
3. County			
4. Owner		Address	
Tele.		E-mail	
Fax		Message	
5. Admin		Address	
Tele.		E-mail	
Fax		Message	
6. Operator		Address	
Tele.		E-mail	
Fax		Message	
7. Population Served		8. No. of Service Connections	
9. Ownership Type		10. Metered (Yes or No)	
11. Source Type			
12. Total PWS Annual Water Used			
13. Number of Water Quality Violations (Prior 36 months)			
Total Coliform		Chemical/Radiological	
Monitoring (CCR, Public Notification, etc.)		Treatment Technique, D/DBP	

A. Basic Information

1. Name of Water System:
2. Name of Person Interviewed:
3. Position:
4. Number of years at job:
5. Number of years experience with drinking water systems:
6. Percent of time (day or week) on drinking water system activities, with current position (how much time is dedicated exclusively to the water system, not wastewater, solid waste or other activities):
7. Certified Water Operator (Yes or No):

 If Yes,
 7a. Certification Level (water):

 7b. How long have you been certified?
8. Describe your water system related duties on a typical day.

B. Organization and Structure

1. Describe the organizational structure of the Utility. Please provide an organizational chart. (Looking to find out the governance structure (who reports to whom), whether or not there is a utility board, if the water system answers to public works or city council, etc.)

2. If not already covered in Question 1, to whom do you report?
3. Do all of the positions have a written job description?
 - 3a. If yes, is it available to employees?
 - 3b. May we see a copy?

C. Personnel

1. What is the current staffing level (include all personnel who spend more than 10% of their time working on the water system)?
2. Are there any vacant positions? How long have the positions been vacant?
3. In your opinion, is the current staffing level adequate? If not adequate, what are the issues or staffing needs (how many and what positions)?
4. What is the rate of employee turnover for management and operators? What are the major issues involved in the turnover (e.g., operator pay, working conditions, hours)?
5. Is the system staffed 24 hours a day? How is this handled (on-site or on-call)? Is there an alarm system to call an operator if an emergency occurs after hours?

D. Communication

1. Does the utility have a mission statement? If yes, what is it?
2. Does the utility have water quality goals? What are they?
3. How are your work priorities set?
4. How are work tasks delegated to staff?
5. Does the utility have regular staff meetings? How often? Who attends?
6. Are there separate management meetings? If so, describe.
7. Do management personnel ever visit the treatment facility? If yes, how often?
8. Is there effective communication between utility management and state regulators (e.g., NMED)?
9. Describe communication between utility and customers.

E. Planning and Funding

1. Describe the rate structure for the utility.
2. Is there a written rate structure, such as a rate ordinance? May we see it?
 - 2a. What is the average rate for 6,000 gallons of water?
3. How often are the rates reviewed?
4. What process is used to set or revise the rates?
5. In general, how often are the new rates set?
6. Is there an operating budget for the water utility? Is it separate from other activities, such as wastewater, other utilities, or general city funds?
7. Who develops the budget, how is it developed and how often is a new budget created or the old budget updated?
8. How is the budget approved or adopted?

9. In the last 5 years, how many budget shortfalls have there been (i.e., didn't collect enough money to cover expenses)? What caused the shortfall (e.g., unpaid bills, an emergency repair, weather conditions)?

9a. How are budget shortfalls handled?
10. In the last 5 years how many years have there been budget surpluses (i.e., collected revenues exceeded expenses)?

10a. How are budget surpluses handled (i.e., what is done with the money)?
11. Does the utility have a line-item in the budget for emergencies or some kind of emergency reserve account?
12. How do you plan and pay for short-term system needs?
13. How do you plan and pay for long- term system needs?
14. How are major water system capital improvements funded? Does the utility have a written capital improvements plan?
15. How is the facility planning for future growth (either new hook-ups or expansion into new areas)?
16. Does the utility have and maintain an annual financial report? Is it presented to policy makers?

17. Has an independent financial audit been conducted of the utility finances? If so, how often? When was the last one?
18. Will the system consider any type of regionalization with any other PWS, such as system interconnection, purchasing water, sharing operator, emergency water connection, sharing bookkeeper/billing or other?

F. Policies, Procedures, and Programs
--

1. Are there written operational procedures? Do the employees use them?
2. Who in the utility department has spending authorization? What is the process for obtaining needed equipment or supplies, including who approves expenditures?
3. Does the utility have a source water protection program? What are the major components of the program?
4. Are managers and operators familiar with current SDWA regulations?
5. How do the managers and operators hear about new or proposed regulations, such as arsenic, DBP, Groundwater Rule? Are there any new regulations that will be of particular concern to the utility?
6. What are the typical customer complaints that the utility receives?
7. Approximately how many complaints are there per month?

8. How are customer complaints handled? Are they recorded?
9. (If not specifically addressed in Question 7) If the complaint is of a water quality nature, how are these types of complaints handled?
10. Does the utility maintain an updated list of critical customers?
11. Is there a cross-connection control plan for the utility? Is it written? Who enforces the plan's requirements?
12. Does the utility have a written water conservation plan?
13. Has there been a water audit of the system? If yes, what were the results?
14. (If not specifically answered in 11 above) What is the estimated percentage for loss to leakage for the system?
15. Are you, or is the utility itself, a member of any trade organizations, such as AWWA or Rural Water Association? Are you an active member (i.e., attend regular meetings or participate in a leadership role)? Do you find this membership helpful? If yes, in what ways does it help you?

G. Operations and Maintenance

1. How is decision-making authority split between operations and management for the following items:
 - a. Process Control
 - b. Purchases of supplies or small equipment
 - c. Compliance sampling/reporting
 - d. Staff scheduling
2. Describe your utility's preventative maintenance program.
3. Do the operators have the ability to make changes or modify the preventative maintenance program?
4. How does management prioritize the repair or replacement of utility assets? Do the operators play a role in this prioritization process?
5. Does the utility keep an inventory of spare parts?
6. Where does staff have to go to buy supplies/minor equipment? How often?
 - 6a. How do you handle supplies that are critical, but not in close proximity (for example if chlorine is not available in the immediate area or if the components for a critical pump are not in the area)

7. Describe the system's disinfection process. Have you had any problems in the last few years with the disinfection system?
 - 7a. Who has the ability to adjust the disinfection process?
8. How often is the disinfectant residual checked and where is it checked?
 - 8a. Is there an official policy on checking residuals or is it up to the operators?
9. Does the utility have an O & M manual? Does the staff use it?
10. Are the operators trained on safety issues? How are they trained and how often?
11. Describe how on-going training is handled for operators and other staff. How do you hear about appropriate trainings? Who suggests the trainings – the managers or the operators? How often do operators, managers, or other staff go to training? Who are the typical trainers used and where are the trainings usually held?
12. In your opinion is the level of your on-going training adequate?
13. In your opinion is the level of on-going training for other staff members, particularly the operators, adequate?

14. Does the facility have mapping of the water utility components? Is it used on any routine basis by the operators or management? If so, how is it used? If not, what is the process used for locating utility components?
15. In the last sanitary survey, were any deficiencies noted? If yes, were they corrected?
16. How often are storage tanks inspected? Who does the inspection?
 - 16a. Have you experienced any problems with the storage tanks?

H. SDWA Compliance

1. Has the system had any violations (monitoring or MCL) in the past 3 years? If so, describe.
2. How were the violations handled?
3. Does the system properly publish public notifications when notified of a violation?
4. Is the system currently in violation of any SDWA or state regulatory requirements, including failure to pay fees, fines, or other administrative type requirements?
5. Does the utility prepare and distribute a Consumer Confidence Report (CCR)? Is it done every year? What type of response does the utility get to the CCR from customers?

I. Emergency Planning

1. Does the system have a written emergency plan to handle emergencies such as water outages, weather issues, loss of power, loss of major equipment, etc?
2. When was the last time the plan was updated?
3. Do all employees know where the plan is? Do they follow it?
4. Describe the last emergency the facility faced and how it was handled.

Attachment A

A. Technical Capacity Assessment Questions

1. Based on available information of water rights on record and water pumped has the system exceeded its water rights in the past year? YES ☐ NO ☐

In any of the past 5 years? YES ☐ NO ☐ How many times? _____

2. Does the system have the proper level of certified operator? *(Use questions a – c to answer.)*
YES ☐ NO ☐

a. What is the Classification Level of the system by NMED? _____

- b. Does the system have one or more certified operator(s)? [20 NMAC 7.4.20]

YES ☐ NO ☐

- c. If YES, provide the number of operators at each New Mexico Certification Level. [20 NMAC 7.4.12]

_____ NM Small System _____ Class 2

_____ NM Small System Advanced _____ Class 3

_____ Class 1 _____ Class 4

3. Did the system correct any sanitary deficiency noted on the most recent sanitary survey within 6 months of receiving that information? [20 NMAC 7.20.504]

YES ☐ NO ☐ No Deficiencies ☐

What was the type of deficiency? *(Check all that are applicable.)*

Source ☐ Storage ☐

Treatment ☐ Distribution ☐

Other _____

From the system's perspective, were there any other deficiencies that were not noted on the sanitary survey?
Please describe.

4. Will the system's current treatment process meet known future regulations?

Radionuclides YES ☐ NO ☐ Doesn't Apply ☐

Arsenic YES ☐ NO ☐ Doesn't Apply ☐

Stage 1 Disinfectants and Disinfection By-Product (DBP)

YES ☐ NO ☐ Doesn't Apply ☐

Surface Water Treatment Rule YES ☐ NO ☐ Doesn't Apply ☐

5. Does the system have a current site plan/map? [20 NMAC 7.10.302 A.1.]

YES ☐ NO ☐

6. Has the system had a water supply outage in the prior 24 months?

YES ☐ NO ☐

What were the causes of the outage(s)? *(Include number of outages for each cause.)*

Drought _____ Limited Supply _____

System Failure _____ Other _____

7. Has the system ever had a water audit or a leak evaluation?

YES ☐ NO ☐ Don't Know ☐

If YES, please complete the following table.

Type of Investigation	Date Done	Water Loss (%)	What approach or technology was used to complete the investigation?	Was any follow-up done? If so, describe

8. Have all drinking water projects received NMED review and approval? [20 NMAC 7.10.201]

YES ☐ NO ☐

If NO, what types of projects have not received NMED review and approval.

Source ☐ Storage ☐

Treatment ☐ Distribution ☐

Other ☐ _____

9. What are the typical customer complaints that the utility receives?

10. Approximately how many complaints are there per month? _____

11. How are customer complaints handled? Are they recorded?

12. What is the age and composition of the distribution system? *(Collect this information from the Sanitary Survey)*

Pipe Material	Approximate Age	Percentage of the system	Comments
			Sanitary Survey Distribution System Records Attached

13. Are there any dead end lines in the system?
 YES ☐ NO ☐

14. Does the system have a flushing program?
 YES ☐ NO ☐

If YES, please describe.

15. Are there any pressure problems within the system?
 YES ☐ NO ☐

If YES, please describe.

16. Does the system disinfect the finished water?
 YES ☐ NO ☐

If yes, which disinfectant product is used? _____

Interviewer Comments on Technical Capacity:

B. Managerial Capacity Assessment Questions

17. Has the system completed a 5-year Infrastructure Capital Improvement Plan (ICIP) plan?

YES ☐ NO ☐

If YES, has the plan been submitted to Local Government Division?

YES ☐ NO ☐

18. Does the system have written operating procedures?

YES ☐ NO ☐

19. Does the system have written job descriptions for all staff?

YES ☐ NO ☐

20. Does the system have:
- | | | | |
|-------------------------------------|--------------------------|-----|--------------------------|
| A preventative maintenance plan? | | | |
| YES | ☐ | NO | ☐ |
| A source water protection plan? | | | |
| YES | ☐ | NO | ☐ |
| | | N/A | ☐ |
| An emergency plan? | | | |
| YES | ☐ | NO | ☐ |
| A cross-connection control program? | | | |
| YES | ☐ | NO | ☐ |
| An emergency source? | | | |
| YES | ☐ | NO | ☐ |
| System security measures? | | | |
| YES | ☐ | NO | ☐ |
21. Does the system report and maintain records in accordance with the drinking water regulations concerning:
- | | | | |
|--------------------------|--------------------------|----|--------------------------|
| Water quality violations | | | |
| YES | ☐ | NO | ☐ |
| Public notification | | | |
| YES | ☐ | NO | ☐ |
| Sampling exemptions | | | |
| YES | ☐ | NO | ☐ |
22. Please describe how the above records are maintained:
23. Describe the management structure for the water system, including board and operations staff. Please include examples of duties, if possible.
24. Please describe type and quantity of training or continuing education for staff identified above.
25. Describe last major project undertaken by the water system, including the following: project in detail, positive aspects, negative aspects, the way in which the project was funded, any necessary rate increases, the public response to the project, whether the project is complete or not, and any other pertinent information.

26. Does the system have any debt? YES ☐ NO ☐

If yes, is the system current with all debt payments?

YES ☐ NO ☐

If no, describe the applicable funding agency and the default.

27. Is the system currently contemplating or actively seeking funding for any project?

YES ☐ NO ☐

If yes, from which agency and how much?

Describe the project?

Is the system receiving assistance from any agency or organization in its efforts?

28. Will the system consider any type of regionalization with other PWS? (Check YES if the system has already regionalized.)

YES ☐ NO ☐

If YES, what type of regionalization has been implemented/considered/discussed? (Check all that apply.)

System interconnection ☐

Sharing operator ☐

Sharing bookkeeper ☐

Purchasing water ☐

Emergency water connection ☐

Other: _____

29. Does the system have any of the following? (Check all that apply.)

Water Conservation Policy/Ordinance ☐ Current Drought Plan ☐

Water Use Restrictions ☐ Water Supply Emergency Plan ☐

Interviewer Comments on Managerial Capacity:

C. Financial Capacity Assessment

30. Does the system have a budget?

YES ☐ NO ☐

If YES, what type of budget?

Operating Budget ☐Capital Budget ☐

31. Have the system revenues covered expenses and debt service for the past 5 years?

YES ☐ NO ☐

If NO, how many years has the system had a shortfall? _____

32. Does the system have a written/adopted rate structure?

YES ☐ NO ☐

33. What was the date of the last rate increase? _____

34. Are rates reviewed annually?

YES ☐ NO ☐

If YES, what was the date of the last review? _____

35. Did the rate review show that the rates covered the following expenses? *(Check all that apply.)*Operation & Maintenance ☐Infrastructure Repair & replacement ☐Staffing ☐Emergency/Reserve fund ☐Debt payment ☐

36. Is the rate collection above 90% of the customers?

YES ☐ NO ☐

37. Is there a cut-off policy for customers who are in arrears with their bill or for illegal connections?

YES ☐ NO ☐

If yes, is this policy implemented?

38. What is the residential water rate for 6,000 gallons of usage in one month. _____

39. In the past 12 months, how many customers have had accounts frozen or dropped for non-payment? _____

[Convert to % of active connections]

Less than 1% ☐ 1% - 3% ☐ 4% - 5% ☐ 6% - 10% ☐11% - 20% ☐ 21% - 50% ☐ Greater than 50% ☐]

40. The following questions refer to the process of obtaining needed equipment and supplies.

a. Can the water system operator buy or obtain supplies or equipment when they are needed?

YES ☐ NO ☐

b. Is the process simple or burdensome to the employees?

c. Can supplies or equipment be obtained quickly during an emergency?

YES ☐ NO ☐

d. Has the water system operator ever experienced a situation in which he/she couldn't purchase the needed supplies?

YES ☐ NO ☐

e. Does the system maintain some type of spare parts inventory?

YES ☐ NO ☐

If yes, please describe.

41. Has the system ever had a financial audit?

YES ☐ NO ☐

If YES, what is the date of the most recent audit? _____

42. Has the system ever had its electricity or phone turned off due to non-payment? Please describe.

Interviewer Comments on Financial Assessment:

43. What do you think the system capabilities are now and what are the issues you feel your system will be facing in the future? In addition, are there any specific needs, such as types of training that you would like to see addressed by NMED or its contractors?

APPENDIX B COST BASIS

This section presents the basis for unit costs used to develop the conceptual cost estimates for the compliance alternatives. Cost estimates are conceptual in nature (+50%/-30%), and are intended to make comparisons between compliance options and to provide a preliminary indication of possible rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. Capital cost includes an allowance for engineering and construction management. It is assumed that adequate electrical power is available near the site. The cost estimates specifically do not include costs for the following:

- Obtaining land or easements.
- Surveying.
- Mobilization/demobilization for construction.
- Insurance and bonds

In general, unit costs are based on recent construction bids for similar work in the area; when possible, consultations with vendors or other suppliers; published construction and O&M cost data; and USEPA cost guidance. Unit costs used for the cost estimates are summarized in Table B.1.

Unit costs for pipeline components are based on 2008 RS Means Site Work & Landscape Cost Data. The number of borings and encasements and open cuts and encasements is estimated by counting the road, highway, railroad, stream, and river crossings for a conceptual routing of the pipeline. The number of air release valves is estimated by examining the land surface profile along the conceptual pipeline route. It is assumed that gate valves and flush valves would be installed, on average, every 5,000 feet along the pipeline. Pipeline cost estimates are based on the use of C-900 PVC pipe. Other pipe materials could be considered for more detailed development of attractive alternatives.

Pump station unit costs are based on experience with similar installations. The cost estimate for the pump stations include two pumps, station piping and valves, station electrical and instrumentation, minor site improvement, installation of a concrete pad, fence and building, and tools. The number of pump stations is based on calculations of pressure losses in the proposed pipeline for each alternative. Back-flow prevention is required in cases where pressure losses are negligible, and pump stations are not needed. Construction cost of a storage tank is based on consultations with vendors and 2008 RS Means Site Work & Landscape Cost Data.

Labor costs are estimated based on 2008 RS Means Site Work & Landscape Cost Data specific to the Lubbock County region.

Electrical power cost is estimated to be \$0.165 per kWh, as supplied by Caprock Energy Co. The annual cost for power to a pump station is calculated based on the pumping head and volume, and includes 11,800 kWh for pump building heating, cooling, and lighting, as recommended in USEPA publication, *Standardized Costs for Water Supply Distribution Systems* (1992).

In addition to the cost of electricity, pump stations have other maintenance costs. These costs cover: materials for minor repairs to keep the pumps operating; purchase of a maintenance vehicle, fuel costs, and vehicle maintenance costs; utilities; office supplies, small tools and equipment; and miscellaneous materials such as safety, clothing, chemicals, and paint. The non-power O&M costs are estimated based on the USEPA publication, *Standardized Costs for Water Supply Distribution Systems* (1992), which provides cost curves for O&M components. Costs from the 1992 report are adjusted to 2008 dollars based on the ENR construction cost index.

Pipeline maintenance costs include routine cleaning and flushing, as well as minor repairs to lines. The unit rate for pipeline maintenance is calculated based on the USEPA technical report, *Innovative and Alternate Technology Assessment Manual MCD 53* (1978). Costs from the 1978 report are adjusted to 2008 dollars based on the ENR construction cost index.

Storage tank maintenance costs include cleaning and renewal of interior lining and exterior coating. Unit costs for storage tank O&M are based on USEPA publication *Standardized Costs for Water Supply Distribution Systems* (1992). Costs from the 1992 report are adjusted to 2008 dollars based on the ENR construction cost index.

The purchase price for point-of-use (POU) water treatment units is based on vendor price lists for treatment units, plus installation. O&M costs for POU treatment units are also based on vendor price lists. It is assumed that a yearly water sample would be analyzed for the contaminant of concern.

The purchase price for point-of-entry (POE) water treatment units is based on vendor price lists for treatment units, plus an allowance for installation, including a concrete pad and shed, piping modifications, and electrical connection. O&M costs for POE treatment units are also based on vendor price lists. It is assumed that a yearly water sample would be analyzed for the contaminant of concern.

Central treatment plant costs include pricing for buildings, utilities, and site work. Costs are based on pricing given in the various R.S. Means Construction Cost Data References, as well as prices obtained from similar work on other projects. Pricing for treatment equipment was obtained from vendors.

Well installation costs are based on 2008 R.S. Means Site Work & Landscape Cost Data. Well installation costs include drilling, a well pump, electrical and instrumentation installation, well finishing, piping, and water quality testing. O&M costs for water wells include power, materials, and labor. It is assumed that new wells located more than 1 mile from the intake point of an existing system would require a storage tank and pump station.

1 Purchase price for the treatment unit dispenser is based on vendor price lists, plus an
2 allowance for installation at a centralized public location. The O&M costs are also based on
3 vendor price lists. It is assumed that weekly water samples would be analyzed for the
4 contaminant of concern.

5 Costs for bottled water delivery alternatives are based on consultation with vendors that
6 deliver residential bottled water. The cost estimate includes an initial allowance for set-up of
7 the program, and a yearly allowance for program administration.

8 The cost estimate for a public dispenser for trucked water includes the purchase price for a
9 water truck and construction of a storage tank. Annual costs include labor for purchasing the
10 water, picking up and delivering the water, truck maintenance, and water sampling and testing.
11 It is assumed the water truck would be required to make one trip each week, and that chlorine
12 residual would be determined for each truck load.

13

Table B.1
Summary of General Data
Twin Oaks Mobile Home Park
1650057
General PWS Information

Service Population	234	Number of Connections	78
Total PWS Daily Water Usage	0.017 (mgd)	Source	Site visit list

Unit Cost Data

General Items	Unit	Unit Cost	Central Treatment Unit Costs	Unit	Unit Cost
Treated water purchase cost	<i>See alternative</i>		General		
Water purchase cost (trucked)	\$/1,000 gals	\$ 1.09	Site preparation	acre	\$ 4,000
			Slab	CY	\$ 1,000
Contingency	20%	n/a	Building	SF	\$ 60
Engineering & Constr. Management	25%	n/a	Building electrical	SF	\$ 8.00
Procurement/admin (POU/POE)	20%	n/a	Building plumbing	SF	\$ 8.00
			Heating and ventilation	SF	\$ 7.00
Pipeline Unit Costs	Unit	Unit Cost	Fence	LF	\$ 15
PVC water line, Class 200, 04"	LF	\$ 12	Paving	SF	\$ 2.00
Bore and encasement, 10"	LF	\$ 240	General O&M		
Open cut and encasement, 10"	LF	\$ 130	Building power	kwh/yr	\$ 0.165
Gate valve and box, 04"	EA	\$ 710	Equipment power	kwh/yr	\$ 0.165
Air valve	EA	\$ 2,050	Labor, O&M	hr	\$ 40
Flush valve	EA	\$ 1,025	Analyses	test	\$ 200
Metal detectable tape	LF	\$ 2.00			
			Reject Pond		
Bore and encasement, length	Feet	200	Reject pond, excavation	CYD	\$ 3,000
Open cut and encasement, length	Feet	50	Reject pond, compacted fill	CYD	\$ 7,000
			Reject pond, lining	SF	\$ 2
Pump Station Unit Costs	Unit	Unit Cost	Reject pond, vegetation	SY	\$ 2
Pump	EA	\$ 8,000	Reject pond, access road	LF	\$ 30
Pump Station Piping, 04"	EA	\$ 550	Reject water haulage truck	EA	\$ 100,000
Gate valve, 04"	EA	\$ 710	Water haulage truck	day	\$ 250
Check valve, 04"	EA	\$ 755			
Electrical/Instrumentation	EA	\$ 10,250	Reverse Osmosis		
Site work	EA	\$ 2,560	Electrical	JOB	\$ 40,000
Building pad	EA	\$ 5,125	Piping	JOB	\$ 20,000
Pump Building	EA	\$ 10,250	RO package plant	UNIT	\$ 138,000
Fence	EA	\$ 6,150	Transfer pumps (5 hp)	EA	\$ 5,000
Tools	EA	\$ 1,025	Permeate/product tank	gal	\$ 3
5,000 gal feed tank	EA	\$ 10,000	RO materials and chemicals	kgal	\$ 0.75
Backflow preventer, 4"	EA	\$ 2,295	RO chemicals	year	\$ 2,000.00
Backflow Testing/Certification	EA	\$ 105	Backwash disposal mileage cost	miles	\$ 1.50
			Backwash disposal fee	1,000 gal/yr	\$ 5.00
Well Installation Unit Costs	Unit	Unit Cost			
Well installation	<i>See alternative</i>		EDR		
Water quality testing	EA	\$ 1,280	Electrical	JOB	\$ 50,000.00
5HP Well Pump	EA	\$ 2,750	Piping	JOB	\$ 20,000
Well electrical/Instrumentation	EA	\$ 5,635	Product storage tank	gal	\$ 3
Well cover and base	EA	\$ 3,075	EDR package plant	UNIT	\$ 165,000
Piping	EA	\$ 3,075	EDR materials	kgal	\$ 0.48
10,000 gal ground storage tank	EA	\$ 15,000	EDR chemicals	kgal	\$ 0.40
			Backwash disposal mileage cost	miles	\$ 1.50
Electrical Power	\$/kWH	\$ 0.165	Backwash disposal fee	1,000 gal/yr	\$ 5
Building Power	kWH	11,800	Transfer pumps (5 hp)	EA	\$ 5,000
Labor	\$/hr	\$ 60			
Materials	EA	\$ 1,540	Ion Exchange		
Transmission main O&M	\$/mile	\$ 275	Electrical	JOB	\$ 35,000
Tank O&M	EA	\$ 1,025	Piping	JOB	\$ 18,000.00
			IX package plant	UNIT	\$ 130,000.00
POU/POE Unit Costs			Backwash tank	GAL	\$ 2.00
POU treatment unit purchase	EA	\$ 615	Sewer connection fee	EA	\$ 15,000
POU treatment unit installation	EA	\$ 155	Supplies and Materials	YR	\$ 4,000
POE treatment unit purchase	EA	\$ 5,125	Resin replacement/disposal	CF	\$ 220
POE - pad and shed, per unit	EA	\$ 2,050			
POE - piping connection, per unit	EA	\$ 1,025	Spent regenerate disposal	1000 gallons	\$ 5
POE - electrical hook-up, per unit	EA	\$ 1,025			
POU Treatment O&M, per unit	\$/year	\$ 230			
POE Treatment O&M, per unit	\$/year	\$ 1,540			
Treatment analysis	\$/year	\$ 205			
POU/POE labor support	\$/hr	\$ 40			
Dispenser/Bottled Water Unit Costs					
POE-Treatment unit purchase	EA	\$ 7,175			
POE-Treatment unit installation	EA	\$ 5,125			
Treatment unit O&M	EA	\$ 2,050			
Administrative labor	hr	\$ 45			
Bottled water cost (inc. delivery)	gallon	\$ 1.00			
Water use, per capita per day	gpcd	1.0			
Bottled water program materials	EA	\$ 5,125			
5,000 gal ground storage tank	EA	\$ 10,000			
Site improvements	EA	\$ 3,075			

APPENDIX C
COMPLIANCE ALTERNATIVE CONCEPTUAL COST ESTIMATES

This appendix presents the conceptual cost estimates developed for the compliance alternatives. The conceptual cost estimates are given in Tables C.1 through C.15. The cost estimates are conceptual in nature (+50%/-30%), and are intended for making comparisons between compliance options and to provide a preliminary indication of possible water rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation.

Table C.1

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *Purchase Water from City of Midland*
Alternative Number *TO-1*

Distance from Alternative to PWS (along pipe) 4.0 miles
Total PWS annual water usage 6.205 MG
Treated water purchase cost \$ 1.09 per 1,000 gals
Pump Stations needed w/ 1 feed tank each 1
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	8	n/a	n/a	n/a
PVC water line, Class 200, 04"	21,161	LF	\$ 12	\$ 253,932
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	400	LF	\$ 130	\$ 52,000
Gate valve and box, 04"	4	EA	\$ 710	\$ 3,005
Air valve	8	EA	\$ 2,050	\$ 16,400
Flush valve	4	EA	\$ 1,025	\$ 4,338
Metal detectable tape	21,161	LF	\$ 2	\$ 42,322
Subtotal				\$ 371,997

Pump Station(s) Installation

Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 04"	1	EA	\$ 550	\$ 550
Gate valve, 04"	4	EA	\$ 710	\$ 2,840
Check valve, 04"	2	EA	\$ 755	\$ 1,510
Electrical/Instrumentation	1	EA	\$ 10,250	\$ 10,250
Site work	1	EA	\$ 2,560	\$ 2,560
Building pad	1	EA	\$ 5,125	\$ 5,125
Pump Building	1	EA	\$ 10,250	\$ 10,250
Fence	1	EA	\$ 6,150	\$ 6,150
Tools	1	EA	\$ 1,025	\$ 1,025
5,000 gal feed tank	1	EA	\$ 10,000	\$ 10,000
10,000 gal ground storage tank	-	EA	\$ 15,000	\$ -
Backflow Preventor	-	EA	\$ 2,295	\$ -
Subtotal				\$ 66,260

Subtotal of Component Costs **\$ 438,257**

Contingency 20% \$ 87,651
Design & Constr Management 25% \$ 109,564

TOTAL CAPITAL COSTS **\$ 638,472**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	4.0	mile	\$ 275	\$ 1,102
Subtotal				\$ 1,102
<i>Water Purchase Cost</i>				
From PWS	6,205	1,000 gal	\$ 1.09	\$ 6,763
Subtotal				\$ 6,763

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.165	\$ 1,948
Pump Power	2,619	kWH	\$ 0.165	\$ 432
Materials	1	EA	\$ 1,540	\$ 1,540
Labor	365	Hrs	\$ 60.00	\$ 21,900
Tank O&M	-	EA	\$ 1,025	\$ -
Backflow Test/Cert	-	EA	\$ 105	\$ -
Subtotal				\$ 25,821

O&M Credit for Existing Well Closure

Pump power	4,927	kWH	\$ 0.165	\$ (813)
Well O&M matl	2	EA	\$ 1,540	\$ (3,080)
Well O&M labor	360	Hrs	\$ 60	\$ (21,600)
Subtotal				\$ (25,493)

TOTAL ANNUAL O&M COSTS **\$ 8,193**

Table C.2

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *Purchase Water from Midland International Airport*
Alternative Number *TO-2*

Distance from Alternative to PWS (along pipe) 11.3 miles
Total PWS annual water usage 6,205 MG
Treated water purchase cost \$ 1.09 per 1,000 gals
Pump Stations needed w/ 1 feed tank each 1
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	3	n/a	n/a	n/a
Number of Crossings, open cut	10	n/a	n/a	n/a
PVC water line, Class 200, 04"	59,480	LF	\$ 12	\$ 713,760
Bore and encasement, 10"	600	LF	\$ 240	\$ 144,000
Open cut and encasement, 10"	500	LF	\$ 130	\$ 65,000
Gate valve and box, 04"	12	EA	\$ 710	\$ 8,446
Air valve	20	EA	\$ 2,050	\$ 41,000
Flush valve	12	EA	\$ 1,025	\$ 12,193
Metal detectable tape	59,480	LF	\$ 2	\$ 118,960
Subtotal				\$ 1,103,360

Pump Station(s) Installation

Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 04"	1	EA	\$ 550	\$ 550
Gate valve, 04"	4	EA	\$ 710	\$ 2,840
Check valve, 04"	2	EA	\$ 755	\$ 1,510
Electrical/Instrumentation	1	EA	\$ 10,250	\$ 10,250
Site work	1	EA	\$ 2,560	\$ 2,560
Building pad	1	EA	\$ 5,125	\$ 5,125
Pump Building	1	EA	\$ 10,250	\$ 10,250
Fence	1	EA	\$ 6,150	\$ 6,150
Tools	1	EA	\$ 1,025	\$ 1,025
5,000 gal feed tank	1	EA	\$ 10,000	\$ 10,000
10,000 gal ground storage tank	-	EA	\$ 15,000	\$ -
Backflow Preventor	-	EA	\$ 2,295	\$ -
Subtotal				\$ 66,260

Subtotal of Component Costs **\$ 1,169,620**

Contingency 20% \$ 233,924
Design & Constr Management 25% \$ 292,405

TOTAL CAPITAL COSTS **\$ 1,695,948**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	11.3	mile	\$ 275	\$ 3,098
Subtotal				\$ 3,098
<i>Water Purchase Cost</i>				
From PWS	6,205	1,000 gal	\$ 1.09	\$ 6,763
Subtotal				\$ 6,763

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.165	\$ 1,948
Pump Power	1,645	kWH	\$ 0.165	\$ 272
Materials	1	EA	\$ 1,540	\$ 1,540
Labor	365	Hrs	\$ 60.00	\$ 21,900
Tank O&M	-	EA	\$ 1,025	\$ -
Backflow Test/Cert	0	EA	\$ 105	\$ -
Subtotal				\$ 25,660

O&M Credit for Existing Well Closure

Pump power	4,927	kWH	\$ 0.165	\$ (813)
Well O&M matl	2	EA	\$ 1,540	\$ (3,080)
Well O&M labor	360	Hrs	\$ 60	\$ (21,600)
Subtotal				\$ (25,493)

TOTAL ANNUAL O&M COSTS **\$ 10,028**

Table C.3

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *Purchase Water from Odessa*
Alternative Number *TO-3*

Distance from Alternative to PWS (along pipe) 14.6 miles
Total PWS annual water usage 6,205 MG
Treated water purchase cost \$ 4.93 per 1,000 gals
Pump Stations needed w/ 1 feed tank each 1
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	18	n/a	n/a	n/a
PVC water line, Class 200, 04"	76,833	LF	\$ 12	\$ 921,996
Bore and encasement, 10"	400	LF	\$ 240	\$ 96,000
Open cut and encasement, 10"	900	LF	\$ 130	\$ 117,000
Gate valve and box, 04"	15	EA	\$ 710	\$ 10,910
Air valve	23	EA	\$ 2,050	\$ 47,150
Flush valve	15	EA	\$ 1,025	\$ 15,751
Metal detectable tape	76,833	LF	\$ 2	\$ 153,666
Subtotal				\$ 1,362,473

Pump Station(s) Installation

Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 04"	1	EA	\$ 550	\$ 550
Gate valve, 04"	4	EA	\$ 710	\$ 2,840
Check valve, 04"	2	EA	\$ 755	\$ 1,510
Electrical/Instrumentation	1	EA	\$ 10,250	\$ 10,250
Site work	1	EA	\$ 2,560	\$ 2,560
Building pad	1	EA	\$ 5,125	\$ 5,125
Pump Building	1	EA	\$ 10,250	\$ 10,250
Fence	1	EA	\$ 6,150	\$ 6,150
Tools	1	EA	\$ 1,025	\$ 1,025
5,000 gal feed tank	1	EA	\$ 10,000	\$ 10,000
10,000 gal ground storage tank	-	EA	\$ 15,000	\$ -
Backflow Preventor	0	EA	\$ 2,295	\$ -
Subtotal				\$ 66,260

Subtotal of Component Costs **\$ 1,428,733**

Contingency 20% \$ 285,747
Design & Constr Management 25% \$ 357,183

TOTAL CAPITAL COSTS **\$ 2,071,663**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	14.6	mile	\$ 275	\$ 4,002
Subtotal				\$ 4,002
<i>Water Purchase Cost</i>				
From PWS	6,205	1,000 gal	\$ 4.93	\$ 30,591
Subtotal				\$ 30,591

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.165	\$ 1,948
Pump Power	2,264	kWH	\$ 0.165	\$ 374
Materials	1	EA	\$ 1,540	\$ 1,540
Labor	365	Hrs	\$ 60.00	\$ 21,900
Tank O&M	-	EA	\$ 1,025	\$ -
Backflow Test/Cert	0	EA	\$ 105	\$ -
Subtotal				\$ 25,762

O&M Credit for Existing Well Closure

Pump power	4,927	kWH	\$ 0.165	\$ (813)
Well O&M matl	2	EA	\$ 1,540	\$ (3,080)
Well O&M labor	360	Hrs	\$ 60	\$ (21,600)
Subtotal				\$ (25,493)

TOTAL ANNUAL O&M COSTS **\$ 34,861**

Table C.4

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *New Well at 10 Miles*
Alternative Number *TO-4*

Distance from PWS to new well location 10.0 miles
 Estimated well depth 110 feet
 Number of wells required 1
 Well installation cost (location specific) \$148 per foot
 Pump Stations needed w/ 1 feed tank each 2
 On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	12	n/a	n/a	n/a
PVC water line, Class 200, 04"	52,800	LF	\$ 12	\$ 633,600
Bore and encasement, 10"	400	LF	\$ 240	\$ 96,000
Open cut and encasement, 10"	600	LF	\$ 130	\$ 78,000
Gate valve and box, 04"	11	EA	\$ 710	\$ 7,498
Air valve	17	EA	\$ 2,050	\$ 34,850
Flush valve	11	EA	\$ 1,025	\$ 10,824
Metal detectable tape	52,800	LF	\$ 2	\$ 105,600
Subtotal				\$ 966,372
<i>Pump Station(s) Installation</i>				
Pump	4	EA	\$ 8,000	\$ 32,000
Pump Station Piping, 04"	2	EA	\$ 550	\$ 1,100
Gate valve, 04"	8	EA	\$ 710	\$ 5,680
Check valve, 04"	4	EA	\$ 755	\$ 3,020
Electrical/Instrumentation	2	EA	\$ 10,250	\$ 20,500
Site work	2	EA	\$ 2,560	\$ 5,120
Building pad	2	EA	\$ 5,125	\$ 10,250
Pump Building	2	EA	\$ 10,250	\$ 20,500
Fence	2	EA	\$ 6,150	\$ 12,300
Tools	2	EA	\$ 1,025	\$ 2,050
5,000 gal feed tank	2	EA	\$ 10,000	\$ 20,000
10,000 gal ground storage tank	-	EA	\$ 15,000	\$ -
Subtotal				\$ 132,520
<i>Well Installation</i>				
Well installation	110	LF	\$ 148	\$ 16,280
Water quality testing	2	EA	\$ 1,280	\$ 2,560
Well pump	1	EA	\$ 2,750	\$ 2,750
Well electrical/instrumentation	1	EA	\$ 5,635	\$ 5,635
Well cover and base	1	EA	\$ 3,075	\$ 3,075
Piping	1	EA	\$ 3,075	\$ 3,075
Subtotal				\$ 33,375

Subtotal of Component Costs **\$ 1,132,267**

Contingency 20% \$ 226,453
 Design & Constr Management 25% \$ 283,067

TOTAL CAPITAL COSTS **\$ 1,641,787**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	10.0	mile	\$ 275	\$ 2,750
Subtotal				\$ 2,750
<i>Pump Station(s) O&M</i>				
Building Power	23,600	kWH	\$ 0.165	\$ 3,896
Pump Power	2,189	kWH	\$ 0.165	\$ 361
Materials	2	EA	\$ 1,540	\$ 3,080
Labor	730	Hrs	\$ 60.00	\$ 43,800
Tank O&M	-	EA	\$ 1,025	\$ -
Subtotal				\$ 51,138
<i>Well O&M</i>				
Pump power	5,042	kWH	\$ 0.165	\$ 832
Well O&M matl	1	EA	\$ 1,540	\$ 1,540
Well O&M labor	180	Hrs	\$ 60	\$ 10,800
Subtotal				\$ 13,172
<i>O&M Credit for Existing Well Closure</i>				
Pump power	4,927	kWH	\$ 0.165	\$ (813)
Well O&M matl	2	EA	\$ 1,540	\$ (3,080)
Well O&M labor	360	Hrs	\$ 60	\$ (21,600)
Subtotal				\$ (25,493)

TOTAL ANNUAL O&M COSTS **\$ 41,567**

Table C.5

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *New Well at 5 Miles*
Alternative Number *TO-5*

Distance from PWS to new well location 5.0 miles
 Estimated well depth 110 feet
 Number of wells required 1
 Well installation cost (location specific) \$148 per foot
 Pump Stations needed w/ 1 feed tank each 1
 On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	6	n/a	n/a	n/a
PVC water line, Class 200, 04"	26,400	LF	\$ 12	\$ 316,800
Bore and encasement, 10"	200	LF	\$ 240	\$ 48,000
Open cut and encasement, 10"	300	LF	\$ 130	\$ 39,000
Gate valve and box, 04"	5	EA	\$ 710	\$ 3,749
Air valve	9	EA	\$ 2,050	\$ 18,450
Flush valve	5	EA	\$ 1,025	\$ 5,412
Metal detectable tape	26,400	LF	\$ 2	\$ 52,800
Subtotal				\$ 484,211
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 04"	1	EA	\$ 550	\$ 550
Gate valve, 04"	4	EA	\$ 710	\$ 2,840
Check valve, 04"	2	EA	\$ 755	\$ 1,510
Electrical/Instrumentation	1	EA	\$ 10,250	\$ 10,250
Site work	1	EA	\$ 2,560	\$ 2,560
Building pad	1	EA	\$ 5,125	\$ 5,125
Pump Building	1	EA	\$ 10,250	\$ 10,250
Fence	1	EA	\$ 6,150	\$ 6,150
Tools	1	EA	\$ 1,025	\$ 1,025
5,000 gal feed tank	1	EA	\$ 10,000	\$ 10,000
10,000 gal ground storage tank	-	EA	\$ 15,000	\$ -
Subtotal				\$ 66,260
<i>Well Installation</i>				
Well installation	110	LF	\$ 148	\$ 16,280
Water quality testing	2	EA	\$ 1,280	\$ 2,560
Well pump	1	EA	\$ 2,750	\$ 2,750
Well electrical/instrumentation	1	EA	\$ 5,635	\$ 5,635
Well cover and base	1	EA	\$ 3,075	\$ 3,075
Piping	1	EA	\$ 3,075	\$ 3,075
Subtotal				\$ 33,375

Subtotal of Component Costs **\$ 583,846**

Contingency 20% \$ 116,769
 Design & Constr Management 25% \$ 145,961

TOTAL CAPITAL COSTS **\$ 846,576**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	5.0	mile	\$ 275	\$ 1,375
Subtotal				\$ 1,375
<i>Pump Station(s) O&M</i>				
Building Power	11,800	kWH	\$ 0.165	\$ 1,948
Pump Power	1,094	kWH	\$ 0.165	\$ 181
Materials	1	EA	\$ 1,540	\$ 1,540
Labor	365	Hrs	\$ 60.00	\$ 21,900
Tank O&M	-	EA	\$ 1,025	\$ -
Subtotal				\$ 25,569
<i>Well O&M</i>				
Pump power	5,042	kWH	\$ 0.165	\$ 832
Well O&M matl	1	EA	\$ 1,540	\$ 1,540
Well O&M labor	180	Hrs	\$ 60	\$ 10,800
Subtotal				\$ 13,172
<i>O&M Credit for Existing Well Closure</i>				
Pump power	4,927	kWH	\$ 0.165	\$ (813)
Well O&M matl	2	EA	\$ 1,540	\$ (3,080)
Well O&M labor	360	Hrs	\$ 60	\$ (21,600)
Subtotal				\$ (25,493)

TOTAL ANNUAL O&M COSTS **\$ 14,623**

Table C.6

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *New Well at 1 Mile*
Alternative Number *TO-6*

Distance from PWS to new well location 1.0 miles
 Estimated well depth 110 feet
 Number of wells required 1
 Well installation cost (location specific) \$148 per foot
 Pump Stations needed w/ 1 feed tank each 0
 On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	5,280	LF	\$ 12	\$ 63,360
Bore and encasement, 10"	-	LF	\$ 240	-
Open cut and encasement, 10"	50	LF	\$ 130	\$ 6,500
Gate valve and box, 04"	1	EA	\$ 710	\$ 750
Air valve	2	EA	\$ 2,050	\$ 4,100
Flush valve	1	EA	\$ 1,025	\$ 1,082
Metal detectable tape	5,280	LF	\$ 2	\$ 10,560
Subtotal				\$ 86,352
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 8,000	\$ -
Pump Station Piping, 04"	-	EA	\$ 550	\$ -
Gate valve, 04"	-	EA	\$ 710	\$ -
Check valve, 04"	-	EA	\$ 755	\$ -
Electrical/Instrumentation	-	EA	\$ 10,250	\$ -
Site work	-	EA	\$ 2,560	\$ -
Building pad	-	EA	\$ 5,125	\$ -
Pump Building	-	EA	\$ 10,250	\$ -
Fence	-	EA	\$ 6,150	\$ -
Tools	-	EA	\$ 1,025	\$ -
5,000 gal feed tank	-	EA	\$ 10,000	\$ -
10,000 gal ground storage tank	-	EA	\$ 15,000	\$ -
Subtotal				\$ -
<i>Well Installation</i>				
Well installation	110	LF	\$ 148	\$ 16,280
Water quality testing	2	EA	\$ 1,280	\$ 2,560
Well pump	1	EA	\$ 2,750	\$ 2,750
Well electrical/instrumentation	1	EA	\$ 5,635	\$ 5,635
Well cover and base	1	EA	\$ 3,075	\$ 3,075
Piping	1	EA	\$ 3,075	\$ 3,075
Subtotal				\$ 33,375

Subtotal of Component Costs **\$ 119,727**

Contingency 20% \$ 23,945
 Design & Constr Management 25% \$ 29,932

TOTAL CAPITAL COSTS **\$ 173,604**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	1.0	mile	\$ 275	\$ 275
Subtotal				\$ 275
<i>Pump Station(s) O&M</i>				
Building Power	-	kWH	\$ 0.165	\$ -
Pump Power	-	kWH	\$ 0.165	\$ -
Materials	-	EA	\$ 1,540	\$ -
Labor	-	Hrs	\$ 60.00	\$ -
Tank O&M	-	EA	\$ 1,025	\$ -
Subtotal				\$ -
<i>Well O&M</i>				
Pump power	5,042	kWH	\$ 0.165	\$ 832
Well O&M matl	1	EA	\$ 1,540	\$ 1,540
Well O&M labor	180	Hrs	\$ 60	\$ 10,800
Subtotal				\$ 13,172
<i>O&M Credit for Existing Well Closure</i>				
Pump power	2,464	kWH	\$ 0.165	\$ (407)
Well O&M matl	1	EA	\$ 1,540	\$ (1,540)
Well O&M labor	180	Hrs	\$ 60	\$ (10,800)
Subtotal				\$ (12,747)

TOTAL ANNUAL O&M COSTS **\$ 701**

Table C.7

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *Central Treatment - Reverse Osmosis*
Alternative Number *TO-7*

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Reverse Osmosis Unit Purchase/Installation</i>				
Site preparation	0.50	acre	\$ 4,000	\$ 2,000
Slab	30	CY	\$ 1,000	\$ 30,000
Building	600	SF	\$ 60	\$ 36,000
Building electrical	600	SF	\$ 8	\$ 4,800
Building plumbing	600	SF	\$ 8	\$ 4,800
Heating and ventilation	600	SF	\$ 7	\$ 4,200
Fence	500	LF	\$ 15	\$ 7,500
Paving	3,000	SF	\$ 2	\$ 6,000
Electrical	1	JOB	\$ 40,000	\$ 40,000
Piping	1	JOB	\$ 20,000	\$ 20,000
Reverse osmosis package including:				
High pressure pumps - 20 hp				
Cartridge filters and vessels				
RO membranes and vessels				
Control system				
Chemical feed systems				
Freight cost				
Vendor start-up services	1	UNIT	\$ 138,000	\$ 138,000
Transfer pumps	4	EA	\$ 5,000	\$ 20,000
Permeate tank	5,000	gal	\$ 3	\$ 15,000
Feed Tank	15,000	gal	\$ 3	\$ 45,000
Reject pond:				
Excavation	1,300	CYD	\$ 3.00	\$ 3,900
Compacted fill	1,040	CYD	\$ 7.00	\$ 7,280
Lining	2,600	SF	\$ 1.50	\$ 3,900
Vegetation	1,050	SY	\$ 1.50	\$ 1,575
Access road	500	LF	\$ 30.00	\$ 15,000
Subtotal of Design/Construction Costs				\$ 404,955
Contingency	20%		\$	80,991
Design & Constr Management	25%		\$	101,239
Reject water haulage truck	1	EA	\$ 100,000	\$ 100,000
TOTAL CAPITAL COSTS			\$ 687,185	

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Reverse Osmosis Unit O&M</i>				
Building Power	5,500	kwh/yr	\$ 0.165	\$ 908
Equipment power	37,000	kwh/yr	\$ 0.165	\$ 6,105
Labor	1,000	hrs/yr	\$ 40.00	\$ 40,000
RO materials and Chemicals	6,000	kgal	\$ 0.75	\$ 4,500
Analyses	24	test	\$ 200	\$ 4,800
Subtotal				\$ 56,313
<i>Reject (brine) disposal</i>				
Disposal truck mileage	7,300	miles	\$ 1.50	\$ 10,950
Reject (brine) disposal fee	2,015	kgal/yr	\$ 5.00	\$ 10,074
Subtotal				\$ 21,024

TOTAL ANNUAL O&M COSTS

\$ 77,337

Table C.8

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *Central Treatment - Electro-dialysis Reversal*
Alternative Number *TO-8*

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Reverse Osmosis Unit Purchase/Installation</i>				
Site preparation	0.40	acre	\$ 4,000	\$ 1,600
Slab	25	CY	\$ 1,000	\$ 25,000
Building	500	SF	\$ 60	\$ 30,000
Building electrical	500	SF	\$ 8	\$ 4,000
Building plumbing	500	SF	\$ 8	\$ 4,000
Heating and ventilation	500	SF	\$ 7	\$ 3,500
Fence	400	LF	\$ 15	\$ 6,000
Paving	2,500	SF	\$ 2	\$ 5,000
Electrical	1	JOB	\$ 50,000	\$ 50,000
Piping	1	JOB	\$ 20,000	\$ 20,000
EDR package including:				
Feed and concentrate pumps				
Cartridge filters and vessels				
EDR membrane stacks				
Electrical module				
Chemical feed systems				
Freight cost				
Vendor start-up services	1	UNIT	\$ 165,000	\$ 165,000
Transfer pumps	4	EA	\$ 5,000	\$ 20,000
Product storage tank	5,000	gal	\$ 3.00	\$ 15,000
Feed Tank	15,000	gal	\$ 3.00	\$ 45,000
Reject pond:				
Excavation	1,000	CYD	\$ 3.00	\$ 3,000
Compacted fill	800	CYD	\$ 7.00	\$ 5,600
Lining	2,000	SF	\$ 1.50	\$ 3,000
Vegetation	900	SY	\$ 1.50	\$ 1,350
Access road	450	LF	\$ 30.00	\$ 13,500
Subtotal of Design/Construction Costs				\$ 420,550
Contingency	20%		\$	84,110
Design & Constr Management	25%		\$	105,138
Reject water haulage truck	1	EA	\$ 100,000	\$ 100,000

TOTAL CAPITAL COSTS **\$ 709,798**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>EDR Unit O&M</i>				
Building Power	4,500	kwh/yr	\$ 0.165	\$ 743
Equipment power	46,000	kwh/yr	\$ 0.165	\$ 7,590
Labor	1,000	hrs/yr	\$ 40.00	\$ 40,000
Materials	6,000	kgal	\$ 0.48	\$ 2,880
Chemicals	6,000	kgal	\$ 0.40	\$ 2,400
Analyses	24	test	\$ 200.00	\$ 4,800
Subtotal				\$ 58,413
<i>Reject (brine) disposal</i>				
Disposal truck mileage	5,400	miles	\$ 1.50	\$ 8,100
Reject (brine) disposal fee	1,511	kgal/yr	\$ 5.00	\$ 7,556
Subtotal				\$ 15,656

TOTAL ANNUAL O&M COSTS **\$ 74,068**

Table C.9

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *Central Treatment - Ion Exchange*
Alternative Number *TO-9*

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Adsorption Unit Purchase/Installation</i>				
Site preparation	0.20	acre	\$ 4,000	\$ 800
Slab	15	CY	\$ 1,000	\$ 15,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8	\$ 3,200
Building plumbing	400	SF	\$ 8	\$ 3,200
Heating and ventilation	400	SF	\$ 7	\$ 2,800
Fence	400	LF	\$ 15	\$ 6,000
Paving	4,500	SF	\$ 2	\$ 9,000
Electrical	1	JOB	\$ 35,000	\$ 35,000
Piping	1	JOB	\$ 18,000	\$ 18,000
		Subtotal		\$ 117,000
Ion Exchange package including:				
2 - IX vessels				
anionic exchange resin				
Controls & instruments	1	UNIT	\$ 130,000	\$ 130,000
Spent Regenerate Tank	14,400	GAL	\$ 2	\$ 28,800
Transfer/backwash pumps	2	EA	\$ 5,000	\$ 10,000
Product water tank	-	gal	\$ 3	\$ -
Feed Tank	5,000	gal	\$ 3	\$ 15,000
Subtotal of Component Costs				\$ 300,800
Contingency	20%		\$	60,160
Design & Constr Management	25%		\$	75,200
TOTAL CAPITAL COSTS			\$ 436,160	

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Adsorption Unit O&M</i>				
Building Power	3,500	kwh/yr	\$ 0.165	\$ 578
Equipment power	4,914	kwh/yr	\$ 0.165	\$ 811
Labor	600	hrs/yr	\$ 40	\$ 24,000
Media replacement/disposal	23	cf	\$ 220	\$ 5,104
Analyses	12	test	\$ 200	\$ 2,400
Regeneration Salt	24,200	lbs	\$ 0.14	\$ 3,388
Supplies and Equipment	1	yr	\$ 4,000	\$ 4,000
Subtotal				\$ 40,280
Disposal Truck Rental	40	day	\$ 250	\$ 10,074
Disposal truck mileage	725	miles	\$ 1.50	\$ 1,088
Reject (brine) disposal fee	121	kgal	\$ 5.00	\$ 604
Subtotal				\$ 11,766
TOTAL ANNUAL O&M COSTS				\$ 52,047

Table C.10

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *Point-of-Use Treatment*
Alternative Number *TO-10*

Number of Connections for POU Unit Installation 78 connections

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>POU-Treatment - Purchase/Installation</i>				
POU treatment unit purchase	78	EA	\$ 615	\$ 47,970
POU treatment unit installation	78	EA	\$ 155	\$ 12,090
Subtotal				\$ 60,060
Subtotal of Component Costs				\$ 60,060
Contingency	20%		\$	12,012
Design & Constr Management	25%		\$	15,015
Procurement & Administration	20%		\$	12,012
TOTAL CAPITAL COSTS			\$	99,099

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>O&M</i>				
POU materials, per unit	78	EA	\$ 230	\$ 17,940
Contaminant analysis, 1/yr per unit	78	EA	\$ 205	\$ 15,990
Program labor, 10 hrs/unit	780	hrs	\$ 40	\$ 31,200
Subtotal				\$ 65,130
TOTAL ANNUAL O&M COSTS				\$ 65,130

Table C.11

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *Point-of-Entry Treatment*
Alternative Number *TO-11*

Number of Connections for POE Unit Installation 78 connections

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>POE-Treatment - Purchase/Installat</i>				
POE treatment unit purchase	78	EA	\$ 5,125	\$ 399,750
Pad and shed, per unit	78	EA	\$ 2,050	\$ 159,900
Piping connection, per unit	78	EA	\$ 1,025	\$ 79,950
Electrical hook-up, per unit	78	EA	\$ 1,025	\$ 79,950
Subtotal				\$ 719,550

Subtotal of Component Costs \$ 719,550

Contingency	20%	\$ 143,910
Design & Constr Management	25%	\$ 179,888
Procurement & Administration	20%	\$ 143,910

TOTAL CAPITAL COSTS \$ 1,187,258

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>O&M</i>				
POE materials, per unit	78	EA	\$ 1,540	\$ 120,120
Contaminant analysis, 1/yr per unit	78	EA	\$ 205	\$ 15,990
Program labor, 10 hrs/unit	780	hrs	\$ 40	\$ 31,200
Subtotal				\$ 167,310

TOTAL ANNUAL O&M COSTS \$ 167,310

Table C.12

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *Public Dispenser for Treated Drinking Water*
Alternative Number *TO-12*

Number of Treatment Units Recommended 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Public Dispenser Unit Installation</i>				
POE-Treatment unit(s)	1	EA	\$ 7,175	\$ 7,175
Unit installation costs	1	EA	\$ 5,125	\$ 5,125
Subtotal				\$ 12,300
Subtotal of Component Costs				\$ 12,300
Contingency	20%			\$ 2,460
Design & Constr Management	25%			\$ 3,075
TOTAL CAPITAL COSTS				17,835

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Treatment unit O&M, 1 per unit	1	EA	\$ 2,050	\$ 2,050
Contaminant analysis, 1/wk per u	52	EA	\$ 205	\$ 10,660
Sampling/reporting, 1 hr/day	365	HRS	\$ 60	\$ 21,900
Subtotal				\$ 34,610
TOTAL ANNUAL O&M COSTS				\$ 34,610

Table C.13

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *Supply Bottled Water to 100% of Population*
Alternative Number *TO-13*

Service Population 234
Percentage of population requiring supply 100%
Water consumption per person 1.00 gpcd
Calculated annual potable water needs 85,410 gallons

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Implementation</i>				
Initial program set-up	500	hours	\$ 45	\$ 22,500
Subtotal				\$ 22,500
Subtotal of Component Costs				\$ 22,500
Contingency	20%			\$ 4,500
TOTAL CAPITAL COSTS				\$ 27,000

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water purchase costs	85,410	gals	\$ 1.00	\$ 85,410
Program admin, 9 hrs/wk	468	hours	\$ 45	\$ 21,060
Program materials	1	EA	\$ 5,125	\$ 5,125
Subtotal				\$ 111,595
TOTAL ANNUAL O&M COSTS				\$ 111,595

Table C.14

PWS Name *Twin Oaks Mobile Home Park*
Alternative Name *Central Trucked Drinking Water*
Alternative Number *TO-14*

Service Population 234
Percentage of population requiring supply 100%
Water consumption per person 1.00 gpcd
Calculated annual potable water needs 85,410 gallons
Travel distance to compliant water source 4 miles

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Storage Tank Installation</i>				
5,000 gal ground storage tank	1	EA	\$ 10,000	\$ 10,000
Site improvements	1	EA	\$ 3,075	\$ 3,075
Potable water truck	1	EA	\$ 75,000	\$ 75,000
Subtotal				\$ 88,075
Subtotal of Component Costs				\$ 88,075
Contingency	20%		\$	17,615
Design & Constr Management	25%		\$	22,019
TOTAL CAPITAL COSTS			\$	127,709

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water delivery labor, 4 hrs/wk	208	hrs	\$ 60	\$ 12,480
Truck operation, 1 round trip/wk	416	miles	\$ 3.00	\$ 1,248
Water purchase	85	1,000 gals	\$ 1.09	\$ 93
Water testing, 1 test/wk	52	EA	\$ 205	\$ 10,660
Sampling/reporting, 2 hrs/wk	104	hrs	\$ 60	\$ 6,240
Subtotal				\$ 30,721
TOTAL ANNUAL O&M COSTS				\$ 30,721

1
2
3

APPENDIX D EXAMPLE FINANCIAL MODEL

Appendix D
General Inputs

Twin Oaks MHP

Number of Alternatives

14

Selected from Results Sheet

Input Fields are Indicated by:

General Inputs		
Implementation Year	2009	Twin Oaks MHP
Months of Working Capital	0	
Depreciation	\$ -	
Percent of Depreciation for Replacement Fund	0%	
Allow Negative Cash Balance (yes or no)	No	
Median Household Income	\$ 31,847	
Median HH Income -- Texas	\$ 39,927	Selected from Results
Grant Funded Percentage	0%	
Capital Funded from Revenues	\$ -	
	Base Year	2007
	Growth/Escalation	
Accounts & Consumption		
Metered Residential Accounts		
Number of Accounts	0.0%	78
Number of Bills Per Year		12
Annual Billed Consumption		6,022,500
Consumption per Account Per Pay Period	0.0%	6,434
Consumption Allowance in Rates		-
Total Allowance		-
Net Consumption Billed		6,022,500
Percentage Collected		100.0%
Unmetered Residential Accounts		
Number of Accounts	0.0%	0
Number of Bills Per Year		12
Percentage Collected		100.0%
Metered Non-Residential Accounts		
Number of Accounts	0.0%	0
Number of Bills Per Year		12
Non-Residential Consumption		-
Consumption per Account	0.0%	-
Consumption Allowance in Rates		-
Total Allowance		-
Net Consumption Billed		-
Percentage Collected		0.0%
Unmetered Non-Residential Accounts		
Number of Accounts	0.0%	0
Number of Bills Per Year		12
Percentage Collected		100.0%
Water Purchase & Production		
Water Purchased (gallons)	0.0%	-
Average Cost Per Unit Purchased	0.0%	\$ -
Bulk Water Purchases	0.0%	\$ -
Water Production	0.0%	6,022,500
Unaccounted for Water		-
Percentage Unaccounted for Water		0.0%

Appendix D
General Inputs

Twin Oaks MHP

Number of Alternatives

14

Selected from Results Sheet

Input Fields are Indicated by:

Residential Rate Structure	Allowance within Tier	
Estimated Average Water Rate (\$/1000gallons)	-	\$ 1.76
Non-Residential Rate Structure		
Estimated Average Water Rate (\$/1000gallons)	-	\$ -
INITIAL YEAR EXPENDITURES	Inflation	Initial Year
Operating Expenditures:		
Salaries & Benefits	0.0%	-
Contract Labor	0.0%	-
Water Purchases	0.0%	-
Chemicals, Treatment	0.0%	-
Utilities	0.0%	-
Repairs, Maintenance, Supplies	0.0%	-
Repairs	0.0%	-
Maintenance	0.0%	-
Supplies	0.0%	-
Administrative Expenses	0.0%	-
Accounting and Legal Fees	0.0%	-
Insurance	0.0%	-
Automotive and Travel	0.0%	-
Professional and Directors Fees	0.0%	-
Bad Debts	0.0%	-
Garbage Pick-up	0.0%	-
Miscellaneous	0.0%	-
Other 3	0.0%	21,551
Other 4	0.0%	-
Incremental O&M for Alternative	0.0%	-
Total Operating Expenses		21,551
Non-Operating Income/Expenditures		
Interest Income	0.0%	-
Other Income	0.0%	-
Other Expense	0.0%	-
Transfers In (Out)	0.0%	-
Net Non-Operating		-
Esisting Debt Service		
Bonds Payable, Less Current Maturities		\$ -
Bonds Payable, Current		\$ -
Interest Expense		\$ -

Funding Source = Loan/Bond

[illegible]

APPENDIX E ANALYSIS OF SHARED SOLUTIONS FOR OBTAINING WATER FROM THE CITY OF MIDLAND

E.1 OVERVIEW OF METHOD USED

There are a few small PWSs with water quality problems located in the vicinity of the Twin Oaks MHP PWS that could benefit from joining together and cooperating to share the cost for obtaining compliant drinking water. This cooperation could involve creating a formal organization of individual PWSs to address obtaining compliant drinking water, consolidating to form a single PWS, or having the individual PWSs taken over or bought out by a larger regional entity.

The small PWSs with water quality problems near the Twin Oaks MHP are listed in Table E.1, along with their average water consumption and estimates of the capital cost for each PWS to construct an individual pipeline. It is assumed for this analysis that all the systems would participate in a shared solution.

This analysis focuses on compliance alternatives related to obtaining water from large water providers interested in providing water outside their current area, either by wholesaling to PWSs, or by expanding their service areas. This type of solution is most likely to have the best prospects for sustainability, and a reliable provision of compliant drinking water.

The purpose of this analysis is to approximate the level of capital cost savings that could be expected from pursuing a shared solution versus a solution where the study PWS obtains compliant drinking water on its own. Regardless of the form a group solution would take, water consumers would have to pay for the infrastructure needed for obtaining compliant water. To keep this analysis as straightforward and realistic as possible, it is assumed the individual PWSs would remain independent, and would share the capital cost for the infrastructure required. Also, to maintain simplicity, this analysis is limited to estimating capital cost savings related to pipeline construction, which is likely to be by far the largest component of the overall capital cost. A shared solution could also produce savings in O&M expenses as a result of reduction in redundant facilities and the potential for shared O&M resources, and these savings would have to be evaluated if the PWSs are interested in implementing a shared solution.

There are many ways pipeline capital costs could be divided between participating PWSs, and the final apportioning of costs would likely be based on negotiation between the participating entities. At this preliminary stage of analysis it is not possible to project results from negotiations regarding cost sharing. For this reason, three methods are used to allocate cost between PWSs in an effort to give an approximation of the range of savings that might be attainable for an individual PWS.

Method A is based on allocating capital cost of the shared pipeline solution proportionate to the amount of water used by each PWS. In this case, the capital cost for the shared pipeline

and the necessary pump stations is estimated, and then this total capital cost is allocated based on the fraction of the total water used by each PWS. For example, PWS #1 has an average daily water use of 0.1 mgd and PWS #2 has an average daily use of 0.3 mgd. Using this method, PWS #1 would be allocated 25 percent of the capital cost of the shared solution. This method is a reasonable method for allocating cost when all the PWSs are different in size but are relatively equidistant from the shared water source.

Method B is also based on allocating capital cost of the shared pipeline solution proportionate to the amount of water used by the PWSs. However, rather than allocating the *total* capital cost of the shared solution between each participating PWS, this approach splits the shared pipeline into segments and allocates flow-proportional costs to the PWSs using each segment. Costs for a pipeline segment are not shared by a PWS if the PWS does not use that particular segment. For example, PWS #1 has an average daily water use of 0.3 mgd and PWS #2 has an average daily use of 0.2 mgd. A 3-mile long pipeline segment is common to both PWSs, while PWS #2 requires an additional 4-mile segment. Using this method, PWS #2 would be allocated 40 percent of the cost of the 3-mile segment and 100 percent of the cost of the 4-mile segment. This method is a reasonable method for allocating cost when all the PWSs are different in size and are located at different distances from the shared water source.

Method C is based on allocating capital cost of the shared pipeline solution proportionate to the cost each PWS would have to pay to obtain compliant water if it were to implement an individual solution. In this case, the total capital cost for the shared pipeline and the necessary pump stations is estimated as well as the capital cost each PWS would have for obtaining its own pipeline. The total capital cost for the shared solution is then allocated between the participating PWSs based on what each PWS would have to pay to construct its own pipeline. For example, the individual solution cost for PWS #1 is \$4 million and the individual solution cost for PWS #2 is \$1 million. Using this method, PWS #1 would be allocated 80 percent of the cost of the shared solution. This method is a reasonable method for allocating cost when the PWS are located at different distances from the water source.

For any given PWS, all three of these methods should generate costs for the shared solution that produce savings for the PWS over an individual solution. However, for different PWSs participating in a shared solution, each of these three methods can produce savings of varying magnitudes: for one PWS, Method A might show the best cost savings while for another Method C might provide the best savings. For this reason, this range is considered to be representative of possible savings that could result from an agreement that should be fair and equitable to all parties involved.

E.2 SHARED SOLUTION FOR OBTAINING WATER FROM MIDLAND

This alternative would consist of constructing 6 miles of 4-inch joint pipeline from the Midland property boundary to South Midland County WS, Johns MHP, Warren Road Development, and Twin Oaks MHP. The pipeline routing is shown in Figure E.1 at the end of this appendix. It is assumed one pump station would be required to transfer the water from Midland to the four public water systems.

1 The capital costs for each pipe segment and the total capital cost for the shared pipeline are
2 summarized in Table E.2. Table E.3 shows the capital costs allocated to each PWS using
3 Method A. Table E.4 shows the capital costs allocated to each PWS using Method B.
4 Table E.5 shows the allocation of pipeline capital costs to each of the PWSs using Method C,
5 as described above. Table E.6 provides a summary of the pipeline capital costs estimated for
6 each PWS, and the savings that could be realized compared to developing individual pipelines.
7 More detailed cost estimates for the pipe segments are shown at the end of this appendix in
8 Tables E.7 through E.16.

9 Based on these estimates, the range of pipeline capital cost savings to Twin Oaks MHP
10 could be between \$287,900 to \$413,300 if they were to implement a shared solution like this,
11 which would be a savings between 45 to 65 percent. These estimates are hypothetical and are
12 only provided to approximate the magnitude of potential savings if this shared solution is
13 implemented as described.

Table E.1
Summary Information for PWSs Participating in Shared Solution

PWS	PWS #	Average Water Demand (gpd)	Water Demand as Percent of Total	Pipeline Capital Cost for Individual Solutions for Twin Oaks, South Midland, Johns MHP, and Warren Road	Percent of Sum of Capital Costs for Individual Solutions for Twin Oaks, South Midland, Johns MHP, and Warren Road
South Midland County WS	1650077	24000	33%	\$ 276,225	16%
Johns MHP	1650043	3400	5%	\$ 389,585	22%
Warren Road Development	1650084	28500	39%	\$ 440,807	25%
Twin Oaks Mobile Home Park	1650057	17000	23%	\$ 635,472	36%
Totals		72900	100%	\$ 1,742,089	100%

Notes: (a) Costs for South Midland County WS, Johns MHP and Warren Road Development to Midland are provided in Tables E.14, E.15 and E.16. Costs for Twin Oaks MHP to Midland (one of the alternatives for the PWS) are provided in Appendix C.

Table E.2
Capital cost for Shared Pipeline from Midland

Pipe Segment	Capital Cost
Pipe 1	\$ 207,160
Pipe 2	\$ 56,696
Pipe 3	\$ 190,426
Pipe A	\$ 85,740
Pipe B	\$ 166,741
Pipe C	\$ 48,692
Pipe D	\$ 197,409
Totals	\$ 952,865

Notes: (b) Pipes 1, 2 and 3 are identified as Main Links 1, 2 and 3, respectively, and are common to both PWSs. The lettered pipes connect each PWS to the Main Links.

Table E.3
Pipeline Capital Cost Allocation by Method A
Shared Pipeline Assessment for Twin Oak MHP

PWS	PWS #	Percentage Based On Flow	Total Costs
South Midland County WS	1650077	33%	\$ 313,700
Johns MHP	1650043	5%	\$ 44,441
Warren Road Development	1650084	39%	\$ 372,519
Twin Oaks Mobile Home Park	1650057	23%	\$ 222,204
Totals		100%	\$ 952,865

Table E.4
Pipeline Capital Cost Allocation by Method B
Shared Pipeline Assessment for Twin Oak MHP

Pipeline Segment	Pipe Segment Capital Cost	South Midland County WS		Johns MHP		Warren Road Development		Twin Oaks Mobile Home Park	
		Percent Allocation Based on Water Use	Allocated Cost	Percent Allocation Based on Water Use	Allocated Cost	Percent Allocation Based on Water Use	Allocated Cost	Percent Allocation Based on Water Use	Allocated Cost
Pipe 1	\$ 207,160	33%	\$ 68,201	5%	\$ 9,662	39%	\$ 80,988	23%	\$ 48,309
Pipe 2	\$ 56,696	0%	\$ -	7%	\$ 3,942	58%	\$ 33,044	35%	\$ 19,710
Pipe 3	\$ 190,426	0%	\$ -	0%	\$ -	63%	\$ 119,278	37%	\$ 71,148
Pipe A	\$ 85,740	100%	\$ 85,740	0%	\$ -	0%	\$ -	0%	\$ -
Pipe B	\$ 166,741	0%	\$ -	100%	\$ 166,741	0%	\$ -	0%	\$ -
Pipe C	\$ 48,692	0%	\$ -	0%	\$ -	100%	\$ 48,692	0%	\$ -
Pipe D	\$ 197,409	0%	\$ -	0%	\$ -	0%	\$ -	100%	\$ 197,409
Totals	\$ 952,865		\$ 153,941		\$ 180,345		\$ 282,002		\$ 336,576

Table E.5
Pipeline Capital Cost Allocation by Method C
Shared Pipeline Assessment for Twin Oak MHP

PWS	PWS #	Cost for Individual Pipelines	Percentage based on Individual Solutions	Allocated Capital Cost
South Midland County WS	1650077	\$ 276,225	16%	\$ 151,086
Johns MHP	1650043	\$ 389,585	22%	\$ 213,090
Warren Road Development	1650084	\$ 440,807	25%	\$ 241,107
Twin Oaks Mobile Home Park	1650057	\$ 635,472	36%	\$ 347,582
Totals		\$ 1,742,089	100%	\$ 952,865

Table E.6
Pipeline Capital Cost Summary
Shared Pipeline Assessment for Twin Oak MHP

PWS	Individual Pipeline Capital Costs	Shared Solution Capital Cost Allocation			Shared Solution Cost Savings			Shared Solution Percentage Savings		
		Method A	Method B	Method C	Method A	Method B	Method C	Method A	Method B	Method C
South Midland County	\$ 276,225	\$ 313,700	\$ 153,941	\$ 151,086	\$ (37,475)	\$ 122,284	\$ 125,139	-14%	44%	45%
Johns MHP	\$ 389,585	\$ 44,441	\$ 180,345	\$ 213,090	\$ 345,144	\$ 209,239	\$ 176,495	89%	54%	45%
Warren Road Development	\$ 440,807	\$ 372,519	\$ 282,002	\$ 241,107	\$ 68,288	\$ 158,805	\$ 199,700	15%	36%	45%
Twin Oaks Mobile Home Park	\$ 635,472	\$ 222,204	\$ 336,576	\$ 347,582	\$ 413,268	\$ 298,896	\$ 287,890	65%	47%	45%
Totals	\$ 1,742,089	\$ 952,865	\$ 952,865	\$ 952,865	\$ 789,224	\$ 789,224	\$ 789,224			

Table E.7

Main Link # 1

Total Pipe Length

0.82 miles

Number of Pump Stations Needed

1

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	4,341	LF	\$ 12	\$ 52,092
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	50	LF	\$ 130	\$ 6,500
Gate valve and box, 04"	1	EA	\$ 710	\$ 710
Air valve	1	EA	\$ 2,050	\$ 2,050
Flush valve	1	EA	\$ 1,025	\$ 1,025
Metal detectable tape	4,341	LF	\$ 2.00	\$ 8,682
Subtotal				\$ 71,059
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 04"	2	EA	\$ 550	\$ 1,100
Gate valve, 04"	4	EA	\$ 710	\$ 2,840
Check valve, 04"	2	EA	\$ 755	\$ 1,510
Electrical/Instrumentation	1	EA	\$ 10,250	\$ 10,250
Site work	1	EA	\$ 2,560	\$ 2,560
Building pad	1	EA	\$ 5,125	\$ 5,125
Pump Building	1	EA	\$ 10,250	\$ 10,250
Fence	1	EA	\$ 6,150	\$ 6,150
Tools	1	EA	\$ 1,025	\$ 1,025
10,000 gal ground storage tank	1	EA	\$ 15,000	\$ 15,000
Subtotal				\$ 71,810
Subtotal of Component Costs				\$ 142,869
Contingency	20%			\$ 28,574
Design & Constr Management	25%			\$ 35,717
TOTAL CAPITAL COSTS				\$ 207,160

Table E.8**Main Link # 2****Total Pipe Length**

0.30 miles

Number of Pump Stations Needed

0

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	2	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,594	LF	\$ 12	\$ 19,128
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	100	LF	\$ 130	\$ 13,000
Gate valve and box, 04"	1	EA	\$ 710	\$ 710
Air valve	1	EA	\$ 2,050	\$ 2,050
Flush valve	1	EA	\$ 1,025	\$ 1,025
Metal detectable tape	1,594	LF	\$ 2.00	\$ 3,188
Subtotal				\$ 39,101
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 8,000	\$ -
Pump Station Piping, 04"	-	EA	\$ 550	\$ -
Gate valve, 04"	-	EA	\$ 710	\$ -
Check valve, 04"	-	EA	\$ 755	\$ -
Electrical/Instrumentation	-	EA	\$ 10,250	\$ -
Site work	-	EA	\$ 2,560	\$ -
Building pad	-	EA	\$ 5,125	\$ -
Pump Building	-	EA	\$ 10,250	\$ -
Fence	-	EA	\$ 6,150	\$ -
Tools	-	EA	\$ 1,025	\$ -
5,000 gal ground storage tank	-	EA	\$ 10,000	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 39,101
Contingency	20%			\$ 7,820
Design & Constr Management	25%			\$ 9,775
TOTAL CAPITAL COSTS				\$ 56,696

Table E.9**Main Link # 3****Total Pipe Length**

1.41 miles

Number of Pump Stations Needed

0

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	7,447	LF	\$ 12	\$ 89,364
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	150	LF	\$ 130	\$ 19,500
Gate valve and box, 04"	2	EA	\$ 710	\$ 1,420
Air valve	2	EA	\$ 2,050	\$ 4,100
Flush valve	2	EA	\$ 1,025	\$ 2,050
Metal detectable tape	7,447	LF	\$ 2.00	\$ 14,894
Subtotal				\$ 131,328
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 8,000	\$ -
Pump Station Piping, 04"	-	EA	\$ 550	\$ -
Gate valve, 04"	-	EA	\$ 710	\$ -
Check valve, 04"	-	EA	\$ 755	\$ -
Electrical/Instrumentation	-	EA	\$ 10,250	\$ -
Site work	-	EA	\$ 2,560	\$ -
Building pad	-	EA	\$ 5,125	\$ -
Pump Building	-	EA	\$ 10,250	\$ -
Fence	-	EA	\$ 6,150	\$ -
Tools	-	EA	\$ 1,025	\$ -
5,000 gal ground storage tank	-	EA	\$ 10,000	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 131,328
Contingency	20%			\$ 26,266
Design & Constr Management	25%			\$ 32,832
TOTAL CAPITAL COSTS				\$ 190,426

Table E.10**Segment A****South Midland County WS****Private Pipe Size**

04"

Total Pipe Length

0.66 miles

Total PWS annual water usage

8,760,000.0 Gallons

Number of Pump Stations Needed

0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	3,489	LF	\$ 12	\$ 41,868
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	50	LF	\$ 130	\$ 6,500
Gate valve and box, 04"	1	EA	\$ 710	\$ 710
Air valve	1	EA	\$ 2,050	\$ 2,050
Flush valve	1	EA	\$ 1,025	\$ 1,025
Metal detectable tape	3,489	LF	\$ 2.00	\$ 6,978
Subtotal				\$ 59,131
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 8,000	\$ -
Pump Station Piping, 04"	-	EA	\$ 550	\$ -
Gate valve, 04"	-	EA	\$ 710	\$ -
Check valve, 04"	-	EA	\$ 755	\$ -
Electrical/Instrumentation	-	EA	\$ 10,250	\$ -
Site work	-	EA	\$ 2,560	\$ -
Building pad	-	EA	\$ 5,125	\$ -
Pump Building	-	EA	\$ 10,250	\$ -
Fence	-	EA	\$ 6,150	\$ -
Tools	-	EA	\$ 1,025	\$ -
5,000 gal ground storage tank	-	EA	\$ 10,000	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 59,131
Contingency	20%			\$ 11,826
Design & Constr Management	25%			\$ 14,783
TOTAL CAPITAL COSTS				\$ 85,740

Table E.11**Segment B****Johns MHP****Private Pipe Size**

04"

Total Pipe Length

1.10 miles

Total PWS annual water usage

1,241,000.0 Gallons

Number of Pump Stations Needed

0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	4	n/a	n/a	n/a
PVC water line, Class 200, 04"	5,816	LF	\$ 12	\$ 69,792
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	200	LF	\$ 130	\$ 26,000
Gate valve and box, 04"	2	EA	\$ 710	\$ 1,420
Air valve	2	EA	\$ 2,050	\$ 4,100
Flush valve	2	EA	\$ 1,025	\$ 2,050
Metal detectable tape	5,816	LF	\$ 2.00	\$ 11,632
Subtotal				\$ 114,994
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 8,000	\$ -
Pump Station Piping, 04"	-	EA	\$ 550	\$ -
Gate valve, 04"	-	EA	\$ 710	\$ -
Check valve, 04"	-	EA	\$ 755	\$ -
Electrical/Instrumentation	-	EA	\$ 10,250	\$ -
Site work	-	EA	\$ 2,560	\$ -
Building pad	-	EA	\$ 5,125	\$ -
Pump Building	-	EA	\$ 10,250	\$ -
Fence	-	EA	\$ 6,150	\$ -
Tools	-	EA	\$ 1,025	\$ -
5,000 gal ground storage tank	-	EA	\$ 10,000	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 114,994
Contingency	20%			\$ 22,999
Design & Constr Management	25%			\$ 28,749
TOTAL CAPITAL COSTS				\$ 166,741

Table E.12

Segment C

Warren Road Development

Private Pipe Size

04"

Total Pipe Length

0.32 miles

Total PWS annual water usage

10,402,500.0 Gallons

Number of Pump Stations Needed

0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,664	LF	\$ 12	\$ 19,968
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	50	LF	\$ 130	\$ 6,500
Gate valve and box, 04"	1	EA	\$ 710	\$ 710
Air valve	1	EA	\$ 2,050	\$ 2,050
Flush valve	1	EA	\$ 1,025	\$ 1,025
Metal detectable tape	1,664	LF	\$ 2.00	\$ 3,328
Subtotal				\$ 33,581
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 8,000	\$ -
Pump Station Piping, 04"	-	EA	\$ 550	\$ -
Gate valve, 04"	-	EA	\$ 710	\$ -
Check valve, 04"	-	EA	\$ 755	\$ -
Electrical/Instrumentation	-	EA	\$ 10,250	\$ -
Site work	-	EA	\$ 2,560	\$ -
Building pad	-	EA	\$ 5,125	\$ -
Pump Building	-	EA	\$ 10,250	\$ -
Fence	-	EA	\$ 6,150	\$ -
Tools	-	EA	\$ 1,025	\$ -
5,000 gal ground storage tank	-	EA	\$ 10,000	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 33,581
Contingency	20%			\$ 6,716
Design & Constr Management	25%			\$ 8,395
TOTAL CAPITAL COSTS				\$ 48,692

Table E.13**Segment D****Twin Oaks Mobile Home Park****Private Pipe Size**

04"

Total Pipe Length

1.48 miles

Total PWS annual water usage

6,205,000.0 MG

Number of Pump Stations Needed

0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	7,791	LF	\$ 12	\$ 93,492
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	150	LF	\$ 130	\$ 19,500
Gate valve and box, 04"	2	EA	\$ 710	\$ 1,420
Air valve	2	EA	\$ 2,050	\$ 4,100
Flush valve	2	EA	\$ 1,025	\$ 2,050
Metal detectable tape	7,791	LF	\$ 2.00	\$ 15,582
Subtotal				\$ 136,144
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 8,000	\$ -
Pump Station Piping, 04"	-	EA	\$ 550	\$ -
Gate valve, 04"	-	EA	\$ 710	\$ -
Check valve, 04"	-	EA	\$ 755	\$ -
Electrical/Instrumentation	-	EA	\$ 10,250	\$ -
Site work	-	EA	\$ 2,560	\$ -
Building pad	-	EA	\$ 5,125	\$ -
Pump Building	-	EA	\$ 10,250	\$ -
Fence	-	EA	\$ 6,150	\$ -
Tools	-	EA	\$ 1,025	\$ -
5,000 gal ground storage tank	-	EA	\$ 10,000	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 136,144
Contingency	20%			\$ 27,229
Design & Constr Management	25%			\$ 34,036
TOTAL CAPITAL COSTS				\$ 197,409

Table E.14**Segment A****South Midland County WS****Private Pipe Size**

04"

Total Pipe Length

1.48 miles

Total PWS annual water usage

8,760,000.0 Gallons

Number of Pump Stations Needed

1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	7,830	LF	\$ 12	\$ 93,960
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	50	LF	\$ 130	\$ 6,500
Gate valve and box, 04"	2	EA	\$ 710	\$ 1,420
Air valve	2	EA	\$ 2,050	\$ 4,100
Flush valve	2	EA	\$ 1,025	\$ 2,050
Metal detectable tape	7,830	LF	\$ 2.00	\$ 15,660
Subtotal				\$ 123,690
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 04"	2	EA	\$ 550	\$ 1,100
Gate valve, 04"	4	EA	\$ 710	\$ 2,840
Check valve, 04"	2	EA	\$ 755	\$ 1,510
Electrical/Instrumentation	1	EA	\$ 10,250	\$ 10,250
Site work	1	EA	\$ 2,560	\$ 2,560
Building pad	1	EA	\$ 5,125	\$ 5,125
Pump Building	1	EA	\$ 10,250	\$ 10,250
Fence	1	EA	\$ 6,150	\$ 6,150
Tools	1	EA	\$ 1,025	\$ 1,025
5,000 gal ground storage tank	1	EA	\$ 10,000	\$ 10,000
Subtotal				\$ 66,810
Subtotal of Component Costs				\$ 190,500
Contingency	20%			\$ 38,100
Design & Constr Management	25%			\$ 47,625
TOTAL CAPITAL COSTS				\$ 276,225

Table E.15

Segment B

Johns MHP

Private Pipe Size

04"

Total Pipe Length

2.23 miles

Total PWS annual water usage

1,241,000.0 Gallons

Number of Pump Stations Needed

1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	4	n/a	n/a	n/a
PVC water line, Class 200, 04"	11,751	LF	\$ 12	\$ 141,012
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	200	LF	\$ 130	\$ 26,000
Gate valve and box, 04"	3	EA	\$ 710	\$ 2,130
Air valve	3	EA	\$ 2,050	\$ 6,150
Flush valve	3	EA	\$ 1,025	\$ 3,075
Metal detectable tape	11,751	LF	\$ 2.00	\$ 23,502
Subtotal				\$ 201,869
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 04"	2	EA	\$ 550	\$ 1,100
Gate valve, 04"	4	EA	\$ 710	\$ 2,840
Check valve, 04"	2	EA	\$ 755	\$ 1,510
Electrical/Instrumentation	1	EA	\$ 10,250	\$ 10,250
Site work	1	EA	\$ 2,560	\$ 2,560
Building pad	1	EA	\$ 5,125	\$ 5,125
Pump Building	1	EA	\$ 10,250	\$ 10,250
Fence	1	EA	\$ 6,150	\$ 6,150
Tools	1	EA	\$ 1,025	\$ 1,025
5,000 gal ground storage tank	1	EA	\$ 10,000	\$ 10,000
Subtotal				\$ 66,810
Subtotal of Component Costs				\$ 268,679
Contingency	20%			\$ 53,736
Design & Constr Management	25%			\$ 67,170
TOTAL CAPITAL COSTS				\$ 389,585

Table E.16**Segment C****Warren Road Development****Private Pipe Size**

04"

Total Pipe Length

2.85 miles

Total PWS annual water usage

10,402,500.0 Gallons

Number of Pump Stations Needed

1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	15,046	LF	\$ 12	\$ 180,552
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	50	LF	\$ 130	\$ 6,500
Gate valve and box, 04"	4	EA	\$ 710	\$ 2,840
Air valve	3	EA	\$ 2,050	\$ 6,150
Flush valve	4	EA	\$ 1,025	\$ 4,100
Metal detectable tape	15,046	LF	\$ 2.00	\$ 30,092
Subtotal				\$ 230,234
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 04"	2	EA	\$ 550	\$ 1,100
Gate valve, 04"	4	EA	\$ 710	\$ 2,840
Check valve, 04"	2	EA	\$ 755	\$ 1,510
Electrical/Instrumentation	1	EA	\$ 10,250	\$ 10,250
Site work	1	EA	\$ 2,560	\$ 2,560
Building pad	1	EA	\$ 5,125	\$ 5,125
Pump Building	1	EA	\$ 10,250	\$ 10,250
Fence	1	EA	\$ 6,150	\$ 6,150
Tools	1	EA	\$ 1,025	\$ 1,025
5,000 gal ground storage tank	1	EA	\$ 10,000	\$ 10,000
Subtotal				\$ 66,810
Subtotal of Component Costs				\$ 297,044
Contingency	20%			\$ 59,409
Design & Constr Management	25%			\$ 74,261
TOTAL CAPITAL COSTS				\$ 430,714

