

DRAFT FEASIBILITY REPORT FEASIBILITY ANALYSIS OF WATER SUPPLY FOR SMALL PUBLIC WATER SYSTEMS

MIDWAY MOBILE HOME PARK
PWS ID# 1330020

Prepared for:

THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



Prepared by:

THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC GEOLOGY

AND

PARSONS

Preparation of this report was financed by the Texas Commission on Environmental Quality through the Drinking Water State Revolving Fund Small Systems Assistance Program

AUGUST 2006

DRAFT FEASIBILITY REPORT

**FEASIBILITY ANALYSIS OF WATER SUPPLY
FOR SMALL PUBLIC WATER SYSTEMS**

**MIDWAY MOBILE HOME PARK
PWS ID# 1330020**

Prepared for:

THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Prepared by:

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC
GEOLOGY**

AND

PARSONS

*Preparation of this report was financed by the Texas Commission on Environmental
Quality through the Drinking Water State Revolving Fund Small Systems Assistance
Program*

THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF INTERIM REVIEW UNDER THE
AUTHORITY OF ERIC J. DAWSON, P.E. 79564 ON AUGUST 31, 2006. IT IS NOT TO BE USED
FOR CONSTRUCTION, BIDDING, OR PERMIT PURPOSES.

AUGUST 2006

EXECUTIVE SUMMARY

INTRODUCTION

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Infrastructure and Technology Group Inc. (Parsons), were contracted by the Texas Commission on Environmental Quality (TCEQ) to conduct a study to assist with identifying and analyzing alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

The overall goal of this project is to promote compliance using sound engineering and financial methods and data for PWSs that have recently had sample results that exceed maximum contaminant levels (MCL). The primary objectives of this project are to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS with regard to future implementation. The feasibility studies identify a range of potential compliance alternatives, and present basic data that can be used for evaluating feasibility. The compliance alternatives addressed include a description of what would be required for implementation, conceptual cost estimates for implementation, and non-cost factors that could be used to differentiate between alternatives. The cost estimates are intended for comparing compliance alternatives, and to give a preliminary indication of potential impacts on water rates resulting from implementation.

It is anticipated that the PWS will review the compliance alternatives in this report to determine if there are promising alternatives, and then select the most attractive alternative(s) for more detailed evaluation and possible subsequent implementation. This report contains a decision tree approach that guided the efforts for this study, and also contains steps to guide a PWS through the subsequent evaluation, selection, and implementation of a compliance alternative.

This feasibility analysis report provides an evaluation of water supply alternatives for the Midway Mobile Home Park (MHP), PWS ID# 1330020, located in Kerr County, Texas (the Midway PWS). The Midway PWS recorded sample results for combined uranium above its MCL of 0.03 milligrams per liter (mg/L), which is equivalent to 20.1 picoCuries per liter (pCi/L) as radioactivity (USEPA 2006; TCEQ 2004a). Sample results have ranged from 20.64 pCi/L in October 2003, to 38 pCi/L in quarterly samples taken between July 1, 2004 and June 30, 2005, to a more recent lower analytical result in December 2005 of 19.3 pCi/L, which is below the MCL. The PWS has no other reported water quality issues.

Basic system information for the Midway PWS is shown in Table ES.1.

Table ES.1
Midway PWS
Basic System Information

Population served	17
Connections	12
Average daily flow rate	0.0013 million gallons per day (mgd)
Peak demand flow rate	0.0052 mgd
Water system peak capacity	0.086 mgd
Reported uranium levels	19.3 to 38 pCi/L

STUDY METHODS

The methods used for this study were based on a pilot study performed in 2004 and 2005 by TCEQ, BEG, and Parsons. Methods for identifying and analyzing compliance options were developed in the pilot study (a decision tree approach).

The process for developing the feasibility study used the following general steps:

1. Gather data from the TCEQ and Texas Water Development Board databases, from TCEQ files, and from information maintained by the PWS;
2. Conduct financial, managerial, and technical (FMT) evaluations of the PWS;
3. Perform a geologic and hydrogeologic assessment of the study area (Midway PWS located in Kerr County – the system includes one operational well and one backup well, both located in the Glen Rose Limestone, Lower Member aquifer);
4. Develop treatment and non-treatment compliance alternatives which, in general, consist of the following possible options:
 - a. Connecting to neighboring PWSs via new pipeline or by pumping water from a newly installed well or an available surface water supply within the jurisdiction of the neighboring PWS;
 - b. Installing new wells within the vicinity of the PWS into other aquifers with confirmed water quality standards meeting the MCLs;
 - c. Installing a new intake system within the vicinity of the PWS to obtain water from a surface water supply with confirmed water quality standards meeting the MCLs;
 - d. Treating the existing non-compliant water supply by various methods depending on the type of contaminant; and
 - e. Delivering potable water by way of a bottled water program or a treated water dispenser as an interim measure only.
5. Assess each of the potential alternatives with respect to economic and non-economic criteria; and

6. Prepare a feasibility report and present the results to the PWS.

This basic approach is summarized in Figure ES-1.

HYDROGEOLOGICAL ANALYSIS

The Midway PWS obtains groundwater from the lower Trinity aquifer (Sligo and Hosston formations). Radionuclide concentrations can vary significantly over relatively short distances or between various depths of the aquifer; as a result, there could be good quality groundwater nearby, as evidenced by a number of water neighboring PWSs with good quality groundwater. A review of surrounding PWSs reveals a trend where deeper wells tend to have lower concentrations of uranium. However, the variability of radionuclide concentrations such as uranium makes it difficult to determine where wells can be located to produce acceptable water. It may be possible to do down-hole testing on non-compliant wells to determine the source of the contaminants. If the contaminants derive primarily from a single part of the formation, that part could be excluded by modifying the existing well, or avoided altogether by completing a new well.

COMPLIANCE ALTERNATIVES

The Midway PWS is managed by the Fritz family and is operated under contract by the J. Tucker Pump Service Corporation. Overall, the system had an inadequate level of FMT capacity. The system had some areas that needed improvement to be able to address future compliance issues; however, the system had positive aspects, such as knowledgeable operators. Areas of concern for the system included inadequate financing, no reserve account, and lack of long-term planning for compliance and sustainability.

There are numerous PWSs within 10 miles of the Midway PWS. Some of these nearby systems also have problems with radionuclides, but there are many with good quality water. In general, feasibility alternatives were developed based on obtaining water from the nearest PWSs, either by directly purchasing water, or by expanding the existing Midway PWS well field.

A number of centralized treatment alternatives for uranium removal have been developed and were considered for this report, including ion exchange, WRT adsorption treatment, and coagulation/filtration. Point-of-use (POU) and point-of-entry treatment alternatives were also considered. Temporary solutions such as providing bottled water or providing a centralized dispenser for treated or trucked-in water, were also considered as alternatives.

Developing a new well near the Midway PWS is likely to be the best solution if compliant groundwater can be found. Having a new well near the existing system is likely to be one of the lower cost alternatives since the PWS already possesses the technical and managerial expertise needed to implement this option. The cost of new well alternatives quickly increases with pipeline length, making proximity of the alternate source a key concern. A new compliant well or obtaining water from a neighboring compliant PWS has the advantage of providing compliant water to all taps in the system.

1 Central treatment can be cost-competitive with the alternative of new nearby wells, but
2 would require significant institutional changes to manage and operate. Like obtaining an
3 alternate compliant water source, central treatment would provide compliant water to all water
4 taps.

5 POU treatment can be cost competitive, but does not supply compliant water to all taps.
6 Additionally, significant efforts would be required for maintenance and monitoring of the POU
7 treatment units.

8 Providing compliant water through a central dispenser is significantly less expensive than
9 providing bottled water to 100 percent of the population. A significant effort is required for
10 clients to fill their containers at the central dispenser.

11 **FINANCIAL ANALYSIS**

12 Financial analysis of the Midway PWS indicated that current water rates are under funding
13 operations, and a rate increase of approximately 128 percent would be necessary to meet
14 operating expenses. This increase would raise the average annual water bill from \$180 to \$411.
15 The current average water bill represents approximately 0.5 percent of the median household
16 income (MHI), and would represent approximately 1.2 percent of the MHI with the increase.
17 Table ES.2 provides a summary of the financial impact of implementing selected compliance
18 alternatives, including the rate increase necessary to meet current operating expenses. The
19 alternatives were selected to highlight results for the best alternatives from each different type
20 or category.

21 Some of the compliance alternatives offer potential for shared or regional solutions. A
22 group of PWSs could work together to implement alternatives for developing a new
23 groundwater source or expanding an existing source, obtaining compliant water from a large
24 regional provider, or for central treatment. Sharing the cost for implementation of these
25 alternatives could reduce the cost on a per user basis. Additionally, merging PWSs or
26 management of several PWSs by a single entity offers the potential for reduction in
27 administrative costs.

28

1
2

**Figure ES-1
Summary of Project Methods**




Table ES.2
Selected Financial Analysis Results

Alternative	Funding Option	Average Annual Water Bill	Percent of MHI
Current	NA	\$180	0.5
To meet current expenses	NA	\$411	1.2
Purchase water from City of Kerrville	100% Grant	\$411	1.2
	Loan/Bond	\$411	1.2
Central treatment – WRT Z-92	100% Grant	\$3,026	8.8
	Loan/Bond	\$5,419	16
Point-of-use	100% Grant	\$1,174	3.4
	Loan/Bond	\$1,228	3.6

TABLE OF CONTENTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33

EXECUTIVE SUMMARY	ES-1
LIST OF TABLES.....	III
LIST OF FIGURES.....	IV
ACRONYMS AND ABBREVIATIONS	V
SECTION 1 INTRODUCTION	1-1
1.1 Public Health and Compliance with MCLs.....	1-1
1.2 Method.....	1-1
1.3 Regulatory Perspective.....	1-2
1.4 Abatement Options.....	1-5
1.4.1 Existing Public Water Supply Systems	1-5
1.4.2 Potential for New Groundwater Sources.....	1-6
1.4.3 Potential for Surface Water Sources.....	1-8
1.4.4 Identification of Treatment Technologies	1-9
1.4.5 Description of Treatment Technologies	1-9
1.4.6 Point-of-Entry and Point-of-Use Treatment Systems.....	1-13
1.4.7 Water Delivery or Central Drinking Water Dispensers	1-14
SECTION 2 EVALUATION METHOD.....	2-1
2.1 Decision Tree.....	2-1
2.2 Data Sources and Data Collection.....	2-1
2.2.1 Data Search.....	2-1
2.2.2 PWS Interviews	2-7
2.3 Alternative Development and Analysis.....	2-10
2.3.1 Existing PWS.....	2-10
2.3.2 New Groundwater Source	2-10
2.3.3 New Surface Water Source	2-11
2.3.4 Treatment.....	2-11
2.4 Cost of Service and Funding Analysis	2-11
2.4.1 Financial Feasibility	2-12
2.4.2 Median Household Income.....	2-12
2.4.3 Annual Average Water Bill.....	2-12
2.4.4 Financial Plan Development.....	2-13
2.4.5 Financial Plan Results	2-13

1	SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS.....	3-1
2	3.1 Radium, Gross alpha, and uranium in the Southern part of the Trinity Aquifer...	3-1
3	3.2 Regional geology.....	3-5
4	3.3 Detailed Assessment for Midway PWS	3-7
5	3.3.1 Summary of Alternative Groundwater Sources for the Midway Mobile Home	
6	PWS.....	3-8
7	SECTION 4 ANALYSIS OF THE MIDWAY PWS	4-1
8	4.1 Description of Existing System	4-1
9	4.1.1. Existing System.....	4-1
10	4.1.2 Capacity Assessment for the Midway PWS.....	4-3
11	4.2 Alternative Water Source Development.....	4-6
12	4.2.1 Identification of Alternative Existing Public Water Supply Sources	4-6
13	4.2.2 Potential for New Groundwater Sources.....	4-10
14	4.2.3 Potential for New Surface Water Sources	4-11
15	4.2.4 Options for Detailed Consideration.....	4-12
16	4.3 Treatment Options	4-12
17	4.3.1 Centralized Treatment Systems.....	4-12
18	4.3.2 Point-of-Use Systems	4-12
19	4.3.3 Point-of-Entry Systems	4-12
20	4.4 Bottled Water.....	4-12
21	4.5 Alternative Development and Analysis.....	4-13
22	4.5.1 Alternative MW-1: Purchase Water from Ingram WSC	4-13
23	4.5.2 Alternative MW-2: New Well in the Vicinity of Sleepy Hollow PWS	4-14
24	4.5.3 Alternative MW-3: Purchase Water from the City of Kerrville.....	4-14
25	4.5.4 Alternative MW-4: New Well at 10 miles	4-15
26	4.5.5 Alternative MW-5: New Well at 5 miles	4-16
27	4.5.6 Alternative MW-6: New Well at 1 mile	4-16
28	4.5.7 Alternative MW-7: Central IX Treatment.....	4-17
29	4.5.8 Alternative MW-8: WRT Z-92 Treatment	4-18
30	4.5.9 Alternative MW-9: Coagulation/Filtration.....	4-18
31	4.5.10 Alternative MW-10: Point-of-Use Treatment	4-19
32	4.5.11 Alternative MW-11: Point-of-Entry Treatment.....	4-20
33	4.5.12 Alternative MW-12: Public Dispenser for Treated Drinking Water	4-21
34	4.5.13 Alternative MW-13: 100 Percent Bottled Water Delivery	4-22
35	4.5.14 Alternative MW-14: Public Dispenser for Trucked Drinking Water	4-22

4.5.15	Summary of Alternatives.....	4-23
4.6	Cost of Service and Funding Analysis	4-23
4.6.1	Midway PWS Financial Data	4-23
4.6.2	Current Financial Condition	4-24
4.6.3	Financial Plan Results	4-24
SECTION 5	REFERENCES	5-1

APPENDICES

Appendix A	PWS Interview Forms
Appendix B	Cost Basis
Appendix C	Compliance Alternative Conceptual Cost Estimates
Appendix D	Example Financial Models
Appendix E	Radionuclide Chemistry

LIST OF TABLES

Table ES.1	Midway PWS Basic System Information.....	ES-2
Table ES.2	Selected Financial Analysis Results	ES-6
Table 3.1	Well Depth and Screen Interval Depths for Wells in the Midway PWS.....	3-7
Table 3.2	Uranium concentrations at Midway PWS	3-7
Table 3.3	Radium concentrations at Midway PWS.....	3-7
Table 3.4	Gross alpha concentrations at Midway PWS	3-7
Table 4.1	Existing Public Water Systems Within 5 Miles of the Midway PWS	4-7
Table 4.2	Public Water Systems in the Vicinity of the Midway Selected for Further Evaluation	4-8
Table 4.3	Summary of Compliance Alternatives for the Midway PWS	4-26
Table 4.4	Financial Impact on Households	4-28
Table E.1	Uranium, Thorium, and Radium Abundance and Half-Lives	E-2

LIST OF FIGURES

1		
2	Figure ES-1	Summary of Project Methods ES-5
3	Figure 1.1	Midway MHP Location Map.....1-3
4	Figure 1.2	Groundwater Districts, Conservation Areas, Municipal Authorities, and
5		Planning Groups1-4
6	Figure 2.1	Decision Tree – Tree 1 Existing Facility Analysis.....2-2
7	Figure 2.2	Decision Tree – Tree 2 Develop Treatment Alternatives.....2-3
8	Figure 2.3	Decision Tree – Tree 3 Preliminary Analysis2-4
9	Figure 2.4	Decision Tree – Tree 4 Financial2-5
10	Figure 3.1.	Radium Concentrations in Groundwater of Southern Part of the
11		Trinity Aquifer.....3-1
12	Figure 3.2	Gross Alpha in Groundwater in the Southern Part of the Trinity Aquifer3-2
13	Figure 3.3	Uranium in Groundwater of the Southern Trinity Aquifer3-3
14	Figure 3.4	Relationships Between Radium, Gross Alpha, and Uranium
15		in Groundwater in the Southern Part of the Trinity Aquifer3-4
16	Figure 3.5	Relationships Between Radium Concentrations and Chloride,
17		TDS, and Sulfate in the Southern Trinity Aquifer3-5
18	Figure 3.6	Uranium in the 5- and 10-km Buffers of the Midway PWS Wells3-8
19	Figure 4.1	Midway MHP4-2
20	Figure 4.2	Alternative Cost Summary: Midway PWS.....4-29
21		

1

ACRONYMS AND ABBREVIATIONS

μ	micrograms per liter
AA	activated alumina
AFY	acre-feet per year
BAT	best available technology
BEG	Bureau of Economic Geology
CA	chemical analysis
CCN	Certificate of Convenience and Necessity
CFR	Code of Federal Regulations
CO	correspondence
FMT	financial, managerial, and technical
ft ²	square foot
GAM	Groundwater Availability Model
IX	Ion exchange
MCL	Maximum contaminant level
mg/L	milligrams per Liter
mgd	million gallons per day
MHI	median household income
MOR	monthly operating report
MPH	mobile home park
NMEFC	New Mexico Environmental Financial Center
NURE	National Uranium Resource Evaluation
O&M	operation and maintenance
Parsons	Parsons Infrastructure and Technology Group Inc.
pCi/L	picoCuries per liter
POE	Point-of-entry
POU	Point-of-use
PSOC	potential source of contamination
PWS	public water system
RO	Reverse osmosis
SDWA	Safe Drinking Water Act
SSCT	small system compliance technologies
TCEQ	Texas Commission on Environmental Quality
TDS	Total dissolved solids
TSS	Total suspended solids
TWDB	Texas Water Development Board
UGRA	Upper Guadalupe River Authority
USEPA	United States Environmental Protection Agency
WAM	Water Availability Model
WRT	Water Remediation Technologies, Inc.

2
3

SECTION 1 INTRODUCTION

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Infrastructure and Technology Group Inc. (Parsons), have been contracted by the Texas Commission on Environmental Quality (TCEQ) to assist with identifying and analyzing compliance alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

The primary objective of this project is to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options. The goal is to promote compliance using sound engineering and financial methods and data for PWSs that have recently had sample results that exceed maximum contaminant levels (MCL).

This feasibility analysis report provides an evaluation of water supply alternatives for the Midway Mobile Home Park (MHP), PWS ID# 1330020, located in Kerr County, Texas (the Midway PWS). The Midway PWS recorded sample results for combined uranium above its MCL of 0.03 mg/L, which is equivalent to 20.1 picoCuries per liter (pCi/L) (USEPA 2006; TCEQ 2004a). Sample results have ranged from 20.64 pCi/L in October 2003, to 38 pCi/L in quarterly samples taken between July 1, 2004 and June 30, 2005, to a more recent lower sample result in December 2005 of 19.3 pCi/L. The PWS has no other reported water quality issues.

The location of the Midway PWS, also referred to as the “study area” in this report, is shown in Figure 1.1. Various water supply and planning jurisdictions are shown on Figure 1.2. These water supply and planning jurisdictions are used in the evaluation of alternate water supplies that may be available in the area.

1.1 PUBLIC HEALTH AND COMPLIANCE WITH MCLS

The goal of this project is to promote compliance for PWSs that supply drinking water exceeding regulatory MCLs. This project only addresses those contaminants and does not address any other violations that may exist for a PWS. As mentioned above, the Midway PWS had recorded sample results exceeding the MCL for combined uranium. In general, uranium in drinking water above the MCL can have both short-term (acute) and long-term or lifetime (chronic) effects. Short-term exposure to uranium in drinking water may result in toxic effects to the kidney. Long-term exposure to drinking water containing alpha emitters in excess of the MCL may increase the risk of cancer and kidney damage (USEPA 2006).

1.2 METHOD

The method used for this project follows that of the pilot study performed in 2004 and 2005 by TCEQ, BEG, and Parsons. The pilot study evaluated water supply alternatives for PWSs that supply drinking water with nitrate concentrations above U.S. Environmental Protection Agency (USEPA) and Texas drinking water standards. Three PWSs were evaluated in the pilot study to develop the method (*i.e.*, decision tree approach) for analyzing options for

provision of compliant drinking water. This project is performed using the decision tree approach developed in the pilot study.

Other tasks of the feasibility study are as follows:

- Identifying available data sources;
- Gathering and compiling data;
- Conducting financial, managerial, and technical (FMT) evaluations of the selected PWSs;
- Performing a geologic and hydrogeologic assessment of the study area;
- Developing treatment and non-treatment compliance alternatives;
- Assessing potential alternatives with respect to economic and non-economic criteria;
- Preparing a feasibility report; and
- Suggesting refinements to the approach for future studies.

The remainder of Section 1 of this report addresses the regulatory background, and provides a summary of abatement options for combined uranium. Section 2 describes the method used to develop and assess compliance alternatives. The groundwater sources of uranium and other radionuclides are addressed in Section 3. Findings for the Midway PWS, along with compliance alternatives development and evaluation, can be found in Section 4. Section 5 references the sources used in this report.

1.3 REGULATORY PERSPECTIVE

The Utilities & Districts and Public Drinking Water Sections of the TCEQ Water Supply Division are responsible for implementing requirements of the Federal Safe Drinking Water Act (SDWA) which include oversight of PWSs and water utilities. These responsibilities include:

- Monitoring public drinking water quality;
- Processing enforcement referrals for MCL violators;
- Tracking and analyzing compliance options for MCL violators;
- Providing FMT assessment and assistance to PWSs;
- Participating in the Drinking Water State Revolving Fund program to assist PWSs in achieving regulatory compliance; and
- Setting rates for privately-owned water utilities.

This project was conducted to assist in achieving these responsibilities.






Figure 1.1

**Midway Mobile Home Park
Location Map**



1.4 ABATEMENT OPTIONS

When a PWS exceeds a regulatory MCL, the PWS must take action to correct the violation. The MCL exceedances at the Midway PWS involve uranium. The following subsections explore alternatives considered as potential options for obtain/providing compliant drinking water.

1.4.1 Existing Public Water Supply Systems

A common approach to achieving compliance is for the PWS to make arrangements with a neighboring PWS for water supply. For this arrangement to work, the PWS from which water is being purchased (supplier PWS) must have water in sufficient quantity and quality, the political will must exist, and it must be economically feasible.

1.4.1.1 Quantity

For purposes of this report, quantity refers to water volume, flowrate, and pressure. Before approaching a potential supplier PWS, the non-compliant PWS should determine its water demand on the basis of average day and maximum day. Peak instantaneous demands can be met through proper sizing of storage facilities. Further, the potential for obtaining the appropriate quantity of water to blend to achieve compliance should be considered. The concept of blending involves combining water with low levels of contaminants with non-compliant water in sufficient quantity that the resulting blended water is compliant. The exact blend ratio would depend on the quality of the water a potential supplier PWS can provide, and would likely vary over time. If high quality water is purchased, produced or otherwise obtained, blending can reduce the amount of high quality water required. Implementation of blending will require a control system to ensure the blended water is compliant.

If the supplier PWS does not have sufficient quantity, the non-compliant community could pay for the facilities necessary to increase the quantity to the extent necessary to supply the needs of the non-compliant PWS. Potential improvements might include, but are not limited to:

- Additional wells;
- Developing a new surface water supply;
- Additional or larger-diameter piping;
- Increasing a water treatment plant capacity;
- Additional storage tank volume;
- Reduction of system losses;
- Higher-pressure pumps; or
- Upsized, or additional, disinfection equipment.

In addition to the necessary improvements, a transmission pipeline would need to be constructed to tie the two PWSs together. The pipeline must tie-in at a point in the supplier PWS where all the upstream pipes and appurtenances are of sufficient capacity to handle the new demand. In the non-compliant PWS, the pipeline must tie in at a point where no downstream bottlenecks are present. If blending is the selected method of operation, the tie-in point must be at the proper point of the existing non-compliant PWS to ensure that all the water in the system is blended to achieve regulatory compliance.

1.4.1.2 Quality

If a potential supplier PWS obtains its water from the same aquifer (or same portion of the aquifer) as the non-compliant PWS, the quality of water may not be significantly better. However, water quality can vary significantly due to well location, even within the same aquifer. If localized areas with good water quality cannot be identified, the non-compliant PWS would need to find a potential supplier PWS that obtains its water from a different aquifer or from a surface water source. Additionally, a potential supplier PWS may treat non-compliant raw water to an acceptable level.

Surface water sources may offer a potential higher-quality source. Since there are significant treatment requirements, utilization of surface water for drinking water is typically most feasible for larger local or regional authorities or other entities that may provide water to several PWSs. Where PWSs that obtain surface water are neighbors, the non-compliant PWS may need to deal with those systems as well as with the water authorities that supply the surface water.

1.4.2 Potential for New Groundwater Sources

1.4.2.1 Existing Non-Public Supply Wells

Often there are wells not associated with PWSs that are located in the vicinity of the non-compliant PWS. The current use of these wells may be for irrigation, industrial purposes, domestic supply, stock watering, and other purposes. The process for investigating existing wells is as follows:

- Use existing data sources (see below) to identify wells in the areas that have satisfactory quality. For the Midway PWS, the following standards could be used in a rough screening to identify compliant groundwater in surrounding systems:
 - Combined uranium concentrations less than 16 pCi/L (below the MCL of 20.1 pCi/L); and
 - Total dissolved solids (TDS) concentrations less than 1,000 mg/L.
- Review the recorded well information to eliminate those wells that appear to be unsuitable for the application. Often, the “Remarks” column in the Texas Water Development Board (TWDB) hard-copy database provides helpful information. Wells eliminated from consideration generally include domestic and stock wells,

dug wells, test holes, observation wells, seeps and springs, destroyed wells, wells used by other communities, *etc.*

- Identify wells of sufficient size which have been used for industrial or irrigation purposes. Often the TWDB database will include well yields, which may indicate the likelihood that a particular well is a satisfactory source.
- At this point in the process, the local groundwater control district (if one exists) should be contacted to obtain information about pumping restrictions. Also, preliminary cost estimates should be made to establish the feasibility of pursuing further well development options.
- If particular wells appear to be acceptable, the owner(s) should be contacted to ascertain their willingness to work with the PWS. Once the owner agrees to participate in the program, questions should be asked about the wells. Many owners have more than one well, and would probably be the best source of information regarding the latest test dates, who tested the water, flowrates, and other well characteristics.
- After collecting as much information as possible from cooperative owners, the PWS would then narrow the selection of wells and sample and analyze them for quality. Wells with good quality would then be potential candidates for test pumping. In some cases, a particular well may need to be refurbished before test pumping. Information obtained from test pumping would then be used in combination with information about the general characteristics of the aquifer to determine whether a well at this location would be suitable as a supply source.
- It is recommended that new wells be installed instead of using existing wells to ensure the well characteristics are known and the well meets construction standards.
- Permit(s) would then be obtained from the groundwater control district or other regulatory authority, and an agreement with the owner (purchase or lease, access easements, *etc.*) would then be negotiated.

1.4.2.2 Develop New Wells

If no existing wells are available for development, the PWS or group of PWSs has an option of developing new wells. Records of existing wells, along with other hydrogeologic information and modern geophysical techniques, should be used to identify potential locations for new wells. In some areas, the TWDB's Groundwater Availability Model (GAM) may be applied to indicate potential sources. Once a general area has been identified, land owners and regulatory agencies should be contacted to determine an exact location for a new well or well field. Pump tests and water quality tests would be required to determine if a new well will produce an adequate quantity of good quality water. Permits from the local groundwater control district or other regulatory authority could also be required for a new well.

1.4.3 Potential for Surface Water Sources

Water rights law dominates the acquisition of water from surface water sources. For a PWS, 100 percent availability of water is required, except where a back-up source is available. For PWSs with an existing water source, although it may be non-compliant because of elevated concentrations of one or more parameters, water rights may not need to be 100 percent available.

1.4.3.1 Existing Surface Water Sources

“Existing surface water sources” of water refers to municipal water authorities and cities that obtain water from surface water sources. The process of obtaining water from such a source is generally less time consuming and less costly than the process of developing a new source; therefore, it should be a primary course of investigation. An existing source would be limited by its water rights, the safe yield of a reservoir or river, or by its water treatment or water conveyance capability. The source must be able to meet the current demand and honor contracts with communities it currently supplies. In many cases, the contract amounts reflect projected future water demand based on population or industrial growth.

A non-compliant PWS would look for a source with sufficient spare capacity. Where no such capacity exists, the non-compliant PWS could offer to fund the improvements necessary to obtain the capacity. This approach would work only where the safe yield could be increased (perhaps by enlarging a reservoir) or where treatment capacity could be increased. In some instances water rights, where they are available, could possibly be purchased.

In addition to securing the water supply from an existing source, the non-compliant PWS would need to arrange for transmission of the water to the PWS. In some cases, that could require negotiations with, contracts with, and payments to an intermediate PWS (an intermediate PWS is one where the infrastructure is used to transmit water from a “supplier” PWS to a “supplied” PWS, but does not provide any additional treatment to the supplied water). The non-compliant PWS could be faced with having to fund improvements to the intermediate PWS in addition to constructing its own necessary transmission facilities.

1.4.3.2 New Surface Water Sources

Communication with the TCEQ and relevant planning groups from the beginning is essential in the process of obtaining a new surface water source. Preliminary assessment of the potential for acquiring new rights may be based on surface water availability maps located on the TWDB website. Where water rights appear to be available, the following activities need to occur:

- Discussions with TCEQ to indicate the likelihood of obtaining those rights. The TCEQ may use the Water Availability Model (WAM) to assist in the determination.
- Discussions with land owners to indicate potential treatment plant locations.
- Coordination with U.S. Army Corps of Engineers and local river authorities.

- Preliminary engineering design to determine the feasibility, costs, and environmental issues of a new treatment plant.

Should these discussions indicate that a new surface water source is the best option, the community would proceed with more intensive planning (initially obtaining funding), permitting, land acquisition, and detailed designs.

1.4.4 Identification of Treatment Technologies

The uranium isotopes U-234, U-235 and U-238 combine with carbonate to form complexed anions (*e.g.*, $\text{UO}_2(\text{CO}_3)_2^{2-}$ and $\text{UO}_2(\text{CO}_3)_3^{4-}$) which are dissolved in water at pH between 6.0 and 8.2, and are not easily removed by particle filtration. The MCL for total uranium is 30 micrograms per liter ($\mu\text{g/L}$) which is equivalent to 20.1 pCi/L as radio activity.

The following best available technologies (BAT) were identified in the Radionuclides Final Rule for achieving compliance with the uranium MCL:

- Ion Exchange (IX);
- Reverse Osmosis (RO);
- Lime Softening; and
- Coagulation/Filtration.

In addition, the following technologies are included in the Radionuclides Final Rule as small system compliance technologies (SSCT):

- IX (Centralized and point of use [POU]);
- RO (Centralized and POU);
- Lime Softening;
- Activated Alumina (AA); and
- Coagulation/Filtration.

1.4.5 Description of Treatment Technologies

In addition to the BAT and SSCTs identified in the Radionuclides Final Rule, a relatively new process using WRT Z-92™ media that is specific for uranium adsorption has been demonstrated to be an effective uranium removal technology. Because capacity of the Midway PWS is very small and the TDS is not high, the use of RO, lime softening, and AA are not practical and these treatment technologies are not evaluated further. The remaining technologies to be evaluated include ion exchange, WRT Z-92 adsorption, and coagulation/filtration. These technologies are described as follows.

1.4.5.1 Ion Exchange

Process – In solution, salts separate into positively-charged cations and negatively-charged anions. Ion exchange (IX) is a reversible chemical process in which ions from an insoluble, permanent, solid resin bed are exchanged for ions in the water. The process relies on the fact that certain ions are preferentially adsorbed on the ion exchange resin. Operation begins with a fully charged cation or anion bed, having enough positively or negatively charged ions to carry out the cation or anion exchange. Usually a polymeric resin bed is composed of millions of spherical beads about the size of medium sand grains. As water passes the resin bed, the charged ions are released into the water, being substituted or replaced with the contaminants in the water (ion exchange). When the resin becomes exhausted of positively or negatively charged ions, the bed must be regenerated by passing a strong, sodium chloride, solution over the resin, displacing the contaminants ions with sodium ions for cation exchange and chloride ion for anion exchange. Many different types of resins can be used to reduce dissolved contaminant concentrations. The IX treatment train for groundwater typically includes cation or anion resins beds with a regeneration system, chlorine disinfection, and clear well storage. Treatment trains for surface water may also include raw water pumps, debris screens, and filters for pre-treatment. Additional treatment or management of the concentrate and the removed solids will be necessary prior to disposal, especially for radium removal resins which have elevated radioactivity.

For uranium removal, a strong base anion exchange resin in the chloride form can remove >95 percent of the uranium. Regeneration of the anion resin uses the chloride portion of salt. Given the extremely heavy molecular weight of uranium and its valence, the longevity of anion exchange resin would likely be one or two months or more between regeneration cycles. Uranium is very tightly held by the anion resin and thus a very high concentration of brine is needed to regenerate the resin. Environmentally, less frequent regeneration can compensate for the high salt usage needed when regeneration is performed.

Pretreatment – Pretreatment guidelines are available on accepted limits for pH, organics, turbidity, and other raw water characteristics. Pretreatment may be required to reduce excessive amounts of total suspended solids (TSS), iron, and manganese, which could plug the resin bed, and typically includes media or carbon filtration.

Maintenance – The IX resin requires regular on-site regeneration, the frequency of which depends on raw water characteristics (especially sulfate), the contaminant concentration, and the size and number of IX vessels. Many systems have undersized the IX vessels only to realize higher than necessary operating costs. Preparation of the sodium chloride solution is required. If used, filter replacement and backwashing will be required.

Waste Disposal – Approval from local authorities is usually required for disposal of concentrate from the regeneration cycle (highly concentrated salt solution with radioactivity); occasional solids wastes (in the form of broken resin beads) which are backwashed during regeneration; and if used, spent filters and backwash wastewater.

Advantages

- Well established process for uranium removal.
- Fully automated and highly reliable process.
- Suitable for small and large installations.

Disadvantages

- Requires salt storage; regular regeneration.
- Concentrate disposal.
- Resins are sensitive to the presence of competing ions such as sulfate and nitrate.

In considering application of IX for inorganics, it is important to understand what the effect of competing ions will be, and to what extent the brine can be recycled. Conventional IX anionic resin removes sulfate in addition to uranium and thus the capacity for uranium removal and frequency of regeneration depend on the concentrations of sulfate and nitrate of the water to be treated. Spent regenerant is produced during IX bed regeneration, and it may have concentrations of the sorbed contaminants which will be expensive to treat and/or dispose because of hazardous waste regulations.

1.4.5.2 WRT Z-92 Media

Process – The WRT Z-92 uranium treatment process is a proprietary process using a uranium specific adsorption resin or zeolite supplied by Water Remediation Technologies, Inc. (WRT). The Z-92 process is similar to IX except that no regeneration of the resin is conducted and the resin is disposed of upon exhaustion. The Z-92 does not remove chloride and sulfate and thus it can last for a long time (2-3 years, according to WRT) before replacement is necessary. The process is operated in an upflow, fluidized mode with a surface loading rate of 10.5 gallons per minute (gpm) per square foot (ft²). Pilot testing of this technology has been conducted successfully for uranium removal in several locations. Seven full-scale systems with capacities of 750 to 1,200 gpm have been constructed in the Village of Oswego, Illinois since July 2005 for radium removal. The treatment equipment is owned by WRT and the ownership of spent media would be transferred to an approved disposal site. The customer pays WRT based on an agreed upon treated water unit cost (e.g., \$.100-6.70/1000 gal, depending on site location and volume).

Pretreatment – Pretreatment may be required to reduce excess amounts of TSS, iron, and manganese, which could plug the resin bed, and typically includes media or carbon filtration. No chemical addition is required for radium removal.

Maintenance – Maintenance is relatively low for this technology as no regeneration or chemical handling is required. Periodical water quality monitoring and inspection of mechanical equipment are required.

Waste Disposal – The Z-92 media would be disposed of in an approved low level radioactive waste landfill by WRT once every 2-3 years. No liquid waste is generated for this process. However, if pretreatment filters are used then spent filters and backwash wastewater disposal is required.

Advantages

- Simple and fully automated process.
- No liquid waste disposal.
- No chemical handling, storage, or feed systems.
- No change in water quality except uranium reduction.
- Low capital cost as WRT owns the equipment.

Disadvantages

- Relatively new technology.
- Proprietary technology without direct competition.
- Long term contract with WRT required.

From a small utilities point of view the Z-92 process is a desirable technology for uranium removal as O&M effort is minimal and no regular liquid waste is generated. However, this technology is very new and without long-term full-scale operating experience. But since the equipment is owned by WRT and the performance is guaranteed by WRT the risk to the utilities is minimized.

1.4.5.3 Coagulation/Filtration

Process – Coagulation using ferric or aluminum salts followed by granular media filtration can remove from 50-90 percent of uranium, depending on pH and coagulant dosage. The process is most effective at pH 6 and pH 10. Uranium is adsorbed and/or co-precipitated onto the metal oxides and removed by filtration. The filtration can be accomplished with granular media filter or microfilter. The filters used in groundwater treatment are usually pressure filters feeding directly by the well pumps. The filter can be regular dual media filters or proprietary media such as the engineered ceramic filtration media, Macrolite[®], developed by Kinetico. Macrolite is a low-density, spherical media and is designed to allow for filtration rates up to 10 gpm/ft², which is a higher loading rate than commonly used for conventional filtration media.

Pretreatment – Adjustment of pH may be required if the water pH deviates much from the effective pH of 6 or 10. The coagulant is fed before filtration which may depress pH to the desirable range. Sometimes a 5-minute contact tank is used ahead of the filters to allow for floc formation to enhance filtration.

Maintenance – Maintenance is mainly to handle coagulant chemical and feed system, and for regular backwash of the filters. No filter media replacement is required for this process.

Waste Disposal – Approval from local authorities is usually required for the backwash wastewater. If local sewer is not available a backwash storage and settling tank would be required to recycle settled water to the process and disposed of the settled solids periodically.

Advantages

- Well established process for uranium removal.
- No regeneration waste generated.
- Low pressure operation and no repumping required.

Disadvantages

- Need to handle coagulant chemical which is corrosive.
- Need to monitor and backwash regularly.
- Sludge disposal.

The coagulation/filtration process is a well established uranium removal. It is suitable for small and large systems and is usually cost competitive with other alternative technologies.

1.4.6 Point-of-Entry and Point-of-Use Treatment Systems

Point-of-entry (POE) and point-of-use (POU) treatment systems can be used to provide compliant drinking water. For uranium removal, these systems typically use small adsorption treatment units that are installed “under the sink” in the case of point-of-use, and where water enters a house or building in the case of point-of-entry. It should be noted that the POU treatment units would need to be more complex than units typically found in commercial retail outlets in order to meet regulatory requirements, making purchase and installation more expensive. Point-of-entry and point-of-use treatment units would be purchased and owned by the PWS. These solutions are decentralized in nature, and require utility personnel entry into houses or at least onto private property for installation, maintenance, and testing. Due to the large number of treatment units that would be employed and would be largely out of the control of the PWS, it is very difficult to ensure 100 percent compliance. Prior to selection of a point-of-entry or point-of-use program for implementation, consultation with TCEQ would be required to address measurement and determination of level of compliance

The SDWA [§1412(b)(4)(E)(ii)] regulates the design, management and operation of POU and POE treatment units used to achieve compliance with an MCL. These restrictions, relevant to uranium are:

- POU and POE treatment units must be owned, controlled, and maintained by the water system, although the utility may hire a contractor to ensure proper O&M and MCL compliance. The water system must retain unit ownership and oversight of unit installation, maintenance and sampling; the utility ultimately is the responsible

party for regulatory compliance. The water system staff need not perform all installation, maintenance, or management functions, as these tasks may be contracted to a third party-but the final responsibility for the quality and quantity of the water supplied to the community resides with the water system, and the utility must monitor all contractors closely. Responsibility for O&M of POU or POE devices installed for SDWA compliance may not be delegated to homeowners.

- POU and POE units must have mechanical warning systems to automatically notify customers of operational problems. Each POU or POE treatment device must be equipped with a warning device (*e.g.*, alarm, light) that would alert users when their unit is no longer adequately treating their water. As an alternative, units may be equipped with an automatic shut-off mechanism to meet this requirement.
- If the American National Standards Institute has issued product standards for a specific type of POU or POE treatment unit, only those units that have been independently certified according to those standards may be used as part of a compliance strategy.

The following observations with regard to using POE and POU devices for SDWA compliance were made by Raucher, *et al.* (2004):

- If POU devices are used as an SDWA compliance strategy, certain consumer behavioral changes will be necessary (*e.g.*, encouraging people to drink water only from certain treated taps) to ensure comprehensive consumer health protection.
- Although not explicitly prohibited in the SDWA, USEPA indicates that POU treatment devices should not be used to treat for radon or for most volatile organic contaminants to achieve compliance, because POU devices do not provide 100 percent protection against inhalation or contact exposure to those contaminants at untreated taps (*e.g.*, shower heads).
- Liability – PWSs considering unconventional treatment options (POU, POE, or bottled water) must address liability issues. These could be meeting drinking water standards, property entry and ensuing liabilities, and damage arising from improper installation or improper function of the POU and POE devices.

1.4.7 Water Delivery or Central Drinking Water Dispensers

Current USEPA regulations (40 Code of Federal Regulations [CFR] 141.101) prohibit the use of bottled water to achieve compliance with an MCL, except on a temporary basis. State regulations do not directly address the use of bottled water. Use of bottled water at a non-compliant PWS would be on a temporary basis. Every 3 years, the PWSs that employ interim measures are required to present the TCEQ with estimates of costs for piping compliant water to their systems. As long as the projected costs remain prohibitively high, the bottled water interim measure is extended. Until USEPA amends the noted regulation, the TCEQ is unable to accept water delivery or central drinking water dispensers as compliance solutions.

Central provision of compliant drinking water would consist of having one or more dispensers of compliant water where customers could come to fill containers with drinking water. The centralized water source could be from small to medium-sized treatment units or could be compliant water delivered to the central point by truck.

Water delivery is an interim measure for providing compliant water. As an interim measure for a small impacted population, providing delivered drinking water may be cost effective. If the susceptible population is large, the cost of water delivery would increase significantly.

Water delivery programs require consumer participation to a varying degree. Ideally, consumers would have to do no more than they currently do for a piped-water delivery system. Least desirable are those systems that require maximum effort on the part of the customer (*e.g.*, customer has to travel to get the water, transport the water, and physically handle the bottles). Such a system may appear to be lowest-cost to the utility; however, should a consumer experience ill effects from contaminated water and take legal action, the ultimate cost could increase significantly.

The ideal system would:

- Completely identify the susceptible population. If bottled water is only provided to customers who are part of the susceptible population, the utility should have an active means of identifying the susceptible population. Problems with illiteracy, language fluency, fear of legal authority, desire for privacy, and apathy may be reasons that some members of the susceptible population do not become known to the utility, and do not take part in the water delivery program.
- Maintain customer privacy by eliminating the need for utility personnel to enter the home.
- Have buffer capacity (*e.g.*, two bottles in service, so that when one is empty, the other is being used over a time period sufficient to allow the utility to change out the empty bottle).
- Provide for regularly scheduled delivery so the customer would not have to notify the utility when the supply is low.
- Use utility personnel and equipment to handle water containers, without requiring customers to lift or handle bottles with water in them.
- Be sanitary (*e.g.*, where an outside connection is made, contaminants from the environment must be eliminated).
- Be vandal-resistant.
- Avoid heating the water due to exterior temperatures and solar radiation.
- Avoid freezing the water.

SECTION 2 EVALUATION METHOD

2.1 DECISION TREE

The decision tree is a flow chart for conducting feasibility studies for a non-compliant PWS. The decision tree is shown in Figures 2.1 through 2.4. The tree guides the user through a series of phases in the design process. Figure 2.1 shows Tree 1, which outlines the process for defining the existing system parameters, followed by optimizing the existing treatment system operation. If optimizing the existing system does not correct the deficiency, the tree leads to six alternative preliminary branches for investigation. The groundwater branch leads through investigating existing wells to developing a new well field. The treatment alternatives address centralized and on-site treatment. The objective of this phase is to develop conceptual designs and cost estimates for the six types of alternatives. The work done for this report follows through Tree 1 and Tree 2, as well as a preliminary pass through Tree 4.

Tree 3, which begins at the conclusion of the work for this report, starts with a comparison of the conceptual designs, selecting the two or three alternatives that appear to be most promising, and eliminating those alternatives which are obviously infeasible. It is envisaged that a process similar to this would be used by the study PWS to refine the list of viable alternatives. The selected alternatives are then subjected to intensive investigation, and highlighted by an investigation into the socio-political aspects of implementation. Designs are further refined and compared, resulting in the selection of a preferred alternative. The steps for assessing the financial and economic aspects of the alternatives (one of the steps in Tree 3) are given in Tree 4 in Figure 2.4.

2.2 DATA SOURCES AND DATA COLLECTION

2.2.1 Data Search

2.2.1.1 Water Supply Systems

The TCEQ maintains a set of files on public water systems, utilities, and districts at its headquarters in Austin, Texas. The files are organized under two identifiers: a PWS identification number and a Certificate of Convenience and Necessity (CCN) number. The PWS identification number is used to retrieve four types of files:

- CO – Correspondence,
- CA – Chemical analysis,
- MOR – Monthly operating reports (quality/quantity), and
- FMT – Financial, managerial and technical issues.

Figure 2.1
TREE 1 – EXISTING FACILITY ANALYSIS




Figure 2.2
TREE 2 – DEVELOP TREATMENT ALTERNATIVES




Figure 2.3

Tree 3 – PRELIMINARY ANALYSIS





Figure 2.4
TREE 4 – FINANCIAL



The CCN files generally contain a copy of the system's Certificate of Convenience and Necessity, along with maps and other technical data.

These files were reviewed for the PWS and surrounding systems.

The following websites were consulted to identify the water supply systems in the study area:

- TCEQ Water Utility Database: www.tnrc.state.tx.us/iwud/pws/index.cfm. Under "Advanced Search", type in the name(s) of the county(ies) in the study area to get a listing of the public water supply systems.
- USEPA Safe Drinking Water Information System: www.epa.gov/safewater/data/getdata.html

Groundwater Control Districts were identified on the TWDB web site, which has a series of maps covering various groundwater and surface water subjects. One of those maps shows groundwater control districts in the State of Texas.

2.2.1.2 Existing Wells

The TWDB maintains a groundwater database available at www.twdb.state.tx.us that has two tables with helpful information. The "Well Data Table" provides a physical description of the well, owner, location in terms of latitude and longitude, current use, and for some wells, items such as flowrate, and nature of the surrounding formation. The "Water Quality Table" provides information on the aquifer and the various chemical concentrations in the water.

2.2.1.3 Surface Water Sources

Regional planning documents were consulted for lists of surface water sources.

2.2.1.4 Groundwater Availability Model

GAMs, developed by the TWDB, are planning tools and should be consulted as part of a search for new or supplementary water sources.

The PWS is located in the southern end of the Trinity aquifer that extends along north central Texas. The aquifer's outcrop is present along east Kerr County and, in some areas, water-bearing rock formations are located below the Edwards-Trinity aquifer. The Midway PWS groundwater supply is the Glen Rose limestone of the Trinity aquifer. Two other aquifer units, the Hosston and Hensell Sand formations, are also widely utilized in PWSs located within 20 miles of the Midway PWS.

The GAM for this area of groundwater was investigated as a potential tool for identifying available and suitable groundwater resources.

2.2.1.5 Water Availability Model

The WAM is a computer-based simulation predicting the amount of water that would be in a river or stream under a specified set of conditions. WAMs are used to determine whether water would be available for a newly requested water right or amendment. If water is available, these models estimate how often the applicant could count on water under various conditions (*e.g.*, whether water would be available only 1 month out of the year, half the year, or all year, and whether that water would be available in a repeat of the drought of record).

WAMs provide information that assist TCEQ staff in determining whether to recommend the granting or denial of an application.

2.2.1.6 Financial Data

Financial data were collected through a site visit. Data sought included:

- Annual Budget
- Audited Financial Statements
 - Balance Sheet
 - Income & Expense Statement
 - Cash Flow Statement
 - Debt Schedule
- Water Rate Structure
- Water Use Data
 - Production
 - Billing
 - Customer Counts

2.2.1.7 Demographic Data

Basic demographic data were collected from the 2000 Census to establish incomes and eligibility for potential low cost funding for capital improvements. Median household income (MHI) and number of families below poverty level were the primary data points of significance. If available, MHI for the customers of the PWS should be used. In addition, unemployment data were collected from current U.S. Bureau of Labor Statistics. These data were collected for the following levels: national, state, and county.

2.2.2 PWS Interviews

2.2.2.1 PWS Capacity Assessment Process

A capacity assessment is the industry standard term for an evaluation of a water system's financial, managerial, and technical capacity to effectively deliver safe drinking water to its

customers now and in the future at a reasonable cost, and to achieve, maintain and plan for compliance with applicable regulations. The assessment process involves interviews with staff and management who have a responsibility in the operations and management of the system.

Financial, managerial, and technical capacity are individual yet highly interrelated components of a system's capacity. A system cannot sustain capacity without maintaining adequate capability in all three components.

Financial capacity is a water system's ability to acquire and manage sufficient financial resources to allow the system to achieve and maintain compliance with SDWA regulations. Financial capacity refers to the financial resources of the water system, including but not limited to revenue sufficiency, credit worthiness, and fiscal controls.

Managerial capacity is the ability of a water system to conduct its affairs so that the system is able to achieve and maintain compliance with SDWA requirements. Managerial capacity refers to the management structure of the water system, including but not limited to ownership accountability, staffing and organization, and effective relationships to customers and regulatory agencies.

Technical capacity is the physical and operational ability of a water system to achieve and maintain compliance with the SDWA regulations. It refers to the physical infrastructure of the water system, including the adequacy of the source water, treatment, storage and distribution infrastructure. It also refers to the ability of system personnel to effectively operate and maintain the system and to otherwise implement essential technical knowledge.

Many aspects of water system operations involve more than one component of capacity. Infrastructure replacement or improvement, for example, requires financial resources, management planning and oversight, and technical knowledge. A deficiency in any one area could disrupt the entire effort. A system that is able to meet both its immediate and long-term challenges demonstrates that it has sufficient financial, managerial, and technical capacity.

Assessment of the FMT capacity of the PWS was based on an approach developed by the New Mexico Environmental Finance Center (NMEFC), which is consistent with TCEQ FMT assessment process. This method was developed from work the NMEFC did while assisting USEPA Region 6 in developing and piloting groundwater comprehensive performance evaluations. The NMEFC developed a standard list of questions that could be asked of water system personnel (the questions are included in Appendix A). Each person with a role in the FMT capacity of the system was asked the applicable standard set of questions. The interviewees were not given the questions in advance. Also, most of the questions are open ended type questions so they were not asked in a fashion to indicate what would be the "right" or "wrong" answer. The interviews lasted between 45 minutes to 75 minutes depending on the individual's role in the system and the length of the individual's answers.

In addition to the interview process, visual observations of the physical components of the system were made. A technical information form was created to capture this information. This form is also contained in Appendix A. This information was considered supplemental to the

interviews because it served as a check on information provided in the interviews. For example, if an interviewee stated he or she had an excellent preventative maintenance schedule and the visit to the facility indicated a significant amount of deterioration (more than would be expected for the age of the facility) then the preventative maintenance program could be further investigated or the assessor could decide that the preventative maintenance program was inadequate.

Following interviews and observations of the facility, answers that all personnel provided were compared and contrasted to provide a clearer picture of the true operations at the water system. The intent was to go beyond simply asking the question, “Do you have a budget?” to actually finding out if the budget was developed and being used appropriately. For example, if a water system manager was asked the question, “Do you have a budget?” he or she may say, “yes” and the capacity assessor would be left with the impression that the system is doing well in this area. However, if several different people are asked about the budget in more detail, the assessor may find that although a budget is present, operations personnel do not have input into the budget, the budget is not used by the financial personnel, the budget is not updated regularly, or the budget is not used in setting or evaluating rates. With this approach, the inadequacy of the budget would be discovered and the capacity deficiency in this area would be noted.

Following the comparison of answers, the next step was to determine which items noted as a potential deficiency truly had a negative effect on the system’s operations. If a system had what appeared to be a deficiency, but this deficiency was not creating a problem in terms of the operations or management of the system, it was not considered critical and may not have needed to be addressed as a high priority. As an example, the assessment may have revealed an insufficient number of staff members to operate the facility. However, it may also have been revealed that the system was able to work around that problem by receiving assistance from a neighboring system, so no severe problems resulted from the number of staff members. Although staffing may not be ideal, the system does not need to focus on this particular issue. The system needs to focus on items that are truly affecting operations. As an example of this type of deficiency, a system may lack a reserve account which can then lead the system to delay much-needed maintenance or repair on its storage tank. In this case, the system needs to address the reserve account issue so that proper maintenance can be completed.

The intent was to develop a list of capacity deficiencies with the greatest impact on the system’s overall capacity. Those were the most critical items to address through follow-up technical assistance or by the system itself.

2.2.2.2 Interview Process

PWS personnel were interviewed by the project team. Interview forms were completed during each interview.

2.3 ALTERNATIVE DEVELOPMENT AND ANALYSIS

The initial objective for developing alternatives to address compliance issues is to identify a comprehensive range of possible options that can be evaluated to determine which are the most promising for implementation. Once the possible alternatives are identified, they must be defined in sufficient detail so a conceptual cost estimate (capital and O&M costs) can be developed. These conceptual cost estimates are used to compare the affordability of compliance alternatives, and to give a preliminary indication of rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. The basis for the unit costs used for the compliance alternative cost estimates is summarized in Appendix B. Other non-economic factors for the alternatives, such as reliability and ease of implementation, are also addressed.

2.3.1 Existing PWS

The neighboring PWSs were identified, and the extents of their systems were investigated. PWSs farther than 30 miles from the non-compliant PWSs were not considered because the length of the pipeline required would make the alternative cost prohibitive. The quality of water provided was also investigated. For neighboring PWSs with compliant water, options for water purchase and/or expansion of existing well fields were considered. The neighboring PWSs with non-compliant water were considered as possible partners in sharing the cost for obtaining compliant water either through treatment or developing an alternate source.

The neighboring PWSs were investigated to get an idea of the water sources in use and the quantity of water that might be available for sale. They were contacted to identify key locations in their systems where a connection might be made to obtain water, and to explore on a preliminary basis their willingness to partner or sell water. Then, the major system components that would be required to provide compliant water were identified. The major system components included treatment units, wells, storage tanks, pump stations, and pipelines.

Once the major components were identified, a preliminary design was developed to identify sizing requirements and routings. A capital cost estimate was then developed based on the preliminary design of the required system components. An annual O&M cost was also estimated to reflect the change in O&M expenditures that would be needed if the alternative was implemented.

Non-economic factors were also identified. Ease of implementation was considered, as well as the reliability for providing adequate quantities of compliant water. Additional factors were whether implementation of an alternative would require significant increase in the management or technical capability of the PWS, and whether the alternative had the potential for regionalization.

2.3.2 New Groundwater Source

It was not possible in the scope of this study to determine conclusively whether new wells could be installed to provide compliant drinking water. To evaluate potential new groundwater

1 source alternatives, three test cases were developed based on distance from the PWS intake
2 point. The test cases were based on distances of 10 miles, 5 miles, and 1 mile. It was assumed
3 that a pipeline would be required for all three test cases, and a storage tank and pump station
4 would be required for the 10-mile and 5-mile alternatives. It was also assumed that new wells
5 would be installed, and that their depths would be similar to the depths of the existing wells, or
6 other existing drinking water wells in the area.

7 A preliminary design was developed to identify sizing requirements for the required
8 system components. A capital cost estimate was then developed based on the preliminary
9 design of the required system components. An annual O&M cost was also estimated to reflect
10 the change (*i.e.*, from current expenditures) in O&M expenditures that would be needed if the
11 alternative was implemented.

12 Non-economic factors were also identified. Ease of implementation was considered, as
13 well as the reliability for providing adequate quantities of compliant water. Additional factors
14 were whether implementation of an alternative would require significant increase in the
15 management or technical capability of the PWS, and whether the alternative had the potential
16 for regionalization.

17 **2.3.3 New Surface Water Source**

18 New surface water sources were investigated. Availability of adequate quality water was
19 investigated for the main rivers in the study area, as well as the major reservoirs. TCEQ
20 WAMs were inspected, and the WAM was run, where appropriate.

21 **2.3.4 Treatment**

22 Treatment technologies for central treatment considered potentially applicable are IX,
23 WRT Z-92™ media, and coagulation/filtration. These technologies are considered most
24 applicable for centralized uranium treatment.

25 Non-economic factors were also identified. Ease of implementation was considered, as
26 well as reliability for providing adequate quantities of compliant water. Additional factors
27 were whether implementation of an alternative would require significant increase in the
28 management or technical capability of the PWS, and whether the alternative had the potential
29 for regionalization.

30 **2.4 COST OF SERVICE AND FUNDING ANALYSIS**

31 The primary purpose of the cost of service and funding analysis is to determine the
32 financial impact of implementing compliance alternatives, primarily by examining the required
33 rate increases, and also the fraction of household income that water bills represent. The current
34 financial situation is also reviewed to determine what rate increases are necessary for the PWS
35 to achieve or maintain financial viability.

2.4.1 Financial Feasibility

A key financial metric is the comparison of average annual household water bill for a PWS customer to the MHI for the area. MHI data from the 2000 Census are used, at the most detailed level available for the community. Typically, county level data are used for small rural water utilities due to small population sizes. Annual water bills are determined for existing, base conditions, including consideration of additional rate increases needed under current conditions. Annual water bills are also calculated after adding incremental capital and operating costs for each of the alternatives to determine feasibility under several potential funding sources.

Additionally, the use of standard ratios provides insight into the financial condition of any business. Three ratios are particularly significant for water utilities:

- Current Ratio = current assets divided by current liabilities provides insight into the ability to meet short-term payments. For a healthy utility, the value should be greater than 1.0.
- Debt to Net Worth Ratio = total debt divided by net worth shows to what degree assets of the company have been funded through borrowing. A lower ratio indicates a healthier condition.
- Operating Ratio = total operating revenues divided by total operating expenses show the degree to which revenues cover ongoing expenses. The value is greater than 1.0 if the utility is covering its expenses.

2.4.2 Median Household Income

The 2000 U.S. Census is used as the basis for MHI. In addition to consideration of affordability, the annual MHI may also be an important factor for sources of funds for capital programs needed to resolve water quality issues. Many grant and loan programs are available to lower income rural areas, based on comparisons of local income to statewide incomes. In the 2000 Census, MHI for the State of Texas was \$39,927, compared to the U.S. level of \$41,994. The census broke down MHIs geographically by block group and ZIP code. The MHIs can vary significantly for the same location, depending on the geographic subdivision chosen. The MHI for each PWS was estimated by selecting the most appropriate value based on block group or ZIP code based on results of the site interview and a comparison with the surrounding area.

2.4.3 Annual Average Water Bill

The annual average household water bill was calculated for existing conditions and for future conditions incorporating the alternative solutions. Average residential consumption is estimated and applied to the existing rate structure to estimate the annual water bill. The estimates are generated from a long-term financial planning model that details annual revenue, expenditure, and cash reserve requirements over a 30-year period.

2.4.4 Financial Plan Development

The financial planning model uses available data to establish base conditions under which the system operates. The model includes, as available:

- Accounts and consumption data
- Water tariff structure
- Beginning available cash balance
- Sources of receipts:
 - Customer billings
 - Membership fees
 - Capital Funding receipts from:
 - ❖ Grants
 - ❖ Proceeds from borrowing
- Operating expenditures:
 - Water purchases
 - Utilities
 - Administrative costs
 - Salaries
- Capital expenditures
- Debt service:
 - Existing principal and interest payments
 - Future principal and interest necessary to fund viable operations
- Net cash flow
- Restricted or desired cash balances:
 - Working capital reserve (based on 1-4 months of operating expenses)
 - Replacement reserves to provide funding for planned and unplanned repairs and replacements

From the model, changes in water rates are determined for existing conditions and for implementing the compliance alternatives.

2.4.5 Financial Plan Results

Results from the financial planning model are summarized in two areas: percentage of household income and total water rate increase necessary to implement the alternatives and maintain financial viability.

2.4.5.1 Funding Options

Results are summarized in a table that shows the following according to alternative and funding source:

- Percentage of the median annual household income that the average annual residential water bill represents.
- The first year in which a water rate increase would be required.
- The total increase in water rates required, compared to current rates.

Water rates resulting from the incremental capital costs of the alternative solutions are examined under a number of funding options. The first alternative examined is always funding from existing reserves plus future rate increases. Several funding options were analyzed to frame a range of possible outcomes.

- Grant funds for 100 percent of required capital. In this case, the PWS is only responsible for the associated O&M costs.
- Grant funds for 75 percent of required capital, with the balance treated as if revenue bond funded.
- Grant funds for 50 percent of required capital, with the balance treated as if revenue bond funded.
- State revolving fund loan at the most favorable available rates and terms applicable to the communities.
- If local MHI >75 percent of state MHI, standard terms, currently at 3.8 percent interest for non-rated entities. Additionally:
 - If local MHI = 70-75 percent of state MHI, 1 percent interest rate on loan.
 - If local MHI = 60-70 percent of state MHI, 0 percent interest rate on loan.
 - If local MHI = 50-60 percent of state MHI, 0 percent interest and 15 percent forgiveness of principal.
 - If local MHI less than 50 percent of state MHI, 0 percent interest and 35 percent forgiveness of principal.
- Terms of revenue bonds assumed to be 25-year term at 6.0 percent interest rate.

2.4.5.2 General Assumptions Embodied in Financial Plan Results

The basis used to project future financial performance for the financial plan model includes:

- No account growth (either positive or negative).
- No change in estimate of uncollectible revenues over time.
- Average consumption per account unchanged over time.

- No change in unaccounted for water as percentage of total (more efficient water use would lower total water requirements and costs).
- No inflation included in the analyses (although the model has provisions to add escalation of O&M costs, doing so would mix water rate impacts from inflation with the impacts from the alternatives being examined).
- Minimum working capital fund established for each district, based on specified months of O&M expenditures.
- O&M for alternatives begins 1 year after capital implementation.
- Balance of capital expenditures not funded from primary grant program is funded through debt (bond equivalent).
- Cash balance drives rate increases, unless provision chosen to override where current net cash flow is positive.

2.4.5.3 Interpretation of Financial Plan Results

Results from the financial plan model for each alternative are presented in Table 4.4 in Section 4 of this report. The model used six funding alternatives: paying cash up front (all revenue); 100 percent grant; 75 percent grant; 50 percent grant, State Revolving Fund; and obtaining a Loan/Bond. Table 4.4 shows the projected average annual water bill, the maximum percent of household income, and the percentage rate increase over current rates.

2.4.5.4 Potential Funding Sources

A number of potential funding sources exist for rural utilities. Both state and federal agencies offer grant and loan programs to assist rural communities in meeting their infrastructure needs.

Within Texas, the following state agencies offer financial assistance if needed:

- Texas Water Development Board;
- Office of Rural Community Affairs, and
- Texas Department of Health (Texas Small Towns Environment Program).

Small rural communities can also get assistance from the federal government. The primary agencies providing aid are:


- United States Department of Agriculture, Rural Utilities Service, and
- United States Housing and Urban Development.

SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS

3.1 RADIUM, GROSS ALPHA, AND URANIUM IN THE SOUTHERN PART OF THE TRINITY AQUIFER

The Hill Country of Central Texas includes aquifers of Cretaceous age (mainly within the Trinity Group) but also of Paleozoic age (Hickory and Ellenburger - San Saba aquifers) as a result of the presence of the nearby Llano uplift whose southern confines crop out in northern Gillespie County (Bluntzer 1992). The PWS wells of concern are located in Gillespie, Kendall, and Kerr Counties and are completed in the southern part of the Trinity aquifer (south of the Colorado River). Most of the wells are designated as in the Trinity Group (aquifer code 218TRNT), and a few are designated specifically in the Hensell Sand and Cow Creek Limestone formations (218HNSL and 218HSCC) which are part of the middle Trinity aquifer. In general, radium concentrations in the southern part of the Trinity aquifer are low and most samples are below the radium MCL of 5 pCi/L (Figure 3.1). Radium concentrations >5pCi/L are found in the western part of the aquifer outcrop in Gillespie, Kendall, and Kerr Counties.

Figure 3.1. Radium Concentrations in Groundwater of Southern Part of the Trinity Aquifer




Data in Figure 3.1 are from the TWDB groundwater database (storet codes 09503 and 81366) and TCEQ public water supply database (contaminant id 4020 and 4030). Figure 3.1 is based on the most recent values for wells from which both isotopes of radium were analyzed.

The data include raw samples from wells and samples from entry points which are connected to a single well.

In this study the terms *radium* or *radium combined* are generally used to refer to radium 226 + radium 228. Otherwise, radium 226 or radium 228 is specified. The values shown in Figure 3.1 generally represent the upper limit of the radium measurements because the detection limit was used for samples that are below the detection limit. Although TCEQ allows public water systems to subtract the reported error from the radium concentrations to assess compliance, the following analysis of general trends used the most recent radium concentration and did not subtract the reported error.

Gross alpha concentrations follow a trend similar to radium. Concentrations of gross alpha are generally <15 pCi/L throughout most of the aquifer. Concentrations >15 pCi/L are generally restricted to the western part of the aquifer in Gillespie and Kerr Counties (Figure 3.2). The MCL for uranium is 30 ppb, which is equivalent to 20 pCi/L (using a conservative factor of 0.67 pCi/μg for converting mass concentration to radiation concentration). Therefore a gross alpha level of 35 pCi/L in a well reflects a level from which the well fails to comply with either the MCL for gross alpha minus alpha radiation due to uranium, which is 15 pCi/L, or with the uranium MCL (neglecting the activity due to radon which is rarely measured in PWS wells). Gross alpha >5 pCi/L requires analysis of radium-226. Radium-228 testing must be done regardless of gross alpha results (TCEQ 2004b).


Figure 3.2 Gross Alpha in Groundwater in the Southern Part of the Trinity Aquifer



Data in Figure 3.2 are from the TCEQ public water supply database (contaminant ID 4109). The most recent sample is shown for each well.

Data from the National Uranium Resource Evaluation (NURE) database were used to evaluate uranium concentrations in the study area (Figure 3.3). Uranium concentrations were below the MCL of 30 ppb and samples in the southern area of the Trinity aquifer were <5 ppb (the NURE database does not include aquifer information).


Figure 3.3 Uranium in Groundwater of the Southern Trinity Aquifer



A total of 11 wells in the Trinity aquifer (not shown in Figure 3.3) have uranium analyses and these show uranium concentrations <10 pCi/L (equivalent to 15 ppb).

The correlation between radium and gross alpha is strong ($r^2 = 0.66$) and positive, while correlations of gross alpha and radium with uranium are negative (Figure 3.4). Although the number of uranium analyses is small (only seven samples with radium and gross alpha), these trends suggest that gross alpha count is mostly from radium in the groundwater.


Figure 3.4 Relationships Between Radium, Gross Alpha, and Uranium in Groundwater in the Southern Part of the Trinity Aquifer



Data shown in Figure 3.4 are from the TCEQ public water supply database and include samples from entry points which are connected to a single well. For each well the most recent sample is used in the analysis (data include only samples where both parameters were analyzed on the same day). N represents the number of samples used in the analysis.

Correlations between gross alpha and radium concentrations and well depth in the southern part of the Trinity aquifer are weak ($r^2 < 0.1$), and correlations with other general parameters such as chloride, TDS, and sulfate are also weak (Figure 3.5).

Figure 3.5 Relationships Between Radium Concentrations and Chloride, TDS, and Sulfate in the Southern Trinity Aquifer



Data in Figure 3.5 are from the TWDB groundwater database. Samples of radium, chloride, TDS, and sulfate were taken on the same day. N represents the number of samples in the analysis.

3.2 REGIONAL GEOLOGY

Subsurface deposits of Cretaceous age in Gillespie, Kendall, and Kerr Counties overlie a Paleozoic basement. The Precambrian Llano uplift with its ring of Paleozoic formations crops out in northern Gillespie County (Bluntzer 1992). Although Kerr and Kendall Counties have access to Paleozoic aquifers, this supply is tapped mostly by Gillespie County operators. Water resources in this three-county area are relatively well known (Anaya and Jones 2004; Mace, *et al.* 2000; Preston, *et al.* 1996; Bluntzer 1992; Ashworth 1983; Walker 1979; Reeves 1967; and Reeves 1969).

Cretaceous sediments were deposited on a mostly flat stable platform and transitions between different depositional facies and rock type (sand, shale, carbonate) are generally laterally smooth. Sandy units suggest proximity to the continent when the sediments were deposited while shaley units reflect a greater distance from the continent. The development of important carbonate accumulations imply periodic limited clastic input. The Cretaceous sediments consist of a basal conglomerate grading into sandy material (Hosston Sand) overlain by mostly calcareous rock (Sligo Member). This marks the beginning of a more shaley and

calcareous series of sediments until the deposition of another continuous sand unit (Hensell Sand). The formation between Hosston Sand and Hensell Sand is known as the Pearsall formation and is composed of a shaley member overlain by the Cow Creek Limestone Member. The previously described formations have been traditionally called the Travis Peak formation in Central Texas. The Travis Peak is overlain by thick accumulation of the Glen Rose formation. Formations from the Hosston Sand to the Glen Rose Limestone make up the Trinity Group. The Paluxy Sand, prevalent farther north, does not exist in the three-county study area. The mostly calcareous accumulations of the Fredericksburg and Washita Groups (including the Comanche Peak, Edwards, and Buda Limestone) that top the Lower Cretaceous close the local stratigraphic column. Pertinent Paleozoic formations are the Hickory Member (mainly sand), first formation of Cambrian age covering the Precambrian basement and the Ellenburger Group (mostly carbonate) of Ordovician age. The dip of Cretaceous layers is generally toward the south and less than 0.3 percent (15 feet per mile) but can be higher and over 1 percent, especially near the Balcones Fault zone, just south of Kendall County. Paleozoic layers, which dip away from the Llano Uplift located just north of Gillespie County, display a higher dip of 7 to 17 percent (400 to 900 feet per mile) (Bluntzer 1992). Paleozoic layers are also compartmentalized by faults that became inactive before the deposition of Cretaceous sediment. Because the Llano Uplift has been a structural high since at least the beginning of the Cretaceous, some layers thin or pinch out when approaching the uplift (*e.g.*, Hosston Sand) (Bluntzer 1992).

Major water-bearing formations are the Hosston Sand (Lower Trinity aquifer) and the Hensell Sand, forming the Middle Trinity aquifer to which is added the Cow Creek Limestone. Some Glen Rose beds can also locally produce some poor quality water; they are then collectively called the Upper Trinity aquifer. The uppermost water-bearing formation is the Edwards limestone under water-table conditions, unlike the other aquifers which are mostly confined. The State of Texas has recognized the Trinity aquifer as a major aquifer while the Hickory and Ellenburger / San Saba aquifers (mainly in Gillespie County) are considered minor aquifers (Ashworth and Hopkins 1995). Hydraulic connection between Cretaceous and Paleozoic aquifers is common (Bluntzer 1992). For example, in Gillespie County, the Hensell Sand was directly deposited on top of the Hickory Member.

Thickness of the entire Hickory Member is up to ~500 feet (McBride, *et al.* 2002). Black (1988) states that lower portions of the Hickory aquifer are nearly stagnant and have minimal interaction with outcrop portions of the aquifer. In Gillespie County, depth to the top of Hickory aquifer is variable from shallow water-table conditions to more than 2,500 feet (Preston, *et al.* 1996). The Ellenburger / San Saba aquifer, composed of over 2,000 feet of sediments, is located ~700 - 1,000 feet above the Hickory aquifer and follows its structural vagaries. Depth to the Hensell Sand and to the Hosston Sand is generally less than 600 feet and 1,000 feet, respectively (Mace, *et al.* 2000). The average thickness of the Hosston Sand can reach more than 250 feet, but it pinches out in Gillespie County. The thickness of the Hensell Sand ranges from 150 to 300 feet. The Cow Creek Limestone is no more than 100 feet thick and pinches out along with the Hosston Sand.

The Paleozoic aquifers yield small to large quantities of fresh (mostly in Gillespie County) to slightly saline water (Ashworth 1983; LBG-Guyton Associates 2003). The Trinity Group

aquifers can produce mostly fresh water often with high hardness (Anaya and Jones 2004) at highly variable yields.

3.3 DETAILED ASSESSMENT FOR MIDWAY PWS

There are two wells in the Midway PWS: G1330020A and G1330020B. The wells are designated as within the lower Trinity aquifer (Sligo and Hosston formations) and have depths of 342 and 360 feet (Table 3.1). Both wells are connected to the same entry point in the water supply system; therefore, water samples taken at the entry point cannot be related to a specific well.

Levels of uranium at the PWS entry point exceed the MCL of 30 ppb which is equivalent to 20 pCi/L (Table 3.2). Radium levels are below the radium MCL of 5 pCi/L (Table 3.3) and gross alpha levels are >15 pCi/L (after deducting the gross alpha from uranium gross alpha is below the 15 pCi/L MCL) (Table 3.4).

Table 3.1 Well Depth and Screen Interval Depths for Wells in the Midway PWS

Water source	Depth (ft)	Screen depth (ft)	Aquifer
G1330020A	360	-	Lower Trinity aquifer (Sligo and Hosston Fms.)
G1330020B	342	-	Lower Trinity aquifer (Sligo and Hosston Fms.)

Table 3.2 Uranium concentrations at Midway PWS

Date	Source	Total Uranium (pCi/L)
10/23/2003	EP1	32.1

Table 3.3 Radium concentrations at Midway PWS

Date	Source	Radium 226 (pCi/L)	Radium 228 (pCi/L)	Radium total (pCi/L)
10/23/2003	EP1	1.9	1.8	3.7
8/23/2001	EP1	1	2.2	3.2


Table 3.4 Gross alpha concentrations at Midway PWS

Date	Source	Gross alpha (pCi/L)
10/23/2003	EP1	25.1
8/23/2001	EP1	14.2

Data from TCEQ and NURE databases have a number of wells with total uranium <20 pCi/L in the vicinity of the Midway PWS (Figure 3.6). Four PWS wells have total uranium <20 pCi/L (wells G1330110A, G1330118A, G1330033A, and G1330135A). These wells are 475 to 573 feet deep (well G1330135 is screened from 420 to 573 feet). All the wells

are categorized as in the lower Trinity aquifer. Samples from the NURE database have uranium <1 pCi/L in the vicinity of the Midway PWS.

Figure 3.6 Uranium in the 5- and 10-km Buffers of the Midway PWS Wells



Potential Sources of Contamination (PSOC) are identified as part of TCEQ's Source Water Assessment Program. The nearest uranium PSOC identified is about 7 km southeast of the Midway PWS, thus PSOC sites are not expected to influence uranium concentrations at the Midway PWS.

3.3.1 Summary of Alternative Groundwater Sources for the Midway Mobile Home PWS

Data in Figure 3.6 show a number of possible alternative groundwater sources that can be used to replace or dilute existing water at the Midway PWS. The four PWS wells with uranium below the MCL have depths from 475 to 573 feet, deeper than the Midway PWS wells which are 342 and 360 feet deep. Based on these data there is a possibility of finding better quality water at greater depths at the existing Midway PWS wells, thus extending the Midway wells to depths of 470 to 570 feet might yield higher quality water that can be used to dilute or replace existing water.

SECTION 4 ANALYSIS OF THE MIDWAY PWS

4.1 DESCRIPTION OF EXISTING SYSTEM

4.1.1. Existing System


The Midway PWS location is shown on Figure 4.1. The PWS groundwater supply is the Glen Rose limestone of the Trinity aquifer. The system includes one operational well and one backup well, both located in the Glen Rose Limestone, Lower Member aquifer. The primary use well is 342 feet deep and the backup well is 360 feet deep. The water is disinfected by hypochlorination before it enters a 2,500-gallon pressure tank that feeds the distribution system.

The Midway PWS has experienced issues with uranium in its drinking water over the past several years. Combined uranium sample results have exceeded the MCL of 20.1 pCi/L (USEPA 2006; TCEQ 2004a). Sample results have ranged from 20.64 pCi/L in October 2003, to 38 pCi/L in quarterly samples taken between July 1, 2004 and June 30, 2005, to a more recent lower sample result in December 2005 of 19.3 pCi/L, which is below the MCL. The PWS has no other reported water quality issues.

The treatment employed for disinfection is not appropriate or effective for removal of uranium, so optimization is not expected to be effective for increasing removal of these contaminants. However, there is a potential opportunity for system optimization to reduce radionuclide concentrations. The system has two wells (a primary use well and a backup well), and the radionuclide results are for the primary use well. Since radionuclide concentrations can vary between wells, radionuclide concentrations should be determined for the backup well. If the backup well is found to produce water with acceptable levels of uranium, as much production as possible should be shifted to that well. It may also be possible to identify natural deposits of materials that contain uranium through comparison of well logs or through sampling of water produced by various strata intercepted by the well screen.

Basic system information is as follows:

- Population served: 17
- Connections: 12
- Average daily flow rate: 0.0013 mgd
- Peak demand flow rate: 0.0052 mgd
- Water system peak capacity: 0.086 mgd



1 Raw Water Characteristics:

- 2 • Typical combined uranium range: 19.3 to 38 pCi/L
- 3 • Typical total dissolved solids range: 405 to 433 mg/L
- 4 • Typical pH range: 7.4 to 7.6 s.u.
- 5 • Typical calcium range: 64.8 to 71 mg/L
- 6 • Typical magnesium range: 43 to 43.5 mg/L
- 7 • Typical sodium range: 20 to 23.1 mg/L
- 8 • Typical chloride range: 22.6 to 28 mg/L
- 9 • Typical bicarbonate (HCO_3): 400 mg/L (one sample result)
- 10 • Typical fluoride range: 0.882 to 1.00 mg/L
- 11 • Typical iron range: 0.048 to 0.051 mg/L
- 12 • Typical manganese range: 0.00113 mg/L (one sample result)

13 **4.1.2 Capacity Assessment for the Midway PWS**

14 The project team conducted a capacity assessment of the Midway PWS. The results of this
15 evaluation are separated into four categories: general assessment of capacity, positive aspects
16 of capacity, capacity deficiencies, and capacity concerns. The general assessment of capacity
17 describes the overall impression of technical, managerial, and financial capability of the water
18 system. The positive aspects of capacity describe those factors that the system is doing well.
19 These factors should provide opportunities for the system to build on to improve capacity
20 deficiencies. The capacity deficiencies noted are those aspects that are creating a particular
21 problem for the system related to long-term sustainability. Primarily, these problems are
22 related to the system's ability to meet current or future compliance, ensure proper revenue to
23 pay the expenses of running the system, and to ensure the proper operation of the system. The
24 last category is titled capacity concerns. These are items that in general are not causing
25 significant problems for the system at this time. However, the system may want to address
26 them before these issues have the opportunity to cause problems.

27 The following individuals were interviewed:

- 28 • Sylvia Fritz – Fritz Family Enterprise
- 29 • William (Junior) and Ann Fritz – Fritz Family Enterprise
- 30 • Jan Bass – J. Tucker Pump Service Corp. (Owner)
- 31 • Randy Bass - J. Tucker Pump Service Corp. (Operator)
- 32 • Jerry Rodriguez – J. Tucker Pump Service Corp. (Operator)

4.1.2.1 General Information

Midway Mobile Home Park is owned by the Fritz Family Enterprise, LP and leased to William (“Junior”) Fritz to operate as rental property. The Fritz family Enterprise owns and operates approximately 17 Mini-Marts in the Texas Hill Country. The office is located in Kerrville. The Fritz family bought the mobile home park in 1979 as an investment. The system is operated by a contract with J. Tucker Pump Service Corporation. Part of the maintenance of the system is provided by employees of the Fritz Family Enterprise.

The mobile home park provides low-income housing to residents in an industrial area on the edge of Kerrville. The system is supplied by groundwater from two wells and the primary well is on private property. It is not clear if the system meets the definition of a community public water system under the federal Safe Drinking Water Act which is “a public water supply system which serves at least 15 service connections used by year-round residents or regularly serves at least 25 year-round residents.” The owners indicated that there are 12 connections, eight mobile home spaces, two small businesses (a windshield replacement business and a woodworking shop), and two homes. It is unclear how many people reside in the park. Tucker Pump believes that there are seven connections serving 13 people. It is estimated there are a total of 17-people using the water system. It appears that at least one of the businesses is not being charged for water. The Fritzs’ have an arrangement with one of the residents to provide water at no charge in return for use of the well which is located on his property. Most of the residents are low-income and have lived there for a long time. The Fritz family has recently increased the lot rent from \$65 a month to \$100 a month for the current residents. However, they have not leased any new lots in the past five years because they are uncertain about what action to take to deal with the issue of high uranium. There are several abandoned mobile homes in the park and the family states that the lots are not large enough for the newer double-wide mobile homes.

4.1.2.2 General Assessment of Capacity

Based on the team’s assessment, this system has an inadequate level of capacity due mainly to deficiencies with financial capabilities. There are several positive managerial and technical aspects of the water system, but there are also a number of deficiencies that prevent the water system from being able to meet compliance. These deficiencies may also impact the water system’s long-term sustainability.

4.1.2.3 Positive Aspects of Capacity

In assessing a system’s overall capacity, it is important to look at all aspects – positive and negative. It is important for systems to understand those characteristics that are working well, so that those activities can be continued or strengthened. In addition, these positive aspects can assist the system in addressing the capacity deficiencies or concerns. The factors that were particularly important for the Midway PWS are listed below.

- **Knowledgeable Operators** – The contract operators have been working at Midway PWS for many years and are familiar with the challenges of providing safe water.

One operator has over 30 years experience and the other has 12 years experience. They are available 24 hours a day and alternate being on-call. The mobile home park residents have been given the operator's phone numbers and can call them directly, if needed.

4.1.2.4 Capacity Deficiencies

The following capacity deficiencies were noted in conducting the assessment and seriously impact the ability of the water system to meet compliance with current and future regulations and to ensure long-term sustainability.

- **Inadequate Financing** – Midway PWS charges its customers a flat fee for lot rental in the trailer park. This rental fee has stayed relatively stable over the years, because the system is serving low-income families. The rent was increased recently. While they do not maintain a budget, they do track operating expenses and income. However, maintenance and line repairs are provided by the Fritz Family Enterprise and these costs are not allocated to the park. It appears that the revenue from the mobile home park does not cover all the expenses and the shortfall is being made up from the family business. However it is difficult to determine if funds are available to cover the cost of current operation, repair and replacement, compliance with the uranium regulations and provide a reserve fund.
- **No Reserve Account** – The lack of a reserve account for future capital expenditures or emergencies is a problem. The Fritz Family Enterprise covers these expenses with funds as the need occurs. In addition, funds have not been set aside to address the uranium compliance problem.
- **Lack of Long-Term Planning for Compliance and Sustainability** – The lack of planning negatively impacts the system's ability to develop a budget and associated rate structure that will provide for the system's long term needs. Although the Midway PWS has been aware of the uranium contamination problem for several years, they have not investigated any treatment options or set-aside any funds to address the compliance issue.

4.1.2.5 Potential Capacity Concerns

The following items were concerns regarding capacity but no specific operational, managerial, or financial problems can be attributed to these items at this time. The system should focus on addressing the deficiencies noted above in the capacity deficiency section, but should address the items listed below to further improve technical, managerial, and financial capabilities and to improve the system's long-term sustainability.

- **Sustainability of Water Supply** – The well is located on private property in the front of the mobile home park. It doesn't appear that there is any type of written agreement between the Fritz family and the property owner. It could be an issue for the long-term sustainability of the water supply. This is also an important consideration if a treatment system were to be installed at this well.

- **Operating Records** – It was indicated that the master water meters were only read about once a month. If maintained, flow meters provide an accurate account of water being pumped, and can help the operator detect changes in the system and take corrective action before a serious problem develops.
- **Lack of Written Contract for Water Operations** – The Fritz family does not have a written agreement with Tucker Pump for water operations services. The operators at Tucker Pump are experienced and know what needs to be done. In addition, Tucker Pump notifies the Fritz family before making any major repairs. However, it is always better to have the responsibilities in writing, in the event there are ever disagreements about what was expected or what was actually done. In addition, it is a good idea to clearly define expectations for both parties.
- **Lack of Emergency Plan** - The system does not have a written emergency plan, nor does it have emergency equipment such as generators. The system should have an emergency or contingency plan that outlines what actions will be taken and by whom. The emergency plan should meet the needs of the facility, the geographical area, and the nature of the likely emergencies. Conditions such as storms, floods, major line breaks, electrical failure, drought, system contamination or equipment failure should be considered. The emergency plan should be updated annually, and larger facilities should practice implementation of the plan annually.

4.2 ALTERNATIVE WATER SOURCE DEVELOPMENT

4.2.1 Identification of Alternative Existing Public Water Supply Sources

Using data drawn from the TCEQ drinking water and TWDB groundwater well databases, PWSs surrounding the Midway PWS were reviewed with regard to reported drinking water quality and production capacity. PWSs without identified water quality issues were investigated further. PWSs that appeared to have water supplies with water quality issues were generally ruled out. If it was determined that a PWS had excess supply capacity and might be willing to sell the excess, or might be a suitable location for a new groundwater well, it was taken forward for further consideration.

Table 4.1 is a list of the existing PWSs within approximately 5 miles of the Midway PWS. This distance was selected as the radius for the evaluation owing to the large number of PWSs in proximity to the Midway PWS.

Based on the initial screening summarized in Table 4.1, several alternatives were selected for further evaluation. These alternatives were selected based on factors such as water quality, distance from the Midway PWS, sufficient total production capacity for selling or sharing water, and willingness of the PWS to sell or share water or drill a new well. Several systems with good water quality were not carried forward for further evaluation since a pipeline to them would have to pass through Kerrville, a large water provider with good water quality. The alternatives for further investigation are summarized in Table 4.2.

1 **Table 4.1 Existing Public Water Systems Within 5 Miles of the Midway PWS**

System Name	Distance from Midway PWS, miles	Comments/Other Issues
Blue Ridge Mobile Home Park	0.3	Small system. No uranium data.
Midway Industrial Park	0.4	Small system. No uranium data.
Buffington Hill Country RV Park	0.5	Small system. No uranium data.
Riverfront Village Mobile Home Park	0.7	Small system. No WQ issues. <i>Investigate further.</i>
Woodhaven Mobile Home Park	0.9	Small system. No WQ issues. <i>Investigate further.</i>
Forest Oaks Mobile Home Park	1.1	Small system. No WQ issues. <i>Investigate further.</i>
Ingram Water Supply Co	1.3	Large system. No WQ issues. <i>Investigate further.</i>
Village West Water System	1.3	Small system. No uranium data.
Sleepy Hollow	1.6	Small system. No WQ issues. <i>Investigate further.</i>
Shalako Water Supply	1.7	Small system. No uranium data.
Wood Trail Water Supply	2.3	Small system. No uranium data.
Saddlewood Subdivision	2.5	Small system. No water quality issues.
Ox Hollow Water System	2.5	Small system. No uranium data.
Hill Country Arts Foundation	2.7	Small system. No uranium data.
Ingram Tom Moore High School	2.9	Small system. No uranium data.
Kerr Villa Mobile Home Park	3.0	Small system. No uranium data.
Hill Country Youth Ranch	3.1	Small system. No uranium data.
Horseshoe Oaks Subd Water System	3.2	Small system with WQ issues: radium and gross alpha.
Buckhorn Lake Resort	3.2	Small system. No uranium data.
Cedar Springs Mobile Home Park	3.4	Small system. No WQ issues. <i>Investigate further.</i>
Hideaway Mobile Home Park	3.4	Small system. No uranium data.
Bear Paw Water System	3.8	Small system. No water quality issues.
James Avery Craftsman Inc.	3.8	Small system. No uranium data.
City of Kerrville	4.0	Large system. No WQ issues. <i>Investigate further.</i>
Northwest Hills Subdivision	4.0	Small system. No water quality issues.
Hill Country Camp	4.2	Small system with WQ issues: radium.
Loma Vista Water System	4.2	Large system. No water quality issues.

**Table 4.2 Public Water Systems in the Vicinity of the Midway
Selected for Further Evaluation**

System Name	Pop	Conn	Total Production (mgd)	Ave Daily Usage (mgd)	Approx. Dist. from Midway PWS	Comments/Other Issues
Ingram WSC (PWS 1300011)	4,824	1,608	1.045	0.47	1.3	Have excess capacity and are willing to discuss selling water.
Sleepy Hollow (PWS 1330101)	174	58	0.122	0.022	1.6	No excess capacity. However, based on WQ data, this PWS may provide a suitable location for a new well.
Cedar Springs MHP (PWS 1330019)	80	40	0.058	0.006	3.4	No excess capacity. However, based on WQ data, this PWS may provide a suitable location for a new well.
City of Kerrville (PWS 1330001)	21,937	10,682	8.712	3.390	4 miles	Have excess capacity and are willing to discuss selling water. A City of Kerrville PWS pipeline lies across the street from the Midway MHP.

4.2.1.1 Ingram WSC (PWS 1330011)

The Ingram WSC is located west of Kerrville, 1.3 miles west of the Midway PWS. The Ingram WSC is supplied by seven groundwater wells completed in the Glen Rose Limestone formation or Hensell Sand. The wells range in depth from 380 to 680 feet, and they range in production from 0.096 to 0.32 million gallons per day (mgd). Water from one well is disinfected using hypochlorination, and the rest is disinfected using gaseous chlorine. The Ingram WSC serves a population of 4,824, has 1,608 metered connections, and has an approximate average daily usage of 0.08 mgd. Ingram WSC is owned by AquaTexas, Inc.

The Woodhaven MHP PWS may have sufficient excess capacity to provide water to Ingram WSC. If an agreement could be negotiated with the AquaTexas, Ingram WSC could be a viable alternative source of water.

4.2.1.5 Sleepy Hollow (PWS 1330101)

The Sleepy Hollow PWS is located northwest of Kerrville, 1.6 miles north of the Midway PWS. The Sleepy Hollow PWS is supplied by a single groundwater well completed in the Glen Rose Limestone formation (Code 218GLRS). This well is 620 feet deep and has a total production of 0.12 mgd. Water is disinfected using hypochlorination before entering the distribution system. The Sleepy Hollow PWS serves a population of 174, has 58 metered connections, and has an approximate average daily usage of 0.022 mgd.

The Sleepy Hollow PWS does not have sufficient excess capacity to supplement Midway PWS's existing supply; however, based on the available water quality data, the location may be a suitable point for a new groundwater well.

4.2.1.7 City of Kerrville

A City of Kerrville water main is located approximately across the street from Midway MHP. The water supply for the City of Kerrville consists of a series of ground water wells and a surface water plant that treats water from the headwaters of the Guadalupe River. There are five groundwater extraction wells located throughout the City of Kerrville, all of which are completed in the Hosston formation (Code 217HSTN). These wells range from 600 to 638 feet in depth and do not have any water quality issues. The current production rates are 6,625 acre-feet/year, or 5.91 mgd and 4.25 mgd for the well field and surface water plant, respectively. The City has a population of 21,650 people and a total of 11,534 connections. The average annual usage for the city of Kerrville is between 3.4 and 3.8 mgd.

The water and waste water systems at the City of Kerrville consist of a staff of 42 personnel who run the day-to-day operations, maintain a small in-house testing lab, and handle small construction and maintenance activities. Until several years ago, the Upper Guadalupe River Authority (UGRA) was involved with a portion of the operations of the Kerrville water system. UGRA is still in existence, but has no means of conveying the water via pipeline or tanker. It has access to 2,000 acre-feet/year or 1.79 mgd from the Upper Guadalupe River until its permit expires in 2010.

Water treatment facility personnel make the day-to-day technical decisions. However, the five-member City Council makes the decisions regarding major changes proposed by the public works staff, such as the current expansion to the surface water plant, which has an anticipated completion date of summer 2006. The sale of treated water to a system such as the Midway PWS must be also approved by the five-member City Council. Future changes planned for the water system include modifying the surface water intake from a standard stream intake system to a river bank extraction system where the stream sediments between the extraction wells and the streambed serve as a filtration system.

To be prepared for any future drought conditions, the City of Kerrville evaluated the feasibility of aquifer storage and recovery in the Kerrville area. Based on the study, it was determined that the Lower Trinity below the Hammond Shale would serve as an excellent rock formation or aquifer for storing approximately 1.5 billion gallons of water (approximate volume of water usage per year). A portion of the water recovered from both the surface water supply and groundwater is chlorinated and then pumped through two injection wells into the Lower Trinity at a depth of about 600 feet. As of July 2005, approximately 485 million gallons of water have been pumped into the Lower Trinity. The first injection well was installed in 1998 followed by a second in 2003. A third injection well is currently being proposed.

The City of Kerrville has sufficient excess capacity to supplement Midway PWS's existing supply. If an agreement could be negotiated with the City Council, the City of Kerrville could be a viable alternative source of water.

4.2.2 Potential for New Groundwater Sources

4.2.2.1 Installing New Compliant Wells

Developing new wells or well fields is recommended, provided good quality groundwater available in sufficient quantity can be identified. Since a number of water systems in the area have problems with uranium, it should be possible to share in the cost and effort of identifying compliant groundwater and constructing well fields.

Installation of a new well in the vicinity of the system intake point is likely to be an attractive option provided compliant groundwater can be found, since the PWS is already familiar with operation of a water well. As a result, existing nearby wells with good water quality should be investigated. Re-sampling and test pumping would be required to verify and determine the quality and quantity of water at those wells.

The use of existing wells should probably be limited to use as indicators of groundwater quality and availability. If a new groundwater source is to be developed, it is recommended that a new well or wells be installed instead of using existing wells. This would ensure well characteristics are known and meet standards for drinking water wells.

Some of the alternatives suggest new wells be drilled in areas where existing wells are compliant. In developing the cost estimates, it is assumed the aquifer in these areas would produce the required amount of water with only one well. Site investigations and geological research, which are beyond the scope of this study, could indicate whether the aquifer at a particular site and depth would provide the amount of water needed or if more than one well would need to be drilled in separate areas. Two wells are used in cases where the PWS is large enough that two wells are required by TCEQ rules.

4.2.2.2 Results of Groundwater Availability Modeling

The PWS is located in the southern end of the Trinity aquifer that extends along north central Texas. The aquifer's outcrop is present along east Kerr County and, in some areas, water-bearing rock formations are located below the Edwards-Trinity aquifer. According to TCEQ records, the Midway PWS groundwater supply is the Glen Rose limestone of the Trinity aquifer. Two other aquifer units, the Hosston and Hensell Sand formations, are also widely utilized in PWSs located within 20 miles of the Midway PWS.

The water supply of the Trinity aquifer is expected to moderately decrease over the next 50 years. The 2002 Texas Water Plan anticipates a supply of 150,317 acre-feet by the year 2050, a 4 percent decline in supply relative to value estimated for the year 2000. A GAM model for the Hill Country area of the Trinity aquifer was completed by the TWDB in September 2000. Long-term numerical simulation of future water levels for drought-of-record conditions indicated that water levels in the aquifer may decline up to 100 feet by 2050. The largest water level decline is anticipated in the Cibolo Creek area in northern Bexar, western Comal, and southern Kendall Counties. For east Kerr County, where Midway PWS is located, the anticipated decline by the year 2050 is moderate, within the 10 to 25-foot range (Mace, *et*

1 *al.* 2000). Potential groundwater usage by the PWS would be a small addition to the regional
2 withdrawal, making potential changes in aquifer levels by the Midway PWS beyond the spatial
3 resolution of the regional GAM model.

4 The Midway PWS overlays a second potential groundwater source, the Edwards-Trinity
5 Plateau aquifer. The 2002 Texas Water Plan indicates that the overall groundwater supply
6 from the aquifer is likely to remain at nearly current levels over the next 50 years. The
7 anticipated aquifer supply in the year 2050 is 220,374 acre-feet per year (AFY), representing a
8 3 percent decline relative to 2000 conditions. In September 2004 the TWDB published results
9 of the GAM for the Edwards-Trinity Plateau aquifer (Anaya and Jones 2004). The Midway
10 PWS is located within the southeastern Edwards Plateau segment of the aquifer. Over this
11 segment, groundwater pumping represents approximately 25 percent of the aquifer discharge.
12 GAM data indicate that the rate of total withdrawal from the Edwards-Trinity Plateau aquifer in
13 Kerr County would increase substantially over the next decades, from an estimated 9,817 AFY
14 in 2000, to 15,266 AFY by the year 2050. The Edwards-Trinity Plateau aquifer GAM was not
15 run for the Midway PWS. Potential groundwater usage by the system would be a small
16 addition to the regional withdrawal, making potential changes in aquifer levels by the PWS
17 beyond the spatial resolution of the regional GAM model.

18 An additional groundwater source, the down dip of the Hickory aquifer, extends through
19 north and east Kerr County. Currently there is a minimum utilization of the Hickory aquifer by
20 PWS in the vicinity of the Midway PWS. The 2002 Texas Water Plan indicates that water
21 supply from this aquifer, considered minor on the basis of potential water production, will
22 steadily decline over several decades from 50,699 AFY in 2000 to 46,133 AFY in 2050.

23 **4.2.3 Potential for New Surface Water Sources**

24 There is a minimum potential for development of new surface water sources for the system
25 as indicated by limited water availability over the entire river basin, and within the site vicinity.

26 The Midway PWS is located in the upper reach of the Guadalupe Basin. Current surface
27 water availability in the Guadalupe Basin is expected to decrease moderately as a result of the
28 increased water demand. The Texas Water Development Board's 2002 Water Plan anticipates
29 a 5 percent reduction in surface water availability in the Guadalupe Basin over the next 50
30 years, from 275,650 AFY in 2000 to 262,173 AFY in 2050.

31 The vicinity of the Midway PWS has a minimum availability of surface water for new uses
32 as indicated by the TCEQ's availability maps for the Colorado Basin. In the site vicinity, and
33 over the entire area of Kerr County, unappropriated flows for new uses are available less than
34 50 percent of the time. This supply is inadequate as the TCEQ requires 100 percent supply
35 availability for a PWS.

4.2.4 Options for Detailed Consideration

The initial review of alternative sources of water results in the following options for more-detailed consideration:

1. Ingram WSC. Water would be purchased from the Ingram WSC to be used by the Midway PWS. A pipeline would be constructed to convey water from the Ingram WSC system to Midway PWS (Alternative MW-1). *This alternative would have almost identical costs to similar alternatives involving the nearby Riverfront Village PWS, Woodhaven MHP PWS, Forest Oaks MHP PWS, and Cedar Springs MHP PWS, so these alternatives will be considered to be identical for purposes of this report.*
2. Sleepy Hollow PWS. Water would be purchased from the Sleepy Hollow PWS to be used by the Midway PWS. A pipeline would be constructed to convey water from the Sleepy Hollow PWS system to the Midway MHP (Alternative MW-2).
3. City of Kerrville. Treated water would be purchased from the City of Kerrville. This alternative involves tie-in to one of the City of Kerrville pipelines which lies adjacent to the Midway MHP (Alternative MW-3).
4. Installing a new well within 10, 5, or 1 mile of the Midway PWS that would produce compliant water (Alternatives MW-4, MW-5, and MW-6).

4.3 TREATMENT OPTIONS

4.3.1 Centralized Treatment Systems

Centralized treatment of well field water is identified as a potential for the Midway PWS. IX, WRT Z-92 treatment, and coagulation/filtration are potential applicable processes. The central IX treatment alternative is Alternative MW-7, the central Z-92 treatment process alternative is Alternative MW-8, and the coagulation/filtration alternative is Alternative MW-9.

4.3.2 Point-of-Use Systems

POU treatment using resin based adsorption technology or RO is valid for uranium removal. The POU treatment alternative is MW-10.

4.3.3 Point-of-Entry Systems

POE treatment using resin based adsorption technology or RO is valid for uranium removal. The POE treatment alternative is MW-11.

4.4 Bottled Water

Providing bottled water is considered an interim measure to be used until a compliance alternative is implemented. Even though the community is small and people know each other; it would be reasonable to require a quarterly communication advising customers of the need to take advantage of the bottled water program. An alternative to providing delivered bottled

1 water is to provide a central, publicly accessible dispenser for treated drinking water.
2 Alternatives addressing bottled water are MW-12, MW-13, and MW-14.

3 **4.5 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

4 A number of potential alternatives for compliance with the MCL for uranium have been
5 identified. Each potential alternative is described in the following subsections. It should be
6 noted that the cost information given is the capital cost and change in O&M costs associated
7 with implementing the particular alternative. Appendix C contains cost estimates for the
8 compliance alternatives. These compliance alternatives represent a range of possibilities, and a
9 number of them are likely not feasible. However, all have been presented to provide a
10 complete picture of the range of alternatives considered. It is anticipated that a PWS will be
11 able to use the information contained herein to select the most attractive alternative(s) for more
12 detailed evaluation and possible subsequent implementation.

13 **4.5.1 Alternative MW-1: Purchase Water from Ingram WSC**

14 This alternative involves purchasing compliant water from the Ingram WSC, which would
15 be used to supply the Midway PWS. Ingram WSC may have excess production capacity and
16 might be willing to consider selling water. Ingram WSC is owned by AquaTexas, Inc.

17 This alternative would require construction of a storage tank at a point adjacent to the
18 Ingram WSC water system, a pipeline from tank to the Midway PWS, and a new storage tank
19 and booster pump set at the Midway PWS. A pump station would also be required to overcome
20 pipe friction and the elevation differences between Ingram WSC and the Midway PWS. The
21 required pipeline from Ingram to Midway would be constructed of 4-inch pipe and would
22 follow Woodland Road and Highway 27. Using this route, the length of pipe required would
23 be 1.9 miles. The required pump horsepower is 2 hp.

24 The pump stations would include four pumps, and would be housed in two buildings. It is
25 assumed the pumps and piping would be installed with capacity to meet all water demand for
26 the Midway PWS even if blending is planned, since the incremental cost would be relatively
27 small, and it would provide operational flexibility.

28 This alternative involves regionalization by definition, since Midway PWS would be
29 obtaining drinking water from an existing larger supplier. It is possible the Midway PWS could
30 turn over provision of drinking water to the Ingram WSC instead of purchasing water.

31 The estimated capital cost for this alternative includes constructing the pipeline, pump
32 station, and a new storage tank and booster pump set at the Midway PWS. The estimated
33 O&M cost for this alternative includes the purchase price for the water minus the cost that
34 Midway PWS currently pays to operate its well, plus maintenance cost for the pipeline, and
35 power and O&M labor and materials for the pump station. The estimated capital cost for this
36 alternative is \$647,526, and the alternative's estimated annual O&M cost is \$29,617. If the
37 purchased water was used for blending rather than for the full water supply, the annual O&M
38 cost for this alternative could be reduced because of reduced pumping costs and reduced water

1 purchase costs. However, additional costs would be incurred for equipment to ensure proper
2 blending, and additional monitoring to ensure the finished water is compliant.

3 The reliability of adequate amounts of compliant water under this alternative should be
4 good. The Ingram WSC has adequate O&M resources. From the perspective of the Midway
5 PWS, this alternative would be characterized as easy to operate and repair, since O&M and
6 repair of pipelines and pump stations is well understood. If the decision were made to perform
7 blending, the operational complexity would increase.

8 The feasibility of this alternative is dependent on an agreement being reached with the
9 Ingram WSC to purchase compliant drinking water.

10 **4.5.2 Alternative MW-2: New Well in the Vicinity of Sleepy Hollow PWS**

11 This alternative involves the completion of a new 650-foot well in the vicinity of the
12 Sleepy Hollow PWS, the construction of a pump station and pipeline, and a new storage tank
13 and booster pump set at the Midway PWS. Based on the water quality data in the TCEQ
14 database, it is expected groundwater from this well would be compliant with drinking water
15 MCLs.

16 This alternative would require drilling a new well, a ground storage tank, a pump station, a
17 pipeline to the Midway PWS, and a new storage tank and feed pump set at the Midway PWS.
18 One of the two pumps in the pump station would be used for backup in the event the other
19 pump fails. The pipeline would be a 4-inch pipeline 2.34 miles long. The pipeline from Sleepy
20 Hollow to Midway would follow Country Lane., Goat Creek Road., Mill Run, and
21 Highway 27. The required pump horsepower is 2 hp.

22 The estimated capital cost for this alternative includes the costs for a new well and small
23 ground storage tank, a pump station, a pipeline to the Midway PWS, and a new storage tank
24 and feed pump set at Midway PWS. The estimated O&M cost for this alternative includes
25 labor and material costs to operate the well field, to maintain the pipeline, and to operate the
26 pump station. The estimated capital cost for this alternative is \$786,390 and the estimated
27 annual O&M cost is \$37,341.

28 The reliability of adequate amounts of compliant water under this alternative should be
29 good. From the perspective of Midway PWS, this alternative is characterized as easy to
30 operate and repair, since O&M and repair of pipelines and pump stations are well understood.

31 The feasibility of this alternative is dependent on finding a suitable well site.

32 **4.5.3 Alternative MW-3: Purchase Water from the City of Kerrville**

33 This alternative involves purchasing compliant water from the City of Kerrville, which
34 would be used to supply the Midway PWS. The City has indicated it does have excess
35 production capacity and would be willing to consider selling water to PWSs within Kerr
36 County, assuming a suitable agreement could be negotiated.

1 This alternative would require boring under the road in front of Midway PWS, and
2 connecting to the City of Kerrville water main on the opposite side of the road, and a pipeline
3 from the tie-in point to the existing intake point for the Midway PWS. The pipeline would be
4 constructed of 4-inch pipe. The length of pipe required would be approximately 528 feet.

5 This alternative involves regionalization by definition, since Midway PWS would be
6 obtaining drinking water from an existing larger supplier. It is possible the Midway PWS could
7 turn over provision of drinking water to the City of Kerrville instead of purchasing water.

8 The estimated capital cost for this alternative includes constructing the pipeline and to tie
9 into the City of Kerrville water main. The estimated O&M cost for this alternative includes the
10 purchase price for the treated water minus the cost that Live Oaks MHP PWS currently pays to
11 operate its well field, plus maintenance cost for the pipe. The estimated capital cost for this
12 alternative is \$37,294, and the alternative's estimated savings in annual O&M cost is \$7,602.

13 The reliability of adequate amounts of compliant water under this alternative should be
14 good. The City of Kerrville has adequate O&M resources. From the perspective of the
15 Midway PWS, this alternative would be characterized as easy to operate and repair.

16 The feasibility of this alternative is dependent on an agreement being reached with the City
17 of Kerrville to purchase compliant drinking water.

18 **4.5.4 Alternative MW-4: New Well at 10 miles**

19 This alternative consists of installing a new well within 10 miles of the Midway PWS that
20 would produce compliant water in place of the water currently produced by the Midway PWS.
21 At this level of study, it is not possible to positively identify existing wells or the locations
22 where new wells could be installed.

23 This alternative would require construction of a new 500-foot well, a new pump station
24 with two storage tanks near the new well, and a pipeline from the new well/tanks to the existing
25 intake point for the Midway PWS. The pump station and storage tanks would be necessary to
26 overcome pipe friction and changes in land elevation. For this alternative, the pipeline is
27 assumed to be 10 miles long, and would be a 4-inch line that discharges to a new storage tank
28 at the Midway PWS. The pump station would include four pumps, including one standby, and
29 would be housed in two pump buildings.

30 Depending on well location and capacity, this alternative could present options for a more
31 regional solution. It may be possible to share water and costs with another nearby system.

32 The estimated capital cost for this alternative includes installing the wells and constructing
33 the pipeline and pump station. The estimated O&M cost for this alternative includes O&M for
34 the pipeline and pump station. The estimated capital cost for this alternative is \$2,637,682, and
35 the estimated annual O&M cost for this alternative is \$39,158

36 The reliability of adequate amounts of compliant water under this alternative should be
37 good, since water wells, pump stations and pipelines are commonly employed. From the

perspective of the Midway PWS, this alternative would be similar to operate as the existing system. The Midway PWS has experience with O&M of wells and pipelines.

The feasibility of this alternative is dependent on the ability to find an adequate existing well or success in installing a well that produces an adequate supply of compliant water. It is possible the alternate groundwater source would not be found on land controlled by the Midway PWS, so landowner cooperation would likely be required.

4.5.5 Alternative MW-5: New Well at 5 miles

This alternative consists of installing a new well within 5 miles of the Midway PWS that would produce compliant water in place of the water currently produced by the Midway PWS. At this level of study, it is not possible to positively identify an existing well or locations where a well could be installed.

This alternative would require constructing a new 500-foot well, a new pump station with two storage tank near the new well, and a pipeline from the new well/tanks to a new storage tank for the Midway PWS. The pump station and storage tank would be necessary to overcome pipe friction and changes in land elevation. For this alternative, the pipeline is assumed to be 5 miles long, and would be a 4-inch line that discharges to a new storage tank at the Midway PWS. The pump station would include four pumps, including one standby, and would be housed in a building.

Depending on well location and capacity, this alternative could present some options for a more regional solution. It may be possible to share water and costs with another nearby system.

The estimated capital cost for this alternative includes installing the well and constructing the pipeline and pump station. The estimated O&M cost for this alternative includes the cost for O&M for the pipeline and pump station. The estimated capital cost for this alternative is \$1,427,142, and the estimated annual O&M cost for this alternative is \$37,985.

The reliability of adequate amounts of compliant water under this alternative should be good, since water wells, pump stations and pipelines are commonly employed. From the perspective of the Midway PWS, this alternative would be similar to operate as the existing system. The Midway PWS has experience with O&M of wells and pipelines.

The feasibility of this alternative is dependent on the ability to find an adequate existing well or success in installing a well that produces an adequate supply of compliant water. It is possible the alternate groundwater source would not be found on land controlled by the Midway PWS, so landowner cooperation would likely be required.

4.5.6 Alternative MW-6: New Well at 1 mile

This alternative consists of installing a new well within 1 mile of the Midway PWS that would produce compliant water in place of the water currently produced by the Midway PWS.

1 At this level of study, it is not possible to positively identify an existing well or the locations
2 where new wells could be installed.

3 This alternative would require construction of a new 500-foot well, a new pump station
4 with storage tank near the new well, and a pipeline from the new well/tank to a new storage
5 tank the Midway PWS. The pump station and storage tank would be necessary to overcome
6 pipe friction and changes in land elevation. For this alternative, the pipeline is assumed to be
7 1 mile long, and would be a 4-inch line that discharges to a new storage tank at the Midway
8 PWS. The pump station would include two pumps, including one standby, and would be
9 housed in a building.

10 Depending on well location and capacity, this alternative could present some options for a
11 more regional solution. It may be possible to share water and costs with another nearby
12 system.

13 The estimated capital cost for this alternative includes installing the wells and constructing
14 the pipeline and pump station. The estimated O&M cost for this alternative includes the cost
15 for O&M for the pipeline and pump station. The estimated capital cost for this alternative is
16 \$378,067 and the estimated annual O&M cost for this alternative is \$18,608.

17 The reliability of adequate amounts of compliant water under this alternative should be
18 good, since water wells, pump stations and pipelines are commonly employed. From the
19 perspective of the Midway PWS, this alternative would be similar to operate as the existing
20 system. The Midway PWS has experience with O&M of wells and pipelines.

21 The feasibility of this alternative is dependent on the ability to find an adequate existing
22 well or success in installing a well that produces an adequate supply of compliant water. It is
23 possible the alternate groundwater source would not be found on land controlled by the
24 Midway PWS, so landowner cooperation would likely be required.

25 **4.5.7 Alternative MW-7: Central IX Treatment**

26 The system would continue to pump water from the Midway PWS well, and would treat
27 the water through an IX system prior to distribution. For this option, the entire flow of the raw
28 water will be treated to obtain compliant water. Water in excess of that currently produced
29 would be required for backwashing and regeneration of the resin beds.

30 The IX treatment plant, located at the Midway PWS well site, features a 400 square foot
31 (ft²) building with a paved driveway; the pre-constructed IX equipment on a skid, a 24"x50"
32 commercial brine drum with regeneration equipment, two transfer pumps, a 5,000-gallon tank
33 for storing the treated water, a 6,000-gallon tank for storing spent backwash water, and a
34 2,000-gallon tank for storing regenerant waste. The spent backwash would be allowed to settle
35 in the spent backwash tank, and the water would be recycled to the head of the plant, and there
36 would be periodic disposal of accumulated sludge. The regenerant waste would be trucked off-
37 site for disposal. The treated water would be chlorinated and stored in the new treated water
38 tank prior to being pumped into the distribution system. The entire facility is fenced.

1 The estimated capital cost for this alternative is \$314,070, and the estimated annual O&M
2 cost is \$30,932.

3 Reliability of supply of adequate amounts of compliant water under this alternative is
4 good, since IX treatment is a common and well-understood treatment technology. IX treatment
5 does not require high pressure, but can be affected by interfering constituents in the water. The
6 O&M efforts required for the central IX treatment plant may be significant, and operating
7 personnel would require training with ion exchange.

8 **4.5.8 Alternative MW-8: WRT Z-92 Treatment**

9 The system would continue to pump water from the Midway PWS well, and would treat
10 the water through the Z-92 adsorption system prior to distribution. The full flow of raw water
11 would be treated by the Z-92 system as the media specifically adsorb uranium and do not affect
12 other constituents. There is no liquid waste generated in this process. The Z-92 media would
13 be replaced and disposed of by WRT in an approved low-level radioactive waste landfill after
14 1-2 years of operation.

15 This alternative consists of constructing the Z-92™ treatment system at the existing
16 Midway PWS well site. WRT owns the Z-92™ equipment and the Midway PWS pays for the
17 installation of the system and auxiliary facilities. The plant comprises a 400-ft² building with a
18 paved driveway; the pre-constructed Z-92 adsorption system (2- 30" diameter x 115" tall
19 vessels) owned by WRT; a treated water storage tank and booster pump set, and piping system.
20 The entire facility is fenced. The treated water will be chlorinated prior to distribution.

21 The estimated capital cost for this alternative is \$290,580 and the annual O&M cost is
22 estimated to be \$24,851.

23 Based on many pilot testing results this technology appears to be reliable. It is very simple
24 to operate and the media replacement and disposal would be handled by WRT. Because WRT
25 owns the equipment the capital cost is relatively low. The main operating cost is the treated
26 water fee charged by WRT. One concern with this technology is the potential health effect of
27 the level of radioactivity accumulated in the Z-92™ vessel on O&M personnel when the media
28 have been operating for a long time.

29 **4.5.9 Alternative MW-9: Coagulation/Filtration**

30 The system would continue to pump water from the Midway PWS well, and would treat
31 the water through a coagulation/filtration system prior to distribution. For this option, the
32 entire flow of the raw water will be treated and the flow will be decreased when one of the two
33 50 percent filters is being backwashed by raw water. It is assumed the existing well pumps
34 have adequate pressure to pump the water through the coagulation/filtration system.

35 The coagulation/filtration plant, located at the Midway PWS well site, features a 400 ft²
36 building with a paved driveway; the pre-constructed filters and a coagulant solution tank on a
37 skid; a 9,000-gallon spent backwash tank, a treated water storage tank and booster pump set,
38 and piping systems. The spent backwash would be allowed to settle in the spent backwash

1 tank, and the water would be recycled to the head of the plant, and there would be periodic
2 disposal of accumulated sludge. The entire facility is fenced.

3 The estimated capital cost for this alternative is \$368,300 and the annual O&M is
4 estimated to be \$33,900.

5 Reliability of supply of adequate amounts of compliant water under this alternative is
6 good, since coagulation/filtration is an established treatment technology for uranium removal.
7 The O&M efforts required is moderate and the operating personnel need to ensure that
8 coagulant is not overfed. The spent backwash water contains metal oxide particles with sorbed
9 uranium and the level of radioactivity in the backwash is relatively low.

10 **4.5.10 Alternative MW-10: Point-of-Use Treatment**

11 This alternative consists of the continued operation of the Midway PWS well, plus
12 treatment of water to be used for drinking or food preparation at the point of use to remove
13 uranium. The purchase, installation, and maintenance of POU treatment systems to be installed
14 “under the sink” would be necessary for this alternative. Blending is not an option in this case.

15 This alternative would require installation of the POU treatment units in residences and
16 other buildings that provide drinking or cooking water. The Midway PWS would be
17 responsible for purchasing and maintaining the treatment units, including media or membrane
18 and filter replacement, periodic sampling, and necessary repairs. In houses, the most
19 convenient point for installation of the treatment units is typically under the kitchen sink, with a
20 separate tap installed for dispensing treated water. Installation of the treatment units in
21 kitchens would require entry by Midway PWS or contract personnel into the houses of
22 customers. As a result, the cooperation of customers would be important for success in
23 implementing this alternative. The treatment units could be installed so they could be accessed
24 without house entry, but that would complicate the installation and increase costs.

25 For the cost estimate, it is assumed the POU uranium treatment would involve RO. RO
26 treatment processes typically produce a reject water stream that requires disposal. The reject
27 stream results in an increase in the overall volume of water used. POU systems have the
28 advantage of using only a minimum volume of treated water for human consumption. This
29 minimizes the size of the treatment units, the increase in water required, and the waste for
30 disposal. For this alternative, it is assumed the increase in water consumption is insignificant in
31 terms of supply cost, and that the reject waste stream could be discharged to the house septic or
32 sewer system.

33 This alternative does not present options for a regional solution.

34 The estimated capital cost for this alternative includes the cost to purchase and install the
35 POU treatment systems. The estimated O&M cost for this alternative includes the purchase
36 and replacement of filters and media or membranes, as well as periodic sampling and record
37 keeping. The estimated capital cost for this alternative is \$7,920, and the estimated annual
38 O&M cost for this alternative is \$8,700. For the cost estimate, it is assumed that one POU

1 treatment unit will be required for each of the 12 connections at the Midway PWS. It should be
2 noted that the POU treatment units would need to be more complex than units typically found
3 in commercial retail outlets in order to meet regulatory requirements, making purchase and
4 installation more expensive.

5 The reliability of adequate amounts of compliant water under this alternative is fair, since
6 it relies on the active cooperation of the customers for system installation, use, and
7 maintenance, and only provides compliant water to single tap within a house. Additionally, the
8 O&M efforts required for the POU systems would be significant, and the Midway PWS
9 personnel are inexperienced in this type of work. From the perspective of the Midway PWS
10 personnel, this alternative would be characterized as more difficult to operate due to the in-
11 home requirements and large number of individual units.

12 The feasibility of this alternative is not dependent on the cooperation, willingness, or
13 capability of other water supply entities.

14 **4.5.11 Alternative MW-11: Point-of-Entry Treatment**

15 This alternative consists of the continued operation of the Midway PWS, plus treatment of
16 water as it enters residences to remove uranium. The purchase, installation, and maintenance
17 of the treatment systems at the POE to a household would be necessary for this alternative.
18 Blending is not an option in this case.

19 This alternative would require installation of the POE treatment units at residences and
20 other buildings that provide drinking or cooking water. The Midway PWS would be
21 responsible for purchasing and maintaining the treatment units, including media or membrane
22 and filter replacement, periodic sampling, and necessary repairs. It may also be desirable to
23 modify piping so water for non-consumptive uses can be withdrawn upstream of the treatment
24 unit. The POE treatment units would be installed outside the residences, so entry would not be
25 necessary for O&M. Some cooperation from customers would be necessary for installation and
26 maintenance of the treatment systems.

27 For the cost estimate, it is assumed the POE treatment would involve RO. RO treatment
28 processes typically produce a reject water stream that requires disposal. The waste streams
29 result in an increased overall volume of water used. POE systems treat a greater volume of
30 water than POU systems. For this alternative, it is assumed the increase in water consumption
31 is insignificant in terms of supply cost, and that the reject waste stream could be discharged to
32 the house septic or sewer system.

33 This alternative does not present options for a regional solution.

34 The estimated capital cost for this alternative includes purchasing and installing the POE
35 treatment systems. The estimated O&M cost for this alternative includes purchasing and
36 replacing filters and media or membranes, as well as periodic sampling and record keeping.
37 The estimated capital cost for this alternative is \$138,600, and the estimated annual O&M cost

1 for this alternative is \$18,000. For the cost estimate, it is assumed that one POE treatment unit
2 would be required for each of the 12 existing connections to the Midway PWS.

3 The reliability of adequate amounts of compliant water under this alternative is fair, but
4 better than POI systems since it relies less on the active cooperation of customers for system
5 installation, use, and maintenance, and compliant water is supplied to all taps within a house.
6 Additionally, O&M efforts required for the POE systems would be significant, and the Midway
7 personnel are inexperienced in this type of work. From the perspective of the Midway, this
8 alternative would be characterized as more difficult to operate due to the on-property
9 requirements and the large number of individual units.

10 The feasibility of this alternative is not dependent on the cooperation, willingness, or
11 capability of other water supply entities.

12 **4.5.12 Alternative MW-12: Public Dispenser for Treated Drinking Water**

13 This alternative consists of the continued operation of the Midway PWS, plus dispensing
14 treated water for drinking and cooking at a publicly accessible location. Implementing this
15 alternative would require purchasing and installing a treatment unit where customers would be
16 able to come to fill their own containers. This alternative also includes notifying customers of
17 the importance of obtaining drinking water from the dispenser. In this way, only a relatively
18 small volume of water requires treatment, but customers are required to pick up and deliver
19 their own water. Blending is not an option in this case. It should be noted that this alternative
20 would be considered an interim measure until a compliance alternative is implemented.

21 The Midway would be responsible for maintaining the treatment units, including media or
22 membrane replacement, periodic sampling, and necessary repairs. The spent media or
23 membranes would require disposal. This alternative relies on a great deal of cooperation and
24 action from the customers to be effective.

25 This alternative does not present options for a regional solution.

26 The estimated capital cost for this alternative includes purchasing and installing the
27 treatment system to be used for the drinking water dispenser. The estimated O&M cost for this
28 alternative includes purchasing and replacing filters and media or membranes, as well as
29 periodic sampling and record keeping. The estimated capital cost for this alternative is
30 \$11,600, and the estimated annual O&M cost for this alternative is \$20,300.

31 The reliability of adequate amounts of compliant water under this alternative is fair,
32 because of the large amount of effort required from customers and the associated
33 inconvenience. The Midway PWS has not provided this type of service in the past. From the
34 perspective of the Midway PWS, this alternative would be characterized as relatively easy to
35 operate, since these types of treatment units are highly automated, and there is only one unit.

36 The feasibility of this alternative is not dependent on the cooperation, willingness, or
37 capability of other water supply entities.

4.5.13 Alternative MW-13: 100 Percent Bottled Water Delivery

This alternative consists of the continued operation of the Midway PWS, but compliant drinking water would be delivered in containers to customers. This alternative involves setting up and operating a bottled water delivery program to serve all customers in the system. It is expected the Midway PWS would find it most convenient and economical to contract a bottled water service. The bottle delivery program would have to be flexible enough to allow delivery of smaller containers should customers be incapable of lifting and manipulating 5-gallon bottles. Blending is not an option in this case. It should be noted that this alternative would be considered an interim measure until a compliance alternative is implemented.

This alternative does not involve capital cost for construction, but would require some initial costs for system setup, and then ongoing costs to have the bottled water furnished. It is assumed for this alternative that bottled water would be provided to 100 percent of the Midway PWS's customers.

This alternative does not present options for a regional solution.

The estimated O&M cost for this alternative includes program administration and purchase of the bottled water, including costs for periodic sampling and record keeping. The estimated capital cost for this alternative is \$31,920, and the estimated annual O&M cost for this alternative is \$39,826. For the cost estimate, it is assumed each person requires 1 gallon of bottled water per day.

The reliability of adequate amounts of compliant water under this alternative is fair, since it relies on the active cooperation of customers to order and utilize the water. Management and administration of the bottled water delivery program would require attention from the Midway PWS.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other water supply entities.

4.5.14 Alternative MW-14: Public Dispenser for Trucked Drinking Water

This alternative consists of continued operation of the Midway PWS, plus dispensing compliant water for drinking and cooking at a publicly accessible location. The compliant water would be purchased from the City of Kerrville, and would be delivered by truck to a tank at a central location where customers would be able to fill their own containers. This alternative also includes notifying customers of the importance of obtaining drinking water from the dispenser. In this way, only a relatively small volume of water requires treatment, but customers are required to pick up and deliver their own water. Blending is not an option in this case. It should be noted that this alternative would be considered an interim measure until a compliance alternative is implemented.

The Midway PWS would purchase a truck suitable for hauling potable water, and install a storage tank. It is assumed the storage tank would be filled once a week, and that the chlorine residual would be tested for each truckload. The truck would have to meet requirements for

1 potable water, and each load would be treated with bleach. This alternative relies on a great
2 deal of cooperation and action from the customers for it to be effective.

3 This alternative does not present options for a regional solution.

4 The estimated capital cost for this alternative includes purchasing a water truck and
5 constructing the storage tank to be used for the drinking water dispenser. The estimated O&M
6 cost for this alternative includes O&M for the truck, maintenance for the tank, water quality
7 testing, record keeping, and water purchase. The estimated capital cost for this alternative is
8 \$102,986, and the estimated annual O&M cost for this alternative is \$17,950.

9 The reliability of adequate amounts of compliant water under this alternative is fair
10 because of the large amount of effort required from the customers and the associated
11 inconvenience. The Midway PWS has not provided this type of service in the past. From the
12 perspective of the Midway PWS, this alternative would be characterized as relatively easy to
13 operate, but the water hauling and storage would have to be done with care to ensure sanitary
14 conditions.

15 The feasibility of this alternative is not dependent on the cooperation, willingness, or
16 capability of other water supply entities.

17 **4.5.15 Summary of Alternatives**

18 Table 4.3 provides a summary of the key features of each alternative for the Midway PWS.

19 **4.6 COST OF SERVICE AND FUNDING ANALYSIS**

20 **4.6.1 Midway PWS Financial Data**

21 No separate financial data are maintained by the system operator for the Midway PWS.
22 Financial information on the water system is included in the consolidated financial data for the
23 overall business. Water usage does not constitute a separate monthly billing, but is included in
24 the monthly rent for the mobile home pads. The estimated water usage per connection is
25 approximately \$15/month, or approximately 15 percent of monthly pad rental. This value was
26 used in the financial model as the basic monthly charge for unlimited water usage with no
27 additional rate structure tiers. Financial data for system expenditures for Midway PWS were
28 based on estimates and pro-rating of expenses based on documented expenses of similar
29 systems.

30 This analysis will need to be performed in a more detailed fashion and applied to
31 alternatives that are deemed attractive and worthy of more detailed evaluation. A more detailed
32 analysis should include additional factors such as:

- 33 • Cost escalation,
- 34 • Price elasticity effects where increased rates may result in lower water consumption,

- Costs for other system upgrades and rehabilitation needed to maintain compliant operation.

4.6.2 Current Financial Condition

4.6.2.1 Cash Flow Needs

Based on estimates for the system, the current average annual water use by residential customers of Midway PWS is estimated to be \$180, or less than 1.0 percent of the annual household income of \$34,374 for the Census Zip code Tract that includes the Midway PWS. Because of the lack of separate financial data exclusively for the water system, it is difficult to determine exact cash flow needs. Water usage revenues likely fall short of expenditures with the system being subsidized by other revenues.

4.6.2.2 Ratio Analysis

Current Ratio

The Current Ratio for the Midway PWS could not be determined due to lack of necessary financial data to determine this ratio.

Debt to Net Worth Ratio

A Debt-to-Net-Worth Ratio also could not be determined owing to lack of the necessary financial data to determine this ratio.

Operating Ratio = 0.46

Because of the lack of complete separate financial data on expenses specifically related to the Midway PWS, the Operating Ratio could not be accurately determined. However, based on expenditure estimates for the system, the system's estimated operating expenditures of approximately \$3,900 were greater than the operating revenues, with a resulting operating ratio of 0.46. Thus, since the operating ratio is less than 1.0, it is most probable that revenues do not cover expenses for the system.

4.6.3 Financial Plan Results

Each compliance alternative for Midway PWS was evaluated, with emphasis on the impact on affordability (expressed as a percentage of household income), and the overall increase in water rates necessary to pay for the improvements. Each alternative was examined under the various funding options described in Subsection 2.4.

For State Revolving Fund funding options, customer MHI compared to the state average determines the availability of subsidized loans. Since the MHI for customers of Midway PWS was not available, Census Zip code Tract data were used. The Census Zip code Tract for the Midway PWS is located had an estimated annual household income of \$34,374 according to the 2000 U.S. Census compared to a statewide average of \$39,927, or 86 percent of the

1 statewide average. Since the MHI for Census Zip code Tract is greater than 75 percent of the
2 statewide average, Midway PWS may qualify for an interest rate of 3.8 percent. If the actual
3 MHI for Midway PWS is below 75 percent of the statewide average, then Midway PWS may
4 qualify for an interest rate of 1.0 percent.

5 Results of the financial impact analysis are provided in Table 4.4 and Figure 4.2.
6 Table 4.4 presents rate impacts assuming that any deficiencies in reserve accounts are funded
7 immediately in the year following the occurrence of the deficiency, which would cause the first
8 few years' water rates to be higher than they would be if the reserve account was built-up over
9 a longer period of time. Figure 4.2 provides a bar chart that in terms of the yearly billing to an
10 average customer (3,954 gallons/month consumption), shows the following:

- 11 • Current annual average bill,
- 12 • Projected annual average bill including rate increase, if needed, to match
13 existing expenditures, and
- 14 • Projected annual bill including rate increases needed to fund implementation of
15 a compliance alternative (this does not include funding for reserve accounts).

16 The two bars shown for each compliance alternative represent the rate changes necessary
17 for revenues to match total expenditures assuming 100 percent grant funding and 100 percent
18 loan/bond funding. Most funding options will fall between 100 percent grant and 100 percent
19 loan/bond funding, with the exception of 100 percent revenue financing. Establishing or
20 increasing reserve accounts would require an increase in rates. If existing reserves are
21 insufficient to fund a compliance alternative, rates would need to be raised before
22 implementing the compliance alternative. This would allow for accumulation of sufficient
23 reserves to avoid larger but temporary rate increases during the years the compliance alternative
24 was being implemented.

1 **Table 4.3 Summary of Compliance Alternatives for the Midway PWS**

Alt No.	Alternative Description	Major Components	Capital Cost ¹	Annual O&M Cost	Total Annualized Cost ²	Reliability	System Impact	Remarks
MW-1	Purchase water from Ingram WSC	- Pump station - 1.9-mile pipeline	\$647,526	\$29,617\$	\$86,072	Good	N	Agreement must be successfully negotiated with Ingram WSC. Blending may be possible.
MW-2	New well at Sleepy Hollow PWS	- New well - Pump station - 2.34-mile pipeline	\$786,390	\$37,341	\$105,902\$	Good	N	Agreement must be successfully negotiated with Sleepy Hollow PWS, or land must be purchased. Blending may be possible.
MW-3	Purchase water from City of Kerrville	- Pump station - 0.1-mile pipeline	\$37,294	\$(7,602)	\$(4,351)	Good	N	Agreement must be successfully negotiated with the City of Kerrville. Blending may be possible.
MW-4	Install new compliant well within 10 miles	- New well - Storage tank - Pump station - 10-mile pipeline	\$2,637,682	\$39,158	\$269,123	Good	N	May be difficult to find well with good water quality.
MW-5	Install new compliant well within 5 miles	- New well - Storage tank - Pump station - 5-mile pipeline	\$1,427,142	\$37,985	\$162,410	Good	N	May be difficult to find well with good water quality.
MW-6	Install new compliant well within 1 mile	- New well - Storage tank - Pump station - 1-mile pipeline	\$378,067	\$18,608	\$51,570	Good	N	May be difficult to find well with good water quality.
MW-7	Continue operation of Midway well with central IX treatment	- Central IX treatment plant	\$314,070	\$30,932	\$58,314	Good	T	No nearby system to possibly share treatment plant cost.
MW-8	Continue operation of Midway well with central WRT Z-88 treatment	- Central WRT Z-88 treatment plant	\$290,580	\$24,851	\$50,185	Good	T	No nearby system to possibly share treatment plant cost.
MW-9	Continue operation of Midway well with central KMnO ₄ treatment	- Central KMnO ₄ treatment plant	\$368,300	\$33,900	\$66,010	Good	T	No nearby system to possibly share treatment plant cost.
MW-10	Continue operation of Midway well, and POU treatment	- POU treatment units - RO package plant for Eden Detention Cntr	\$ 7920	\$8,700	\$9,391	Fair	T, M	Only one compliant tap in home. Cooperation of residents required for installation, maintenance, and testing.
MW-11	Continue operation of Midway well, and POE treatment	- POE treatment units - RO package plant for Eden Detention Cntr	\$138,600	\$18,000	\$30,084	Fair (better than POU)	T, M	All home taps compliant and less resident cooperation required.
MW-12	Continue operation of Midway well, but furnish public dispenser for treated drinking water	- Water treatment and dispenser unit - RO package plant for Eden Detention Cntr	\$11,600	\$20,300	\$21,311	Fair/interim measure	T	Does not provide compliant water to all taps, and requires a lot of effort by customers.

Alt No.	Alternative Description	Major Components	Capital Cost ¹	Annual O&M Cost	Total Annualized Cost ²	Reliability	System Impact	Remarks
MW-13	Continue operation of Midway well, but furnish bottled drinking water for all customers	- Set up bottled water system - RO package plant for Eden Detention Cntr	\$31,920	\$39,826	\$42,609	Fair/interim measure	T, M	Does not provide compliant water to all taps, and requires customers to order and use. Management of program may be significant.
MW-14	Continue operation of Midway well, but furnish public dispenser for trucked drinking water.	- Construct storage tank and dispenser - Purchase potable water truck - RO package plant for Eden Detention Cntr	\$102,986	\$17,950	\$26,929	Fair/interim measure	T, M	Does not provide compliant water to all taps, and requires a lot of effort by customers.

1
2
3
4
5
6


Notes: *N – No significant increase required in technical or management capability*
 T – Implementation of alternative would require increase in technical capability
 M – Implementation of alternative would require increase in management capability
 1 – See cost breakdown in Appendix C
 2 – 20-year return period and 6 percent interest

1

Table 4.4 Financial Impact on Households

Alternative	Description		All Revenue	100% Grant	75% Grant	50% Grant	SRF	Bond
1	Purchase water from Ingram WSC	Max % of HH Income	212%	24%	31%	39%	51%	55%
		Max % Rate Increase Compared to Current	24244%	2619%	3508%	4396%	5745%	6174%
		Average Water Bill Required by Alternative	\$ 68,204	\$ 7,302	\$ 9,753	\$ 12,204	\$ 15,922	\$ 17,106
2	New well at Sleepy Hollow	Max % of HH Income	258%	29%	39%	48%	62%	67%
		Max % Rate Increase Compared to Current	29433%	3252%	4331%	5410%	7047%	7569%
		Average Water Bill Required by Alternative	\$ 82,735	\$ 8,985	\$ 11,962	\$ 14,938	\$ 19,454	\$ 20,892
3	Purchase water from City of Kerrville	Max % of HH Income	14%	3%	3%	3%	3%	3%
		Max % Rate Increase Compared to Current	1503%	194%	220%	246%	284%	297%
		Average Water Bill Required by Alternative	\$ 4,510	\$ 838	\$ 910	\$ 981	\$ 1,090	\$ 1,125
4	New Well at 10 Miles	Max % of HH Income	825%	31%	62%	94%	142%	157%
		Max % Rate Increase Compared to Current	94465%	3400%	7020%	10640%	16131%	17880%
		Average Water Bill Required by Alternative	\$ 265,237	\$ 9,381	\$ 19,365	\$ 29,349	\$ 44,494	\$ 49,317
5	New Well at 5 Miles	Max % of HH Income	454%	30%	47%	64%	90%	98%
		Max % Rate Increase Compared to Current	51942%	3304%	5263%	7221%	10193%	11139%
		Average Water Bill Required by Alternative	\$ 145,902	\$ 9,125	\$ 14,527	\$ 19,929	\$ 28,124	\$ 30,733
6	New Well at 1 Mile	Max % of HH Income	126%	16%	20%	25%	32%	34%
		Max % Rate Increase Compared to Current	14339%	1718%	2237%	2756%	3543%	3793%
		Average Water Bill Required by Alternative	\$ 40,448	\$ 4,904	\$ 6,335	\$ 7,766	\$ 9,936	\$ 10,628
7	Central Treatment - Ion Exchange	Max % of HH Income	111%	25%	28%	32%	38%	40%
		Max % Rate Increase Compared to Current	12598%	2727%	3158%	3589%	4243%	4451%
		Average Water Bill Required by Alternative	\$ 35,513	\$ 7,589	\$ 8,778	\$ 9,966	\$ 11,770	\$ 12,344
8	Central Treatment - WRT Z-92	Max % of HH Income	101%	20%	24%	27%	33%	34%
		Max % Rate Increase Compared to Current	11525%	2229%	2628%	3027%	3631%	3824%
		Average Water Bill Required by Alternative	\$ 32,526	\$ 6,264	\$ 7,364	\$ 8,464	\$ 10,132	\$ 10,663
9	Central Treatment - Coagulation/Filtration	Max % of HH Income	128%	27%	31%	36%	42%	44%
		Max % Rate Increase Compared to Current	14622%	2970%	3475%	3981%	4747%	4992%
		Average Water Bill Required by Alternative	\$ 41,183	\$ 8,235	\$ 9,629	\$ 11,024	\$ 13,138	\$ 13,812
10	Point-of-Use Treatment	Max % of HH Income	8%	8%	8%	8%	8%	8%
		Max % Rate Increase Compared to Current	840%	788%	797%	806%	820%	824%
		Average Water Bill Required by Alternative	\$ 2,609	\$ 2,429	\$ 2,454	\$ 2,479	\$ 2,517	\$ 2,529
11	Point-of-Entry Treatment	Max % of HH Income	44%	13%	15%	16%	18%	19%
		Max % Rate Increase Compared to Current	4978%	1422%	1581%	1739%	1980%	2057%
		Average Water Bill Required by Alternative	\$ 14,193	\$ 4,117	\$ 4,555	\$ 4,992	\$ 5,655	\$ 5,866
12	Public Dispenser for Treated Drinking Water	Max % of HH Income	17%	17%	17%	17%	18%	18%
		Max % Rate Increase Compared to Current	1856%	1856%	1872%	1888%	1912%	1920%
		Average Water Bill Required by Alternative	\$ 5,351	\$ 5,272	\$ 5,316	\$ 5,360	\$ 5,427	\$ 5,448
13	Supply Bottled Water to 100% of Population	Max % of HH Income	31%	31%	31%	32%	32%	33%
		Max % Rate Increase Compared to Current	3455%	3455%	3499%	3543%	3609%	3630%
		Average Water Bill Required by Alternative	\$ 9,743	\$ 9,527	\$ 9,647	\$ 9,768	\$ 9,951	\$ 10,010
14	Central Trucked Drinking Water	Max % of HH Income	42%	15%	17%	18%	20%	20%
		Max % Rate Increase Compared to Current	4660%	1664%	1805%	1947%	2161%	2229%
		Average Water Bill Required by Alternative	\$ 13,288	\$ 4,760	\$ 5,150	\$ 5,540	\$ 6,131	\$ 6,319

23



SECTION 5 REFERENCES

- Anaya, R. and I. Jones, 2004. Groundwater Availability Model for the Edwards-Trinity (Plateau) and Cenozoic Pecos Alluvium Aquifer Systems, Texas. Texas Water Development Board GAM Report (available online at <http://www.twdb.state.tx.us/gam/index.htm>).
- Ashworth, J.B. 1983. Ground-Water Availability of the Lower Cretaceous Formations in the Hill Country of South-Central Texas. Texas Water Development Board Report 273, 65 p. <http://www.twdb.state.tx.us/publications/reports/GroundWaterReports/GWReports/GWreports.asp>.
- Ashworth, J.B., and J. Hopkins 1995. Major and Minor Aquifers of Texas: Texas Water Development Board, Report 345, 69p. <http://www.twdb.state.tx.us/publications/reports/GroundWaterReports/GWReports/GWreports.asp>
- Black, C.W. 1988. Hydrogeology of the Hickory Sandstone aquifer, upper Cambrian Riley Formation, Mason, and McCulloch Counties: The University of Texas at Austin, Department of Geological Sciences, Master's thesis, 195 p.
- Bluntzer, Robert L. 1992. Evaluation of Ground-Water Resources of the Paleozoic and Cretaceous Aquifers in the Hill Country of Central Texas, Texas Water Development Board Report 339, 130 p. + Appendices <http://www.twdb.state.tx.us/publications/reports/GroundWaterReports/GWReports/GWreports.asp>
- LBG-Guyton Associates 2003. Brackish groundwater manual for Texas Regional Water Planning Groups, Report prepared for the Texas Water Development Board, 188p.
- Mace, R.E., A.H. Chowdhury, R. Anaya, S.C. Way 2000. Groundwater Availability of the Trinity Aquifer, Hill Country Area, Texas - Numerical Simulations through 2050: Texas Water Development Board Report 353, 117 p. http://www.twdb.state.tx.us/gam/trnt_h/trinity.htm
- McBride, E.F., A.A. Abdel-Wahab, and K. Milliken, K. 2002. Petrography and diagenesis of a half-billion-year-old cratonic sandstone (Hickory), Llano Region, Texas: The University of Texas at Austin, Bureau of Economic Geology Report of Investigations No. 264, 77 p.
- Preston, Richard D., Dianne J. Pavilcek, Robert L. Bluntzer, and John Derton 1996. The Paleozoic and Related Aquifers of Central Texas. Texas Water Development Board Report 346, 76 p. + Appendices <http://www.twdb.state.tx.us/publications/reports/GroundWaterReports/GWReports/GWreports.asp>
- Raucher, Robert S., M.L. Hagenstad, J. Cotruvo, R. Narasimhan, K. Martin, H. Arora, R. Regunathan, J.A. Drago, and F. Pontius 2004. Conventional and Unconventional Approaches to Water Service Provision. AWWA Research Foundation and American Water Works Association.
- Reeves, Richard D. 1967. Ground-Water Resources of Kendall County, Texas. Texas Water Development Board Report 60, 90 p.
- Reeves, Richard D. 1969. Ground-Water Resources of Kerr County, Texas. Texas Water Development Board Report 102, 58 p.
- TCEQ. 2004a. Drinking Water Quality and Reporting Requirements for PWSs: 30 TAC 290 Subchapter F (290.104. Summary of Maximum Contaminant Levels, Maximum Residual Disinfectant Levels, Treatment Techniques, and Action Levels). Revised February 2004.

- 1 TCEQ 2004b. How to Conduct Radionuclide Testing for Well Completion Interim Approval available
2 at: http://www.tceq.state.tx.us/permitting/water_supply/pdw/chemicals/radionuclides/pdw_rad.
- 3 USEPA 2006. List of Drinking Water Contaminants & MCLs. Online. Last updated February 28,
4 2006. www.epa.gov/safewater/mcl.html.
- 5 Walker, L.E. 1979. Occurrence, availability, and chemical quality of ground water in the Edwards
6 Plateau region of Texas: Texas Water Development Board Report 235, 114 p.
- 7

1
2

**APPENDIX A
PWS INTERVIEW FORMS**

CAPACITY DEVELOPMENT ASSESSMENT FORM

Prepared By _____

Date _____

Section 1. Public Water System Information

1. PWS ID # 2. Water System Name 3. County 4. Owner Address Tele. E-mail Fax Message 5. Admin Address Tele. E-mail Fax Message 6. Operator Address Tele. E-mail Fax Message 7. Population Served 8. No. of Service Connections 9. Ownership Type 10. Metered (Yes or No) 11. Source Type 12. Total PWS Annual Water Used

13. Number of Water Quality Violations (Prior 36 months)

Total Coliform Chemical/Radiological Monitoring (CCR, Public Notification, etc.) Treatment Technique, D/DBP

A. Basic Information

1. Name of Water System:
2. Name of Person Interviewed:
3. Position:
4. Number of years at job:
5. Number of years experience with drinking water systems:
6. Percent of time (day or week) on drinking water system activities, with current position (how much time is dedicated exclusively to the water system, not wastewater, solid waste or other activities):
7. Certified Water Operator (Yes or No):

 If Yes,
 7a. Certification Level (water):

 7b. How long have you been certified?
8. Describe your water system related duties on a typical day.

B. Organization and Structure

1. Describe the organizational structure of the Utility. Please provide an organizational chart. (Looking to find out the governance structure (who reports to whom), whether or not there is a utility board, if the water system answers to public works or city council, etc.)

2. If not already covered in Question 1, to whom do you report?
3. Do all of the positions have a written job description?
 - 3a. If yes, is it available to employees?
 - 3b. May we see a copy?

C. Personnel

1. What is the current staffing level (include all personnel who spend more than 10% of their time working on the water system)?
2. Are there any vacant positions? How long have the positions been vacant?
3. In your opinion, is the current staffing level adequate? If not adequate, what are the issues or staffing needs (how many and what positions)?
4. What is the rate of employee turnover for management and operators? What are the major issues involved in the turnover (e.g., operator pay, working conditions, hours)?
5. Is the system staffed 24 hours a day? How is this handled (on-site or on-call)? Is there an alarm system to call an operator if an emergency occurs after hours?

D. Communication

1. Does the utility have a mission statement? If yes, what is it?
2. Does the utility have water quality goals? What are they?
3. How are your work priorities set?
4. How are work tasks delegated to staff?
5. Does the utility have regular staff meetings? How often? Who attends?
6. Are there separate management meetings? If so, describe.
7. Do management personnel ever visit the treatment facility? If yes, how often?
8. Is there effective communication between utility management and state regulators (e.g., NMED)?
9. Describe communication between utility and customers.

E. Planning and Funding

1. Describe the rate structure for the utility.
2. Is there a written rate structure, such as a rate ordinance? May we see it?
 - 2a. What is the average rate for 6,000 gallons of water?
3. How often are the rates reviewed?
4. What process is used to set or revise the rates?
5. In general, how often are the new rates set?
6. Is there an operating budget for the water utility? Is it separate from other activities, such as wastewater, other utilities, or general city funds?
7. Who develops the budget, how is it developed and how often is a new budget created or the old budget updated?
8. How is the budget approved or adopted?

9. In the last 5 years, how many budget shortfalls have there been (i.e., didn't collect enough money to cover expenses)? What caused the shortfall (e.g., unpaid bills, an emergency repair, weather conditions)?

9a. How are budget shortfalls handled?
10. In the last 5 years how many years have there been budget surpluses (i.e., collected revenues exceeded expenses)?

10a. How are budget surpluses handled (i.e., what is done with the money)?
11. Does the utility have a line-item in the budget for emergencies or some kind of emergency reserve account?
12. How do you plan and pay for short-term system needs?
13. How do you plan and pay for long- term system needs?
14. How are major water system capital improvements funded? Does the utility have a written capital improvements plan?
15. How is the facility planning for future growth (either new hook-ups or expansion into new areas)?
16. Does the utility have and maintain an annual financial report? Is it presented to policy makers?

17. Has an independent financial audit been conducted of the utility finances? If so, how often? When was the last one?
18. Will the system consider any type of regionalization with any other PWS, such as system interconnection, purchasing water, sharing operator, emergency water connection, sharing bookkeeper/billing or other?

F. Policies, Procedures, and Programs

1. Are there written operational procedures? Do the employees use them?
2. Who in the utility department has spending authorization? What is the process for obtaining needed equipment or supplies, including who approves expenditures?
3. Does the utility have a source water protection program? What are the major components of the program?
4. Are managers and operators familiar with current SDWA regulations?
5. How do the managers and operators hear about new or proposed regulations, such as arsenic, DBP, Groundwater Rule? Are there any new regulations that will be of particular concern to the utility?
6. What are the typical customer complaints that the utility receives?
7. Approximately how many complaints are there per month?

8. How are customer complaints handled? Are they recorded?
9. (If not specifically addressed in Question 7) If the complaint is of a water quality nature, how are these types of complaints handled?
10. Does the utility maintain an updated list of critical customers?
11. Is there a cross-connection control plan for the utility? Is it written? Who enforces the plan's requirements?
12. Does the utility have a written water conservation plan?
13. Has there been a water audit of the system? If yes, what were the results?
14. (If not specifically answered in 11 above) What is the estimated percentage for loss to leakage for the system?
15. Are you, or is the utility itself, a member of any trade organizations, such as AWWA or Rural Water Association? Are you an active member (i.e., attend regular meetings or participate in a leadership role)? Do you find this membership helpful? If yes, in what ways does it help you?

G. Operations and Maintenance

1. How is decision-making authority split between operations and management for the following items:
 - a. Process Control
 - b. Purchases of supplies or small equipment
 - c. Compliance sampling/reporting
 - d. Staff scheduling
2. Describe your utility's preventative maintenance program.
3. Do the operators have the ability to make changes or modify the preventative maintenance program?
4. How does management prioritize the repair or replacement of utility assets? Do the operators play a role in this prioritization process?
5. Does the utility keep an inventory of spare parts?
6. Where does staff have to go to buy supplies/minor equipment? How often?
 - 6a. How do you handle supplies that are critical, but not in close proximity (for example if chlorine is not available in the immediate area or if the components for a critical pump are not in the area)

7. Describe the system's disinfection process. Have you had any problems in the last few years with the disinfection system?

7a. Who has the ability to adjust the disinfection process?

8. How often is the disinfectant residual checked and where is it checked?

8a. Is there an official policy on checking residuals or is it up to the operators?

9. Does the utility have an O & M manual? Does the staff use it?

10. Are the operators trained on safety issues? How are they trained and how often?

11. Describe how on-going training is handled for operators and other staff. How do you hear about appropriate trainings? Who suggests the trainings – the managers or the operators? How often do operators, managers, or other staff go to training? Who are the typical trainers used and where are the trainings usually held?

12. In your opinion is the level of your on-going training adequate?

13. In your opinion is the level of on-going training for other staff members, particularly the operators, adequate?

14. Does the facility have mapping of the water utility components? Is it used on any routine basis by the operators or management? If so, how is it used? If not, what is the process used for locating utility components?
15. In the last sanitary survey, were any deficiencies noted? If yes, were they corrected?
16. How often are storage tanks inspected? Who does the inspection?
 - 16a. Have you experienced any problems with the storage tanks?

H. SDWA Compliance

1. Has the system had any violations (monitoring or MCL) in the past 3 years? If so, describe.
2. How were the violations handled?
3. Does the system properly publish public notifications when notified of a violation?
4. Is the system currently in violation of any SDWA or state regulatory requirements, including failure to pay fees, fines, or other administrative type requirements?
5. Does the utility prepare and distribute a Consumer Confidence Report (CCR)? Is it done every year? What type of response does the utility get to the CCR from customers?

I. Emergency Planning

1. Does the system have a written emergency plan to handle emergencies such as water outages, weather issues, loss of power, loss of major equipment, etc?
2. When was the last time the plan was updated?
3. Do all employees know where the plan is? Do they follow it?
4. Describe the last emergency the facility faced and how it was handled.

Attachment A

A. Technical Capacity Assessment Questions

1. Based on available information of water rights on record and water pumped has the system exceeded its water rights in the past year? YES ☐ NO ☐

In any of the past 5 years? YES ☐ NO ☐ How many times? _____

2. Does the system have the proper level of certified operator? *(Use questions a – c to answer.)*
YES ☐ NO ☐

a. What is the Classification Level of the system by NMED? _____

- b. Does the system have one or more certified operator(s)? [20 NMAC 7.4.20]

YES ☐ NO ☐

- c. If YES, provide the number of operators at each New Mexico Certification Level. [20 NMAC 7.4.12]

_____ NM Small System _____ Class 2

_____ NM Small System Advanced _____ Class 3

_____ Class 1 _____ Class 4

3. Did the system correct any sanitary deficiency noted on the most recent sanitary survey within 6 months of receiving that information? [20 NMAC 7.20.504]

YES ☐ NO ☐ No Deficiencies ☐

What was the type of deficiency? *(Check all that are applicable.)*

Source ☐ Storage ☐

Treatment ☐ Distribution ☐

Other _____

From the system's perspective, were there any other deficiencies that were not noted on the sanitary survey?
Please describe.

4. Will the system's current treatment process meet known future regulations?

Radionuclides YES ☐ NO ☐ Doesn't Apply ☐

Arsenic YES ☐ NO ☐ Doesn't Apply ☐

Stage 1 Disinfectants and Disinfection By-Product (DBP)

YES ☐ NO ☐ Doesn't Apply ☐

Surface Water Treatment Rule YES ☐ NO ☐ Doesn't Apply ☐

5. Does the system have a current site plan/map? [20 NMAC 7.10.302 A.1.]

YES ☐ NO ☐

6. Has the system had a water supply outage in the prior 24 months?

YES ☐ NO ☐

What were the causes of the outage(s)? *(Include number of outages for each cause.)*

Drought _____ Limited Supply _____

System Failure _____ Other _____

7. Has the system ever had a water audit or a leak evaluation?

YES ☐ NO ☐ Don't Know ☐

If YES, please complete the following table.

Type of Investigation	Date Done	Water Loss (%)	What approach or technology was used to complete the investigation?	Was any follow-up done? If so, describe

8. Have all drinking water projects received NMED review and approval? [20 NMAC 7.10.201]

YES ☐ NO ☐

If NO, what types of projects have not received NMED review and approval.

Source ☐ Storage ☐

Treatment ☐ Distribution ☐

Other ☐ _____

9. What are the typical customer complaints that the utility receives?

10. Approximately how many complaints are there per month? _____

11. How are customer complaints handled? Are they recorded?

12. What is the age and composition of the distribution system? *(Collect this information from the Sanitary Survey)*

Pipe Material	Approximate Age	Percentage of the system	Comments
			Sanitary Survey Distribution System Records Attached

13. Are there any dead end lines in the system?
 YES ☐ NO ☐

14. Does the system have a flushing program?
 YES ☐ NO ☐

If YES, please describe.

15. Are there any pressure problems within the system?
 YES ☐ NO ☐

If YES, please describe.

16. Does the system disinfect the finished water?
 YES ☐ NO ☐

If yes, which disinfectant product is used? _____

Interviewer Comments on Technical Capacity:

B. Managerial Capacity Assessment Questions

17. Has the system completed a 5-year Infrastructure Capital Improvement Plan (ICIP) plan?

YES ☐ NO ☐

If YES, has the plan been submitted to Local Government Division?

YES ☐ NO ☐

18. Does the system have written operating procedures?

YES ☐ NO ☐

19. Does the system have written job descriptions for all staff?

YES ☐ NO ☐

20. Does the system have:
- | | | | |
|-------------------------------------|--------------------------|-----|--------------------------|
| A preventative maintenance plan? | | | |
| YES | <input type="checkbox"/> | NO | <input type="checkbox"/> |
| A source water protection plan? | | | |
| YES | <input type="checkbox"/> | NO | <input type="checkbox"/> |
| | | N/A | <input type="checkbox"/> |
| An emergency plan? | | | |
| YES | <input type="checkbox"/> | NO | <input type="checkbox"/> |
| A cross-connection control program? | | | |
| YES | <input type="checkbox"/> | NO | <input type="checkbox"/> |
| An emergency source? | | | |
| YES | <input type="checkbox"/> | NO | <input type="checkbox"/> |
| System security measures? | | | |
| YES | <input type="checkbox"/> | NO | <input type="checkbox"/> |
21. Does the system report and maintain records in accordance with the drinking water regulations concerning:
- | | | | |
|--------------------------|--------------------------|----|--------------------------|
| Water quality violations | | | |
| YES | <input type="checkbox"/> | NO | <input type="checkbox"/> |
| Public notification | | | |
| YES | <input type="checkbox"/> | NO | <input type="checkbox"/> |
| Sampling exemptions | | | |
| YES | <input type="checkbox"/> | NO | <input type="checkbox"/> |
22. Please describe how the above records are maintained:
23. Describe the management structure for the water system, including board and operations staff. Please include examples of duties, if possible.
24. Please describe type and quantity of training or continuing education for staff identified above.
25. Describe last major project undertaken by the water system, including the following: project in detail, positive aspects, negative aspects, the way in which the project was funded, any necessary rate increases, the public response to the project, whether the project is complete or not, and any other pertinent information.

26. Does the system have any debt? YES ☐ NO ☐

If yes, is the system current with all debt payments?

YES ☐ NO ☐

If no, describe the applicable funding agency and the default.

27. Is the system currently contemplating or actively seeking funding for any project?

YES ☐ NO ☐

If yes, from which agency and how much?

Describe the project?

Is the system receiving assistance from any agency or organization in its efforts?

28. Will the system consider any type of regionalization with other PWS? *(Check YES if the system has already regionalized.)*

YES ☐ NO ☐

If YES, what type of regionalization has been implemented/considered/discussed? *(Check all that apply.)*

System interconnection ☐

Sharing operator ☐

Sharing bookkeeper ☐

Purchasing water ☐

Emergency water connection ☐

Other: _____

29. Does the system have any of the following? *(Check all that apply.)*

Water Conservation Policy/Ordinance ☐ Current Drought Plan ☐

Water Use Restrictions ☐ Water Supply Emergency Plan ☐

Interviewer Comments on Managerial Capacity:

C. Financial Capacity Assessment

30. Does the system have a budget?

YES ☐ NO ☐

If YES, what type of budget?

Operating Budget ☐Capital Budget ☐

31. Have the system revenues covered expenses and debt service for the past 5 years?

YES ☐ NO ☐

If NO, how many years has the system had a shortfall? _____

32. Does the system have a written/adopted rate structure?

YES ☐ NO ☐

33. What was the date of the last rate increase? _____

34. Are rates reviewed annually?

YES ☐ NO ☐

If YES, what was the date of the last review? _____

35. Did the rate review show that the rates covered the following expenses? (*Check all that apply.*)Operation & Maintenance ☐Infrastructure Repair & replacement ☐Staffing ☐Emergency/Reserve fund ☐Debt payment ☐

36. Is the rate collection above 90% of the customers?

YES ☐ NO ☐

37. Is there a cut-off policy for customers who are in arrears with their bill or for illegal connections?

YES ☐ NO ☐

If yes, is this policy implemented?

38. What is the residential water rate for 6,000 gallons of usage in one month. _____

39. In the past 12 months, how many customers have had accounts frozen or dropped for non-payment? _____

[Convert to % of active connections]

Less than 1% ☐ 1% - 3% ☐ 4% - 5% ☐ 6% - 10% ☐11% - 20% ☐ 21% - 50% ☐ Greater than 50% ☐]

40. The following questions refer to the process of obtaining needed equipment and supplies.

a. Can the water system operator buy or obtain supplies or equipment when they are needed?

YES ☐ NO ☐

b. Is the process simple or burdensome to the employees?

c. Can supplies or equipment be obtained quickly during an emergency?

YES ☐ NO ☐

d. Has the water system operator ever experienced a situation in which he/she couldn't purchase the needed supplies?

YES ☐ NO ☐

e. Does the system maintain some type of spare parts inventory?

YES ☐ NO ☐

If yes, please describe.

41. Has the system ever had a financial audit?

YES ☐ NO ☐

If YES, what is the date of the most recent audit? _____

42. Has the system ever had its electricity or phone turned off due to non-payment? Please describe.

Interviewer Comments on Financial Assessment:

43. What do you think the system capabilities are now and what are the issues you feel your system will be facing in the future? In addition, are there any specific needs, such as types of training that you would like to see addressed by NMED or its contractors?

APPENDIX B COST BASIS

This section presents the basis for unit costs used to develop the conceptual cost estimates for the compliance alternatives. Cost estimates are conceptual in nature (+50%/-30%), and are intended to make comparisons between compliance options and to provide a preliminary indication of possible rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. Capital cost includes an allowance for engineering and construction management. It is assumed that adequate electrical power is available near the site. The cost estimates specifically do not include costs for the following:

- Obtaining land or easements.
- Surveying.
- Mobilization/demobilization for construction.
- Insurance and bonds

In general, unit costs are based on recent construction bids for similar work in the area; when possible, consultations with vendors or other suppliers; published construction and O&M cost data; and USEPA cost guidance. Unit costs used for the cost estimates are summarized in Table B.1.

Unit costs for pipeline components are based on 2006 RS Means Building Construction Cost Data. The number of borings and encasements and open cuts and encasements is estimated by counting the road, highway, railroad, stream, and river crossings for a conceptual routing of the pipeline. The number of air release valves is estimated by examining the land surface profile along the conceptual pipeline route. It is assumed gate valves and flush valves would be installed, on average, every 5,000 feet along the pipeline. Pipeline cost estimates are based on use of C-900 PVC pipe. Other pipe materials could be considered for more detailed development of attractive alternatives..

Pump station unit costs are based on experience with similar installations. The cost estimate for the pump stations include two pumps, station piping and valves, station electrical and instrumentation, minor site improvement, installation of a concrete, fence and building, and tools. Construction cost of a storage tank is based on 2006 RS Means Building Construction Cost Data.

Labor costs are estimated based on RS Means Building Construction Data specific to each region.

Electrical power cost is estimated to be \$0.128 per kWh. The annual cost for power to a pump station is calculated based on the pumping head and volume, and includes 11,800 kWh for pump building heating, cooling, and lighting, as recommended in USEPA publication, *Standardized Costs for Water Supply Distribution Systems* (1992).

1 In addition to the cost of electricity, pump stations have other maintenance costs. These
2 costs cover: materials for minor repairs to keep the pumps operating; purchase of a
3 maintenance vehicle, fuel costs, and vehicle maintenance costs; utilities; office supplies, small
4 tools and equipment; and miscellaneous materials such as safety, clothing, chemicals, and
5 paint. The non-power O&M costs are estimated based on the USEPA publication,
6 *Standardized Costs for Water Supply Distribution Systems* (1992), which provides cost curves
7 for O&M components. Costs from the 1992 report are adjusted to 2006 dollars based on the
8 ENR construction cost index.

9 Pipeline maintenance costs include routine cleaning and flushing, as well as minor repairs
10 to lines. The unit rate for pipeline maintenance is calculated based on the USEPA technical
11 report, *Innovative and Alternate Technology Assessment Manual MCD 53* (1978). Costs from
12 the 1978 report are adjusted to 2006 dollars based on the ENR construction cost index.

13 Storage tank maintenance costs include cleaning and renewal of interior lining and exterior
14 coating. Unit costs for storage tank O&M are based on USEPA publication *Standardized Costs
15 for Water Supply Distribution Systems* (1992). Costs from the 1992 report are adjusted to 2006
16 dollars based on the ENR construction cost index.

17 The purchase price for point-of-use (POU) water treatment units is based on vendor price
18 lists for treatment units, plus installation. O&M costs for POU treatment units are also based
19 on vendor price lists. It is assumed that a yearly water sample would be analyzed for the
20 contaminant of concern.

21 The purchase price for point-of-entry (POE) water treatment units is based on vendor price
22 lists for treatment units, plus an allowance for installation, including a concrete pad and shed,
23 piping modifications, and electrical connection. O&M costs for POE treatment units are also
24 based on vendor price lists. It is assumed that a yearly water sample would be analyzed for the
25 contaminant of concern.

26 Central treatment plant costs, for both adsorption and coagulation/filtration, include pricing
27 for buildings, utilities, and site work. Costs are based on pricing given in the various R.S.
28 Means Construction Cost Data References, as well as prices obtained from similar work on
29 other projects. Pricing for treatment equipment was obtained from vendors.

30 Well installation costs are based on quotations from drillers for installation of similar depth
31 wells in the area. Well installation costs include drilling, a well pump, electrical and
32 instrumentation installation, well finishing, piping, and water quality testing. O&M costs for
33 water wells include power, materials, and labor. It is assumed that new wells located more than
34 1 mile from the intake point of an existing system would require at least one storage tank and
35 pump station.

36 Purchase price for the treatment unit dispenser is based on vendor price lists, plus an
37 allowance for installation at a centralized public location. The O&M costs are also based on
38 vendor price lists. It is assumed that weekly water samples would be analyzed for the
39 contaminant of concern.

1 Costs for bottled water delivery alternatives are based on consultation with vendors that
2 deliver residential bottled water. The cost estimate includes an initial allowance for set-up of
3 the program, and a yearly allowance for program administration.

4 The cost estimate for a public dispenser for trucked water includes the purchase price for a
5 water truck and construction of a storage tank. Annual costs include labor for purchasing the
6 water, picking up and delivering the water, truck maintenance, and water sampling and testing.
7 It is assumed the water truck would be required to make one trip per dispenser each week, and
8 that chlorine residual would be determined for each truck load.

9 **APPENDIX REFERENCES**

10 USEPA 1978. Technical Report, *Innovative and Alternate Technology Assessment Manual* MCD 53.

11 USEPA 1992. Standardized Costs for Water Supply Distribution Systems. EPA/600/R-92/009.

12

Table B.1
Summary of General Data
Midway Mobile Home Park
PWS # 1330020
General PWS Information

Service Population **17**
Total PWS Daily Water Usage **0.001 (mgd)**

Number of Connections **12**
Source **TCEQ website**

Unit Cost Data

Central Texas

General Items	Unit	Unit Cost	Central Treatment Unit Costs	Unit	Unit Cost
Treated water purchase cost	<i>See alternative</i>		<i>General</i>		
Water purchase cost (trucked)	\$/1,000 gals	\$ 1.60	Site preparation	acre	\$ 4,000
			Slab	CY	\$ 1,000
Contingency	20%	n/a	Building	SF	\$ 60
Engineering & Constr. Management	25%	n/a	Building electrical	SF	\$ 8.00
Procurement/admin (POU/POE)	20%	n/a	Building plumbing	SF	\$ 8.00
			Heating and ventilation	SF	\$ 7.00
			Fence	LF	\$ 15
Pipeline Unit Costs	Unit	Unit Cost	Paving	SF	\$ 2.00
PVC water line, Class 200, 04"	LF	\$ 27	Chlorination point	EA	\$ 2,000
Bore and encasement, 10"	LF	\$ 60			
Open cut and encasement, 10"	LF	\$ 35	Building power	kwh/yr	\$ 0.136
Gate valve and box, 04"	EA	\$ 395	Equipment power	kwh/yr	\$ 0.136
Air valve	EA	\$ 1,000	Labor, O&M	hr	\$ 40
Flush valve	EA	\$ 750	Analyses	test	\$ 200
Metal detectable tape	LF	\$ 0.15			
			<i>Ion exchange</i>		
Bore and encasement, length	Feet	200	Electrical	JOB	\$ 50,000
Open cut and encasement, length	Feet	50	Piping	JOB	\$ 20,000
Pump Station Unit Costs	Unit	Unit Cost	Ion exchange package plant	UNIT	\$ 20,000
Pump	EA	\$ 7,500	Transfer pumps (10 hp)	EA	\$ 5,000
Pump Station Piping, 04"	EA	\$ 4,000	Clean water tank	gal	\$ 1.00
Gate valve, 04"	EA	\$ 460	Regenerant tank	gal	\$ 1.50
Check valve, 04"	EA	\$ 540	Backwash tank	gal	\$ 2.00
Electrical/Instrumentation	EA	\$ 10,000	Sewer connection fee	EA	\$ 15,000
Site work	EA	\$ 2,000			
Building pad	EA	\$ 4,000	Ion exchange materials	year	\$ 1,000
Pump Building	EA	\$ 10,000	Ion exchange chemicals	year	\$ 1,000
Fence	EA	\$ 5,870	Backwash discharge to sewer	kgal/year	\$ 5.00
Tools	EA	\$ 1,000	Waste haulage truck rental	days	\$ 700
			Mileage charge	mile	\$ 1.00
Well Installation Unit Costs	Unit	Unit Cost	Waste disposal fee	kgal/yr	\$ 200
Well installation	<i>See alternative</i>				
Water quality testing	EA	\$ 1,500	<i>WRT Z-92 package</i>		
Well pump	EA	\$ 7,500	Electrical	JOB	\$ 50,000
Well electrical/instrumentation	EA	\$ 5,000	Piping	JOB	\$ 20,000
Well cover and base	EA	\$ 3,000	WRT Z-92 package plant	UNIT	\$ 52,000
Piping	EA	\$ 2,500	(Initial setup cost for WRT Z-92 package)		
Storage Tank - 5,000 gals	EA	\$ 7,025			
			WRT treated water charge	1,000 gal/yr	\$ 3.50
Electrical Power	\$/kWH	\$ 0.136			
Building Power	kWH	11,800	<i>Coagulation-filtration package</i>		
Labor	\$/hr	\$ 40	Electrical	JOB	\$ 50,000
Materials	EA	\$ 1,200	Piping	JOB	\$ 20,000
Transmission main O&M	\$/mile	\$ 200	Coagulation-Filtration Packaged Plant	UNIT	\$ 80,000
Tank O&M	EA	\$ 1,000	Backwash tank	gal	\$ 2.00
			Sewer connection fee	EA	\$ 15,000
POU/POE Unit Costs					
POU treatment unit purchase	EA	\$ 250	Coagulation-filtration materials	year	\$ 1,000
POU treatment unit installation	EA	\$ 150	Coagulation-filtration chemicals	year	\$ 1,000
POE treatment unit purchase	EA	\$ 3,000	Backwash discharge to sewer	1,000 gal/yr	\$ 5.00
POE - pad and shed, per unit	EA	\$ 2,000	Sludge truck rental	days	\$ 700
POE - piping connection, per unit	EA	\$ 1,000	Sludge truck mileage fee	miles	\$ 1.00
POE - electrical hook-up, per unit	EA	\$ 1,000	Sludge disposal fee	1,000 gal/yr	\$ 200.00
POU treatment O&M, per unit	\$/year	\$ 225			
POE treatment O&M, per unit	\$/year	\$ 1,000			
Contaminant analysis	\$/year	\$ 100			
POU/POE labor support	\$/hr	\$ 40			
Dispenser/Bottled Water Unit Costs					
Treatment unit purchase	EA	\$ 3,000			
Treatment unit installation	EA	\$ 5,000			
Treatment unit O&M	EA	\$ 500			
Administrative labor	hr	\$ 53			
Bottled water cost (inc. delivery)	gallon	\$ 1.60			
Water use, per capita per day	gpcd	1.0			
Bottled water program materials	EA	\$ 5,000			
Storage Tank - 5,000 gals	EA	\$ 7,025			
Site improvements	EA	\$ 4,000			
Potable water truck	EA	\$ 60,000			
Water analysis, per sample	EA	\$ 100			
Potable water truck O&M costs	\$/mile	\$ 1.00			

APPENDIX C
COMPLIANCE ALTERNATIVE CONCEPTUAL COST ESTIMATES

This appendix presents the conceptual cost estimates developed for the compliance alternatives. The conceptual cost estimates are given in Tables C.1 through C.14. The cost estimates are conceptual in nature (+50%/-30%), and are intended for making comparisons between compliance options and to provide a preliminary indication of possible water rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation.

Table C.1

PWS Name *Midway Mobile Home Park*
Alternative Name *Purchase water from Ingram WSC*
Alternative Number *MW-1*

Distance from Alternative to PWS (along pipe) 1.9 miles
Total PWS annual water usage 0.475 MG
Treated water purchase cost \$ 1.60 per 1,000 gals
Number of Pump Stations Needed 1
Number of feed tanks/pump sets needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	12	n/a	n/a	n/a
PVC water line, Class 200, 04"	10,266	LF	\$ 26.50	\$ 272,049
Bore and encasement, 10"	400	LF	\$ 60.00	\$ 24,000
Open cut and encasement, 10"	600	LF	\$ 35.00	\$ 21,000
Gate valve and box, 04"	2	EA	\$ 395.00	\$ 811
Air valve	2	EA	\$ 1,000.00	\$ 2,000
Flush valve	2	EA	\$ 750.00	\$ 1,540
Metal detectable tape	10,266	LF	\$ 0.15	\$ 1,540
Subtotal				\$ 322,940
<i>Pump Station(s) Installation</i>				
Pump	4	EA	\$ 7,500	\$ 30,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	8	EA	\$ 460	\$ 3,680
Check valve, 04"	4	EA	\$ 540	\$ 2,160
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 5,000 gals	2	EA	\$ 7,025	\$ 14,050
Subtotal				\$ 123,630

Subtotal of Component Costs **\$ 446,570**

Contingency 20% \$ 89,314
Design & Constr Management 25% \$ 111,642

TOTAL CAPITAL COSTS **\$ 647,526**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	1.9	mile	\$ 200	\$ 389
Subtotal				\$ 389
<i>Water Purchase Cost</i>				
From Source	475	1,000 gal	\$ 1.60	\$ 759
Subtotal				\$ 759
<i>Pump Station(s) O&M</i>				
Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	498	kWH	\$ 0.136	\$ 68
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 40	\$ 29,200
Tank O&M	2	EA	\$ 1,000	\$ 2,000
Subtotal				\$ 36,877

O&M Credit for Existing Well Closure

Pump power	60	kWH	\$ 0.136	\$ (8)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (8,408)

TOTAL ANNUAL O&M COSTS **\$ 29,617**

Table C.2

PWS Name *Midway Mobile Home Park*
Alternative Name *New well at Sleepy Hollow*
Alternative Number *MW-2*

Distance from PWS to new well location 2.34 miles
Estimated well depth 650 feet
Number of wells required 1
Well installation cost (location specific) \$25 per foot
Number of pump stations needed 1
Number of feed tanks/pump sets needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	13	n/a	n/a	n/a
PVC water line, Class 200, 04"	12,378	LF	\$ 26.50	\$ 328,017
Bore and encasement, 10"	400	LF	\$ 60.00	\$ 24,000
Open cut and encasement, 10"	650	LF	\$ 35.00	\$ 22,750
Gate valve and box, 04"	2	EA	\$ 395.00	\$ 978
Air valve	2	EA	\$ 1,000.00	\$ 2,000
Flush valve	2	EA	\$ 750.00	\$ 1,857
Metal detectable tape	12,378	LF	\$ 0.15	\$ 1,857
Subtotal				\$ 381,458
<i>Pump Station(s) Installation</i>				
Pump	4	EA	\$ 7,500	\$ 30,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	8	EA	\$ 460	\$ 3,680
Check valve, 04"	4	EA	\$ 540	\$ 2,160
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 5,000 gals	2	EA	\$ 7,025	\$ 14,050
Subtotal				\$ 123,630
<i>Well Installation</i>				
Well installation	650	LF	\$ 25	\$ 16,250
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
Subtotal				\$ 37,250

Subtotal of Component Costs **\$ 542,338**

Contingency 20% \$ 108,468
Design & Constr Management 25% \$ 135,585

TOTAL CAPITAL COSTS **\$ 786,390**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	2.3	mile	\$ 200	\$ 469
Subtotal				\$ 469
<i>Pump Station(s) O&M</i>				
Building Power	23,600	KWH	\$ 0.136	\$ 3,210
Pump Power	412	KWH	\$ 0.136	\$ 56
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 40	\$ 29,200
Tank O&M	2	EA	\$ 1,000	\$ 2,000
Subtotal				\$ 36,866
<i>Well O&M</i>				
Pump power	108	KWH	\$ 0.136	\$ 15
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 40	\$ 7,200
Subtotal				\$ 8,415
<i>O&M Credit for Existing Well Closure</i>				
Pump power	60	KWH	\$ 0.136	\$ (8)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (8,408)

TOTAL ANNUAL O&M COSTS **\$ 37,341**

Table C.3

PWS Name *Midway Mobile Home Park*
Alternative Name *Purchase water from City of Kerrville*
Alternative Number *MW-3*

Distance from Alternative to PWS (along pipe) 0.1 miles
Total PWS annual water usage 0.475 MG
Treated water purchase cost \$ 1.60 per 1,000 gals
Number of Pump Stations Needed 1
Number of feed tanks/pump sets needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	-	n/a	n/a	n/a
PVC water line, Class 200, 04"	500	LF	\$ 26.50	\$ 13,250
Bore and encasement, 10"	200	LF	\$ 60.00	\$ 12,000
Open cut and encasement, 10"	-	LF	\$ 35.00	\$ -
Gate valve and box, 04"	0	EA	\$ 395.00	\$ 40
Air valve	1	EA	\$ 1,000.00	\$ 1,000
Flush valve	0	EA	\$ 750.00	\$ 75
Metal detectable tape	500	LF	\$ 0.15	\$ 75
Subtotal				\$ 26,440
<i>Pump Station(s) Installation</i>				
Pump	4	EA	\$ 7,500	\$ 30,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	8	EA	\$ 460	\$ 3,680
Check valve, 04"	4	EA	\$ 540	\$ 2,160
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 5,000 gals	2	EA	\$ 7,025	\$ 14,050
Subtotal				\$ 123,630

Subtotal of Component Costs **\$ 150,070**

Contingency 20% \$ 30,014
Design & Constr Management 25% \$ 37,517

TOTAL CAPITAL COSTS **\$ 217,601**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	0.1	mile	\$ 200	\$ 19
Subtotal				\$ 19
<i>Water Purchase Cost</i>				
From Source	475	1,000 gal	\$ 1.60	\$ 759
Subtotal				\$ 759
<i>Pump Station(s) O&M</i>				
Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	203	kWH	\$ 0.136	\$ 28
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 40	\$ 29,200
Tank O&M	2	EA	\$ 1,000	\$ 2,000
Subtotal				\$ 36,837

O&M Credit for Existing Well Closure

Pump power	60	kWH	\$ 0.136	\$ (8)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (8,408)

TOTAL ANNUAL O&M COSTS **\$ 29,207**

Table C.4

PWS Name *Midway Mobile Home Park*
Alternative Name *New Well at 10 Miles*
Alternative Number *MW-4*

Distance from PWS to new well location 10.0 miles
Estimated well depth 500 feet
Number of wells required 1
Well installation cost (location specific) \$25 per foot
Number of pump stations needed 1
Number of feed tanks/pump sets needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	11	n/a	n/a	n/a
Number of Crossings, open cut	57	n/a	n/a	n/a
PVC water line, Class 200, 04"	52,800	LF	\$ 26.50	\$ 1,399,200
Bore and encasement, 10"	2,200	LF	\$ 60.00	\$ 132,000
Open cut and encasement, 10"	2,850	LF	\$ 35.00	\$ 99,750
Gate valve and box, 04"	11	EA	\$ 395.00	\$ 4,171
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	11	EA	\$ 750.00	\$ 7,920
Metal detectable tape	52,800	LF	\$ 0.15	\$ 7,920
Subtotal				\$ 1,661,961
<i>Pump Station(s) Installation</i>				
Pump	4	EA	\$ 7,500	\$ 30,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	8	EA	\$ 460	\$ 3,680
Check valve, 04"	4	EA	\$ 540	\$ 2,160
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 5,000 gals	2	EA	\$ 7,025	\$ 14,050
Subtotal				\$ 123,630
<i>Well Installation</i>				
Well installation	500	LF	\$ 25	\$ 12,500
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
Subtotal				\$ 33,500

Subtotal of Component Costs **\$ 1,819,091**

Contingency 20% \$ 363,818
Design & Constr Management 25% \$ 454,773

TOTAL CAPITAL COSTS **\$ 2,637,682**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	10.0	mile	\$ 200	\$ 2,000
Subtotal				\$ 2,000
<i>Pump Station(s) O&M</i>				
Building Power	23,600	KWH	\$ 0.136	\$ 3,210
Pump Power	2,539	KWH	\$ 0.136	\$ 345
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 40	\$ 29,200
Tank O&M	2	EA	\$ 1,000	\$ 2,000
Subtotal				\$ 37,155
<i>Well O&M</i>				
Pump power	83	KWH	\$ 0.136	\$ 11
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 40	\$ 7,200
Subtotal				\$ 8,411
<i>O&M Credit for Existing Well Closure</i>				
Pump power	60	KWH	\$ 0.136	\$ (8)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (8,408)

TOTAL ANNUAL O&M COSTS **\$ 39,158**

Table C.5

PWS Name *Midway Mobile Home Park*
Alternative Name *New Well at 5 Miles*
Alternative Number *MW-5*

Distance from PWS to new well location 5.0 miles
Estimated well depth 500 feet
Number of wells required 1
Well installation cost (location specific) \$25 per foot
Number of pump stations needed 1
Number of feed tanks/pump sets needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	6	n/a	n/a	n/a
Number of Crossings, open cut	29	n/a	n/a	n/a
PVC water line, Class 200, 04"	26,400	LF	\$ 26.50	\$ 699,600
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	100	LF	\$ 35.00	\$ 3,500
Gate valve and box, 04"	5	EA	\$ 395.00	\$ 2,086
Air valve	6	EA	\$ 1,000.00	\$ 6,000
Flush valve	5	EA	\$ 750.00	\$ 3,960
Metal detectable tape	26,400	LF	\$ 0.15	\$ 3,960
Subtotal				\$ 827,106
<i>Pump Station(s) Installation</i>				
Pump	4	EA	\$ 7,500	\$ 30,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	8	EA	\$ 460	\$ 3,680
Check valve, 04"	4	EA	\$ 540	\$ 2,160
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 5,000 gals	2	EA	\$ 7,025	\$ 14,050
Subtotal				\$ 123,630
<i>Well Installation</i>				
Well installation	500	LF	\$ 25	\$ 12,500
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
Subtotal				\$ 33,500

Subtotal of Component Costs **\$ 984,236**

Contingency 20% \$ 196,847
Design & Constr Management 25% \$ 246,059

TOTAL CAPITAL COSTS **\$ 1,427,142**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	5.0	mile	\$ 200	\$ 1,000
Subtotal				\$ 1,000
<i>Pump Station(s) O&M</i>				
Building Power	23,600	KWH	\$ 0.136	\$ 3,210
Pump Power	1,270	KWH	\$ 0.136	\$ 173
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 40	\$ 29,200
Tank O&M	2	EA	\$ 1,000	\$ 2,000
Subtotal				\$ 36,982
<i>Well O&M</i>				
Pump power	83	KWH	\$ 0.136	\$ 11
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 40	\$ 7,200
Subtotal				\$ 8,411

<i>O&M Credit for Existing Well Closure</i>				
Pump power	60	KWH	\$ 0.136	\$ (8)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (8,408)

TOTAL ANNUAL O&M COSTS **\$ 37,985**

Table C.6

PWS Name *Midway Mobile Home Park*
Alternative Name *New Well at 1 Mile*
Alternative Number *MW-6*

Distance from PWS to new well location 1.0 miles
Estimated well depth 500 feet
Number of wells required 1
Well installation cost (location specific) \$25 per foot
Number of pump stations needed 0
Number of feed tanks/pump sets needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	6	n/a	n/a	n/a
PVC water line, Class 200, 04"	5,280	LF	\$ 26.50	\$ 139,920
Bore and encasement, 10"	200	LF	\$ 60.00	\$ 12,000
Open cut and encasement, 10"	300	LF	\$ 35.00	\$ 10,500
Gate valve and box, 04"	1	EA	\$ 395.00	\$ 417
Air valve	1.00	EA	\$ 1,000.00	\$ 1,000
Flush valve	1	EA	\$ 750.00	\$ 792
Metal detectable tape	5,280	LF	\$ 0.15	\$ 792
Subtotal				\$ 165,421
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 460	\$ 1,840
Check valve, 04"	2	EA	\$ 540	\$ 1,080
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 61,815
<i>Well Installation</i>				
Well installation	500	LF	\$ 25	\$ 12,500
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
Subtotal				\$ 33,500

Subtotal of Component Costs **\$ 260,736**

Contingency 20% \$ 52,147
Design & Constr Management 25% \$ 65,184

TOTAL CAPITAL COSTS **\$ 378,067**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	1.0	mile	\$ 200	\$ 200
Subtotal				\$ 200
<i>Pump Station(s) O&M</i>				
Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	-	kWH	\$ 0.136	\$ -
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 40	\$ 14,600
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 18,405
<i>Well O&M</i>				
Pump power	83	kWH	\$ 0.136	\$ 11
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 40	\$ 7,200
Subtotal				\$ 8,411
<i>O&M Credit for Existing Well Closure</i>				
Pump power	60	kWH	\$ 0.136	\$ (8)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (8,408)

TOTAL ANNUAL O&M COSTS **\$ 18,608**

Table C.7

PWS Name *Midway Mobile Home Park*
Alternative Name *Central Treatment - Ion Exchange*
Alternative Number *MW-7*

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Ion Exchange Unit Purchase/Installation</i>				
Site preparation	0.75	acre	\$ 4,000	\$ 3,000
Slab	30	CY	\$ 1,000	\$ 30,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8	\$ 3,200
Building plumbing	400	SF	\$ 8	\$ 3,200
Heating and ventilation	400	SF	\$ 7	\$ 2,800
Fence	600	LF	\$ 15	\$ 9,000
Paving	3,200	SF	\$ 2	\$ 6,400
Electrical	1	JOB	\$ 50,000	\$ 50,000
Piping	1	JOB	\$ 20,000	\$ 20,000
Ion exchange package including:				
Regeneration system				
Brine tank				
IX resins & FRP vessels	1	UNIT	\$ 20,000	\$ 20,000
Transfer pumps (10 hp)	2	EA	\$ 5,000	\$ 10,000
Clean water tank	5,000	gal	\$ 1.00	\$ 5,000
Regenerant tank	2,000	gal	\$ 1.50	\$ 3,000
Backwash Tank	6,000	gal	\$ 2.00	\$ 12,000
Storage tank	5,000	gal	\$ 3	\$ 15,000
Sewer Connection Fee	-	EA	\$ 15,000	\$ -
Subtotal of Component Costs				\$ 216,600
Contingency	20%		\$	43,320
Design & Constr Management	25%		\$	54,150
TOTAL CAPITAL COSTS			\$ 314,070	

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Ion Exchange Unit O&M</i>				
Building Power	12,000	kwh/yr	\$ 0.136	\$ 1,632
Equipment power	10,000	kwh/yr	\$ 0.136	\$ 1,360
Labor	400	hrs/yr	\$ 40	\$ 16,000
Materials	1	year	\$ 1,000	\$ 1,000
Chemicals	1	year	\$ 1,000	\$ 1,000
Analyses	24	test	\$ 200	\$ 4,800
Backwash discharge disposal	1	kgal/yr	\$ 200	\$ 200
Subtotal				\$ 25,992
<i>Haul Regenerant Waste and Brine</i>				
Waste haulage truck rental	5	days	\$ 700	\$ 3,500
Mileage charge	240	miles	\$ 1.00	\$ 240
Waste disposal	6	kgal/yr	\$ 200.	\$ 1,200
Subtotal				\$ 4,940
TOTAL ANNUAL O&M COSTS			\$ 30,932	

Table C.8

PWS Name *Midway Mobile Home Park*
Alternative Name *Central Treatment - WRT Z-92*
Alternative Number *MW-8*

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Coagulation/Filtration Unit Purchase/Installation</i>				
Site preparation	0.75	acre	\$ 4,000	\$ 3,000
Slab	30	CY	\$ 1,000	\$ 30,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8	\$ 3,200
Building plumbing	400	SF	\$ 8	\$ 3,200
Heating and ventilation	400	SF	\$ 7	\$ 2,800
Fence	600	LF	\$ 15	\$ 9,000
Paving	1,600	SF	\$ 2	\$ 3,200
Electrical	1	JOB	\$ 50,000	\$ 50,000
Piping	1	JOB	\$ 20,000	\$ 20,000

WRT Z-88 package including:

Z-88 vessels

Adsorption media 1 UNIT \$ 52,000 \$ 52,000

(Initial Setup Cost for WRT Z-92 package plant)

Subtotal of Component Costs \$ 200,400

Contingency 20% \$ 40,080

Design & Constr Management 25% \$ 50,100

TOTAL CAPITAL COSTS \$ 290,580

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Coagulation/Filtration Unit O&M</i>				
Building Power	6,000	kwh/yr	\$ 0.136	\$ 816
Equipment power	5,000	kwh/yr	\$ 0.136	\$ 680
Labor	400	hrs/yr	\$ 40	\$ 16,000
Analyses	24	test	\$ 200	\$ 4,800
WRT treated water charge	730	kgal/yr	\$ 3.50	\$ 2,555
Subtotal				\$ 24,851

TOTAL ANNUAL O&M COSTS \$ 24,851

Table C.9

PWS Name *Midway Mobile Home Park*
Alternative Name *Central Treatment - Coagulation/Filtration*
Alternative Number *MW-9*

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Coagulation/Filtration Unit Purchase/Installation</i>				
Site preparation	0.75	acre	\$ 4,000	\$ 3,000
Slab	30	CY	\$ 1,000	\$ 30,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8	\$ 3,200
Building plumbing	400	SF	\$ 8	\$ 3,200
Heating and ventilation	400	SF	\$ 7	\$ 2,800
Fence	600	LF	\$ 15	\$ 9,000
Paving	1,600	SF	\$ 2	\$ 3,200
Electrical	1	JOB	\$ 45,000	\$ 45,000
Piping	1	JOB	\$ 15,000	\$ 15,000
Coagulant/filter package including:				
Chemical feed system				
Pressure ceramic filters				
Controls & Instruments	1	UNIT	\$ 80,000	\$ 80,000
Backwash Tank	9,000	GAL	\$ 2	\$ 18,000
Coagulant Tank	200	GAL	\$ 3	\$ 600
Storage tank	5,000	gal	\$ 3	\$ 15,000
Sewer Connection Fee	-	EA	\$ 15,000	\$ -
Chlorination Point	1	EA	\$ 2,000	\$ 2,000
Subtotal of Component Costs			\$	254,000
Contingency	20%		\$	50,800
Design & Constr Management	25%		\$	63,500
TOTAL CAPITAL COSTS			\$	368,300

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Coagulation/Filtration Unit O&M</i>				
Building Power	9,000	kwh/yr	\$ 0.136	\$ 1,224
Equipment power	1,000	kwh/yr	\$ 0.136	\$ 136
Labor	500	hrs/yr	\$ 40	\$ 20,000
Materials	1	year	\$ 1,000	\$ 1,000
Chemicals	1	year	\$ 1,000	\$ 1,000
Analyses	24	test	\$ 200	\$ 4,800
Backwash discharge disposal	10.0	kgal/yr	\$ 200	\$ 2,000
Subtotal			\$	30,160
<i>Haul Regenerant Waste and Brine</i>				
Waste haulage truck rental	5	days	\$ 700	\$ 3,500
Mileage charge	240	miles	\$ 1.00	\$ 240
Subtotal			\$	3,740
TOTAL ANNUAL O&M COSTS			\$	33,900

Table C.10

PWS Name *Midway Mobile Home Park*
Alternative Name *Point-of-Use Treatment*
Alternative Number *MW-10*

Number of Connections for POU Unit Installation 12

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>POU-Treatment - Purchase/Installation</i>				
POU treatment unit purchase	12	EA	\$ 250	\$ 3,000
POU treatment unit installation	12	EA	\$ 150	\$ 1,800
Subtotal				\$ 4,800
Subtotal of Component Costs				\$ 4,800
Contingency	20%		\$	960
Design & Constr Management	25%		\$	1,200
Procurement & Administration	20%		\$	960
TOTAL CAPITAL COSTS			\$	7,920

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>O&M</i>				
POU materials, per unit	12	EA	\$ 225	\$ 2,700
Contaminant analysis, 1/yr per unit	12	EA	\$ 100	\$ 1,200
Program labor, 10 hrs/unit	120	hrs	\$ 40	\$ 4,800
Subtotal				\$ 8,700
TOTAL ANNUAL O&M COSTS				\$ 8,700

Table C.11

PWS Name *Midway Mobile Home Park*
Alternative Name *Point-of-Entry Treatment*
Alternative Number *MW-11*

Number of Connections for POE Unit Installation 12

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>POE-Treatment - Purchase/Installation</i>				
POE treatment unit purchase	12	EA	\$ 3,000	\$ 36,000
Pad and shed, per unit	12	EA	\$ 2,000	\$ 24,000
Piping connection, per unit	12	EA	\$ 1,000	\$ 12,000
Electrical hook-up, per unit	12	EA	\$ 1,000	\$ 12,000
Subtotal				\$ 84,000

Subtotal of Component Costs **\$ 84,000**

Contingency	20%	\$ 16,800
Design & Constr Management	25%	\$ 21,000
Procurement & Administration	20%	\$ 16,800

TOTAL CAPITAL COSTS **\$ 138,600**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>O&M</i>				
POE materials, per unit	12	EA	\$ 1,000	\$ 12,000
Contaminant analysis, 1/yr per unit	12	EA	\$ 100	\$ 1,200
Program labor, 10 hrs/unit	120	hrs	\$ 40	\$ 4,800
Subtotal				\$ 18,000

TOTAL ANNUAL O&M COSTS **\$ 18,000**

Table C.12

PWS Name *Midway Mobile Home Park*
Alternative Name *Public Dispenser for Treated Drinking Water*
Alternative Number *MW-12*

Number of Treatment Units Recommended 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Public Dispenser Unit Installation</i>				
POE-Treatment unit(s)	1	EA	\$ 3,000	\$ 3,000
Unit installation costs	1	EA	\$ 5,000	\$ 5,000
Subtotal				\$ 8,000
Subtotal of Component Costs				\$ 8,000
Contingency	20%			\$ 1,600
Design & Constr Management	25%			\$ 2,000
TOTAL CAPITAL COSTS				11,600

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Treatment unit O&M, 1 per unit	1	EA	\$ 500	\$ 500
Contaminant analysis, 1/wk per u	52	EA	\$ 100	\$ 5,200
Sampling/reporting, 1 hr/day	365	HRS	\$ 40	\$ 14,600
Subtotal				\$ 20,300
TOTAL ANNUAL O&M COSTS				\$ 20,300

Table C.13

PWS Name *Midway Mobile Home Park*
Alternative Name *Supply Bottled Water to Population*
Alternative Number *MW-13*

Service Population 17
Percentage of population requiring supply 100%
Water consumption per person 1.00 gpcd
Calculated annual potable water needs 6,205 gallons

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Implementation</i>				
Initial program set-up	500	hours	\$ 53	\$ 26,600
Subtotal				\$ 26,600
Subtotal of Component Costs				\$ 26,600
Contingency	20%			\$ 5,320
TOTAL CAPITAL COSTS				\$ 31,920

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water purchase costs	6,205	gals	\$ 1.60	\$ 9,928
Program admin, 9 hrs/wk	468	hours	\$ 53	\$ 24,898
Program materials	1	EA	\$ 5,000	\$ 5,000
Subtotal				\$ 39,826
TOTAL ANNUAL O&M COSTS				\$ 39,826

Table C.14

PWS Name *Midway Mobile Home Park*
Alternative Name *Central Trucked Drinking Water*
Alternative Number *MW-14*

Service Population 17
Percentage of population requiring supply 100%
Water consumption per person 1.00 gpcd
Calculated annual potable water needs 6,205 gallons
Travel distance to compliant water source (roundtrip) 5 miles

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Storage Tank Installation</i>				
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Site improvements	1	EA	\$ 4,000	\$ 4,000
Potable water truck	1	EA	\$ 60,000	\$ 60,000
Subtotal				\$ 71,025
Subtotal of Component Costs				\$ 71,025
Contingency	20%		\$	14,205
Design & Constr Management	25%		\$	17,756
TOTAL CAPITAL COSTS			\$	102,986

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water delivery labor, 4 hrs/wk	208	hrs	\$ 40	\$ 8,320
Truck operation, 1 round trip/wk	260	miles	\$ 1.00	\$ 260
Water purchase	6	1,000 gals	\$ 1.60	\$ 10
Water testing, 1 test/wk	52	EA	\$ 100	\$ 5,200
Sampling/reporting, 2 hrs/wk	104	hrs	\$ 40	\$ 4,160
Subtotal				\$ 17,950
TOTAL ANNUAL O&M COSTS				\$ 17,950

1
2

**APPENDIX D
EXAMPLE FINANCIAL MODEL**

Table D.1 Example Financial Model

Water System	Midway
Funding Alternative	Bond
Alternative Description	New well at Sleepy Hollow

Sum of Amount		Year																							
Group	Type	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025		
Capital Expenditures	Capital Expenditures-Funded from	\$ -	\$ -	\$ -	\$ 786,390	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
	Capital Expenditures-Funded from	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
	Capital Expenditures-Funded from	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
	Capital Expenditures-Funded from	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
Capital Expenditures Sum		\$ -	\$ -	\$ -	\$ 786,390	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
Debt Service	Revenue Bonds				\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517		
	State Revolving Funds				\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
Debt Service Sum					\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517	\$ 61,517		
Operating Expenditures	Chemicals, Treatment		\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300	\$ 300		
	Contract Labor		\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200	\$ 1,200		
	Repairs		\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900	\$ 900		
	Supplies		\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400		
	Utilities		\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450	\$ 450		
	O&M Associated with Alternative				\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341	\$ 37,341		
	Maintenance		\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650	\$ 650		
Operating Expenditures Sum			\$ 3,900	\$ 3,900	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241	\$ 41,241		
Residential Operating Revenues	Residential Base Monthly Rate		\$ 1,710	\$ 1,710	\$ 69,907	\$ 178,328	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552		
	Residential Tier 1 Monthly Rate		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
	Residential Tier2 Monthly Rate		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
	Residential Tier3 Monthly Rate		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
	Residential Tier4 Monthly Rate		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
	Residential Unmetered Monthly Rate		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	
Residential Operating Revenues Sum			\$ 1,710	\$ 1,710	\$ 69,907	\$ 178,328	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552	\$ 218,552		

Location_Name	Midway
Alt_Desc	New well at Sleepy Hollow

[illegible]

APPENDIX E RADIONUCLIDE GEOCHEMISTRY

Radionuclide impact on water quality is measured according to two scales: intrinsic measurement of radioactivity and impact on human beings. Activity or number of disintegrations per unit time is typically measured in picoCuries (pCi), whereas impact on living organisms is measured in mrem. Radioactive decay can generate alpha or beta particles, as well as gamma rays. Two radioactive elements with the same activity may have vastly different impacts on life, depending on the energy released during decay. Each radionuclide has a conversion factor from pCi to mrem as a function of exposure pathway. Activity is related to contaminant concentration and half-life. A higher concentration and a shorter half-life lead to increased activity. Given the ratio of the half-life of each (Table E.1), it is apparent that radium is approximately 1 million times more radioactive than uranium. Concentrations of gross alpha and beta emitters take into account the whole decay series and not just uranium and radium, as well as other elements such as K 40.

Uranium and thorium (atomic numbers 92 and 90, respectively), both radium sources, are common trace elements and have a crustal abundance of 2.6 and 10 ppm, respectively. They are abundant in acidic rock. A study of the Cambrian aquifers in the Llano Uplift area suggests an average whole-rock concentration of 4 and 14 ppm for uranium and thorium, respectively (Kim, *et al.* 1995). Uranium and thorium do not fit readily into the structure of rock-forming minerals and are concentrated in melt during the series of fractionations leading to major rock types (acidic, intermediate, basic). Intrusive rock such as granite will partly sequester uranium and thorium in erosion-resistant accessory minerals (*e.g.*, monazite, thorite), whereas uranium in volcanic rock is much more labile and can be leached by surface and groundwater. Lattice substitution in minerals (*e.g.*, Ca^{+2} and U^{+4} , have almost the same ionic radius), as well as micrograins of uranium and thorium minerals, are other possibilities. In sedimentary rock, uranium and thorium aqueous concentrations are controlled mainly by the sorbing potential of the rock (metal oxide, clay, and organic matter). In the Cambrian aquifers of Central Texas, uranium concentrations are high in accessory minerals and cannot readily be mobilized. Uranium is also present in phosphatic and hematitic cements (Kim, *et al.* 1995), with which the aqueous concentration is most likely in equilibrium.

The geochemistry of uranium is complicated but can be summarized by the following. Uranium(VI) in oxidizing conditions exists as the soluble positively charged uranyl UO_2^{+2} . Solubility is higher at acid pHs, decreases at neutral pHs, and increases at alkaline pHs. The uranyl ion can easily form aqueous complexes, including with hydroxyl, fluoride, carbonate, and phosphate ligands. Hence, in the presence of carbonates, uranium solubility is considerably enhanced in the form of uranyl-carbonate (UO_2CO_3) and other higher order carbonate complexes: uranyl-di-carbonate ($\text{UO}_2(\text{CO}_3)_2^{-2}$ and uranyl-tri-carbonates $\text{UO}_2(\text{CO}_3)_3^{-4}$). Adsorption of uranium is inversely related to its solubility and is highest at neutral pH's (De Soto 1978). Uranium sorbs strongly to metal oxide and clay. Uranium(IV) is the other commonly found redox state. In that state, however, uranium is not very soluble and precipitates as uranite, UO_2 , coffinite, $\text{USiO}_4 \cdot n\text{H}_2\text{O}$ (if $\text{SiO}_2 > 60 \text{ mg/L}$, Henry, *et al.* 1982), or related minerals. In most aquifers, no mineral controls uranium solubility in oxidizing

conditions. However, uranite and coffinite are the controlling minerals if Eh drops below 0-100 mV.

Thorium exists naturally only in one redox state Th(IV). Th^{+4} forms complexes with most common aqueous anions. However, thorium solubility remains low except perhaps at higher pH when complexed by carbonate ions (USEPA 1999). Thorium sorbs strongly to metal oxides in a way similar to uranium.

Radium has an atomic number of 88. Radium originates from the radioactive decay of uranium and thorium. Ra226 is an intermediate product of U238 (the most common uranium isotope >99%, Table A-1) decay, whereas Ra228 belongs to the Th232 (~100% of natural thorium) decay series. Both radium isotopes further decay to radon and, ultimately, to lead. Radon is a gas and tends to volatilize from shallower units. Ra223 and Ra224 isotopes are also naturally present but in minute quantities. Ra224 belongs to the thorium decay series, whereas Ra223 derives from the much rarer U235 (~0.7%). Radium is an alkaline Earth element and belongs to the same group (2A in periodic table) as magnesium, calcium, strontium, and barium. It most resembles barium chemically, as evidenced by removal technologies such as ion exchange with Na and lime softening. Sorption on iron and manganese oxides is also a common trait of alkaline Earth elements. Radium exists only under one oxidation state, the divalent cation Ra^{+2} , similar to other alkaline Earth elements (Ca^{+2} , Mg^{+2} , Sr^{+2} , and Ba^{+2}). RaSO_4 is extremely insoluble (more so than barium sulfate), with a log K solubility product of -10.5, compared to that of barium sulfate at ~-10. Radium solubility is mostly controlled by sulfate activity.

Table E.1 Uranium, Thorium, and Radium Abundance and Half-Lives

Decay series	Uranium/thorium	Radium	Radon
U238	U238 – ~99.3% (4.47×10^9 yrs)	Ra226 - (1,599 yrs)	Rn222 - (3.8 days)
	U234 – 0.0055% (0.246×10^9 yrs)	Intermediate product of U238 decay	
U235	U235 - ~0.7% (0.72×10^9 yrs)	Ra223 – (11.4 days)	Rn219 - (4 seconds)
Th232	Th232 – ~100% (14.0×10^9 yrs)	Ra228 - (5.76 yrs) Ra224 - (3.7 days)	Rn220 - (~1 min)

NOTE: half-life from Parrington et al. (1996)

USEPA Maximum Contaminant Levels

- Uranium: 30 ppb
- Gross alpha : 15 pCi/L
- Beta particles and photon emitters: 4 mrem/yr
- Radium 226 and radium 228: 5 pCi/L

APPENDIX E REFERENCES:

- Bluntzer, Robert L. 1992. Evaluation of Ground-Water Resources of the Paleozoic and Cretaceous Aquifers in the Hill Country of Central Texas, Texas Water Development Board Report 339, 130 p. + Appendices <http://www.twdb.state.tx.us/publications/reports/GroundWaterReports/GWReports/GWreports.asp>
- De Soto, R.H. 1978. Uranium geology and exploration: lecture notes and references: Golden, CO, Colorado School of Mines, March, 396 p.
- USEPA 1999. Understanding variations in partition coefficients, K_d values. Environment Protection Agency report EPA-402-R-99-004A, August 1999, Volume II: Review of geochemistry and available K_d values for cadmium, cesium, chromium, lead, plutonium, radon, strontium, thorium, tritium (³H), and uranium. Variously paginated.
- Henry, C.D., W.E. Galloway, G.E. Smith, C.L. Ho, J.P. Morton, and J.K. Gluck 1982. Geochemistry of ground water in the Miocene Oakville sandstone – A major aquifer and uranium host of the Texas coastal plain. The University of Texas at Austin, Bureau of Economic Geology Report of Investigations No. 118. 63p.
- Kim, Y, T.T. Tieh, and E.B. Ledger 1995. Aquifer mineralogy and natural radionuclides in groundwater—the lower Paleozoic of Central Texas: Gulf Coast Association of Geological Societies Transactions, Vol. XLV.
- Parrington, J.R., H.E. Knox, S.L. Breneman, E.M. Baum, and F. Feiner 1996. Nuclides and Isotopes, Chart of the Nuclides. 15th Edition. San Jose, California: General Electric Company and KAPL, Inc.