

# DRAFT FEASIBILITY REPORT FEASIBILITY ANALYSIS OF WATER SUPPLY FOR SMALL PUBLIC WATER SYSTEMS

ORBIT SYSTEMS, INC. – SANDY MEADOW ESTATES SUBDIVISION  
PWS ID# 0200335, CCN# 11982

*Prepared for:*

**THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY**



*Prepared by:*

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC GEOLOGY**

**AND**

**PARSONS**

*Preparation of this report was financed by the Texas Commission on Environmental Quality through the Drinking Water State Revolving Fund Small Systems Assistance Program*

**AUGUST 2005**

**DRAFT FEASIBILITY REPORT**

**FEASIBILITY ANALYSIS OF WATER SUPPLY  
FOR SMALL PUBLIC WATER SYSTEMS**

**Orbit Systems, Inc. – Sandy Meadow  
Estates Subdivision  
PWS ID# 0200335, CCN# 11982**

*Prepared for:*

**THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY**

*Prepared by:*

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC  
GEOLOGY**

**AND**

**PARSONS**

***PREPARATION OF THIS REPORT WAS FINANCED BY THE TEXAS COMMISSION  
ON ENVIRONMENTAL QUALITY THROUGH THE DRINKING WATER STATE  
REVOLVING FUND SMALL SYSTEMS ASSISTANCE PROGRAM***

THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF INTERIM REVIEW UNDER THE  
AUTHORITY OF ERIC J. DAWSON, P.E. 79564 ON AUGUST 31, 2005. IT IS NOT TO BE USED  
FOR CONSTRUCTION, BIDDING, OR PERMIT PURPOSES.

**August 2005**

1

## EXECUTIVE SUMMARY

2

### INTRODUCTION

3

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Infrastructure and Technology Group Inc. (Parsons), were contracted by the Texas Commission on Environmental Quality (TCEQ) to conduct a study to assist with identifying and analyzing alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

8

The overall goal of this project was to promote compliance using sound engineering and financial methods and data for PWSs that had recently recorded sample results exceeding maximum contaminant levels (MCL). The primary objectives of this project were to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS for future implementation.

10

11

12

13

14

15

This feasibility report provides an evaluation of water supply alternatives for the Sandy Meadow Estates PWS, located in Brazoria County. Samples for arsenic were below the previous MCL for arsenic of 50 micrograms per liter ( $\mu\text{g/L}$ ), which was the MCL for arsenic at the time of sample collection; however, the arsenic concentrations were above the 10  $\mu\text{g/L}$  MCL for arsenic effective beginning January 23, 2006 (USEPA 2005a; TCEQ 2004a). Therefore, it was likely that the Sandy Meadow Estates PWS would face potential compliance issues under the new arsenic drinking water standard.

16

17

18

19

20

21

22

23

Basic system information for the Sandy Meadow Estates PWS is shown in Table ES.1.

24

25

26

27

**Table ES.1**  
**Sandy Meadow Estates PWS**  
**Basic System Information**

Population served	170
Connections	56
Average daily flow rate	0.016 million gallons per day (mgd)
Water system peak capacity	0.154 mgd
Typical arsenic range	16.9 to 20.1 $\mu\text{g/L}$

1 **STUDY METHODS**

2 The methods used for this study were based on a pilot study performed in 2004 and  
3 2005 by TCEQ, BEG, and Parsons. Methods for identifying and analyzing compliance  
4 options were developed in the pilot study (a decision tree approach).

5 The process for developing the feasibility study used the following general steps:

- 6 1. Gather data from the TCEQ and Texas Water Development Board  
7 databases, from TCEQ files, and from information maintained by the  
8 PWS;
- 9 2. Conduct financial, managerial, and technical (FMT) evaluations of the  
10 PWS;
- 11 3. Perform a geologic and hydrogeologic assessment of the study area;
- 12 4. Develop treatment and non-treatment compliance alternatives which, in  
13 general, consist of the following possible options:
  - 14 a. Connecting to neighboring PWSs via new pipeline or by pumping  
15 water from a newly installed well or an available surface water  
16 supply within the jurisdiction of the neighboring PWS;
  - 17 b. Installing new wells within the vicinity of the PWS into other  
18 aquifers with confirmed water quality standards meeting the  
19 MCLs;
  - 20 c. Installing a new intake system within the vicinity of the PWS to  
21 obtain water from a surface water supply with confirmed water  
22 quality standards meeting the MCLs;
  - 23 d. Treating the existing non-compliant water supply by various  
24 methods depending on the type of contaminant; and
  - 25 e. Delivering potable water by way of a bottled water program or a  
26 treated water dispenser as an interim measure only.
- 27 5. Assess each of the potential alternatives with respect to economic and  
28 non-economic criteria; and
- 29 6. Prepare a feasibility report and present the results to the PWS.


30 This basic approach is summarized in Figure ES-1.

31 **HYDROGEOLOGICAL ANALYSIS**

32 The Sandy Meadow Estates PWS obtains groundwater from the Chicot subunit of  
33 the Gulf Coast aquifer. Arsenic is commonly found in area wells at concentrations  
34 greater than the MCL. Volcanic ash incorporated into the aquifer material may be the  
35 source of arsenic. Arsenic concentrations can vary significantly over relatively short  
36 distances; as a  
37

1  
2

**Figure ES-1**  
**Summary of Project Methods**



1 result, there could be good quality groundwater nearby. However, the variability of  
2 arsenic concentrations makes it difficult to determine where wells can be located to  
3 produce acceptable water. Additionally, systems with more than one well should  
4 characterize the water quality of each well. If one of the wells is found to produce  
5 compliant water, as much production as possible should be shifted to that well as a  
6 method of achieving compliance. It may also be possible to do down-hole testing on  
7 non-compliant wells to determine the source of the contaminant. If the contaminant  
8 derives primarily from a single part of the formation, that part could be excluded by  
9 modifying the existing well, or avoided altogether by completing a new well.

## 10 **COMPLIANCE ALTERNATIVES**

11 The Sandy Meadow Estates PWS is managed by Orbit Systems, an investor-owned  
12 utility that manages 33 water systems in the region. Overall, the system had an adequate  
13 level of FMT capacity. The system had some areas that needed improvement to be able  
14 to address future compliance issues; however, the system does have many positive  
15 aspects, including staff longevity, good communication, in-house expertise, effective  
16 planning for system growth, the regional nature of the Orbit organization, and  
17 maintenance and use of up-to-date system maps. Areas of concern for the system  
18 included lack of regular training; lack of ventilation, alarms, and breathing apparatus for  
19 chlorine buildings; lack of budgeting for individual systems; lack of capital improvement  
20 planning; lack of emergency planning; and lack of independently audited financial  
21 reports.

22 There are numerous PWSs within 15 miles of Sandy Meadow Estates. Many of  
23 these nearby systems also have problems with arsenic, but there are several with good  
24 quality water. In general, feasibility alternatives were developed based on obtaining  
25 water from the nearest PWSs, either by directly purchasing water, or by expanding the  
26 existing well field. There is a minimum of surface water available in the area, and  
27 obtaining a new surface water source is considered through an alternative where treated  
28 surface water is obtained from the Brazosport Water Authority (BWA). In addition to the  
29 BWA, the City of Alvin is a potential large regional water supplier, and there are plans  
30 for the Gulf Coast Water Authority to build a surface water treatment plant in Fort Bend  
31 County that could potentially supply water to Sandy Meadow Estates.

32 A number of centralized treatment alternatives for arsenic removal have been  
33 developed and were considered for this report, for example, iron-based adsorption and  
34 coagulation/filtration. Point-of-use (POU) and point-of-entry treatment alternatives were  
35 also considered. Temporary solutions such as providing bottled water or providing a  
36 centralized dispenser for treated or trucked-in water, were also considered as alternatives.

37 Developing a new well close to Sandy Meadow Estates is likely to be the best  
38 solution if compliant groundwater can be found. Having a new well close to Sandy  
39 Meadow is likely to be one of the lower cost alternatives since the PWS already  
40 possesses the technical and managerial expertise needed to implement this option. The  
41 cost of new well alternatives quickly increases with pipeline length, making proximity of

1 the alternate source a key concern. A new compliant well or obtaining water from a  
2 neighboring compliant PWS has the advantage of providing compliant water to all taps in  
3 the system.

4 Central treatment can be cost-competitive with the alternative of new nearby wells,  
5 but would require significant institutional changes to manage and operate. Like  
6 obtaining an alternate compliant water source, central treatment would provide compliant  
7 water to all water taps.

8 POU treatment can be cost competitive, but does not supply compliant water to all  
9 taps. Additionally, significant efforts would be required for maintenance and monitoring  
10 of the POU treatment units.

11 Providing compliant water through a central dispenser is significantly less expensive  
12 than providing bottled water to 100 percent of the population, but a significant effort is  
13 required for clients to fill their containers at the central dispenser.

## 14 **FINANCIAL ANALYSIS**

15 Financial analysis of the Sandy Meadow Estates PWS indicated that current water  
16 rates are fully funding operations. At \$344, the current average annual water bill  
17 represents approximately 0.9 percent of the 2000 median household income (MHI) for  
18 Texas, which is \$39,927. Table ES.2 provides a summary of the financial impact of  
19 implementing selected compliance alternatives, including the rate increase necessary to  
20 meet future operating expenses. The alternatives were selected to highlight results for the  
21 best alternatives from each different type or category.

22 Some of the compliance alternatives offer potential for shared or regional solutions.  
23 A group of PWSs could work together to implement alternatives for developing a new  
24 groundwater source or expanding an existing source, obtaining compliant water from a  
25 large regional provider, or for central treatment. Sharing the cost for implementation of  
26 these alternatives could reduce the cost on a per user basis. Additionally, merging PWSs  
27 or management of several PWSs by a single entity offers the potential for reduction in  
28 administrative costs.

29 **Table ES.2**  
30 **Selected Financial Analysis Results**

Alternative	Funding Option	Average Annual Water Bill	Percent of MHI
Current	NA	\$344	0.9
To meet current expenses	NA	\$295	0.7
Nearby well within	100% Grant	\$344	0.9

approximately 1 mile	Loan/Bond	\$758	1.9
Central treatment	100% Grant	\$1234	3.1
	Loan/Bond	\$7,796	19.5
Point-of-use	100% Grant	\$1,249	3.1
	Loan/Bond	\$1,319	3.3
Public dispenser	100% Grant	\$760	1.9
	Loan/Bond	\$782	2.0



## TABLE OF CONTENTS

1		
2	<b>EXECUTIVE SUMMARY .....</b>	<b>ES-1</b>
3	Introduction.....	ES-1
4	Study Methods .....	ES-2
5	Hydrogeological Analysis.....	ES-2
6	Compliance Alternatives.....	ES-4
7	Financial Analysis.....	ES-5
8	<b>TABLE OF CONTENTS .....</b>	<b>i</b>
9	<b>LIST OF TABLES .....</b>	<b>v</b>
10	<b>LIST OF FIGURES .....</b>	<b>v</b>
11	<b>ACRONYMS AND ABBREVIATIONS.....</b>	<b>vii</b>
12	<b>SECTION 1 INTRODUCTION.....</b>	<b>1-1</b>
13	1.1 Public Health and Compliance with MCLs .....	1-2
14	1.2 Methodology .....	1-2
15	1.3 Regulatory Perspective .....	1-4
16	1.4 Abatement Options .....	1-4
17	1.4.1 Existing Public Water Supply Systems .....	1-5
18	1.4.1.1 Quantity .....	1-5
19	1.4.1.2 Quality .....	1-6
20	1.4.2 Potential for New Groundwater Sources .....	1-6
21	1.4.2.1 Existing Non-Public Supply Wells.....	1-6
22	1.4.2.2 Develop New Wells.....	1-7
23	1.4.3 Potential for Surface Water Sources.....	1-7
24	1.4.3.1 Existing Surface Water Sources .....	1-8
25	1.4.3.2 New Surface Water Sources .....	1-8
26	1.4.4 Identification of Treatment Technologies.....	1-9
27	1.4.4.1 Treatment Technologies for Arsenic .....	1-9
28	1.4.5 Description of Treatment Technologies .....	1-10
29	1.4.5.1 Ion Exchange .....	1-10
30	1.4.5.2 Reverse Osmosis.....	1-11
31	1.4.5.3 Adsorption .....	1-13
32	1.4.5.4 Coagulation/Filtration and Iron Removal Technologies .....	1-15
33	1.4.6 Point-of-Entry and Point-of-Use Treatment Systems.....	1-16
34	1.4.7 Water Delivery or Central Drinking Water Dispensers.....	1-17

---

---

1		
2	<b>SECTION 2 EVALUATION METHODOLOGY .....</b>	<b>2-1</b>
3	2.1 Decision Tree .....	2-1
4	2.2 Data Sources and Data Collection .....	2-1
5	2.2.1 Data Search .....	2-1
6	2.2.1.1 Water Supply Systems .....	2-1
7	2.2.1.2 Existing Wells.....	2-6
8	2.2.1.3 Surface Water Sources.....	2-6
9	2.2.1.4 Groundwater Availability Model.....	2-6
10	2.2.1.5 Water Availability Model .....	2-6
11	2.2.1.6 Financial Data .....	2-7
12	2.2.1.7 Demographic Data .....	2-7
13	2.2.2 PWS Interviews .....	2-7
14	2.2.2.1 PWS Capacity Assessment Process.....	2-7
15	2.2.2.2 Interview Process.....	2-9
16	2.3 Alternative Development and Analysis .....	2-9
17	2.3.1 Existing PWS .....	2-10
18	2.3.2 New Groundwater Source.....	2-10
19	2.3.3 New Surface Water Source.....	2-11
20	2.3.4 Treatment .....	2-11
21	2.4 Cost of Service and Funding Analysis.....	2-12
22	2.4.1 Financial Feasibility.....	2-12
23	2.4.2 Median Household Income .....	2-12
24	2.4.3 Annual Average Water Bill .....	2-13
25	2.4.4 Financial Plan Development.....	2-13
26	2.4.5 Financial Plan Results.....	2-14
27	2.4.5.1 Funding Options .....	2-14
28	2.4.5.2 General Assumptions Embodied in Financial Plan Results .....	2-15
29	2.4.5.3 Interpretation of Financial Plan Results .....	2-15
30	2.4.5.4 Potential Funding Sources .....	2-15
31	<b>SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS.....</b>	<b>3-1</b>
32	3.1 Arsenic in the Gulf Coast Aquifer .....	3-1
33	3.2 Geology of Brazoria County.....	3-2
34	3.3 General Trends in Arsenic Concentrations.....	3-4
35	3.4 Arsenic and Point Sources of Contamination.....	3-7
36	3.5 Salt Domes .....	3-8

1	3.6	Correlation with Depth .....	3-9
2	3.7	Detailed Assessment .....	3-9
3	3.7.1	Sandy Meadow Estates Subdivision (PWS 0200335) .....	3-11
4	<b>SECTION 4 ANALYSIS OF THE SANDY MEADOW ESTATES PWS.....</b>		<b>4-1</b>
5	4.1	Description of Existing System .....	4-1
6	4.1.1	Existing System .....	4-1
7	4.1.2	Capacity Assessment for the Orbit Systems, Inc. ....	4-3
8	4.1.2.1	General Structure .....	4-3
9	4.1.2.2	General Assessment of Capacity .....	4-3
10	4.1.2.3	Positive Aspects of Capacity .....	4-3
11	4.1.2.4	Capacity Deficiencies .....	4-4
12	4.1.2.5	Potential Capacity Concerns.....	4-5
13	4.2	Alternative Water Source Development .....	4-6
14	4.2.1	Identification of Alternative Existing Public Water Supply Sources .....	4-6
15	4.2.1.1	City of Alvin .....	4-8
16	4.2.1.2	City of Angleton/Brazosport Water Authority .....	4-9
17	4.2.1.3	Briar Meadows.....	4-10
18	4.2.1.4	J M P Utilities .....	4-10
19	4.2.1.5	Mammoet USA, Inc.....	4-10
20	4.2.1.6	Oak Bend Estates.....	4-11
21	4.2.1.7	TDCJ Darrington Unit .....	4-11
22	4.2.1.8	TDCJ Ramsey Area .....	4-11
23	4.2.2	Potential for New Groundwater Sources .....	4-12
24	4.2.2.1	Installing New Compliant Wells .....	4-12
25	4.2.2.2	Results of Groundwater Availability Modeling .....	4-12
26	4.2.3	Potential for New Surface Water Sources .....	4-13
27	4.2.4	Options for Detailed Consideration .....	4-14
28	4.3	Treatment Options .....	4-15
29	4.3.1	Centralized Treatment Systems .....	4-15
30	4.3.2	Point-of-Use Systems.....	4-15
31	4.3.3	Point-of-Entry Systems.....	4-15
32	4.4	Bottled Water .....	4-15
33	4.5	Alternative Development and Analysis .....	4-15
34	4.5.1	Alternative SM-1: Purchased Water from City of Alvin.....	4-15
35	4.5.2	Alternative SM-2: Purchased Water from Brazosport Water Authority .....	4-16
36	4.5.3	Alternative SM-3: New Well near Briar Meadows .....	4-17

1	4.5.4	Alternative SM-4: Purchased Water from J M P Utilities .....	4-18
2	4.5.5	Alternative SM-5: New Well near Mammoet USA, Inc.....	4-18
3	4.5.6	Alternative SM-6: New Well near Oak Bend Estates.....	4-19
4	4.5.7	Alternative SM-7: New Well near TDCJ Darrington Unit.....	4-20
5	4.5.8	Alternative SM-8: New Well near TDCJ Ramsey Area.....	4-21
6	4.5.9	Alternative SM-9: Central Iron-Based Adsorption Treatment .....	4-21
7	4.5.10	Alternative SM-10: Central Coagulation/Filtration Treatment .....	4-22
8	4.5.11	Alternative SM-11: Point-of-Use Treatment .....	4-22
9	4.5.12	Alternative SM-12: Point-of-Entry Treatment .....	4-23
10	4.5.13	Alternative SM-13: New Well at 10 Miles.....	4-24
11	4.5.14	Alternative SM-14: New Well at 5 Miles.....	4-25
12	4.5.15	Alternative SM-15: New Well at 1 Mile .....	4-26
13	4.5.16	Alternative SM-16: Public Dispenser for Treated Drinking Water.....	4-27
14	4.5.17	Alternative SM-17: 100 Percent Bottled Water Delivery.....	4-28
15	4.5.18	Alternative SM-18: Public Dispenser for Trucked Drinking Water.....	4-28
16	4.5.19	Summary of Alternatives .....	4-29
17	4.6	Cost of Service and Funding Analysis.....	4-33
18	4.6.1	Financial Plan Development.....	4-33
19	4.6.1.1	Sandy Meadow Estates Financial Data.....	4-33
20	4.6.1.2	Current Financial Condition .....	4-34
21	4.6.1.3	Financial Plan Results.....	4-35
22	<b>SECTION 5</b>	<b>REFERENCES.....</b>	<b>5-1</b>

## APPENDICES

25	Appendix A	PWS Interview Form
26	Appendix B	Cost Basis
27	Appendix C	Compliance Alternative Conceptual Cost Estimates
28	Appendix D	Example Financial Model
29	Appendix E	General Arsenic Geochemistry
30	Appendix F	Orbit Systems Water Usage
31	Appendix G	Analysis of Shared Solutions for Obtaining Water from BWA and City of Alvin
32		

1

## LIST OF TABLES

2	Table ES.1	Sandy Meadow Estates PWS Basic System Information .....	ES-1
3	Table ES.2	Selected Financial Analysis Results .....	ES-5
4	Table 3.1	Maximum and Minimum Arsenic Concentrations .....	3-10
5	Table 3.2	Arsenic Concentrations in the Sandy Meadow Estates PWS .....	3-11
6	Table 3.3	Maximum and Minimum Arsenic Concentrations in the 5- and 10-km 7 Buffers of the Sandy Meadow Estates PWS.....	3-13
8	Table 4.1	Existing Public Water Systems within 15 Miles of Sandy Meadow Estates..	4-6
9	Table 4.2	Existing Public Water Systems within 15 Miles of Sandy Meadow Estates 10 Selected for Further Evaluation .....	4-8
11	Table 4.3	Summary of Compliance Alternatives for Sandy Meadow Estates.....	4-30
12	Table 4.4	Summary of Orbit Systems 2004 Water Revenues.....	4-34
13	Table 4.5	Summary of Orbit Systems 2004 Expenses.....	4-34
14	Table 4.6	Summary of Orbit Systems 2004 Operations .....	4-34
15	Table 4.7	Summary of Orbit Systems Required Revenue Increases .....	4-35
16	Table 4.8	Financial Impact on Households for Sandy Meadow Estates Alternatives..	4-36

17

18

## LIST OF FIGURES

19	Figure ES-1	Summary of Project Methods .....	ES-3
20	Figure 1.1	Location Map.....	1-3
21	Figure 2.1	Decision Tree – Tree 1 Existing Facility Analysis.....	2-2
22	Figure 2.2	Decision Tree – Tree 2 Develop Treatment Alternatives .....	2-3
23	Figure 2.3	Decision Tree – Tree 3 Preliminary Analysis.....	2-4
24	Figure 2.4	Decision Tree – Tree 4 Financial.....	2-5
25	Figure 3.1	Detectable Arsenic Concentrations in Groundwater (TWDB Database) .....	3-1
26	Figure 3.2	Detectable Arsenic Concentrations in Groundwater (NURE Database) .....	3-2
27	Figure 3.3	Spatial Distribution of Arsenic Concentrations (TWDB Database).....	3-4
28	Figure 3.4	Spatial Distribution of Arsenic Concentrations (NURE Database).....	3-5
29	Figure 3.5	Relationship Between Arsenic and Molybdenum (NURE Database) .....	3-6
30	Figure 3.6	Relationship Between Arsenic and Molybdenum (TWDB Database) .....	3-6
31	Figure 3.7	Relationship Between High Arsenic Concentrations and pH.....	3-7
32	Figure 3.8	Potential Sources of Arsenic Contamination and Arsenic Concentrations 33 (TWDB Database) .....	3-7
34	Figure 3.9	Potential Sources of Arsenic Contamination and Arsenic Concentrations 35 (NURE Database) .....	3-8
36	Figure 3.10	Salt Dome Locations and Arsenic Concentrations .....	3-8

---

---

1	Figure 3.11	Relationship Between Arsenic Concentrations and Well Depth .....	3-9
2	Figure 3.12	Arsenic Concentrations in the Vicinity of PWS Wells .....	3-10
3	Figure 3.13	Arsenic Concentrations in 5- and 10-km Buffers of Sandy Meadow Estates PWS Wells (TWDB and NURE Databases) .....	3-12
4			
5	Figure 3.14	Arsenic Concentrations in 5- and 10-km Buffers of Sandy Meadow Estates PWS Wells (TCEQ Database) .....	3-13
6			
7	Figure 4.1	Sandy Meadow Estates Pipeline Alternatives .....	4-2
8	Figure 4.2	Alternative Cost Summary: Sandy Meadow Estates .....	4-39

1

## ACRONYMS AND ABBREVIATIONS

ft <sup>2</sup>	Square feet
°F	Degrees Fahrenheit
AA	Activated Alumina
BAT	Best available technology
BEG	Bureau of Economic Geology
BWA	Brazosport Water Authority
CA	Chemical analysis
CCN	Certificate of Convenience and Necessity
CO	Correspondence
EDR	Electrodialysis reversal
ETJ	Extra-territorial jurisdiction
FMT	Financial, managerial, and technical
GAM	Groundwater Availability Model
gpm	Gallons per minute
gpm/ft <sup>2</sup>	Gallons per minute per square foot
gpy	Gallons per year
HGCSD	Harris-Galveston Coastal Subsidence District
IX	Ion exchange
MCL	Maximum contaminant level
µg/L	Microgram per liter
mg/L	Milligram per liter
mgd	Million gallons per day
MHI	Median household income
MOR	Monthly operating report
NMEFC	New Mexico Environmental Financial Center
NURE	National Uranium Resource Evaluation
O&M	Operation and Maintenance
Orbit	Orbit Systems Inc.
POE	Point-of-entry
POU	Point-of-use
PVC	Polyvinyl chloride
PWS	Public water system
RO	Reverse osmosis
SCBA	Self-contained breathing apparatus
SDWA	Safe Drinking Water Act
SMCL	Secondary maximum contaminant level
TCEQ	Texas Commission on Environmental Quality
TDCJ	Texas Department of Criminal Justice

---

---

TDS	Total dissolved solids
TSS	Total suspended solids
TWDB	Texas Water Development Board
USEPA	U.S. Environmental Protection Agency
WAM	Water Availability Model
WC&ID	Water Control and Improvement District
WTP	Water treatment plant



**SECTION 1**  
**INTRODUCTION**

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Infrastructure and Technology Group Inc. (Parsons), have been contracted by the Texas Commission on Environmental Quality (TCEQ) to assist with identifying and analyzing compliance alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards. A total of 15 PWSs were evaluated in this project and each is addressed in a separate report. The 15 systems evaluated for this project are listed below:

Public Water System	Texas County
City of Danbury	Brazoria
Rosharon Road Estates	Brazoria
Mark V Estates	Brazoria
Rosharon Township	Brazoria
Sandy Meadow Estates Subdivision	Brazoria
Grasslands	Brazoria
City of Eden	Concho
City of Mason	Mason
Falling Water	Kerr
Greenwood Independent School District (ISD)	Midland
Country Village Mobile Home Estates	Midland
South Midland County Water Systems	Midland
Warren Road Subdivision Water Supply	Midland
Huber Garden Estates	Ector
Devilla Mobile Home Park	Ector

The overall goal of this project is to promote compliance using sound engineering and financial methods and data for PWSs that have recently had sample results that exceed maximum contaminant levels (MCL). The primary objectives of this project are to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS with regard to future implementation. The feasibility studies identify a range of potential compliance alternatives, and present basic data that can be used for evaluating feasibility. The compliance alternatives addressed include a description of what would be required for implementation, conceptual cost estimates for implementation, and non-cost factors that could be used to differentiate between alternatives. The cost estimates are intended for comparing compliance alternatives, and to give a preliminary indication of potential impacts on water rates resulting from implementation.

1 It is anticipated that the PWS will review the compliance alternatives in this report to  
2 determine if there are promising alternatives, and then select the most attractive  
3 alternative(s) for more detailed evaluation and possible subsequent implementation. This  
4 report contains a decision tree approach that guided the efforts for this study, and also  
5 contains steps to guide a PWS through the subsequent evaluation, selection, and  
6 implementation of a compliance alternative.

7 This feasibility report provides an evaluation of water supply compliance options for  
8 the Sandy Meadow Estates Subdivision Water System, PWS ID# 0200335, Certificate of  
9 Convenience and Necessity (CCN) # 11982, located in Brazoria County. The Sandy  
10 Meadow Estates Subdivision Water System is also referred to as the Sandy Meadow  
11 Estates Water System. Recent sample results from the Sandy Meadow Estates Water  
12 System have exceeded the MCL for arsenic of 0.01 milligrams per liter (mg/L) that will  
13 go into effect January 23, 2006 (USEPA 2005a; TCEQ 2004). The location of the Sandy  
14 Meadow Estates Water System, also referred to as the “study area” in this report, is  
15 shown on Figure 1.1.



## 16 1.1 PUBLIC HEALTH AND COMPLIANCE WITH MCLS

17 The goal of this project is to promote compliance for PWSs that supply drinking  
18 water exceeding regulatory MCLs. This project only addresses these contaminants and  
19 does not address any other violations that may exist for a PWS. As mentioned above, the  
20 Sandy Meadow Estates Water System has had recent sample results that exceed the MCL  
21 for arsenic. The health concerns related to drinking water above the MCL for arsenic are  
22 briefly described below.

23 In general, contaminants in drinking water above MCLs can have both short-term  
24 (acute) and long-term or lifetime (chronic) effects. Potential health effects from  
25 long-term ingestion of water with levels of arsenic above the MCL (0.01 mg/L) include  
26 non-cancerous effects, such as cardiovascular, pulmonary, immunological, neurological  
27 and endocrine effects, and cancerous effects, including skin, bladder, lung, kidney, nasal  
28 passage, liver, and prostate cancer (USEPA 2005b).

## 29 1.2 METHODOLOGY

30 The methodology for this project follows that of the pilot study performed in 2004  
31 and 2005 by TCEQ, BEG, and Parsons. The pilot study evaluated water supply  
32 alternatives for PWSs that supply drinking water with nitrate concentrations above  
33 USEPA and Texas drinking water standards. Three PWSs were evaluated in the pilot  
34 study to develop the methodology (*i.e.*, decision tree approach) for analyzing options for  
35 provision of compliant drinking water. This project is performed using the decision tree  
36 approach developed in the pilot study.



**Figure 1.1**  
**Sandy Meadow Estates**  
**Location Map**

1 Other tasks of the feasibility study are as follows:

- 2 • Identifying available data sources;
- 3 • Gathering and compiling data;
- 4 • Conducting financial, managerial, and technical (FMT) evaluations of the
- 5 selected PWSs;
- 6 • Performing a geologic and hydrogeologic assessment of the study area;
- 7 • Developing treatment and non-treatment compliance alternatives;
- 8 • Assessing potential alternatives with respect to economic and
- 9 non-economic criteria;
- 10 • Preparing a feasibility report; and
- 11 • Suggesting refinements to the approach for future studies.

12 The remainder of Section 1 of this report addresses the regulatory background, and  
13 provides a summary of compliance alternatives. Section 2 describes the methodology  
14 used to develop and assess compliance alternatives. The groundwater sources of arsenic  
15 are addressed in Section 3. Findings for the Sandy Meadow Estates Water System, along  
16 with compliance alternatives development and evaluation, can be found in Section 4.  
17 Section 5 references the sources used in this report.

### 18 **1.3 REGULATORY PERSPECTIVE**

19 The Utilities & Districts and Public Drinking Water Sections of the TCEQ Water  
20 Supply Division are responsible for implementing the federal Safe Drinking Water Act  
21 (SDWA) requirements that include oversight of PWSs and water utilities. These  
22 responsibilities include:

- 23 • Monitoring public drinking water quality;
- 24 • Processing enforcement referrals for MCL violators;
- 25 • Tracking and analyzing compliance options for MCL violators;
- 26 • Providing FMT assessment and assistance to PWSs;
- 27 • Participating in the Drinking Water State Revolving Fund program to
- 28 assist PWSs in achieving regulatory compliance; and
- 29 • Setting rates for privately-owned water utilities.

30 This project was conducted to assist in achieving these responsibilities.

### 31 **1.4 ABATEMENT OPTIONS**

32 When a PWS exceeds a regulatory MCL, the PWS must take action to correct the  
33 violation. The MCL exceedance at the Sandy Meadow Estates PWS is for arsenic. The  
34 following subsections explore alternatives considered as potential options for  
35 obtaining/providing compliant drinking water.

## 1 1.4.1 Existing Public Water Supply Systems

2 A common approach to achieve compliance is for the PWS to make arrangements  
3 with a neighboring PWS for water supply. For this arrangement to work, the PWS from  
4 which water is being purchased (supplier PWS) must have water in sufficient quantity  
5 and quality, the political will must exist, and it must be economically feasible.

### 6 1.4.1.1 Quantity

7 For purposes of this report, quantity refers to water volume, flow rate, and pressure.  
8 Before approaching a potential supplier PWS, the non-compliant PWS should determine  
9 its water demand on the basis of average day and maximum day. Peak instantaneous  
10 demands can be met through proper sizing of storage facilities. Further, the potential for  
11 obtaining the appropriate quantity of water to blend to achieve compliance should be  
12 considered. The concept of blending involves combining water with low levels of  
13 contaminants with non-compliant water in sufficient quantity that the resulting blended  
14 water is compliant. The exact blend ratio would depend on the quality of the water a  
15 potential supplier PWS can provide, and would likely vary over time. If high quality  
16 water is purchased, produced or otherwise obtained, blending can reduce the amount of  
17 high quality water required. Implementation of blending will require a control system to  
18 ensure the blended water is compliant.

19 If the supplier PWS does not have sufficient quantity, the non-compliant community  
20 could pay for the facilities necessary to increase the quantity to the extent necessary to  
21 supply the needs of the non-compliant PWS. Potential improvements might include, but  
22 are not limited to:

- 23 • Additional wells;
- 24 • Developing a new surface water supply;
- 25 • Additional or larger-diameter piping;
- 26 • Increasing water treatment plant capacity;
- 27 • Additional storage tank volume;
- 28 • Reduction of system losses;
- 29 • Higher-pressure pumps; or
- 30 • Upsized, or additional, disinfection equipment.

31 In addition to the necessary improvements, a transmission pipeline would need to be  
32 constructed to tie the two PWSs together. The pipeline must tie-in at a point in the  
33 supplier PWS where all the upstream pipes and appurtenances are of sufficient capacity  
34 to handle the new demand. In the non-compliant PWS, the pipeline must tie in at a point  
35 where no down stream bottlenecks are present. If blending is the selected method of  
36 operation, the tie-in point must be at the proper point of the existing non-compliant PWS  
37 to ensure that all the water in the system is blended to achieve regulatory compliance.

## 1 1.4.1.2 Quality

2 If a potential supplier PWS obtains its water from the same aquifer (or same portion  
3 of the aquifer) as the non-compliant PWS, the quality of water may not be significantly  
4 better. However, water quality can vary significantly due to well location, even within  
5 the same aquifer. If localized areas with good water quality cannot be identified, the  
6 non-compliant PWS would need to find a potential supplier PWS that obtains its water  
7 from a different aquifer or from a surface water source. Additionally, a potential supplier  
8 PWS may treat non-compliant raw water to an acceptable level.

9 Surface water sources may offer a potential higher-quality source. Since there are  
10 significant treatment requirements, utilization of surface water for drinking water is  
11 typically most feasible for larger local or regional authorities or other entities that may  
12 provide water to several PWSs. Where PWSs that obtain surface water are neighbors, the  
13 non-compliant PWS may need to deal with those systems as well as with the water  
14 authorities that supply the surface water.

## 15 1.4.2 Potential for New Groundwater Sources

### 16 1.4.2.1 Existing Non-Public Supply Wells

17 Often there are wells not associated with PWSs that are located in the vicinity of the  
18 non-compliant PWS. The current use of these wells may be for irrigation, industrial  
19 purposes, domestic supply, stock watering, and other purposes. The process for  
20 investigating existing wells is as follows:

- 21 • Use existing data sources (see below) to identify wells in the areas that  
22 have satisfactory quality. For Brazoria County, the following standards  
23 could be used in a rough screening to identify compliant groundwater:
  - 24 ○ Arsenic concentrations less than 0.008 mg/L (below the MCL of  
25 0.01 mg/L); and
  - 26 ○ Total dissolved solids (TDS) concentrations less than 1,000 mg/L.
- 27 • Review the recorded well information to eliminate those wells that appear  
28 to be unsuitable for the application. Often, the “Remarks” column in the  
29 Texas Water Development Board (TWDB) hard-copy database provides  
30 helpful information. Wells eliminated from consideration generally  
31 include domestic and stock wells, dug wells, test holes, observation wells,  
32 seeps and springs, destroyed wells, wells used by other communities, *etc.*
- 33 • Identify wells of sufficient size which have been used for industrial or  
34 irrigation purposes. Often the TWDB database includes well yields,  
35 which may indicate the likelihood of a particular well being a satisfactory  
36 source.
- 37 • At this point in the process, the local groundwater control district (if one  
38 exists) should be contacted to obtain information about pumping

1 restrictions. Also, preliminary cost estimates should be made to establish  
2 the feasibility of pursuing further well development options.

- 3 • If particular wells appear to be acceptable, the owner(s) should be  
4 contacted to ascertain the willingness to work with the PWS. Once the  
5 owner agrees to participate with the program, questions should be asked  
6 about the wells. Many owners have more than one well, and would  
7 probably be the best source of information regarding the latest test dates,  
8 who tested the water, flow rates, and other well characteristics.
- 9 • After collecting as much information as possible from cooperative owners,  
10 the PWS would then narrow down the selection of wells and sample and  
11 analyze the selected wells for quality. Wells with good water quality  
12 would then be potential candidates for test pumping. In some cases, a  
13 particular well may need to be refurbished before test pumping.  
14 Information obtained from test pumping would then be used in  
15 combination with information about the general characteristics of the  
16 aquifer to determine whether a well at this location would be suitable as a  
17 supply source.
- 18 • It is recommended that new wells be installed instead of using existing  
19 wells to ensure the well characteristics are known and the well meets  
20 construction standards.
- 21 • Permit(s) would then be obtained from the groundwater control district or  
22 other regulatory authority, and an agreement with the owner (purchase or  
23 lease, access easements, *etc.*) would then be negotiated.

#### 24 **1.4.2.2 Develop New Wells**

25 If no existing wells are available for development, the PWS or group of PWSs has an  
26 option of developing new wells. Records of existing wells, along with other  
27 hydrogeologic information and modern geophysical techniques, should be used to  
28 identify potential locations for new wells. In some areas, the TWDB's Groundwater  
29 Availability Model (GAM) may be applied to indicate potential sources. Once a general  
30 area has been identified, land owners and regulatory agencies should be contacted to  
31 determine an exact location for a new well or well field. Pump tests and water quality  
32 tests would be required to determine if a new well will produce an adequate quantity of  
33 good quality water. Permits from the local groundwater control district or other  
34 regulatory authority could also be required for a new well.

#### 35 **1.4.3 Potential for Surface Water Sources**

36 Water rights law dominates the acquisition of water from surface water sources. For  
37 a PWS, 100 percent availability of water is required, except where a back-up source is  
38 available. For PWSs with an existing water source, although it may be non-compliant  
39 because of elevated concentrations of one or more parameters, water rights may not need  
40 to be 100 percent available.

### 1.4.3.1 Existing Surface Water Sources

“Existing surface water sources” of water refers to municipal water authorities and cities that obtain water from surface water sources. The process of obtaining water from such a source is generally less time consuming and less costly than the process of developing a new source; therefore, it should be a primary course of investigation. An existing source would be limited by its water rights, the safe yield of a reservoir or river, or by its water treatment or water conveyance capability. The source must be able to meet the current demand and honor contracts with communities it currently supplies. In many cases, the contract amounts reflect projected future water demand based on population or industrial growth.

A non-compliant PWS would look for a source with sufficient spare capacity. Where no such capacity exists, the non-compliant PWS could offer to fund the improvements necessary to obtain the capacity. This approach would work only where the safe yield could be increased (perhaps by enlarging a reservoir) or where treatment capacity could be increased. In some instances, where they are available, water rights could possibly be purchased.

In addition to securing the water supply from an existing source, the non-compliant PWS would have to arrange for the transmission of the water to the PWS. In some cases, this may require negotiations with, contracts with, and payments to an intermediate PWS (an intermediate PWS is one where the infrastructure is used to transmit water from a “supplier” PWS to a “supplied” PWS, but does not provide any additional treatment to the supplied water). The non-compliant PWS could be faced with having to fund improvements to the intermediate PWS in addition to constructing its own necessary transmission facilities.

### 1.4.3.2 New Surface Water Sources

Communication with the TCEQ and relevant planning groups from the beginning is essential in the process of obtaining a new surface water source. Preliminary assessment of the potential for acquiring new rights may be based on surface water availability maps located on the TWDB website. Where water rights appear to be available, the following activities need to occur:

- Discussions with TCEQ to indicate the likelihood of obtaining those rights. The TCEQ may use the Water Availability Model (WAM) to assist in the determination.
- Discussions with land owners to indicate potential treatment plant locations.
- Coordination with U.S. Army Corps of Engineers and local river authorities.
- Preliminary engineering design to determine the feasibility, costs, and environmental issues of a new intake, treatment plant, and conveyance system.



1           Should these discussions indicate that a new surface water source is the best option,  
2 the community would proceed with more intensive planning (initially obtaining funding),  
3 permitting, land acquisition, and detailed designs.

#### 4   **1.4.4    Identification of Treatment Technologies**

5           Various treatment technologies were also investigated as compliance alternatives for  
6 treatment of arsenic to the regulatory level (*i.e.*, MCL). Numerous options have been  
7 identified by the USEPA as best available technologies (BAT) for the non-compliant  
8 constituents. Identification and descriptions of the various BATs are provided in the  
9 following sections.

##### 10   **1.4.4.1   Treatment Technologies for Arsenic**

11           In January 2001, the USEPA published a final rule in the Federal Register that  
12 established an MCL for arsenic of 0.01 mg/L (USEPA 2001). The regulation applies to  
13 all community water systems and non-transient, non-community water systems,  
14 regardless of size.

15           The new arsenic MCL of 0.01 mg/L becomes effective on January 23, 2006, at  
16 which time the running average annual arsenic level must be at or below 0.01 mg/L at  
17 each entry point to the distribution system, although point-of-use (POU) treatment can be  
18 instituted in place of centralized treatment. All groundwater systems must complete  
19 initial monitoring or have a State-approved waiver by December 31, 2007.

20           The following BATs were identified in the final rule for achieving compliance with  
21 the arsenic MCL:

- 22           • Reverse Osmosis (RO);
- 23           • Ion Exchange (IX);
- 24           • Electrodialysis Removal (EDR);
- 25           • Activated Alumina (AA);
- 26           • Oxidation/Filtration;
- 27           • Enhanced Coagulation/Filtration; and
- 28           • Enhanced Lime Softening.

29           In addition, the following technologies are listed in the final rule as Small System  
30 Compliance Technologies:

- 31           • RO (centralized and POU);
- 32           • IX;
- 33           • EDR;
- 34           • AA (centralized and POU);
- 35           • Oxidation/Filtration;

- 1                   • Coagulation/Filtration, Enhanced Coagulation/Filtration, and Coagulation-  
2                   Assisted Microfiltration; and
- 3                   • Lime Softening and Enhanced Lime Softening.

#### 4   **1.4.5   Description of Treatment Technologies**

5           According to a recent USEPA report for small water systems with <10,000  
6 customers (USEPA 2004), a number of drinking water treatment technologies are  
7 available to reduce arsenic concentrations in source water to below the new MCL of  
8 0.01 mg/L, including IX, membrane processes such as RO, adsorption, and  
9 coagulation/filtration-related processes. Many of the most effective arsenic removal  
10 processes available are iron-based treatment technologies such as chemical  
11 coagulation/filtration with iron salts, and adsorptive media with iron-based products.  
12 These processes are particularly effective at removing arsenic from aqueous systems  
13 because iron surfaces have a strong affinity for adsorbing arsenic. Other arsenic removal  
14 processes such as AA and enhanced lime softening are more applicable to larger water  
15 systems because of their operational complexity and cost. A description and discussion  
16 of arsenic removal technologies applicable to smaller systems follows.

##### 17   **1.4.5.1   Ion Exchange**

18           Process – In solution, salts separate into positively charged cations and negatively  
19 charged anions. Ion exchange is a reversible chemical process in which ions from an  
20 insoluble, permanent, solid resin bed are exchanged for ions in water. The process relies  
21 on the fact that certain ions are preferentially adsorbed on the ion exchange resin.  
22 Operation begins with a fully charged cation or anion bed, having enough positively or  
23 negatively charged ions to carry out the cation or anion exchange. Usually a polymeric  
24 resin bed is composed of millions of spherical beads about the size of medium sand  
25 grains. As water passes the resin bed, the charged ions are released into the water, being  
26 substituted or replaced with the contaminants in the water (ion exchange). When the  
27 resin becomes exhausted of positively or negatively charged ions, the bed must be  
28 regenerated by passing a strong, sodium chloride, solution over the resin bed, displacing  
29 the contaminant ions with sodium ions for cation exchange and chloride ions for anion  
30 exchange. Many different types of resins can be used to reduce dissolved contaminant  
31 concentrations. The IX treatment train for groundwater typically includes cation or anion  
32 resin beds with a regeneration system, chlorine disinfection, and clear well storage.  
33 Treatment trains for surface water may also include raw water pumps, debris screens, and  
34 filters for pre-treatment. Additional treatment or management of the concentrate and the  
35 removed solids would be necessary prior to disposal. For arsenic removal, an anion  
36 exchange resin in the chloride form is used to remove arsenate [As(V)]. Because arsenite  
37 [As(III)] occurs in water below pH 9 with no ionic charge, As(III) is not consistently  
38 removed by the anionic exchange process.

39           Pretreatment – There are pretreatment requirements for pH, organics, turbidity, and  
40 other raw water characteristics. Pretreatment may be required to reduce excessive  
41 amounts of total suspended solids (TSS), iron, and manganese, which could plug the

1 resin bed, and typically includes media or carbon filtration. In addition, chlorination or  
2 oxidation may be required to convert As(III) to As(V) for effective removal.

3 Maintenance – The IX resin requires regular on-site regeneration, the frequency of  
4 which depends on raw water characteristics, the contaminant concentration, and the size  
5 and number of IX vessels. Many systems have undersized the IX vessels only to realize  
6 higher than necessary operating costs. Preparation of the sodium chloride solution is  
7 required. If used, filter replacement and backwashing would be required.

8 Waste Disposal – Approval from local authorities is usually required for disposal of  
9 concentrate from the regeneration cycle (highly concentrated salt solution); occasional  
10 solid wastes (in the form of broken resin beads) which are backwashed during  
11 regeneration; and if used, spent filters and backwash wastewater.

### 12 **Advantages (IX)**

- 13 • Well established process for arsenic removal.
- 14 • Fully automated and highly reliable process.
- 15 • Suitable for small and large installations.

### 16 **Disadvantages (IX)**

- 17 • Requires salt storage; regular regeneration.
- 18 • Concentrate disposal.
- 19 • Resins are sensitive to the presence of competing ions such as sulfate.

20 In considering the application of IX for removal of inorganics, it is important to  
21 understand what the effect of competing ions would be, and to what extent the brine can  
22 be recycled. Similar to AA, IX exhibits a selectivity sequence, which refers to an order  
23 in which ions are preferred. Sulfate competes with both nitrate and arsenic, but is more  
24 aggressive with arsenic in anion exchange. Source waters with TDS levels above  
25 500 mg/L or sulfate above 50 mg/L are not amenable to IX treatment for arsenic removal.  
26 Spent regenerant is produced during IX bed regeneration, and it may have high  
27 concentrations of the sorbed contaminants which would be expensive to treat and/or  
28 dispose because of hazardous waste regulations. Research has been conducted to  
29 minimize this effect: recent research on arsenic removal shows that the brine can be  
30 reused as many as 25 times.

### 31 **1.4.5.2 Reverse Osmosis**

32 Process – RO is a pressure-driven membrane separation process capable of removing  
33 dissolved solutes from water by means of particle size and electrical charge. The raw  
34 water is typically called feed, the product water is called permeate, and the concentrated  
35 reject is called concentrate. Common RO membrane materials include asymmetric  
36 cellulose acetate and polyamide thin film composite. Common RO membrane  
37 configurations include spiral wound hollow fine fiber, but most RO systems to date are  
38 the spiral wound type. A typical RO installation includes a high pressure feed pump with

1 chemical feed, parallel first and second stage membrane elements in pressure vessels, and  
2 valving and piping for feed, permeate, and concentrate streams. Factors influencing  
3 membrane selection are cost, recovery, rejection, raw water characteristics, and  
4 pretreatment. Factors influencing performance are raw water characteristics, pressure,  
5 temperature, and regular monitoring and maintenance. RO is capable of achieving over  
6 97 percent removal of As(V) and 92 percent removal of As(III). The treatment process is  
7 relatively insensitive to pH. Water recovery is typically 60-80 percent, depending on the  
8 raw water characteristics. The concentrate volume for disposal can be significant.

9 Pretreatment – RO requires careful review of raw water characteristics and  
10 pretreatment needs to prevent membranes from fouling, scaling or other membrane  
11 degradation. Removal or sequestering of suspended and colloidal solids is necessary to  
12 prevent fouling, and removal of sparingly soluble constituents such as calcium,  
13 magnesium, silica, sulfate, barium, *etc.* may be required to prevent scaling. Pretreatment  
14 can include media filters, ion exchange softening, acid and antiscalant feed, activated  
15 carbon or bisulfite feed to dechlorinate, and cartridge filters to remove any remaining  
16 suspended solids to protect membranes from upsets.

17 Maintenance – Monitoring rejection percentage is required to ensure contaminant  
18 removal below MCL. Regular monitoring of membrane performance is necessary to  
19 determine fouling, scaling, or other membrane degradation. Acidic or caustic solutions  
20 are regularly flushed through the system at high volume/low pressure with a cleaning  
21 agent to remove foulants and scalants. Frequency of membrane replacement is dependent  
22 on raw water characteristics, pretreatment, and maintenance.

23 Waste Disposal – Pretreatment waste streams, concentrate flows, spent filters and  
24 membrane elements all require approved disposal methods.

### 25 **Advantages (RO)**

- 26 • Can remove both As(III) and As(V) effectively.
- 27 • Can remove other undesirable dissolved constituents and excessive salts,  
28 if required.

### 29 **Disadvantages (RO)**

- 30 • Relatively expensive to install and operate.
- 31 • Need sophisticated monitoring systems.
- 32 • Need to handle multiple chemicals.
- 33 • Waste of water because of the significant concentrate flows.
- 34 • Concentrated disposal.

35 RO is an expensive alternative to remove arsenic and is usually not economically  
36 competitive with other processes unless removal of nitrate and/or TDS is also required.  
37 The biggest drawback for using RO to remove arsenic is the waste of water through  
38 concentrate disposal which is also difficult or expensive because of the volume involved.

### 1 1.4.5.3 Adsorption

2 Process – The adsorptive media process is a fixed-bed process by which ions in  
3 solution, such as arsenic, are removed by available adsorptive sites on an adsorptive  
4 media. When the available adsorptive sites are filled, spent media may be regenerated or  
5 simply thrown away and replaced with new media. Granular AA was the first adsorptive  
6 media successfully applied for the removal of arsenic from water supplies. More  
7 recently, other adsorptive media (mostly iron-based) were developed and marketed for  
8 arsenic removal. Recent USEPA studies demonstrated that iron-based adsorption media  
9 typically have higher arsenic removal capacities compared to alumina-based media. In  
10 the USEPA-sponsored Round 1 full-scale demonstration of arsenic removal technologies  
11 for small water systems program, the selected arsenic treatment technologies included  
12 nine adsorptive media systems, one IX system, one coagulation/filtration system, and one  
13 process modification.

14 The selected adsorptive media systems used four different adsorptive media,  
15 including three iron-based media (*e.g.*, ADI's G2, Severn Trent and AdEdge's E33, and  
16 US Filter's GFH), and one iron-modified AA media (*e.g.*, Kinetico's AAFS50, a product  
17 of Alcan). The G2 media is a dry powder of diatomaceous earth impregnated with a  
18 coating of ferric hydroxide, developed by ADI specifically for arsenic adsorption. ADI  
19 markets G2 for both As(V) and As(III) removal, but it preferentially removes As(V).  
20 G2 media adsorbs arsenic most effectively at pH values within the 5.5 to 7.5 range, and  
21 less effectively at a higher pH value.

22 The Bayoxide® E33 media was developed by Bayer AG for the removal of arsenic  
23 from drinking water supplies. It is a dry granular iron oxide media designed to remove  
24 dissolved arsenic via adsorption onto its ferric oxide surface. Severn Trent markets the  
25 media in the U.S. for As(III) and As(V) removal as Sorb-33, and offers several arsenic  
26 package units with flow rates ranging from 150 to 300 gallons per minute (gpm).  
27 Another company, AdEdge, provides similar systems using the same media (marketed as  
28 AD-33) with flow rates ranging from 5 to 150 gpm. E33 adsorbs arsenic and other ions,  
29 such as antimony, cadmium, chromate, lead, molybdenum, selenium, and vanadium. The  
30 adsorption is effective at pH values ranging between 6.0 and 9.0. At greater than 8.0 to  
31 8.5, pH adjustment is recommended to maintain adsorption capacity. Two competing  
32 ions that can reduce the adsorption capacity are silica (at levels greater than 40 mg/L) and  
33 phosphate (at levels greater than 1 mg/L).

34 GFH is a moist granular ferric hydroxide media produced by GEH Wasserchemie  
35 GmbH of Germany and marketed by US Filter under an exclusive marketing agreement.  
36 GFH is capable of adsorbing both As(V) and As(III). GFH media adsorb arsenic with a  
37 pH range of 5.5 to 9.0, but less effectively at the upper end of this range. Competing ions  
38 such as silica and phosphate in source water can adsorb onto GFH media, thus reducing  
39 its arsenic removal capacity.

40 The AAFS50 is a dry granular media of 83 percent alumina and a proprietary  
41 iron-based additive to enhance the arsenic adsorption performance. Standard AA was the  
42 first adsorptive media successfully applied for the removal of arsenic from water

1 supplies. However, it often requires pH adjustment to 5.5 in order to achieve optimum  
2 arsenic removal. The AAFS50 product is modified with an iron-based additive to  
3 improve its performance and to increase the pH range within which it can achieve  
4 effective removal. Optimum arsenic removal efficiency is achieved with a pH of the feed  
5 water less than 7.7. Competing ions such as fluoride, sulfate, silica, and phosphate can  
6 adsorb onto AAFS50 media, and potentially can reduce its arsenic removal capacity. The  
7 adsorption capacity of AAFS50 can be impacted by both high levels of silica (>40 mg/L)  
8 and phosphate (>1 mg/L). The vendor recommended that the system be operated in a  
9 series configuration to minimize the chance for arsenic breakthrough to impact drinking  
10 water quality.

11 All of the iron-based or iron-modified adsorptive media are of the throwaway type  
12 after exhaustion. The operations of these adsorption systems are quite similar and  
13 simple. Some of the technologies such as the E33 and GFH media have been operated  
14 successfully on large scale plants in Europe for several years.

15 Pretreatment – The adsorptive media are primarily used to remove dissolved arsenic  
16 and not for suspended solids removal. Pretreatment to remove TSS may be required if  
17 raw water turbidity is >0.3 NTU. However, most well waters are low in turbidity and  
18 hence pre-filtration is usually not required. Pre-chlorination may be required to oxidize  
19 As(III) to As(V) if the proportion of As(III) is high. No pH adjustment is required unless  
20 pH is relatively high.

21 Maintenance – Maintenance for the adsorption media system is minimal if no  
22 pretreatment is required. Backwash is required infrequently (monthly) and replacement  
23 and disposal of the exhausted media occurs between 1 to 3 years, depending on average  
24 water consumption, the concentrations of arsenic and competing ions in the raw water,  
25 and the media bed volume.

26 Waste Disposal – If no pretreatment is required there is minimal waste disposal  
27 involved with the adsorptive media system. Disposal of backwash wastewater is required  
28 especially during startup. Regular backwash is infrequent and disposal of the exhausted  
29 media occurs once every 1 to 3 years, depending on operating conditions. The exhausted  
30 media are usually considered non-hazardous wastes.

### 31 **Advantages (Adsorption)**

- 32 • Some adsorbents can remove both As(III) and As(V).
- 33 • Very simple to operate.

### 34 **Disadvantages (Adsorption)**

- 35 • Relatively new technology.
- 36 • Need replacement of adsorption media when exhausted.

37 The adsorption media process is the most simple and requires minimal operator  
38 attention, compared to other arsenic removal processes. The process is most applicable  
39 to small wellhead systems with low or moderate arsenic concentrations with no treatment

1 process in place (e.g., iron and manganese removal; if treatment facilities for iron and/or  
2 manganese removal are already in place, incorporating ferric chloride coagulation in the  
3 existing system would be a more cost-effective alternative for arsenic removal). The  
4 choice of media would depend on raw water characteristics, life cycle cost, and  
5 experience of the vendor. Many of the adsorption media are at the field-trial stage, but  
6 others are already being used in full-scale applications throughout Europe and the United  
7 States. Pilot testing may or may not be necessary prior to implementation depending on  
8 the experience of the vendor with similar water characteristics.

#### 9 **1.4.5.4 Coagulation/Filtration and Iron Removal Technologies**

10 Process – Iron removal processes can be used to removal arsenic from drinking  
11 water supplies. Iron removal processes involved the oxidation of soluble iron and  
12 As(III), adsorption and/or co-precipitation of As(V) onto iron hydroxides, and filtration.  
13 The filtration can be accomplished with granular media filter or microfilter. When iron  
14 in the raw water is inadequate to accomplish arsenic removal, an iron salt such as ferric  
15 chloride is added to the water to form ferric hydroxide. The iron removal process is  
16 commonly called coagulation/filtration because iron in the form of ferric chloride is a  
17 common coagulant. The actual capacity to remove arsenic during iron removal depends  
18 on a number of factors, including the amount of arsenic present, arsenic speciation, pH,  
19 amount and form of iron present, and existence of competing ions, such as phosphate,  
20 silicate, and natural organic matter. The filters used in groundwater treatment are usually  
21 pressure filters feeding directly by the well pumps. The filter media can be regular dual  
22 media filters or proprietary media such as the engineered ceramic filtration media,  
23 Macrolite<sup>®</sup>, developed by Kinetico. Macrolite is a low-density, spherical media designed  
24 to allow for filtration rates up to 10 gpm per square foot (gpm/ft<sup>2</sup>), which is a higher  
25 loading rate than commonly used for conventional filtration media.

26 Pretreatment – Pre-chlorination to oxidize As(III) to As(V) is usually required for  
27 most groundwater sources. The adjustment of pH is required only for relatively high pH  
28 value. Coagulation with the feed of ferric chloride is required for this process.  
29 Sometimes a 5-minute contact tank is required ahead of the filters if the pH is high.

30 Maintenance – Maintenance is mainly to handle the ferric chloride chemical and feed  
31 systems, and for regular backwash of the filters. No filter replacement is required for this  
32 process.

33 Waste Disposal – Waste from the coagulation/filtration process is mainly iron  
34 hydroxide sludge with adsorbed arsenic in the backwash water. The backwash water can  
35 be discharged to a public sewer if it is available. If a sewer is not available, the backwash  
36 water can be discharged to a storage and settling tank from where the supernatant is  
37 recycled in a controlled rate to the front of the treatment system and the settled sludge  
38 can be disposed of periodically to a landfill. Iron hydroxide sludge is usually not  
39 classified as hazardous waste.

1       **Advantages**

- 2               • Very established technology for arsenic removal.  
3               • Most economical process for arsenic removal.

4       **Disadvantages**

- 5               • Need to handle chemical.  
6               • Need to dispose of regular backwash wastewater.  
7               • Sludge disposal.

8       The coagulation/filtration process is usually the most economical arsenic removal  
9       alternative, especially if a public sewer is available for accepting the discharge of the  
10       backwash water. However, because of the regular filter backwash requirements, more  
11       operation and maintenance (O&M) attention is required from the utilities. Because of  
12       potential interference by competing ions, bench-scale or pilot testing may be required to  
13       ensure that the arsenic MCL can be met with this process alternative.

14       **1.4.6 Point-of-Entry and Point-of-Use Treatment Systems**

15       Point-of-entry (POE) and point-of-use (POU) treatment systems can be used to  
16       provide compliant drinking water. For arsenic removal, these systems typically use small  
17       RO treatment units that are installed “under the sink” in the case of POU, and where  
18       water enters a house or building in the case of POE. It should be noted that the POU  
19       treatment units would need to be more complex than units typically found in commercial  
20       retail outlets in order to meet regulatory requirements, making purchase and installation  
21       more expensive. POE and POU treatment units would be purchased and owned by the  
22       PWS. These solutions are decentralized in nature, and require utility personnel entry into  
23       houses or at least onto private property for installation, maintenance, and testing. Due to  
24       the large number of treatment units that would be employed and would be largely out of  
25       the control of the PWS, it is very difficult to ensure 100 percent compliance. Prior to  
26       selection of a POE or POU program for implementation, consultation with TCEQ will be  
27       required to address measurement and determination of level of compliance.

28       The SDWA [§1412(b)(4)(E)(ii)] regulates the design, management and operation of  
29       POU and POE treatment units used to achieve compliance with an MCL. These  
30       restrictions, relevant to arsenic are:

- 31               • POU and POE treatment units must be owned, controlled, and maintained  
32               by the water system, although the utility may hire a contractor to ensure  
33               proper O&M and MCL compliance. The water system must retain unit  
34               ownership and oversight of unit installation, maintenance and sampling;  
35               the utility ultimately is the responsible party when it comes to regulatory  
36               compliance. The water system staff need not perform all installation,  
37               maintenance, or management functions, as these tasks may be contracted  
38               to a third party, but the final responsibility for quality and quantity of the  
39               water supplied to the community resides with the water system, and the



1 utility must monitor all contractors closely. Responsibility for the O&M  
2 of POU or POE devices installed for SDWA compliance may not be  
3 delegated to homeowners.

- 4 • POU and POE units must have mechanical warning systems to  
5 automatically notify customers of operational problems. Each POU or  
6 POE treatment device must be equipped with a warning device  
7 (e.g., alarm, light) that will alert users when their unit is no longer  
8 adequately treating their water. As an alternative, units may be equipped  
9 with an automatic shut-off mechanism to meet this requirement.
- 10 • If the American National Standards Institute has issued product standards  
11 for a specific type of POU or POE treatment unit, only those units that  
12 have been independently certified according to these standards may be  
13 used as part of a compliance strategy.

14 The following observations with regard to using POE and POU devices for SDWA  
15 compliance were made by Raucher, *et al.* (2004):

- 16 • If POU devices are used as an SDWA compliance strategy, certain  
17 consumer behavioral changes would be necessary (e.g., encouraging  
18 people to drink water only from certain treated taps) to ensure  
19 comprehensive consumer health protection.
- 20 • Although not explicitly prohibited in SDWA, USEPA indicates that POU  
21 treatment devices should not be used to treat for radon or for most volatile  
22 organic contaminants to achieve compliance, because POU devices do not  
23 provide 100 percent protection against inhalation or contact exposure to  
24 those contaminants at untreated taps (e.g., shower heads).
- 25 • Liability – PWSs considering unconventional treatment options (POU,  
26 POE, or bottled water) must address liability issues. These could be  
27 meeting the drinking water standards, property entry and ensuing  
28 liabilities, and damage arising from improper installation or improper  
29 function of the POU and POE devices.

#### 30 **1.4.7 Water Delivery or Central Drinking Water Dispensers**

31 Current USEPA regulations 40 Code of Federal Regulations (CFR) 141.101 prohibit  
32 the use of bottled water to achieve compliance with an MCL, except on a temporary  
33 basis. State regulations do not directly address the use of bottled water. Use of bottled  
34 water at a non-compliant PWS would be on a temporary basis. Every 3 years, the PWSs  
35 that employ interim measures are required to present the TCEQ with estimates of costs  
36 for piping compliant water to their systems. As long as the projected costs remain  
37 prohibitively high, the bottled water interim measure is extended. Until USEPA amends  
38 the noted regulation, the TCEQ is unable to accept water delivery or central drinking  
39 water dispensers as compliance solutions.

40 Central provision of compliant drinking water would consist of having one or more  
41 dispensers of compliant water where customers could come to fill containers with

1 drinking water. The centralized water source could be from small to medium sized  
2 treatment units or could be compliant water delivered to the central point by truck.

3 Water delivery is an interim measure for providing compliant water. As an interim  
4 measure for a small impacted population, providing delivered drinking water may be cost  
5 effective. If the susceptible population is large, the cost of water delivery would increase  
6 significantly.

7 Water delivery programs require consumer participation to a varying degree.  
8 Ideally, the consumer would have to do no more than he/she currently does for a piped-  
9 water delivery system. Least desirable are those systems that require maximum effort on  
10 the part of the customer (*e.g.*, customer has to travel to get the water, transport the water,  
11 and physically handle the bottles). Such a system may appear to be lowest-cost to the  
12 utility; however, should a consumer experience ill effects from contaminated water and  
13 take legal action, the ultimate cost could increase significantly.

14 The ideal system would:

- 15 • Identify populations potentially susceptible to the health risk associated  
16 with arsenic, if any. If bottled water is only provided to customers who  
17 are part of the susceptible population, the utility should have an active  
18 means of identifying the susceptible population. Problems with illiteracy,  
19 language fluency, fear of legal authority, desire for privacy, and apathy  
20 may be reasons that some members of the susceptible population do not  
21 become known to the utility, and do not take part in the water delivery  
22 program.
- 23 • Maintain customer privacy by eliminating the need for utility personnel to  
24 enter the home.
- 25 • Have buffer capacity (*e.g.*, two bottles in service, so that when one is  
26 empty, the other is being used over a time period sufficient to allow the  
27 utility to change out the empty bottle).
- 28 • Provide for regularly scheduled delivery so that the customer would not  
29 have to notify the utility when the supply is low.
- 30 • Use utility personnel and equipment to handle water containers, without  
31 requiring customers to lift or handle bottles containing water.
- 32 • Be sanitary (*e.g.*, where an outside connection is made, contaminants from  
33 the environment must be eliminated).
- 34 • Be vandal-resistant.
- 35 • Avoid heating the water due to exterior temperatures and solar radiation.
- 36 • Avoid freezing the water.

## SECTION 2 EVALUATION METHODOLOGY

### 2.1 DECISION TREE

The decision tree is a flow chart for conducting feasibility studies for a non-compliant PWS. The decision tree is shown in Figures 2.1 through 2.4. The tree guides the user through a series of phases in the design process. Figure 2.1 shows Tree 1, which outlines the process for defining the existing system parameters, followed by optimizing the existing treatment system operation. If optimizing the existing system does not correct the deficiency, the tree leads to six alternative preliminary branches for investigation. The groundwater branch leads through investigating existing wells to developing a new well field. The treatment alternatives address centralized and on-site treatment. The objective of this phase is to develop conceptual designs and cost estimates for the six types of alternatives. The work done for this report follows through Tree 1 and Tree 2, as well as a preliminary pass through Tree 4.

Tree 3, which begins at the conclusion of the work for this report, starts with a comparison of the conceptual designs, selecting the two or three alternatives that appear to be most promising, and eliminating those alternatives which are obviously infeasible. It is envisaged that a process similar to this would be used by the study PWS to refine the list of viable alternatives. The selected alternatives are then subjected to intensive investigation, and highlighted by an investigation into the socio-political aspects of implementation. Designs are further refined and compared, resulting in the selection of a preferred alternative. The steps for assessing the financial and economic aspects of the alternatives (one of the steps in Tree 3) are given in Tree 4 in Figure 2.4.

### 2.2 DATA SOURCES AND DATA COLLECTION

#### 2.2.1 Data Search

##### 2.2.1.1 Water Supply Systems

The TCEQ maintains a set of files on public water systems, utilities, and districts at its headquarters in Austin, Texas. The files are organized under two identifiers: a PWS identification number and a Certificate of Convenience and Necessity (CCN) number. The PWS identification number is used to retrieve four types of files:

- CO – Correspondence,
- CA – Chemical analysis,
- MOR – Monthly operating reports (quality/quantity), and
- FMT – Financial, managerial and technical issues.

Figure 2.1  
TREE 1 – EXISTING FACILITY ANALYSIS




Figure 2.2  
TREE 2 – DEVELOP TREATMENT ALTERNATIVES





Figure 2.3


Tree 3 – PRELIMINARY ANALYSIS



End\* -- Discard this alternative and reconsider next most-desirable alternative.

**Develop financial model of top alternative:**  
 Existing rates, revenues, expenditures  
 Existing reserves and debts  
 Future rates, revenues, expenditures  
 Future capital expenditures  
 Future water demands

**Figure 2.4**  
**TREE 4 – FINANCIAL AND MANAGERIAL**



1 The CCN files generally contain a copy of the system’s Certificate of Convenience  
2 and Necessity, along with maps and other technical data.

3 These files were reviewed for the PWS and surrounding systems.

4 The following websites were consulted to identify the water supply systems in the  
5 study area:

- 6 • Texas Commission on Environmental Quality  
7 [www.tnrcc.state.tx.us/iwud/pws/index.cfm](http://www.tnrcc.state.tx.us/iwud/pws/index.cfm). Under “Advanced Search”,  
8 type in the name(s) of the County(ies) in the study area to get a listing of  
9 the public water supply systems.
- 10 • USEPA Safe Drinking Water Information System  
11 [www.epa.gov/safewater/data/getdata.html](http://www.epa.gov/safewater/data/getdata.html).

12 Groundwater control districts were identified on the TWDB web site, which has a  
13 series of maps covering various groundwater and surface water subjects. One of those  
14 maps shows groundwater control districts in the State of Texas.

### 15 **2.2.1.2 Existing Wells**

16 The TWDB maintains a groundwater database available at [www.twdb.state.tx.us](http://www.twdb.state.tx.us) that  
17 has two tables with helpful information. The “Well Data Table” provides a physical  
18 description of the well, owner, location in terms of latitude and longitude, current use,  
19 and for some wells, items such as flow rate, and nature of the surrounding formation.  
20 The “Water Quality Table” provides information on the aquifer and the various chemical  
21 concentrations in the water.

### 22 **2.2.1.3 Surface Water Sources**

23 Regional planning documents were consulted for lists of surface water sources.

### 24 **2.2.1.4 Groundwater Availability Model**

25 GAMs, developed by the TWDB, are planning tools and should be consulted as part  
26 of a search for new or supplementary water sources. The GAM for the northern part of  
27 the Gulf Coast aquifer was investigated as a potential tool for identifying available and  
28 suitable groundwater resources.

### 29 **2.2.1.5 Water Availability Model**

30 The WAM is a computer-based simulation predicting the amount of water that would  
31 be in a river or stream under a specified set of conditions. WAMs are used to determine  
32 whether water would be available for a newly requested water right or amendment. If  
33 water is available, these models estimate how often the applicant could count on water  
34 under various conditions (*e.g.*, whether water would be available only 1 month out of the  
35 year, half the year, or all year, and whether that water would be available in a repeat of  
36 the drought of record).



1 WAMs provide information that assist TCEQ staff in determining whether to  
2 recommend the granting or denial of an application.

### 3 **2.2.1.6 Financial Data**

4 Financial data were collected through a site visit. Data sought included:

- 5 • Annual Budget
- 6 • Audited Financial Statements
  - 7 ○ Balance Sheet
  - 8 ○ Income & Expense Statement
  - 9 ○ Cash Flow Statement
  - 10 ○ Debt Schedule
- 11 • Water Rate Structure
- 12 • Water Use Data
  - 13 ○ Production
  - 14 ○ Billing
  - 15 ○ Customer Counts

### 16 **2.2.1.7 Demographic Data**

17 Basic demographic data were collected from the 2000 Census to establish incomes  
18 and eligibility for potential low cost funding for capital improvements. Median  
19 household income (MHI) and number of families below poverty level were the primary  
20 data points of significance. If available, MHI for the customers of the PWS should be  
21 used. In addition, unemployment data were collected from current U.S. Bureau of Labor  
22 Statistics. These data were collected for the following levels: national, state, and county.

## 23 **2.2.2 PWS Interviews**

### 24 **2.2.2.1 PWS Capacity Assessment Process**

25 A capacity assessment is the industry standard term for an evaluation of a water  
26 system's financial, managerial, and technical capacity to effectively deliver safe drinking  
27 water to its customers now and in the future at a reasonable cost, and to achieve, maintain  
28 and plan for compliance with applicable regulations. The assessment process involves  
29 interviews with staff and management who have a responsibility in the operations and the  
30 management of the system.

31 Financial, managerial, and technical capacity are individual yet highly interrelated  
32 components of a system's capacity. A system cannot sustain capacity without  
33 maintaining adequate capability in all three components.

1        **Financial capacity** is a water system’s ability to acquire and manage sufficient  
2 financial resources to allow the system to achieve and maintain compliance with the  
3 SDWA requirements. Financial capacity refers to the financial resources of the water  
4 system, including but not limited to revenue sufficiency, credit worthiness, and fiscal  
5 controls.

6        **Managerial capacity** is the ability of a water system to conduct its affairs so that the  
7 system is able to achieve and maintain compliance with SDWA regulations. Managerial  
8 capacity refers to the management structure of the water system, including but not limited  
9 to ownership accountability, staffing and organization, and effective relationships to  
10 customers and regulatory agencies.

11       **Technical capacity** is the physical and operational ability of a water system to  
12 achieve and maintain compliance with SDWA regulations. It refers to the physical  
13 infrastructure of the water system, including the adequacy of the source water, treatment,  
14 storage and distribution infrastructure. It also refers to the ability of system personnel to  
15 effectively operate and maintain the system and to otherwise implement essential  
16 technical knowledge.

17       Many aspects of water system operations involve more than one component of  
18 capacity. Infrastructure replacement or improvement, for example, requires financial  
19 resources, management planning and oversight, and technical knowledge. A deficiency  
20 in any one area could disrupt the entire effort. A system that is able to meet both its  
21 immediate and long-term challenges demonstrates that it has sufficient financial,  
22 managerial, and technical capacity.

23       Assessment of the FMT capacity of the PWS was based on an approach developed  
24 by the New Mexico Environmental Finance Center (NMEFC), which is consistent with  
25 the TCEQ FMT assessment process. This methodology was developed from work the  
26 NMEFC did while assisting USEPA Region 6 in developing and piloting groundwater  
27 comprehensive performance evaluations. The NMEFC developed a standard list of  
28 questions that could be asked of water system personnel. The list was then tailored  
29 slightly to have two sets of questions – one for managerial and financial personnel and  
30 one for operations personnel (the questions are included in Appendix A). Each person  
31 who has a role in the FMT capacity of the system is asked the applicable standard set of  
32 questions individually. The interviewees are not given the questions in advance and are  
33 not told the answers others have provided. Also, most of the questions are open ended  
34 type questions so they are not asked in a fashion to indicate what would be the “right” or  
35 “wrong” answer. The interviews last between 45 minutes to 75 minutes depending on the  
36 individual’s role in the system and the length of the individual’s answers.

37       In addition to the interview process, visual observations of the physical components  
38 of the system are made. A technical information form was created to capture this  
39 information. This form is contained in Appendix A. This information was considered  
40 supplemental to the interviews because it could serve as a check on information provided  
41 in the interviews. For example, if an interviewee stated he or she had an excellent  
42 preventative maintenance schedule and the visit to the facility indicated a significant

1 amount of deterioration (more than would be expected for the age of the facility) then the  
2 preventative maintenance program could be further investigated or the assessor could  
3 decide that the preventative maintenance program was inadequate.

4 Following interviews and the observations of the facility, answers that all personnel  
5 provided were compared and contrasted to provide a clearer picture of the true operations  
6 at the water system. The intent was to go beyond simply asking the question, “Do you  
7 have a budget?” to actually finding out if the budget was developed and being used  
8 appropriately. For example, if a water system manager is asked the question, “Do you  
9 have a budget?” he or she may say, “yes” and the capacity assessor is left with the  
10 impression that the system is doing well in this area. However, if several different people  
11 are asked about the budget in more detail, the assessor may find that although a budget is  
12 present, operations personnel do not have input into the budget, the budget is not used by  
13 the financial personnel, the budget is not updated regularly, or the budget is not used in  
14 setting or evaluating rates. With this approach, the inadequacy of the budget would be  
15 discovered and the capacity deficiency in this area would be noted.

16 Following the comparison of answers, the next step is to determine which items that  
17 were noted as a potential deficiency truly have a negative effect on the system’s  
18 operations. If a system has what appears to be a deficiency, but this deficiency is not  
19 creating a problem in terms of the operations or management of the system, it is not  
20 critical and may not need to be addressed as a high priority. As an example, the  
21 assessment may reveal that there appear to be insufficient staff members to operate the  
22 facility. However, it may also be revealed that the system is able to work around this  
23 problem by receiving assistance from a neighboring system so no severe problems result  
24 from the number of staff members. Although staffing may not be ideal, the system does  
25 not need to focus on this particular issue. The system needs to focus on items truly  
26 affecting operations. As an example of this type of deficiency, a system may lack a  
27 reserve account which can then lead the system to delay much-needed maintenance or  
28 repair on their storage tank. In this case, the system needs to address the reserve account  
29 issue so that proper maintenance can be completed.

30 The intent is to develop a list of capacity deficiencies with the greatest impact on the  
31 system’s overall capacity. These are the most critical items to address through follow-up  
32 technical assistance or by the system itself.

### 33 **2.2.2.2 Interview Process**

34 PWS personnel were interviewed by the project team, and each was interviewed  
35 separately. Interview forms were completed during each interview.

## 36 **2.3 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

37 The initial objective for compliance alternative development is to identify a  
38 comprehensive range of possible options that can be evaluated to determine which are the  
39 most promising for implementation. Once the possible alternatives have been identified,

1 they must be defined in sufficient detail so that a conceptual cost estimate (capital and  
2 O&M costs) can be developed. These conceptual cost estimates are used to compare the  
3 affordability of compliance alternatives, and to give a preliminary indication of rate  
4 impacts. Consequently, these costs are pre-planning level and should not be viewed as  
5 final estimated costs for alternative implementation. The basis for the unit costs used for  
6 the compliance alternative cost estimates is summarized in Appendix B. Other  
7 non-economic factors for the alternatives, such as reliability and ease of implementation,  
8 are also addressed. The compliance alternative conceptual cost estimates are provided in  
9 Appendix C. Cost analyses for shared solutions with other PWSs in the area are provided  
10 in Appendix G.

### 11 **2.3.1 Existing PWS**

12 The neighboring PWSs were identified, and the extents of their systems were  
13 investigated. PWSs farther than 15 miles from the non-compliant PWS were not  
14 considered because the length of pipelines required would make the alternative cost  
15 prohibitive. The quality of water provided was also investigated. For neighboring PWSs  
16 with compliant water, options for water purchase and/or expansion of existing well fields  
17 were considered. The neighboring PWSs with non-compliant water were considered as  
18 possible partners in sharing the cost for obtaining compliant water either through  
19 treatment or developing an alternate source.

20 The neighboring PWSs were investigated to get an idea of the water sources they use  
21 and the quantity of water they might have available for sale. They were contacted to  
22 identify key locations in their systems where a connection might be made to obtain water,  
23 and to explore on a preliminary basis their willingness to partner or sell water. Then, the  
24 major system components that would be required to provide compliant water were  
25 identified. The major system components included treatment units, wells, storage tanks,  
26 pump stations, and pipelines.

27 Once the major components were identified, a preliminary design was developed to  
28 identify sizing requirements and routings. A capital cost estimate was then developed  
29 based on the preliminary design of the required system components. An annual O&M  
30 cost was also estimated to reflect the change in O&M expenditures that would be needed  
31 if the alternative was implemented.

32 Non-economic factors were also identified. Ease of implementation was considered,  
33 as well as the reliability for providing adequate quantities of compliant water. Additional  
34 factors were whether implementation of an alternative would require significant increase  
35 in the management or technical capability of the PWS, and whether the alternative had  
36 the potential for regionalization.

### 37 **2.3.2 New Groundwater Source**

38 It was not possible in the scope of this study to determine conclusively whether new  
39 wells could be installed to provide compliant drinking water. In order to evaluate  
40 potential new groundwater source alternatives, three test cases were developed based on

1 distance from the PWS intake point. The test cases were based on distances of 10 miles,  
2 5 miles, and 1 mile. It was assumed that a pipeline would be required for all three of the  
3 test cases, and a storage tank and pump station would be required for the 10-mile and  
4 5-mile alternatives. It was also assumed that new wells would be installed, and that their  
5 depths would be similar to the depths of the existing wells, or other existing drinking  
6 water wells in the area.

7 A preliminary design was developed to identify sizing requirements for the required  
8 system components. A capital cost estimate was then developed based on the  
9 preliminary design of the required system components. An annual O&M cost was also  
10 estimated to reflect the change (*i.e.*, from current expenditures) in O&M expenditures  
11 that would be needed if the alternative was implemented.

12 Non-economic factors were also identified. Ease of implementation was considered,  
13 as well as the reliability for providing adequate quantities of compliant water. Additional  
14 factors were whether implementation of an alternative would require significant increase  
15 in the management or technical capability of the PWS, and whether the alternative had  
16 the potential for regionalization.

### 17 **2.3.3 New Surface Water Source**

18 New surface water sources were investigated. Availability of adequate quality water  
19 was investigated for the main rivers in the study area, as well as the major reservoirs.  
20 TCEQ WAMs were inspected, and the WAM was run, where appropriate.

### 21 **2.3.4 Treatment**

22 Treatment technologies considered potentially applicable are adsorption and  
23 coagulation/filtration for arsenic removal since they are proven technologies with  
24 numerous successful installations that can be implemented with relatively low cost.  
25 Reverse osmosis and ion exchange were not deemed to be applicable in this study, since  
26 they are typically more expensive and more difficult to operate.

27 Adsorption treatment is considered for central treatment alternatives, as well as POU  
28 and POE alternatives. Coagulation/filtration treatment is considered for central treatment  
29 alternatives only. Adsorption treatment produces a spent media solid waste stream, and  
30 both adsorption and coagulation/filtration treatment produce a liquid backwash stream.  
31 The backwash volume from adsorption is much less than from coagulation/filtration. As  
32 a result, the treated volume of water is less than the volume of raw water that enters the  
33 treatment system. The treatment units were sized based on flow rates, and capital and  
34 annual O&M cost estimates were made based on the size of the treatment equipment  
35 required. Neighboring non-compliant PWSs were identified to look for opportunities  
36 where the costs and benefits of central treatment could be shared between systems.

37 Non-economic factors were also identified. Ease of implementation was considered,  
38 as well as the reliability for providing adequate quantities of compliant water. Additional  
39 factors were whether implementation of an alternative would require significant increase

1 in the management or technical capability of the PWS, and whether the alternative had  
2 the potential for regionalization.

## 3 **2.4 COST OF SERVICE AND FUNDING ANALYSIS**

4 The primary purpose of the cost of service and funding analysis was to determine the  
5 financial impact of implementing compliance alternatives, primarily by examining the  
6 required rate increases, and analyzing the fraction of household income that water bills  
7 consume. The current financial situation was also reviewed to determine what rate  
8 increases were necessary for the PWS to achieve or maintain financial viability.

### 9 **2.4.1 Financial Feasibility**

10 A key financial metric is comparison of the average annual household water bill for a  
11 PWS customer to the MHI for the area. MHI data from the 2000 Census were used at the  
12 most detailed level available for the community. Typically, county level data are used  
13 for small water utilities due to small population sizes. Annual water bills were  
14 determined for existing base conditions and included consideration of additional rate  
15 increases needed under current conditions. Annual water bills were also calculated after  
16 adding incremental capital and operating costs for each of the alternatives to determine  
17 feasibility under several potential funding sources.

18 Additionally, the use of standard ratios provided insight into the financial condition  
19 of any business. Three ratios are particularly significant for water utilities:

- 20 • Current Ratio = current assets divided by current liabilities provides  
21 insight into the ability to meet short-term payments. For a healthy utility,  
22 the value should be greater than 1.0.
- 23 • Debt to Net Worth Ratio = total debt divided by net worth shows to what  
24 degree assets of the company have been funded through borrowing. A  
25 lower ratio indicates a healthier condition.
- 26 • Operating Ratio = total operating revenues divided by total operating  
27 expenses show the degree to which revenues cover ongoing expenses.  
28 The value is greater than 1.0 if the utility is covering its expenses.

### 29 **2.4.2 Median Household Income**

30 The 2000 Census was used as the basis for MHI. In addition to consideration of  
31 affordability, MHI may also be an important factor for sources of funds for capital  
32 programs needed to resolve water quality issues. Many grant and loan programs are  
33 available to lower income rural areas, based on comparisons of local income to statewide  
34 incomes. In the 2000 Census, MHI for the State of Texas was \$39,927, compared to the  
35 U.S. level of \$41,994. For service areas with a sparse population base, county data may  
36 be the most reliable and, for many rural areas, correspond to census tract data.

### 1   **2.4.3   Annual Average Water Bill**

2       The annual average household water bill was calculated for existing conditions and  
3 for future conditions incorporating the alternative solutions. Average residential  
4 consumption was estimated and applied to the existing rate structure to estimate the  
5 annual water bill. The estimates were generated from a long-term financial planning  
6 model that detailed annual revenue, expenditure, and cash reserve requirements over a  
7 30-year period.

### 8   **2.4.4   Financial Plan Development**

9       The financial planning model used available data to establish base conditions under  
10 which the system operates. The model included, as available:

- 11       • Accounts and consumption data
- 12       • Water tariff structure
- 13       • Beginning available cash balance
- 14       • Sources of receipts:
  - 15           ○ Customer billings
  - 16           ○ Membership fees
  - 17           ○ Capital Funding receipts from:
    - 18               ❖ Grants
    - 19               ❖ Proceeds from borrowing
- 20       • Operating expenditures:
  - 21           ○ Water purchases
  - 22           ○ Utilities
  - 23           ○ Administrative costs
  - 24           ○ Salaries
- 25       • Capital expenditures
- 26       • Debt service:
  - 27           ○ Existing principal and interest payments
  - 28           ○ Future principal and interest necessary to fund viable operations
- 29       • Net cash flow
- 30       • Restricted or desired cash balances:
  - 31           ○ Working capital reserves (based on 1-4 months of operating expenses)
  - 32           ○ Replacement reserves to provide funding for planned and unplanned
  - 33           repairs and replacements

1 From the model, changes in water rates were determined for existing conditions and  
2 for implementing the compliance alternatives.

### 3 **2.4.5 Financial Plan Results**

4 Results from the financial planning model were summarized in two ways: by  
5 percentage of household income and by total water rate increase necessary to implement  
6 the alternatives and maintain financial viability.

#### 7 **2.4.5.1 Funding Options**

8 Results, summarized in Table 4.8, show the following according to alternative and  
9 funding source:

- 10 • Percentage of the annual MHI that the average annual residential water  
11 bill represents.
- 12 • The first year in which a water rate increase would be required.
- 13 • The total increase in water rates required, compared to current rates.

14 Water rates resulting from the incremental capital costs of the alternative solutions  
15 were examined under a number of funding options. The first alternative examined was  
16 always funded from existing reserves plus future rate increases. Several funding options  
17 were analyzed to frame a range of possible outcomes.

- 18 • Grant funds for 100 percent of required capital. In this case, the PWS was  
19 only responsible for the associated O&M costs.
- 20 • Grant funds for 75 percent of required capital, with the balance treated as  
21 if revenue bond funded.
- 22 • Grant funds for 50 percent of required capital, with the balance treated as  
23 if revenue bond funded.
- 24 • State revolving fund loan at the most favorable available rates and terms  
25 applicable to the communities.
- 26 • If local MHI > 75 percent of state MHI, standard terms, currently at  
27 3.8 percent interest for non-rated entities. Additionally:
  - 28 ○ If local MHI = 70-75 percent of state MHI, 1 percent interest  
29 rate on loan.
  - 30 ○ If local MHI = 60-70 percent of state MHI, 0 percent interest  
31 rate on loan.
  - 32 ○ If local MHI = 50-60 percent of state MHI, 0 percent interest  
33 and 15 percent forgiveness of principal.
  - 34 ○ If local MHI less than 50 percent of state MHI, 0 percent  
35 interest and 35 percent forgiveness of principal.
- 36 • Terms of revenue bonds assumed to be 25-year term at 6.0 percent interest  
37 rate.



## 2.4.5.2 General Assumptions Embodied in Financial Plan Results

The basis used to project future financial performance for the financial plan model included:

- No account growth (either positive or negative).
- No change in estimate of uncollectible revenues over time.
- Average consumption per account unchanged over time.
- No change in unaccounted for water as percentage of total (more efficient water use would lower total water requirements and costs).
- No inflation included in the analyses (although the model had provisions to add escalation of O&M costs, doing so would mix water rate impacts from inflation with the impacts from the alternatives being examined).
- Minimum working capital fund established for each district, based on specified months of O&M expenditures.
- O&M for alternatives begins 1 year after capital implementation.
- Balance of capital expenditures not funded from primary grant program is funded through debt (bond equivalent).
- Cash balance drives rate increases, unless provision chosen to override where current net cash flow is positive.

## 2.4.5.3 Interpretation of Financial Plan Results

Results of the financial plan model, as presented in Section 4 (Table 4.8), show the percentage of MHI represented by the annual water bill that resulted from any rate increases necessary to maintain financial viability over time. In some cases, this may require rate increases even without implementing a compliance alternative (the no action alternative). The table shows any increases such as these separately. The results table shows the total increase in rates necessary, including both the no action alternative increase and any increase required for the alternative. For example, if the no action alternative required a 10 percent increase in rates and the results table shows a rate increase of 25 percent, then the impact from the alternative was an increase in water rates of 15 percent. Likewise, the percentage of household income in the table reflects the total impact from all rate increases.

## 2.4.5.4 Potential Funding Sources

A number of potential funding sources exist for small public water systems. Both state and federal agencies offer grant and loan programs to assist rural communities in meeting their infrastructure needs.

Within Texas, the following state agencies offer financial assistance if needed:

- Texas Water Development Board,
- Office of Rural Community Affairs, and

- 1                   • Texas Department of Health (Texas Small Towns Environment Program).  
2           Small rural communities can also get assistance from the federal government. The  
3 primary agencies providing aid are:  
4                   • United States Department of Agriculture, Rural Utilities Service, and  
5                   • United States Housing and Urban Development.


1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18

## SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS

### 3.1 ARSENIC IN THE GULF COAST AQUIFER

The Gulf Coast aquifer parallels the Texas Gulf Coast and extends from the Texas-Louisiana border to the Rio Grande. Subunits of the Gulf Coast aquifer are, from oldest to youngest, the Jasper, Evangeline, and Chicot aquifers. The aquifer is a leaky artesian system composed of middle to upper Tertiary and younger interbedded and hydrologically connected layers of clay, silt, sand, and gravel (Ashworth and Hopkins 1992). The PWS wells of concern in Brazoria County are completed in the Chicot aquifer. Figure 3.1 shows detectable arsenic concentrations in the Gulf Coast aquifer from the TWDB database, and Figure 3.2 shows arsenic concentrations from the National Geochemical Database, also known as the National Uranium Resource Evaluation (NURE) database (<http://pubs.usgs.gov/of/1997/ofr-97-0492/index.html>).

**Figure 3.1 Detectable Arsenic Concentrations in Groundwater  
(TWDB Database)**




Source: (TWDB database, analyses from 1987 through 2004)

The most recent value is shown for each well (number of samples shown is 503).

1  
2

**Figure 3.2 Detectable Arsenic Concentrations in Groundwater  
(NURE Database)**



3  
4

Source: NURE database, analyses from 1976 through 1980

5  
6

In the NURE database there is one sample per well (number of samples shown is 3,920).

7

### **3.2 GEOLOGY OF BRAZORIA COUNTY**

8  
9  
10  
11  
12  
13  
14  
15

Geologic units included in the Chicot aquifer are the Pleistocene formations, Willis, Lissie, and Beaumont (Doering 1935; Baker 1979). Since Pleistocene time, packages of fluvial sediments representing successively younger progradational cycles have been deposited along the Texas Gulf Coast (Blum 1992). The fluvial sediments, ranging in texture from gravel to clay, contain very little intergranular cement. The older parts of this depositional sequence are more coarse grained and dip 10 to 25 feet per mile (Willis Formation), whereas the younger units are more fine grained and dip only approximately 1 foot per mile (Beaumont Formation) (Doering 1935).

16  
17  
18  
19  
20  
21  
22  
23

The Willis Formation was first described as a formal stratigraphic unit by Doering (1935). It is red sand with minor amounts of coarse sand and gravel that unconformably overlie Pliocene-age clay layers of the Fleming Formation in the vicinity of Brazoria County. In this area, the Willis Formation has a 30- to 40-foot thick gravel layer at the base that can provide an ample supply of usable quality water. The Lissie Formation is finer grained than the underlying Willis Formation; it contains interbedded layers of light-colored, fine-grained sand, clayey sand, and sandy clay (Doering 1935). Although the Beaumont Formation as a whole is much more fine grained than directly underlying

1 formations, it contains localized distributary channel deposits. The inclusive list of  
2 lithologies contained in the Beaumont Formation is clay, limey clay, sandy clay, clayey  
3 sand, and fine-grained sand (Doering 1935). Water wells completed in the Beaumont  
4 Formation section of the Chicot aquifer are usually no deeper than 75 to 100 feet and  
5 probably do not provide large quantities of water.

6 The lithology of geologic units within the Chicot aquifer is similar to that of the  
7 underlying Evangeline aquifer, which makes it difficult for drillers to determine in which  
8 aquifer they are completing water wells along the Texas Gulf Coast. The combined  
9 thickness of geologic units in the Chicot aquifer in the vicinity of Brazoria County varies  
10 among different researchers between 400 and 1,200 feet. According to Baker (1979), the  
11 maximum thickness of the entire Gulf Coast aquifer along the northern Gulf Coast is  
12 approximately 1,300 feet.

13 The 11 PWS wells of concern in Brazoria County are identified as being in the  
14 Chicot aquifer; completion depths are grouped around 300, 400, and 600 feet. It is  
15 possible the deeper wells are completed in the Evangeline aquifer or that screened  
16 intervals in these wells span both Chicot and Evangeline aquifers. A recognized geologic  
17 source of arsenic in groundwater is volcanic ash. Arsenic is often associated with other  
18 chemical elements such as fluoride, vanadium, molybdenum, selenium, and uranium.  
19 The association is generally seen at the subregional level, although not necessarily at the  
20 well level because of different geochemical behavior of individual elements. There are  
21 no reports of volcanic material in the geologic units that compose the Chicot aquifer.  
22 However, layers of bentonite (altered volcanic ash beds) and devitrified ash, have been  
23 recognized in some parts of the Evangeline aquifer especially in South Texas. The major  
24 geologic unit of the Evangeline aquifer in South Texas is the Goliad Formation, but it is  
25 not present in outcrops north of the Colorado River (Hoel 1982). General hydrologic  
26 patterns with upward cross-formational flow along the coast support this hypothesis.  
27 However, other sources of arsenic are also possible. Arsenic hot spots exist in older  
28 formations (Catahoula and Goliad); some of those have eroded and are now part of the  
29 Chicot aquifer sediment. Additional potential sources include upwelling of highly  
30 mineralized water from salt domes. However, the spatial mismatch between salt dome  
31 distribution and areas with high arsenic concentration, as well as the lack of correlation  
32 between chloride and arsenic concentrations, precludes such an association, as discussed  
33 later.


34 Using uranium and radioactivity as proxies for arsenic sources, geophysical logs in  
35 Brazoria County near the PWS wells were analyzed to assess potential linkages between  
36 geologic units and elevated arsenic concentrations. Given the common association  
37 between uranium deposits and occurrences of arsenic, it was reasonable to inspect local  
38 oilfield geophysical logs for evidence of radioactive fluids in sandstone strata at depths  
39 sufficiently shallow to potentially contact fresh groundwater. A total of 40 hydrocarbon  
40 wells were identified with geophysical well logs that had (1) recorded geophysical  
41 responses within the upper 500 feet of the subsurface; and (2) latitude/longitude  
42 coordinates. Of these wells, 17 were selected on the basis of proximity to the  
43 aforementioned PWS wells. Among these 17 hydrocarbon wells, only one provided the

1 gamma ray and resistivity logs necessary for analysis. Wells range in depth between 295  
2 and 625 feet and are completed in the Chicot aquifer. Only one well log for the area  
3 recorded sufficiently shallow data and also showed gamma ray and resistivity responses  
4 necessary to detect radioactively elevated pore fluids in the geologic section. The well is  
5 the Kilmarovo Jamison located at west longitude 95.3483° and north latitude 29.2586°.  
6 The nearest PWS wells are operated by the City of Danbury a few miles to the south of  
7 the logged well. Elevated gamma ray values greater than 150 American Petroleum  
8 Institute units occurred in sandstone beds with resistivities greater than 10 ohms at  
9 1,520- to 1,550-foot depths in the Jamison well. An additional bed containing fluids with  
10 elevated radioactivity occurred at the depth of approximately 177 feet. Both of these  
11 stratigraphic intervals dip toward the south and are, therefore, at greater depths in more  
12 southerly locations. The City of Danbury PWS wells are completed at depths of 295 to  
13 304 feet. Unless groundwater flow is upward between excessively radioactive strata  
14 contacted by the Jamison well and the Danbury PWS wells, it appears unlikely that  
15 radioactive fluids and associated ionic constituents, including possible arsenic, would  
16 contact the Chicot aquifer in the Danbury area.

### 17 3.3 GENERAL TRENDS IN ARSENIC CONCENTRATIONS

18 The geochemistry of arsenic is described in Appendix E. A general analysis of  
19 arsenic trends in the vicinity of Brazoria County was conducted to assess spatial trends,  
20 as well as correlations with other water quality parameters. Arsenic measurements from  
21 the TWDB database, the TCEQ database, and from a subset of the National Geochemical  
22 Database, also known as NURE (National Uranium Resource Evaluation) database, were  
23 used to assess arsenic trends. Figures 3.3 and 3.4 show spatial distribution of arsenic  
24 concentrations from TWDB (Figure 3.3) and NURE (Figure 3.4) databases.


25 **Figure 3.3 Spatial Distribution of Arsenic Concentrations (TWDB Database)**



Source: TWDB database

26  
27

1 **Figure 3.4 Spatial Distribution of Arsenic Concentrations (NURE Database)**




Source: NURE database

4 The databases were queried in an area delineated by the following coordinates:  
5 bottom left, -97.45, 28.18; top right, -94.30, 30.64. Seven hundred thirty measurements  
6 were extracted from the TWDB database. Measurements representing the most recent  
7 arsenic measurement taken at a specific well, and wells not in the Gulf Coast aquifer  
8 were excluded. The NURE database contained 2,118 groundwater (sample type 03)  
9 arsenic measurements within the defined boundary. Because the wells have no aquifer  
10 identifier, no measurements were excluded.


11 Relationships between arsenic and well depth, pH, SO<sub>4</sub>, fluoride, chloride, TDS,  
12 dissolved oxygen, phosphorus, iron, selenium, boron, vanadium, uranium, and  
13 molybdenum, were evaluated using data separately from the NURE and TWDB  
14 databases. Correlations between arsenic concentrations and most parameters were weak  
15 (r square values < 0.1); the highest correlation was found between arsenic and  
16 molybdenum. The relationship between the probability of arsenic > 10 micrograms per  
17 liter (µg/L) and molybdenum concentration levels is shown for the NURE (Figure 3.5)  
18 and TWDB (Figure 3.6) databases.

1 **Figure 3.5 Relationship Between Arsenic and Molybdenum (NURE Database)**



2  
3 Source: NURE database

4  
5 **Figure 3.6 Relationship Between Arsenic and Molybdenum (TWDB Database)**




6  
7 Source: TWDB database

8 N represents the number of measurements used from each database. Numbers on top  
9 of the graph columns show the number of arsenic measurements exceeding 10  $\mu\text{g/L}$  and  
10 total number of measurements in each bin. For example, “7/76” in the bin of  
11 molybdenum > 20 means that seven of 76 arsenic measurements were greater than  
12 10  $\mu\text{g/L}$ .

13 Elevated arsenic concentrations and pH are also related (Figure 3.7). The absence of  
14 high arsenic concentrations (>10  $\mu\text{g/L}$ ) at pH less than 6.5 is notable.



1 **Figure 3.7 Relationship Between High Arsenic Concentrations and pH**




2

3 Correlations between arsenic, molybdenum, and pH suggest natural sources of  
4 elevated arsenic in Brazoria County; however, data are insufficient to make this  
5 conclusion definitively.

6 **3.4 ARSENIC AND POINT SOURCES OF CONTAMINATION**

7 Information regarding the location of potential source of contamination (PSOC) is  
8 collected as part of the TCEQ Source Water Assessment Program. Arsenic  
9 concentrations from TWDB (Figure 3.8) and NURE (Figure 3.9) databases were  
10 compared with PSOC coverage. A density map of PSOCs was generated (number of  
11 PSOCs per square kilometer), and PSOC density values were compared with arsenic  
12 concentrations from the NURE database.

13 **Figure 3.8 Potential Sources of Arsenic Contamination and Arsenic**  
14 **Concentrations (TWDB Database)**




Source: TWDB database

15  
16

1  
2

**Figure 3.9 Potential Sources of Arsenic Contamination and Arsenic Concentrations (NURE Database)**



3  
4

Source: NURE database


5 No correlation was found between high arsenic concentrations and density of  
6 potential sources of contamination, strengthening the conclusion that sources of arsenic  
7 in this area are natural.

### 8 3.5 SALT DOMES

9 Elevated arsenic concentrations were not correlated with salt dome locations  
10 (Figure 3.10).

11

**Figure 3.10 Salt Dome Locations and Arsenic Concentrations**




12  
13

Source: TWDB and NURE databases

1 **3.6 CORRELATION WITH DEPTH**

2 Arsenic concentrations were compared with well depth in an attempt to assess  
3 relationships between elevated arsenic concentrations and specific stratigraphic units  
4 (Figure 3.11). Data do not show a definite correlation between arsenic levels and well  
5 depth. Lack of geologic descriptions and geophysical logs makes it difficult to further  
6 evaluate relationships between arsenic concentrations and depth distributions of geologic  
7 units.

8 **Figure 3.11 Relationship Between Arsenic Concentrations and Well Depth**




9

10 The most recent sample was used for each well. N represents total number of wells  
11 in the analysis (719), and numbers above each column represent number of arsenic  
12 measurements > 10 µg/L and total number of analyses in the bin. For example, 5/181  
13 represents five samples > 10 µg/L out of 181 analyses at a well depth between 0 and  
14 200 feet.

15 **3.7 DETAILED ASSESSMENT**

16 There are eight wells with arsenic samples > 10 µg/L near the assessed PWS wells,  
17 seven from the TCEQ database, and one from the TWDB database (Figure 3.12).  
18 Samples from the TCEQ PWS database include only those that could be related to a  
19 specific well.

1 **Figure 3.12 Arsenic Concentrations in the Vicinity of PWS Wells**



2

3 Arsenic samples are from TWDB and TCEQ databases. The maximum arsenic  
4 concentration is shown for each well. PWS wells from the TCEQ database include two  
5 types of samples: raw (related to a single well), and entry point (taken from a single  
6 entry point related to a single well). Table 3.1 details well and screen depths of PWS  
7 wells with high arsenic concentrations (> 10 µg/L).

8 **Table 3.1 Maximum and Minimum Arsenic Concentrations**

Water Source	Max. – Min. – Number As samples (µg/L)	Well Depth (feet)	Screen Depth (feet)	Geology	Source
G0200494A	16.7 – 14.2 – 2	419	399 – 419	NA	TCEQ
G0200011B	11.3 – 6.0 – 2	235	160 – 230	NA	TCEQ
G0200036A	14.8 – 9.2 – 3	324	307 – 323	NA	TCEQ
G0200566A	10.3 – 9.4 – 4	310	NA	NA	TCEQ
G0200389A	11.7 – 8.3 – 2	374	NA	NA	TCEQ
G0200408A	10.6 – 10.6 – 1	400	NA	NA	TCEQ
G0200570A	55.2 – 8 – 3	740	710 – 740	NA	TCEQ
G537904	16 – 16 – 1	400	NA	NA	TWDB

1 Well depths range from 235 to 740 feet, and wells are screened between 160 and  
2 740 feet. These large ranges in depth make it difficult to make a definitive statement  
3 regarding local correlation of arsenic with well or screen depth. Lack of geologic  
4 descriptions of these wells also prohibits a more comprehensive evaluation of  
5 relationships between arsenic concentrations and geology.

### 6 **3.7.1 Sandy Meadow Estates Subdivision (PWS 0200335)**

7 There are two wells are in the Sandy Meadow Estates PWS, wells G0200335A and  
8 G0200335B. The depth of Well A, 624 feet, is screened between 604 and 624 feet.  
9 Well B has a depth of 625 feet and is screened between 600 and 625 feet. Both wells are  
10 related to the same entry point of the water supply, thus making it difficult to separate the  
11 source of arsenic. Table 3.2 summarizes arsenic concentrations measured at the PWS.


12 Groundwater arsenic concentrations can have a high degree of spatial variability.  
13 Because of this variability, an investigation of the existing wells should be conducted to  
14 determine whether both or only one produces non-compliant water. If one well is found  
15 to produce compliant water, as much production as possible should be shifted to the  
16 compliant well. Also, if one well is found to produce compliant water, the wells should  
17 be compared in terms of depths and well logs to try and identify differences that could be  
18 responsible for the elevated concentration of arsenic in the other well. Then if blending  
19 of water from the existing wells does not produce a sufficient quantity of compliant  
20 water, it may be possible to install a new well similar to the existing compliant well that  
21 also would provide compliant water.

22 **Table 3.2 Arsenic Concentrations in the Sandy Meadow Estates PWS**

Date	As (µg/L)	Source
4/1/1997	20.1	TCEQ
4/1/1997	20.1	TCEQ
2/17/1998	16.9	TCEQ
5/16/2001	18.8	TCEQ
3/11/2004	17.3	TCEQ
2/17/2005	19	TCEQ


23 Six arsenic measurements from the TCEQ database were collected at the PWS  
24 between 1997 and 2005 (Table 3.2). All samples had elevated arsenic (>10 µg/L).  
25 Figure 3.13 shows arsenic concentrations from TWDB and NURE databases measured at  
26 wells in 5- and 10-km buffers of the PWS wells.

1 **Figure 3.13 Arsenic Concentrations in 5- and 10-km Buffers of Sandy Meadow**  
2 **Estates PWS Wells (TWDB and NURE Databases)**



3  
4  
5 The top figure shows arsenic concentrations from the TWDB database. Wells are  
6 symbolized by maximum concentrations, and labels show the maximum, minimum, and  
7 number of samples, as well as first and last sample years. Values from the NURE  
8 database were taken between 1976 and 1980. Negative values are less than detection  
9 limit (0.5  $\mu\text{g/L}$ ). One well, in the 10-km buffer range from the TWDB database, had high  
10 arsenic levels (16  $\mu\text{g/L}$ ). In addition to the TWDB and NURE databases, samples from  
11 the TCEQ PWS database were analyzed (Figure 3.14).

1 **Figure 3.14 Arsenic Concentrations in 5- and 10-km Buffers of Sandy Meadow**  
2 **Estates PWS Wells (TCEQ Database)**



3  
4 Two types of samples were used in the analysis: raw samples that can be related to a  
5 single well and entry-point samples taken from a single entry point, which can be related  
6 to a single well. Table 3.3 details arsenic concentrations, well depth, and screen depths  
7 of wells in 5- and 10-km buffers of PWS wells.

8 **Table 3.3 Maximum and Minimum Arsenic Concentrations in the 5- and 10-km**  
9 **Buffers of the Sandy Meadow Estates PWS**

Water Source	Max. – Min. – No. As samples (µg/L)	Well Depth (feet)	Screen Depth (feet)
G0200335A	20.1 – 16.9 – 6	624	604-624
G0200335B		625	600-625
G0200566A	10.3 – 9.4 – 4	310	NA
G0200036A	14.8 – 9.2 – 3	324	307-323
G0200527B	6.5 – 6.5 – 1	159	NA
G0200410A	2.0 – 2 – 2	210	NA
G0200573A	2.7 – 2.3 – 2	510	NA
G0200423A	2.0 – 2 – 1	166	NA
G0200146A	2.0 – 2 – 3	147	NA
G0200243A	2.0 – 2 – 1	400	NA
G0200570A	55.2 – 8 – 3	740	710-740

10  
11 In addition to assessed PWS wells (G0200335A and G0200335B), three wells  
12 (G0200566A, G0200036A, and G0200570A) have concentrations >10 µg/L, and one

- 1 well (G0200527B) has concentrations  $>5$   $\mu\text{g/L}$ . Wells with higher concentrations have
- 2 well depths between 310 and 740 feet and screen depths between 307 and 740 feet.



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34

## **SECTION 4**

### **ANALYSIS OF THE SANDY MEADOW ESTATES PWS**

#### **4.1 DESCRIPTION OF EXISTING SYSTEM**



##### **4.1.1 Existing System**

The Sandy Meadow Estates PWS is shown on Figure 4.1. The system consists of two wells: G0200335A and G0200335B, also referred to as Well A and Well B, respectively. The wells are completed in the Lower Chicot aquifer (Code 112CHCT). Well depths are 624 and 625 feet, respectively. The water system includes two submersible pumps (50 gpm at Well A and 60 gpm at Well B), one ground storage tank (20,000 gallons), two service pumps, and one pressure tank (2,500 gallons). The system has a peak production capacity of 0.151 million gallons per day (mgd).

Arsenic has been detected in the Sandy Meadow Estates water supply at concentrations above the impending MCL of 0.01 mg/L, effective January 23, 2006. Although the current MCL for arsenic (0.05 mg/L) has not been exceeded at this system, all PWSs should take actions to reach the new regulatory health standard by the January 2006 date. Arsenic concentrations at Sandy Meadow Estates ranged between 0.0169 and 0.019 mg/L for samples collected between February 17, 1998 and February 17, 2005. Manganese has also been reported above the secondary MCL (SMCL) of 0.05 mg/L. SMCLs are established as guidelines for nuisance chemicals that do not present any type of health risk; for manganese, the noticeable effects above the SMCL include black to brown color, black staining, and bitter metallic taste. Manganese concentrations were between 0.0566 and 0.079 mg/L for samples collected between February 17, 1998 and March 11, 2004.

Groundwater from the wells is treated by hypochlorination for disinfection and polyphosphate injection to sequester manganese prior to discharge into the ground storage tank. The treatment employed is not appropriate or effective for removal of arsenic, so optimization is not expected to be effective at increasing arsenic removal.

There is, however, a potential opportunity for system optimization to reduce arsenic concentrations. The system has two wells, and since arsenic concentrations can vary significantly between wells, arsenic concentrations should be determined for each well. If one of the wells happens to produce water with acceptable arsenic levels, as much production as possible should be shifted to that well. It may also be possible to identify arsenic-producing strata through comparison of well logs or through sampling of water produced by various strata within the well screen interval.



**Figure 4.1**  
**Sandy Meadow Estates Pipeline Alternatives**

1 Basic system information is as follows:

- 2 • Population served: 170
- 3 • Connections: 56
- 4 • Average daily flow rate: 0.016 mgd
- 5 • Maximum flow rate: 0.154 mgd

#### 6 **4.1.2 Capacity Assessment for the Orbit Systems, Inc.**

7 Sandy Meadow Estates is owned and operated by Orbit Systems, Inc. (Orbit). The  
8 following personnel associated with Orbit were interviewed:

- 9 • Peggy Paul, Environmental Engineer.
- 10 • Jeff Walker, Operations Supervisor.

11 All interviews were conducted in person.

##### 12 **4.1.2.1 General Structure**

13 Orbit is an investor-owned utility. Management includes a President, an Operations  
14 Supervisor, and an Engineer who handle all of the management, engineering, and  
15 financial issues for the system. These individuals also establish policies and supervise  
16 the three water operators. There is also an office worker who handles paperwork, phone  
17 calls, and other related issues.

18 Orbit manages 33 regional water systems. The population ranges from 170 for the  
19 smallest system to 450 for the largest system. The Orbit systems included in this study –  
20 Sandy Meadow Estates, Rosharon Township, Rosharon Road Estates, Grasslands, and  
21 Mark V Estates – had approximately 56, 85, 76, 150, and 94 connections, respectively,  
22 and populations of 170, 255, 230, 450, and 285, respectively. All are metered  
23 groundwater systems.

24 The managerial structure of all the water systems is the same, so only one capacity  
25 assessment was completed that covers all of the Orbit PWSs.

##### 26 **4.1.2.2 General Assessment of Capacity**

27 Overall, the system had an adequate level of capacity. The system has some areas of  
28 needed improvement to be able to address its future compliance issues. However, the  
29 system has many positive aspects.

##### 30 **4.1.2.3 Positive Aspects of Capacity**

31 In assessing a system's overall capacity, it is important to look at all aspects –  
32 positive and negative. It is important for systems to understand those characteristics that  
33 are working well so that those activities can be continued or strengthened. In addition,  
34 these positive aspects can assist the system in addressing the capacity deficiencies or  
35 concerns. As an example, this particular system has been able to manage 33 regional

1 small water systems so that greater efficiencies are achieved through economy of scale.  
2 The factors particularly important for Orbit are listed below.

- 3 • Staff Longevity – The system is owned and the main managerial positions  
4 are staffed by one family. As such, the system has been able to maintain  
5 the same President, Engineer, and Operator/Operations Supervisor for  
6 over 20 years. This longevity in staff creates a long-term memory of the  
7 system components and system characteristics. The staff is very dedicated  
8 to the system. Other than the general operators, the system has  
9 experienced little turnover.
- 10 • Communication – There is excellent communication among the staff.  
11 There is also good communication between the system and the customers.  
12 Communication occurs through Consumer Confidence Reports, personal  
13 visits with customers who have a complaint, and monthly billing  
14 statements.
- 15 • In-House Expertise – The system has an engineer on staff that is able to  
16 meet the systems engineering needs. Also, the system installs many of its  
17 own lines (less than 6 inches in diameter). Part of the reason for doing so  
18 is to ensure that the lines are installed properly. In the past, the system has  
19 had problems with poorly constructed lines that were put in by private  
20 developers.
- 21 • Planning for System Growth – The systems are installed with  
22 consideration given to potential future connections. All future  
23 connections are installed initially and the lines are sized accordingly to  
24 ensure that build-out of the developments can be accommodated easily.
- 25 • Regional Nature of the System – Orbit operates 33 regional water systems.  
26 There is a single rate structure to cover all of the systems. This combined  
27 rate allows the overall system to create an economy of scale and an  
28 efficiency that helps all of the systems. As new rules are introduced that  
29 will require more complex treatment, the ability to take advantage of this  
30 regional approach will be critical. Orbit is willing to explore  
31 regionalization opportunities with neighboring systems who wish to work  
32 with them.
- 33 • The system maintains a good set of maps and uses them regularly. The  
34 maps are updated as the system is changed. Some private systems that  
35 were purchased did not have good mapping of the system components.  
36 Orbit is working on improving these maps over time.

#### 37 **4.1.2.4 Capacity Deficiencies**

38 The following capacity deficiencies were noted in conducting the assessment.

- 39 • Training – The managerial staff does not regularly attend training. This  
40 lack of training may become a greater issue as new and more complex  
41 rules come into place. None of the staff, other than the President, are  
42 members of any water-related organization. Attendance at organization

1 meetings could help keep the staff current on operational procedures and  
2 regulatory changes.

- 3 • Safety – The systems rely on gas chlorination. Gas chlorination has  
4 inherent dangers. The chlorination buildings do not have mechanical  
5 ventilation, no alarm systems, and no self-contained breathing apparatus  
6 (SCBA). There are no written procedures for handling chlorine gas and a  
7 buddy system is not used.
- 8 • Budget – Orbit does not have an official budget. Also, there are no  
9 budgets for each of the individual systems to track what is needed by each  
10 system. There is no process of preparing and approving budgets.
- 11 • Capital Improvements Planning – There is no long-term capital  
12 improvements planning done for the overall system or the individual  
13 systems. Issues are addressed as they arise, rather than planned for in  
14 advance. Needs are considered but they are not written down or included  
15 in a plan.
- 16 • Emergency Planning – The system does not have a written emergency  
17 plan, nor does it have emergency equipment such as generators or SCBAs.  
18 The lack of a generator caused a problem when an electrical storm  
19 knocked out power for 3 days and the system was not able to deliver  
20 water.
- 21 • Audited Financial Report – There is no independently audited financial  
22 report. An annual financial statement is generated in house for the  
23 facilities. However, because there is no budget, there is nothing to  
24 evaluate the annual financial statements against.

#### 25 **4.1.2.5 Potential Capacity Concerns**

26 The following items were concerns regarding capacity but there are no particular  
27 operational, managerial, or financial problems that can be attributed to these items. The  
28 system should focus on the deficiencies noted above in the capacity deficiency section.  
29 Addressing the items listed below will help in further improving technical, managerial,  
30 and financial capabilities.

- 31 • Source Water Protection – The system has not implemented any type of  
32 source water protection program.
- 33 • Written Operational Procedures – There are no written operational  
34 procedures for the staff. Currently, due to the family nature of the  
35 business and the longevity of the staff, no problems are created by a lack  
36 of these procedures. However, if there is a turn-over in staff, the lack of  
37 written procedures could be a major problem for the system. In addition,  
38 written procedures would help the general operators.
- 39 • Emergency Funding – Orbit should have a fund to cover emergencies.  
40 Currently, emergencies or other conditions that cause a short fall in  
41 funding are covered by private investment by the President. This practice  
42 has been able to sustain the system in the past, but it may not be a

1 sustainable practice in the future. Orbit should consider some other means  
2 of covering these emergencies, such as reserve accounts.

### 3 4.2 ALTERNATIVE WATER SOURCE DEVELOPMENT

#### 4 4.2.1 Identification of Alternative Existing Public Water Supply Sources

5 Table 4.1 is a list of the existing groundwater-supplied public water systems within  
6 approximately 15 miles of the Sandy Meadow Estates PWS. From this list of water  
7 systems, eight were selected for further evaluation based on factors such as water quality,  
8 distance from the Sandy Meadow Estates PWS, sufficient total production capacity for  
9 selling or sharing water, and willingness of the system to sell or share water or drill a new  
10 well. The wells selected for further evaluation are shown on Table 4.2.

11 **Table 4.1 Existing Public Water Systems within 15 Miles of**  
12 **Sandy Meadow Estates**

System Name	Dist. From Sandy Meadow	Comments / Other Issues
Rosharon Road Estates Subdivision	1.2	Small system with WQ issues: As, Mn
Briar Meadows	2.4	Small system with marginal Fe exceedances. <b>Evaluate further.</b>
Grasslands	3.0	Small system with WQ issues: As
Schlumberger Reservoir Comp	3.5	Large system (> 1 mgd) with WQ issues: As, Mn
Oak Meadows Estates Subdivision	3.6	Small system with WQ issues: As, Fe
Rosharon Township	4.2	Small system with WQ issues: As, Mn
Mammoet USA, Inc.	4.3	Small system with marginal Mn exceedances. <b>Evaluate further.</b>
JMP Utilities Inc.	5.2	Small system with Mn exceedances. <b>Evaluate further.</b>
Bayou Shadows Water System	5.4	Small system with WQ issues: As, Mn
Oak Bend Estates	5.7	Small system with Mn exceedances. <b>Evaluate further.</b>
Oak Manor MUD	6.0	Small system with WQ issues: As, Mn
TDCJ Darrington Unit	6.8	Large system (> 1 mgd) without identified WQ issues. <b>Evaluate further.</b>
Mark V Estates	6.8	Small system with WQ issues: As
Wolf Glen Water System	7.1	Small system with WQ issues: As, Fe, Mn
Brazoria County Detention Center 2	7.2	Large system (> 1 mgd) with WQ issues: As, Fe (marginal)
Brandi Estates	7.7	Small system with Mn exceedances.
City of Liverpool	7.9	Small system with WQ issues: As
Bateman Water Works	8.1	Small system with Mn exceedances.
Weybridge Subdivision Water System	8.3	Small system with Mn exceedances.
Country Acres Estates	8.4	Small system with Mn exceedances.
City of Manvel	8.5	Small system with Mn exceedances.
Country Meadows	8.5	Small system with Mn exceedances.
Alameda Water Well Service	8.6	Small system with Fe, Mn exceedances.
Lee Ridge Subdivision	8.8	Small system with Mn exceedances.
City of Danbury	8.8	Large system (> 1 mgd) with WQ issues: As, Fe, Mn, nitrate
Willow Wood Duplex	9.1	Small system with Mn exceedances.

System Name	Dist. From Sandy Meadow	Comments / Other Issues
TDCJ Ramsey Area	9.2	Large system (> 1 mgd) with Fe exceedances. <b>Evaluate further.</b>
Calico Farms Subdivision	9.5	Small system with Mn exceedances.
Ashley Oaks Mobile Home Comm.	9.6	Small system with Mn exceedances.
Beechwood Subdivision	9.7	Small system with Fe, Mn exceedances.
Colony Cove Subdivision Water System	9.9	Small system with Mn exceedances.
City of Liverpool	10.0	Small system with marginal Fe and Mn exceedances.
Southwood Estates Inc.	10.0	Small system with Fe, Mn exceedances.
City of Alvin	10.2	Large system (> 1 mgd) with marginal Mn exceedances. <b>Evaluate further.</b>
Anglecrest Subdivision	10.3	Small system with Mn exceedances.
City of Hillcrest Village	10.7	Small system with marginal Fe and Mn exceedances.
Pleasant Meadows Subdivision	10.9	Small system with Mn exceedances.
Pleasantdale Subdivision	11.0	Small system with Mn exceedances.
Meadowland Subdivision	11.2	Small system with Mn exceedances.
Country Creek Estates Water System	11.2	Small system with Mn exceedances.
Riverside Estates	11.2	Small system with Mn exceedances.
Heights Country Subdivision	11.4	Small system with Mn exceedances.
Pine Colony Mobile Home Park	11.8	Small system with Mn exceedances.
Anchor Road Mobile Home Park	11.8	Small system with Fe, Mn exceedances.
City of Angleton/Brazosport Water Authority	11.9	Large system (> 1 mgd) without identified WQ issues. <b>Evaluate further.</b>
Moreland Subdivision Block 3&4	11.9	Small system with Mn exceedances.
Sandy Ridge Subdivision	11.9	Small system with Mn exceedances.
Televue Terrace Subdivision	12.1	Small system with Fe, Mn exceedances.
Mooreland Subdivision Water System	12.1	Small system with Mn exceedances.
Mooreland Subdivision Block 1&2	12.1	Small system with Fe exceedances.
City of Holiday Lake	12.2	Small system with WQ issues: TDS, Fe, Mn (marginal)
Sienna Plantation MUD 1	12.2	Large system (> 1 mgd) with marginal Fe exceedances.
Meadowview Subdivision	12.3	Small system with Mn exceedances.
Westwood Subdivision	12.4	Small system with Mn exceedances.
Palmetto Subdivision	12.4	Small system with Mn exceedances.
Village Trace Water System	12.5	Small system with marginal Mn exceedances.
Ryan Long Subdivision 2 Water System	12.5	Small system with Mn exceedances.
Windsong Subdivision	12.6	Small system with Mn exceedances.
Frontier Water Co.	12.8	Small system with Fe, Mn exceedances.
Halliburton Services Fresno	12.8	Small system with Fe (marginal), Mn exceedances.
Niagara Public Water Supply	12.9	Small system with Fe, Mn exceedances.
Fort Bend County MUD 23	13.1	Large system (> 1 mgd) with Fe exceedances.
Angle Acres Water System	13.2	Small system with Fe, Mn exceedances.
Coronado County	13.3	Small system with Mn exceedances.
West Lea Water System	13.4	Small system with Mn exceedances.
Fresno Mobile Home Park	13.4	Small system with Mn exceedances.
Meadowlark Subdivision	13.4	Small system with Mn exceedances.
Turner Water Service	13.5	Small system with Mn exceedances.
Johnsons Water Service	13.5	Small system with Mn exceedances.
Sharondale Subdivision	13.5	Small system with Mn exceedances.
Hasting Homeowners Water System	13.6	Small system without identified WQ issues.

System Name	Dist. From Sandy Meadow	Comments / Other Issues
Quail Meadows Subdivision	13.6	Small system with Mn exceedances.
Wellborn Acres	13.6	Small system with Fe, Mn exceedances.
Blue Sage Gardens Subdivision	13.8	Small system with Mn exceedances.
Manvel Road Terrace Subdivision	13.9	Small system with Mn exceedances.
Brazoria County MUD 2	14.5	Large system (> 1 mgd) without identified WQ issues.

1

2 **Table 4.2 Existing Public Water Systems within 15 Miles of Sandy Meadow**  
3 **Estates Selected for Further Evaluation**

System Name	Pop	Conn	Total Production (mgd)	Avg Daily Demand (mgd)	Approx. Dist. From Sandy Meadow Estates (mile)	Comments/ Other Issues
City of Alvin	17,916	5,817	8.739	1.307	10.2	Excess capacity and willing to sell water.
City of Angleton/Brazosport Water Authority (BWA)	19,167	6,389	5.112	1.910	11.9	The City purchases supplemental treated water from BWA. BWA has excess capacity and is willing to sell water. There is an 18-inch BWA main to north of city.
Briar Meadows	111	37	0.101	0.015	2.4	No excess capacity. However, based on WQ data and proximity to Sandy Meadow Estates, this PWS may provide a suitable location for a new well. (WQ: Marginal Fe)
J M P Utilities	57	19	0.086	0.008	5.2	Excess capacity. (WQ: Elevated Mn)
Mammoet USA, Inc.	25	2	0.029	na	4.3	No excess capacity. However, based on WQ data and proximity to Sandy Meadow Estates, this PWS may provide a suitable location for a new well. (WQ: Marginal Mn)
Oak Bend Estates	114	38	0.055	0.015	5.7	No excess capacity. However, based on WQ data and proximity to Sandy Meadow Estates, this PWS may provide a suitable location for a new well. (WQ: Elevated Mn)
TCDJ ID Darrington Unit	2,037	1,250	1.886	0.51	6.8	Adequate production with excess capacity.
TCDJ Ramsey Area	6,000	2,000	1.919	1.263	9.2	Adequate production with excess capacity. (WQ: Elevated Fe)

4

n/a (not applicable); na (not available); WQ (water quality); Fe (iron); Mn (manganese).

5 **4.2.1.1 City of Alvin**

6 The City of Alvin is located 10.2 miles northeast of Sandy Meadow Estates. The  
7 PWS is supplied by four groundwater wells, three of which are completed in the Lower  
8 Chicot aquifer (Code 112CHCTL) and one of which is completed in the Evangeline  
9 aquifer (Code 121EVGL). The four wells are between 688 and 711 feet deep, and have a  
10 total production of 8.739 mgd. Well water is treated with polyphosphate and



1 hypochlorite before being discharged to several ground and elevated storage tanks. The  
2 City serves a population of 17,916 and has 5,817 metered connections. The reported  
3 average daily demand is 1.307 mgd.

4 The City of Alvin currently provides finished water to several small PWSs within its  
5 extra-territorial jurisdiction (ETJ) and is building lines out towards Manvel, which is  
6 located to the west along Highway 6. The City plans to build lines past Manvel and a  
7 new plant and storage tank in that region sometime in the next couple of years.  
8 Currently, the City has up to 4 mgd of excess capacity, and is willing to negotiate to sell  
9 water to other PWSs outside its ETJ.

10 The Gulf Coast Water Authority also plans to build a 150 mgd water treatment plant  
11 (WTP) to treat Brazos River water. Sandy Meadow Estates may be able to connect to  
12 this regional WTP distribution system within the City of Alvin. The new WTP may be  
13 built on 80 acres of land currently owned by the Fort Bend County Water Control &  
14 Improvement District (WC&ID) No. 2 ([http://www.fortbendcountywcid2.com/Water  
15 Source.htm](http://www.fortbendcountywcid2.com/WaterSource.htm)). This would be a regional WTP that may serve west Harris County, City of  
16 Sugar Land, City of Missouri City, City of Arcola, City of Pearland, City of Alvin, City  
17 of Manvel, City of Friendswood, and the area within the boundaries of Fort Bend County  
18 WC&ID No. 2, which includes the City of Stafford.

#### 19 **4.2.1.2 City of Angleton/Brazosport Water Authority**

20 The City of Angleton is located 11.9 miles south of Sandy Meadow Estates. The  
21 PWS is supplied by six local groundwater wells, which are supplemented by treated  
22 surface water purchased from the Brazosport Water Authority (BWA). The BWA is a  
23 wholesale water provider that operates a WTP located in the City of Lake Jackson and  
24 supplies many communities in Brazoria County with treated water. Its primary water  
25 source is the Brazos River.

26 The City of Angleton's six wells draw water from the Chicot Aquifer  
27 (Code 112CHCT), are between 650 and 960 feet deep, and have a total production of  
28 5.112 mgd. Well water is aerated and treated with polyphosphate and chlorine before  
29 being discharged to two storage tanks. The City uses the purchased water from BWA to  
30 mix with water from the wells. The City of Angleton serves a population of 19,200 and  
31 has approximately 6,400 metered connections. It is currently not in a position to sell  
32 water to third parties.

33 The BWA has up to 5 mgd of excess treated water capacity it is willing to sell,  
34 assuming that suitable arrangements can be negotiated. The BWA has an 18-inch supply  
35 line that terminates on the north side of the City of Angleton, near the corner of Vasquez  
36 and Henderson. The BWA requires that all its customers provide for a minimum of  
37 8 hours storage capacity to sustain supply in the event of BWA's maintenance activities.  
38 Based on recent experience with Dow Chemical, the negotiation and approval process  
39 could take up to 2 years; however, it is expected the process would be less difficult for  
40 another PWS.

1     **4.2.1.3 Briar Meadows**

2           Briar Meadows is located on FM 1462, 2.4 miles to the northeast of Sandy Meadow  
3 Estates. The PWS is owned by Orbit Systems, Inc., and is supplied by a single  
4 groundwater well. The well, completed in the Chicot aquifer, is 210 feet deep and rated  
5 for 0.086 mgd. The system has 5,000 gallons of storage capacity. Briar Meadows serves  
6 a population of 111 with 37 metered connections. The water delivery system has a total  
7 peak production of 0.101 mgd and water is hypochlorinated and treated with  
8 polyphosphate before distribution.

9           The estimated average and maximum daily demand is 0.015 mgd and 0.059 mgd,  
10 respectively. The well does not have enough capacity to meet the peak demand flow rate  
11 of Sandy Meadow Estates. However, based on Briar Meadows water quality data and its  
12 proximity to Sandy Meadow Estates, Briar Meadows may provide a suitable location for  
13 a new well.

14     **4.2.1.4 J M P Utilities**

15           J M P Utilities serves a mobile home park located adjacent to County Road 184  
16 approximately 1 mile north of FM 1462. The PWS is 5.2 miles northeast of Sandy  
17 Meadow Estates. The PWS is operated by J M P Utilities in Manvel, Texas. The PWS  
18 serves a population of 57 (19 meters) with one well that has a total capacity of 0.288 mgd  
19 and a 3,000-gallon pressure tank. The water delivery system has a total peak production  
20 of 0.086 mgd. The well, completed in the Chicot aquifer, is 510 feet deep. The water is  
21 sequestered for manganese, which averages 0.128 mg/L.

22           The estimated average and maximum daily demand is 0.008 mgd and 0.030 mgd,  
23 respectively. The system is large enough to provide water to Sandy Meadow Estates.

24     **4.2.1.5 Mammoet USA, Inc.**

25           Mammoet USA, Inc. is located off State Highway 288B in Bonney, Texas, 4.3 miles  
26 southwest of Sandy Meadow Estates. The PWS is operated by Mammoet USA, Inc., and  
27 serves a population of 25 with two connections. The well is 270 feet deep with a rated  
28 capacity of 0.029 mgd. The water is used primarily for industrial and agricultural  
29 purposes. The water is hypochlorinated for disinfection before distribution. The system  
30 has one 310-gallon pressure tank. There is no information on the capacity of the booster  
31 pumps. Water consumption cannot be estimated because the water is used for industrial  
32 and agricultural purposes. The quality of the water is good with an average arsenic  
33 concentration of 0.002 mg/L based on two sample results.

34           There is not sufficient excess capacity at Mammoet USA to supplement the Sandy  
35 Meadow Estates existing supply; however, based on the available water quality data, the  
36 location may be a suitable point for a new groundwater well.

1     **4.2.1.6 Oak Bend Estates**

2           Oak Bend Estates is located on County Road 864A off County Road 172,  
3 approximately 5.7 miles east-northeast of Sandy Meadow Estates. The PWS is operated  
4 by Southwest Utilities, Inc., in El Campo, Texas. Oak Bend Estates serves a population  
5 of 114 with 38 connections. The well is 145 feet deep with a rated capacity of 0.05 mgd.  
6 The system has a 21,000-gallon ground storage tank, two 125 gpm service pumps, and  
7 one 2,500-gallon pressure tank. The water delivery system has a total peak production of  
8 0.055 mgd. The estimated average and maximum daily demand is 0.015 mgd and  
9 0.06 mgd, respectively. Manganese is above the SMCL and the water is treated before  
10 distribution. The well has no excess capacity.

11           There is not sufficient excess capacity at Oak Bend Estates to supplement the Sandy  
12 Meadow Estates existing supply. However, based on overall water quality data, the  
13 location may be a suitable point for a new groundwater well.

14     **4.2.1.7 TDCJ Darrington Unit**

15           The Texas Department of Criminal Justice (TDCJ) operates the Darrington Unit  
16 prison located 6.8 miles northwest of Sandy Meadow Estates. The TDCJ Darrington  
17 Unit serves a population of 2,037 with 1,250 connections. The PWS is supplied by three  
18 local groundwater wells, two of which are completed in the Lower Chicot aquifer and  
19 one of which is completed in the Evangeline aquifer. The wells G0200204A,  
20 G0200204B, and G0200204C were drilled to depths of 595 feet, 537 feet and 1,140 feet,  
21 respectively. The tested flow rates of each well are 360, 350 and 600 gpm for a total  
22 system production capacity of 1.886 mgd. The treatment process consists of  
23 sequestration and chlorination. The average daily demand is 0.51 mgd which means that  
24 the TDCJ Darrington system is utilizing approximately 27 percent of the total system  
25 capacity.

26           This water supply system has excess capacity to supplement the Sandy Meadow  
27 Estates Water System. No water quality issues are reported for the TDCJ Darrington  
28 system in the TCEQ database.

29     **4.2.1.8 TDCJ Ramsey Area**

30           The TDCJ also operates the Ramsey Area prison located 9.2 miles to the west-  
31 southwest of Sandy Meadow Estates. The TDCJ Ramsey Area PWS serves a population  
32 of 6,000 with 2,000 metered connections. The PWS is supplied by five groundwater  
33 wells.

34           The average consumption for the system is 1.263 mgd, the maximum capacity is  
35 2.203 mgd, and the service pump capacity is 5.4 mgd. The total storage capacity is  
36 1,350,000 gallons with elevated storage of 200,000 gallons. The quality of the water is  
37 good with an average arsenic concentration of 0.002 mg/L based on four samples  
38 collected between March 1999 and November 2003. However, iron concentrations have

1 exceeded the SMCL of 0.3 mg/L based on two samples collected between March 1999  
2 and April 2002.

3       There is sufficient excess capacity at the TDCJ Ramsey Area PWS to supplement the  
4 Sandy Meadow Estates existing supply.

## 5 **4.2.2 Potential for New Groundwater Sources**

### 6 **4.2.2.1 Installing New Compliant Wells**

7       Developing new wells or well fields is recommended, provided good quality  
8 groundwater available in sufficient quantity can be identified. Since a number of water  
9 systems in the area also have problems with arsenic, it should be possible to share in the  
10 cost and effort of identifying compliant groundwater and constructing well fields.

11       Since the PWS is already familiar with well operation, installation of a new well in  
12 the vicinity of the system intake point is likely to be an attractive option, provided  
13 compliant groundwater can be found. As a result, existing wells with good water quality  
14 should be investigated. Re-sampling and test pumping would be required to verify and  
15 determine the quality and quantity of water at those wells.

16       The use of existing wells should probably be limited to use as indicators of  
17 groundwater quality and availability. If a new groundwater source is to be developed, it  
18 is recommended that a new well or wells be installed instead of using existing wells.  
19 This will ensure the well characteristics are known and the well construction meets  
20 standards for drinking water wells.

21       Some of the alternatives suggest new wells be drilled in areas where existing wells  
22 are compliant with the new arsenic MCL of 0.01 mg/L. In developing the cost estimates,  
23 it is assumed that the aquifer in these areas would produce the required amount of water  
24 with only one well. Site investigations and geological research, which is beyond the  
25 scope of this study, may indicate that the aquifer at a particular site and depth may not  
26 provide the amount of water needed or more than one well would need to be drilled in  
27 separate areas.

### 28 **4.2.2.2 Results of Groundwater Availability Modeling**

29       Regional groundwater withdrawal in the area is extensive and is likely to steadily  
30 increase over the next decades. In Brazoria County, the Chicot aquifer constitutes the  
31 primary groundwater source for public supplies. This aquifer is the upper unit of the  
32 Gulf Coast aquifer system that extends along the entire Texas coastal region. Throughout  
33 the northern part of the Gulf Coast aquifer system, large groundwater withdrawals since  
34 the 1900s have resulted in declines in the aquifer's potentiometric surface from tens to  
35 hundreds of feet. The largest declines have occurred in the Harris-Galveston Coastal  
36 Subsidence District (HGCSA), around the Houston metropolitan area, where the area of  
37 influence encompasses most of Brazoria County, including the Sandy Meadow Estates  
38 system.

1 A GAM for the northern part of the Gulf Coast aquifer was recently developed by  
2 the TWDB. Modeling was performed by the U.S. Geological Survey to simulate  
3 historical conditions (Kasmerek and Robinson, 2004), and to develop long-term  
4 groundwater projections (Kasmerek, Reece and Houston, 2005). Two projections were  
5 evaluated, a TWDB scenario based on 50-year regional projections by regional user  
6 groups, and a HGCSO scenario that incorporates 30-year projections by the HGCSO for  
7 the Houston Metropolitan area. Modeling of both projections anticipates extensive  
8 groundwater use and drop in aquifer levels, with far more critical groundwater  
9 availability conditions anticipated under the 30-year HGCSO scenario.

10 Under the HGCSO scenario, withdrawals from the Chicot aquifer and underlying  
11 Evangeline aquifer would increase by 2030 to an estimated 1,520 mgd, a 74 percent  
12 increase relative to 1995 conditions. Modeling of these projections indicate a significant  
13 increase in the aquifer's cone of depression by 2030, with depth increases of over 200  
14 feet relative to current conditions (Kasmerek, Reece and Houston, 2005). The percent of  
15 withdrawals supplied by net aquifer recharges would also steadily decrease, from an  
16 estimated 72 percent in 1995 to 43 percent projected in 2030 (Kasmerek, Reece and  
17 Houston, 2005).

18 Under the TWDB scenario, long-term withdrawals from the Chicot aquifer and  
19 underlying Evangeline aquifer would moderately increase or remain level over the  
20 50-year simulation period; the largest increase in withdrawal would occur between 2000  
21 and 2010, with an 8 percent increase from 850 to 920 mgd (Kasmerek, Reece and  
22 Houston, 2005). Modeling of the TWDB scenario showed relatively little change in  
23 elevation of the Chicot aquifer's potentiometric surface. In Matagorda County, however,  
24 a drop of elevation from 50 to 100 feet would occur under 2010 withdrawal conditions.  
25 The simulated net recharge of the aquifer, in contrast with the HGCSO scenario, would  
26 moderately increase under the TWDB scenario (Kasmerek, Reece and Houston, 2005).

27 The GAM of the northern part of the Gulf Coast aquifer was not run for the Sandy  
28 Meadow Estates system as groundwater availability would reflect regional HGCSO  
29 conditions. Water use by the system would represent a minor addition to the regional  
30 HGCSO groundwater withdrawal, making potential changes in aquifer levels well  
31 beyond the spatial resolution of the regional GAM model.

### 32 **4.2.3 Potential for New Surface Water Sources**

33 There is a low potential for development of new surface water sources for the Sandy  
34 Meadow Estates system as indicated by limited water availability within the site vicinity.  
35 The system is located within the San Jacinto-Brazos Basin where current surface water  
36 availability is expected to remain at current levels over the next 50 years according to the  
37 TWDB's 2002 Water Plan (47,692 acre-feet per year during drought conditions).  
38 Approximately 12 miles west of the site, the San Jacinto-Brazos Basin transitions into the  
39 Brazos River Basin where water availability is expected to decrease up to 17 percent over  
40 the next 50 years.

1 The vicinity of the Sandy Meadow Estates system has a minimum availability of  
2 surface water for new uses. The TCEQ availability map for the San Jacinto-Brazos Basin  
3 and Brazos Basin indicates that, over a 20-mile radius of the site, unappropriated flows  
4 for new uses are typically available less than 50 percent of the time. This supply is  
5 inadequate as the TCEQ requires 100 percent supply availability for a municipal water  
6 supply.

#### 7 **4.2.4 Options for Detailed Consideration**

8 The initial review of existing PWS sources results in the following options for more  
9 detailed consideration:

- 10 1. Purchase treated groundwater from the City of Alvin; install a storage tank,  
11 pump station, two transfer pumps, and pipeline (Alternative SM-1).
- 12 2. Purchase treated surface water from the BWA; install a storage tank, pump  
13 station, two transfer pumps, and pipeline to tie into existing BWA main north  
14 of the City of Angleton (Alternative SM-2).
- 15 3. Drill a new well near Briar Meadows; install a storage tank, pump station, two  
16 transfer pumps, and pipeline (Alternative SM-3).
- 17 4. Purchase groundwater from J M P Utilities; install a storage tank, pump  
18 station, two transfer pumps, and pipeline (Alternative SM-4).
- 19 5. Drill a new well near Mammoet USA; install a storage tank, pump station,  
20 two transfer pumps, and pipeline (Alternative SM-5).
- 21 6. Drill a new well near Oak Bend Estates; install a storage tank, pump station,  
22 two transfer pumps, and pipeline (Alternative SM-6).
- 23 7. Drill a new well near TDCJ Darrington Unit; install a storage tank, pump  
24 station, two transfer pumps, and pipeline (Alternative SM-7).
- 25 8. Drill a new well near TDCJ Ramsey Area; install a storage tank, pump station,  
26 two transfer pumps, and pipeline (Alternative SM-8).

27 In addition to the location-specific alternatives above, three hypothetical alternatives  
28 are considered in which new wells would be installed 10-, 5-, and 1-miles from the Sandy  
29 Meadow Estates PWS. Under each of these alternatives, it is assumed that a source of  
30 compliant water can be located and then a new well would be completed and a pipeline  
31 would be constructed to transfer the compliant water to Sandy Meadow Estates. These  
32 alternatives are SM-13, SM-14, and SM-15.

1 **4.3 TREATMENT OPTIONS**

2 **4.3.1 Centralized Treatment Systems**

3 Centralized treatment of the water is identified as a potential option for the Sandy  
4 Meadow Estates system. Both iron-based adsorption and coagulation/filtration are  
5 potentially applicable technologies for arsenic removal from the groundwater. The  
6 central iron-based adsorption treatment alternative is Alternative SM-9, and the central  
7 coagulation/filtration alternative is Alternative SM-10.

8 **4.3.2 Point-of-Use Systems**

9 Point-of-use treatment using iron-based adsorption technology is valid for arsenic  
10 removal. The POU adsorption treatment alternative is SM-11.

11 **4.3.3 Point-of-Entry Systems**

12 Point-of-entry treatment using iron-based adsorption technology is valid for arsenic  
13 removal. The POE adsorption treatment alternative is SM-12.

14 **4.4 BOTTLED WATER**

15 Providing bottled water is considered an interim measure to be used until a  
16 compliance alternative is implemented. Even though the community is small and people  
17 know each other, it would be reasonable to require quarterly communication advising  
18 customers of the need to take advantage of the bottled water program. An alternative to  
19 providing delivered bottled water is to provide a central, publicly accessible dispenser for  
20 treated drinking water. Alternatives addressing bottled water are SM-16, SM-17, and  
21 SM-18.

22 **4.5 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

23 A number of potential alternatives for compliance with the MCL for arsenic have  
24 been identified. Each of the potential alternatives is described in the following  
25 subsections. It should be noted that the cost information given is the capital cost and  
26 change in O&M costs associated with implementing the particular alternative.  
27 Appendix C contains cost estimates for the compliance alternatives. These compliance  
28 alternatives represent a range of possibilities, and a number of them are likely not  
29 feasible. However, all have been presented to provide a complete picture of the range of  
30 alternatives considered. It is anticipated that a PWS will be able to use the information  
31 contained herein to select the most attractive alternative(s) for more detailed evaluation  
32 and possible subsequent implementation. Cost analyses for shared solutions with other  
33 PWSs in the area are provided in Appendix G.

34 **4.5.1 Alternative SM-1: Purchased Water from City of Alvin**

35 The SM-1 alternative consists of connecting directly to the City of Alvin PWS. The  
36 PWS is supplied by four local groundwater wells having a total capacity 8.739 mgd. The

1 reported average daily demand is 1.307 mgd. The peak demand is estimated to be 5.228  
2 mgd. Water is treated with polyphosphate and hypochlorite before being discharged to  
3 several ground and elevated storage tanks.

4 This alternative would require installation of two ground storage tanks, two pump  
5 stations with two transfer pumps at each station, and a pipeline to the Sandy Meadow  
6 Estates system. One of the two pumps in each pump station would be for backup in the  
7 event the other pump fails. The pipeline would be a maximum of 11.5 miles long, and  
8 would be a 4-inch polyvinyl chloride (PVC) line that discharges to the existing storage  
9 tank at Sandy Meadow Estates. It is possible that a closer connection point exists that  
10 would reduce the length of the transfer pipeline.

11 This alternative presents a regional solution, since other PWSs in the area also need  
12 compliant water. The City is already building lines to supply other small systems within  
13 its ETJ and is willing to negotiate to sell water to other PWSs outside its ETJ.  
14 Additionally, the regional surface water treatment plant proposed by the Gulf Coast  
15 Water Authority will replace some groundwater from wells in the Alvin area in the near  
16 future.

17 The estimated capital cost for this alternative includes construction of the pump  
18 stations and transfer pumps and a pipeline to the Sandy Meadow Estates system. The  
19 estimated O&M cost for this alternative includes the purchase price for treated water plus  
20 maintenance cost for the pipeline, and power and O&M labor and materials for the pump  
21 stations minus the cost Sandy Meadow Estates currently pays to operate its well field.  
22 The estimated capital cost for this alternative is \$3,192,000, and the estimated annual  
23 O&M cost is \$35,600.

24 The reliability of adequate amounts of compliant water under this alternative should  
25 be good. From the perspective of Orbit, this alternative is characterized as easy to  
26 operate and repair, since O&M and repair of pipelines and pump stations are well  
27 understood, and Orbit currently operates pipelines and a pump station.

#### 28 **4.5.2 Alternative SM-2: Purchased Water from Brazosport Water** 29 **Authority**

30 The SM-2 alternative involves the purchase of treated surface water from the BWA.  
31 BWA currently has sufficient excess capacity for this alternative to be feasible and is  
32 willing to negotiate an agreement to supply water to PWSs in the area.

33 This alternative would require installing two ground storage tanks and constructing a  
34 pipeline from the BWA 18-inch water main, located adjacent to State Highway 227 north  
35 of the City of Angleton, to the existing intake point at Sandy Meadow Estates. Two  
36 pump stations would also be required to overcome pipe friction and elevation differences  
37 between Angleton and Sandy Meadow Estates. The pipeline would be approximately  
38 14.2 miles long and constructed of 4-inch PVC pipe.



1 Each pump station would be housed in a building and would include two pumps.  
2 One of the two pumps would be for backup. It is assumed the pumps and piping would  
3 be installed with capacity to meet all water demand for Sandy Meadow Estates, since the  
4 incremental cost would be relatively small and would provide operational flexibility.

5 The estimated capital cost for this alternative includes construction of the pump  
6 stations and transfer pumps and a pipeline to the Sandy Meadow Estates system. The  
7 estimated O&M cost for this alternative includes the purchase price for the treated water  
8 plus maintenance cost for the pipeline, and power and O&M labor and materials for the  
9 pump stations minus the cost that Sandy Meadow Estates currently pays to operate its  
10 well field. The estimated capital cost for this alternative is \$3,598,300, and the estimated  
11 annual O&M cost is \$37,300.

12 The reliability of adequate amounts of compliant water under this alternative should  
13 be good. BWA provides treated surface water on a large scale, facilitating adequate  
14 O&M resources. From the perspective of Orbit, this alternative is characterized as easy  
15 to operate and repair, since O&M and repair of pipelines and pump stations are well  
16 understood, and Orbit currently operates pipelines and a pump station.

17 The feasibility of this alternative is dependent on an agreement being reached with  
18 BWA to purchase treated drinking water.

#### 19 **4.5.3 Alternative SM-3: New Well near Briar Meadows**

20 The SM-3 alternative consists of drilling a new well in the Briar Meadows area to  
21 supplement the existing capacity at Sandy Meadow Estates. Records indicate that water  
22 from the Briar Meadows system is meeting the MCL for arsenic, and the SMCL for iron  
23 and manganese. It is expected that groundwater from a new well in the area will also be  
24 compliant with drinking water standards.

25 This alternative would require drilling a new well and installing a ground storage  
26 tank, a pump station with two transfer pumps, and a pipeline to the Sandy Meadow  
27 Estates system. One of the two pumps in the pump station would be for backup in the  
28 event the other pump fails. The pipeline would be constructed of 4-inch PVC pipe and  
29 would be approximately 3.2 miles long and discharge to the existing storage tank at  
30 Sandy Meadow Estates.

31 The Sandy Meadow Estates and Briar Meadows water systems are owned and  
32 operated by Orbit. This alternative presents a good opportunity for a regional solution,  
33 since there are other PWSs in the area, including those owned and operated by Orbit, that  
34 need compliant water. Regionalization would allow the sharing of the cost of drilling the  
35 well(s) at the Briar Meadows well field.

36 The estimated capital cost for this alternative includes drilling a new well and  
37 installing a well pump, small ground storage tank, pump station with two transfer pumps,  
38 and a pipeline to the Sandy Meadow Estates system. The estimated O&M cost for this  
39 alternative includes maintenance cost for the pipeline, and power and O&M labor and

1 materials for the pump station minus the cost Sandy Meadow Estates currently pays to  
2 operate its well field. The estimated capital cost for this alternative is \$961,400, and the  
3 estimated annual O&M cost is \$11,100.

4 The reliability of adequate amounts of compliant water under this alternative should  
5 be good. From the perspective of Orbit, this alternative is characterized as easy to  
6 operate and repair, since O&M and repair of pipelines and pump stations are well  
7 understood, and Orbit currently operates pipelines and a pump station. Additionally,  
8 both Sandy Meadow Estates PWS and Briar Meadows PWS are owned and operated by  
9 Orbit.

10 The feasibility of this alternative is dependent on finding a suitable well site.

#### 11 **4.5.4 Alternative SM-4: Purchased Water from J M P Utilities**

12 The SM-4 alternative consists of connecting directly to the J M P Utilities PWS well.  
13 The well capacity is 0.288 mgd. The estimated peak demand is 0.030 mgd (57 people)  
14 providing an excess capacity of 0.258 mgd.

15 This alternative would require installing a ground storage tank, a pump station with  
16 two transfer pumps, and a 4-inch PVC pipeline to the Sandy Meadow Estates system.  
17 One of the transfer pumps would be for backup in the event the other pump fails. The  
18 pipeline would be constructed of 4-inch PVC pipe and would be approximately 7.1 miles  
19 long.

20 This alternative presents a limited regional solution since other PWSs in the area also  
21 need compliant water. Some regionalization could be accomplished by sharing the cost  
22 of the pump station and pipeline with other non-compliant PWSs in the area.

23 The estimated capital cost for this alternative includes installing a pump station with  
24 two transfer pumps and a pipeline to the Sandy Meadow Estates system. The estimated  
25 O&M cost for this alternative includes the purchase price for treated water, plus  
26 maintenance cost for the pipeline, and power and O&M labor and materials for the pump  
27 station minus the cost Sandy Meadow Estates currently pays to operate its well field.  
28 The estimated capital cost for this alternative is \$1,832,400, and the estimated annual  
29 O&M cost is \$17,300.

30 The reliability of adequate amounts of compliant water under this alternative should  
31 be good. From the perspective of Orbit, this alternative is characterized as easy to  
32 operate and repair, since O&M and repair of pipelines and pump stations are well  
33 understood, and Orbit currently operates pipelines and a pump station.

#### 34 **4.5.5 Alternative SM-5: New Well near Mammoet USA, Inc.**

35 The SM-5 alternative consists of drilling a new well near the Mammoet USA well in  
36 Bonney, Texas. Records indicate there is no detectable amount of arsenic in the

1 Mammoet USA well water. Treatment may be required for manganese which is  
2 marginally high at times.

3 This alternative would require drilling a new well and installing a ground storage  
4 tank, a pump station with two transfer pumps, and a pipeline to the Sandy Meadow  
5 Estates system. One of the two pumps in the pump station would be used for backup in  
6 the event the other pump fails. The pipeline would be a 4-inch PVC pipeline  
7 approximately 6.6 miles long.

8 This alternative presents a limited regional solution since other PWSs in the area also  
9 need compliant water. Some regionalization could be accomplished by sharing the cost  
10 of drilling the well with other non-compliant PWSs in the area.

11 The estimated capital cost for this alternative includes the costs for a new well and  
12 small ground storage tank, a pump station with two transfer pumps, and a pipeline to the  
13 Sandy Meadow Estates system. The estimated O&M cost for this alternative includes  
14 labor and material costs to operate the well field, to maintain the pipeline, and to operate  
15 the pump station. The estimated capital cost for this alternative is \$1,682,500 and the  
16 estimated annual O&M cost is \$14,000.

17 The reliability of adequate amounts of compliant water under this alternative should  
18 be good. From the perspective of Orbit, this alternative is characterized as easy to  
19 operate and repair, since O&M and repair of pipelines and pump stations are well  
20 understood, and Orbit currently operates pipelines and a pump station.

21 The feasibility of this alternative is dependent on finding a suitable well site.

#### 22 **4.5.6 Alternative SM-6: New Well near Oak Bend Estates**

23 This alternative consists of drilling a new well in the Oak Bend Estates area.  
24 Records indicate that arsenic is not above the MCL in the Oak Bend Estates well water;  
25 however, manganese is above the SMCL.

26 This alternative would require drilling a new well and installing a ground storage  
27 tank, a pump station with two transfer pumps, and a pipeline to the Sandy Meadow  
28 Estates system. One of the two pumps in the pump station would be for backup in the  
29 event the other pump fails. The pipeline would be a 4-inch PVC line approximately  
30 8.3 miles long.

31 This alternative presents a limited regional solution, since other PWSs in the area  
32 also need compliant water. Some regionalization could be accomplished by sharing the  
33 cost of drilling the well with other non-compliant PWS in the area.

34 The estimated capital cost for this alternative includes the cost to drill a new well and  
35 install a small ground storage tank, a pump station with two transfer pumps, and a  
36 pipeline to the Sandy Meadow Estates system. The estimated O&M cost for this  
37 alternative includes maintenance cost for the pipeline, and power and O&M labor and

1 materials for the pump station minus the cost that the Sandy Meadow Estates currently  
2 pays to operate their well field. The estimated capital cost for this alternative is  
3 \$2,147,600 and the estimated annual O&M cost is \$15,100.

4 The reliability of adequate amounts of compliant water under this alternative should  
5 be good. From the perspective of Orbit, this alternative is characterized as easy to  
6 operate and repair, since O&M and repair of pipelines and pump stations are well  
7 understood, and Orbit currently operates pipelines and a pump station.

8 The feasibility of this alternative is dependent on finding a suitable well site.

#### 9 **4.5.7 Alternative SM-7: New Well near TDCJ Darrington Unit**

10 The SM-7 alternative consists of drilling a new well near the TDCJ Darrington well  
11 field. Records indicate there is no detectable amount of arsenic in the TDCJ Darrington  
12 Unit well water.

13 This alternative would require drilling a new well and installing a well pump, small  
14 ground storage tank, a pump station with two transfer pumps, and a pipeline to the Sandy  
15 Meadow Estates system. One of the two pumps in the pump station would be for backup  
16 in the event the other pump fails. The pipeline would be a 4-inch PVC line  
17 approximately 8.3 miles long.

18 This alternative presents a limited regional solution since other PWSs in the area also  
19 need compliant water. Some regionalization could be accomplished by sharing the cost  
20 of drilling the well with other non-compliant PWSs in the area.

21 The estimated capital cost for this alternative includes the costs for a new well and  
22 small ground storage tank, a pump station with two transfer pumps, and a pipeline to the  
23 Sandy Meadow Estates system. The estimated O&M cost for this alternative includes  
24 labor and material costs to operate the well field, to maintain the pipeline, and to operate  
25 the pump station. The estimated capital cost for this alternative is \$2,010,000 and the  
26 estimated annual O&M cost is \$15,600.

27 Reliability of supply of adequate amounts of compliant water under this alternative  
28 should be good. From the perspective of Orbit Systems, this alternative would be  
29 characterized as easy to operate and repair since Orbit Systems currently operates  
30 pipelines and a pump station.

31 The reliability of adequate amounts of compliant water under this alternative should  
32 be good. From the perspective of Orbit, this alternative is characterized as easy to  
33 operate and repair, since O&M and repair of pipelines and pump stations is well  
34 understood, and Orbit currently operates pipelines and a pump station.

35 The feasibility of this alternative is dependent on finding a suitable well site.

1 **4.5.8 Alternative SM-8: New Well near TDCJ Ramsey Area**

2 The SM-8 alternative consists of drilling a new well near the TDCJ Ramsey Area  
3 well field. Although iron concentrations exceeded the SMCL of 0.3 mg/L, based on two  
4 samples collected between March 1999 and April 2002, the arsenic concentration was  
5 less than the MCL. The average arsenic concentration, based on four samples collected  
6 between March 1999 and November 2003, was 0.002 mg/L.

7 This alternative would require drilling a new well and installing two well pumps,  
8 two small ground storage tanks, two pump stations with two transfer pumps at each  
9 station, and a pipeline to the Sandy Meadow Estates system. One of the two pumps at  
10 each pump station would be for backup in the event the other pump fails. The pipeline  
11 would be a 4-inch PVC line approximately 13.7 miles long.

12 This alternative presents a limited regional solution since other PWSs in the area also  
13 need compliant water. Some regionalization could be accomplished by sharing the cost  
14 of drilling the well with other non-compliant PWSs in the area.

15 The estimated capital cost for this alternative includes the costs for a new well and  
16 small ground storage tanks, two pump stations with two transfer pumps at each station,  
17 and a pipeline to the Sandy Meadow Estates system. The estimated O&M cost for this  
18 alternative includes labor and material costs to operate the well field, to maintain the  
19 pipeline, and to operate the pump stations. The estimated capital cost for this alternative  
20 is \$3,457,900, and the estimated annual O&M cost is \$34,400.

21 The reliability of adequate amounts of compliant water under this alternative should  
22 be good. From the perspective of Orbit, this alternative is characterized as easy to  
23 operate and repair, since O&M and repair of pipelines and pump stations is well  
24 understood, and Orbit currently operates pipelines and a pump station.

25 The feasibility of this alternative is dependent on finding a suitable well site.

26 **4.5.9 Alternative SM-9: Central Iron-Based Adsorption Treatment**

27 Orbit would treat groundwater from both Wells A and B using an iron-based  
28 adsorption system prior to distribution. This alternative consists of constructing the  
29 adsorption treatment plant at or near one of the two wells. The plant comprises a  
30 400 square feet (ft<sup>2</sup>) building with a paved driveway, the pre-constructed adsorption  
31 system on a skid (e.g., two Model APU-300 package units from Severn Trent), and a  
32 5,000-gallon backwash wastewater equalization tank. The entire facility would be  
33 fenced. The water would be pre-chlorinated to oxidize As(III) to As(V) and  
34 post-chlorinated for disinfection prior to flowing to the distribution system. Backwash  
35 would be required monthly with raw well water supplied directly by the well pump. The  
36 backwash wastewater would be equalized in the 5,000-gallon tank and periodically  
37 hauled to a disposal site, such as Orbit's Grasslands wastewater treatment plant. The  
38 adsorption media are expected to last approximately 2 years before replacement and  
39 disposal.

1 The estimated capital cost for this alternative is \$376,900, and the estimated annual  
2 O&M cost is \$55,700, which includes the annualized media replacement cost of \$14,000.

3 The reliability of adequate amounts of compliant water under this alternative is good  
4 as the adsorption technology has been demonstrated effective in full-scale and pilot-scale  
5 facilities. The technology is simple and requires minimal O&M effort.

6 The feasibility of this alternative is not dependent on the cooperation, willingness, or  
7 capability of other water supply entities.

#### 8 **4.5.10 Alternative SM-10: Central Coagulation/Filtration Treatment**

9 Orbit would treat groundwater from both Wells A and B using a  
10 coagulation/filtration system prior to distribution. This alternative consists of  
11 constructing the coagulation/filtration plant at or near one of the two wells. The plant  
12 comprises a 400 ft<sup>2</sup> building with a paved driveway, the pre-constructed  
13 coagulation/filtration system on a skid (*e.g.*, three Macrolite filters from Kinetico), a  
14 ferric chloride feed and storage system, and a 5,000-gallon backwash wastewater  
15 equalization tank. The entire facility would be fenced. The water would be  
16 pre-chlorinated to oxidize As(III) to As(V) and post-chlorinated for disinfection prior to  
17 flowing to the distribution system. Ferric chloride solution would be fed to the well  
18 water after pre-chlorination and before entering the filters. The filters would be  
19 backwashed once every 1 to 2 days by well water directly from the well pump. The  
20 backwash wastewater would be equalized in the 5,000-gallon tank and periodically  
21 hauled to a disposal site. The Macrolite media does not need replacement.

22 The estimated capital cost for this alternative is \$291,600, and the estimated annual  
23 O&M cost is \$125,300. This alternative requires more O&M labor cost and sewer  
24 disposal charges than the adsorption alternative.

25 The reliability of adequate amounts of compliant water under this alternative is good  
26 as the coagulation/filtration is a well-established technology. The technology is simple  
27 but requires significant effort for chemical handling and backwash monitoring.

28 The feasibility of this alternative is not dependent on the cooperation, willingness, or  
29 capability of other water supply entities.

#### 30 **4.5.11 Alternative SM-11: Point-of-Use Treatment**

31 This alternative consists of the continued operation of the wells at Sandy Meadow  
32 Estates, plus treatment of water to be used for drinking or food preparation at the POU to  
33 remove arsenic. The purchase, installation, and maintenance of POU treatment systems  
34 to be installed “under the sink” would be necessary for this alternative. The POU  
35 treatment system most applicable is the adsorption process using iron-based IX media.  
36 Blending is not an option in this case.

1 This alternative would require installation of the POU treatment units in houses and  
2 other buildings that provide water for drinking or cooking. Orbit would be responsible  
3 for purchase and maintenance of the treatment units, including media replacement,  
4 periodic sampling, and necessary repairs. In houses, the most convenient point for  
5 installation of the treatment units is typically under the kitchen sink, with a separate tap  
6 installed for dispensing treated water. Installation of the treatment units in kitchens  
7 would require entry into the homes of customers by Orbit personnel or contract  
8 personnel. As a result, the cooperation of customers would be important for success in  
9 implementation of this alternative. The treatment units could be installed without house  
10 entry, but that would complicate the installation and increase costs.

11 POU arsenic treatment processes typically produce spent media that require disposal  
12 and possibly a small backwash waste stream. The backwash waste stream results in a  
13 slight increase in the overall volume of water used. POU systems have the advantage  
14 that only a minimum volume of water is treated (only that for human consumption). This  
15 minimizes the size of the treatment units, the increase in water required, and the waste for  
16 disposal. For this alternative, it is assumed that the increase in water consumption would  
17 be insignificant in terms of supply cost, and that the backwash waste stream can be  
18 discharged to the house septic or sewer system.

19 This alternative does not present options for a regional solution.

20 The estimated capital cost for this alternative includes purchasing and installing the  
21 POU treatment systems. The estimated O&M cost for this alternative includes the  
22 purchase and replacement of filters and media, as well as periodic sampling and record  
23 keeping. The estimated capital cost for this alternative is \$37,000, and the estimated  
24 annual O&M cost is \$35,000. For the cost estimate, it is assumed that one POU  
25 treatment unit would be required for each of the 56 existing connections to the Sandy  
26 Meadow Estates system. It should be noted that the POU treatment units would need to  
27 be more complex than units typically found in commercial retail outlets in order to meet  
28 regulatory requirements, making purchase and installation more expensive.

29 The reliability of adequate amounts of compliant water under this alternative is fair,  
30 since it relies on active cooperation of the customers for system installation, use, and  
31 maintenance, and only provides compliant water to a single tap within a house.  
32 Additionally, the O&M efforts required for the POU systems would be significant, and  
33 Orbit personnel are inexperienced in this type of work. From the perspective of Orbit,  
34 this alternative would be characterized as more difficult to operate due to the in-home  
35 requirements and the large number of individual units.

36 The feasibility of this alternative is not dependent on the cooperation, willingness, or  
37 capability of other PWS entities.

#### 38 **4.5.12 Alternative SM-12: Point-of-Entry Treatment**

39 This alternative consists of the continued operation of the Sandy Meadow Estates  
40 well field, plus treatment of water to remove arsenic as it enters the residence. The

1 purchase, installation, and maintenance of the treatment systems at the POE would be  
2 necessary for this alternative. Blending is not an option in this case.

3 This alternative would require installation of the POE treatment units at houses and  
4 other buildings that provide water for drinking or cooking. Orbit would be responsible  
5 for purchase and maintenance of the treatment units, including media and filter  
6 replacement, periodic sampling, and necessary repairs. It may also be desirable to  
7 modify piping so that water for non-consumptive uses can be withdrawn upstream of the  
8 treatment unit. The POE treatment units would be installed outside the residence, so  
9 entry would not be necessary for O&M. Some cooperation from customers would be  
10 necessary for installation and maintenance of the treatment systems.

11 POE arsenic treatment processes typically produce spent adsorption media as waste,  
12 and possibly backwash water that requires disposal. The backwash water stream results  
13 in a slight increase in the overall volume of water used. POE systems treat a greater  
14 volume of water than POU systems. For this alternative, it is assumed that the increase in  
15 water consumption would be insignificant in terms of supply cost, and that the backwash  
16 waste stream can be discharged to the house septic or sewer system.

17 This alternative does not present options for a regional solution.

18 The estimated capital cost for this alternative includes purchasing and installing the  
19 POE treatment systems. The estimated O&M cost for this alternative includes the  
20 purchase and replacement of filters and media, as well as periodic sampling and record  
21 keeping. The estimated capital cost for this alternative is \$646,800, and the estimated  
22 annual O&M cost is \$78,400. For the cost estimate, it is assumed that one POE treatment  
23 unit would be required for each of the 56 existing connections to the Sandy Meadow  
24 Estates system.

25 The reliability of adequate amounts of compliant water under this alternative is fair,  
26 but better than POU systems since it relies less on the active cooperation of customers for  
27 system installation, use, and maintenance, and compliant water is supplied to all taps  
28 within a house. Additionally, the O&M efforts required for the POE systems would be  
29 significant, and Orbit personnel are inexperienced in this type of work. From the  
30 perspective of Orbit, this alternative would be characterized as more difficult to operate  
31 due to the on-property requirements and the large number of individual units.

32 The feasibility of this alternative is not dependent on the cooperation, willingness, or  
33 capability of other PWS entities.

#### 34 **4.5.13 Alternative SM-13: New Well at 10 Miles**

35 This alternative consists of installing one new well within 10 miles of the Sandy  
36 Meadow Estates which would produce compliant water in place of the water produced by  
37 the current well field. At this level of study, it is not possible to positively identify an  
38 existing well or the location where a new well could be installed. In order to address a



1 range of solutions, three different well alternatives are developed, assuming the new well  
2 is located within 10 miles, 5 miles, and 1 mile from the existing intake point.

3 This alternative would require construction of one new 310-foot well, a new pump  
4 station with storage tank near the new well, and a pipeline from the new well/tank to the  
5 existing intake point for the Sandy Meadow Estates system. The pump station and  
6 storage tank would be necessary to overcome pipe friction and changes in land elevation.  
7 For this alternative, the pipeline is assumed to be approximately 10 miles long, and  
8 would be a 4-inch PVC line that discharges to the existing Sandy Meadow Estates  
9 storage tank. The pump station would include two pumps, including one standby, and  
10 would be housed in a building.

11 Depending on well location and capacity, this alternative could present some options  
12 for a more regional solution. It may be possible to share water and costs with another  
13 nearby system.

14 The estimated capital cost for this alternative includes installing the well, and  
15 constructing the pipeline and pump station. The estimated O&M cost for this alternative  
16 includes O&M for the pipeline and pump station, plus an amount for plugging and  
17 abandoning (in accordance with TCEQ requirements) the existing wells. The estimated  
18 capital cost for this alternative is \$2,559,000, and the estimated annual O&M cost is  
19 \$16,700.

20 The reliability of adequate amounts of compliant water under this alternative should  
21 be good, since water wells, pump stations and pipelines are commonly employed. From  
22 the perspective of Orbit, this alternative would be similar to operating the existing  
23 system. Orbit personnel are experienced with O&M of wells, pipelines, and pump  
24 stations.

25 The feasibility of this alternative is dependent on the ability to find an adequate  
26 existing well or success in installing a well that produces an adequate supply of  
27 compliant water. It is possible that an alternate groundwater source may not be found on  
28 Sandy Meadow Estates or Orbit-controlled land, so landowner cooperation would be  
29 required.

#### 30 **4.5.14 Alternative SM-14: New Well at 5 Miles**

31 This alternative consists of installing one new well within 5 miles of Sandy Meadow  
32 Estates that would produce compliant water in place of the water produced by the current  
33 well field. At this level of study, it is not possible to positively identify an existing well  
34 or the location where a new well could be installed.

35 This alternative would require construction of one new 310-foot well, a new pump  
36 station with storage tank near the new well, and a pipeline from the new well/tank to the  
37 existing intake point for the Sandy Meadow Estates system. The pump station and  
38 storage tank would be necessary to overcome pipe friction and changes in land elevation.  
39 For this alternative, the pipeline is assumed to be approximately 5 miles long, and would

1 be a 4-inch PVC line that discharges to the existing Sandy Meadow Estates storage tank.  
2 The pump station would include two pumps, including one standby, and would be housed  
3 in a building.

4 Depending on well location and capacity, this alternative could present some options  
5 for a more regional solution. It may be possible to share water and costs with another  
6 nearby PWS system.

7 The estimated capital cost for this alternative includes installing the well and  
8 constructing the pipeline and pump station. The estimated O&M cost for this alternative  
9 includes the cost for O&M for the pipeline and pump station, plus an amount for  
10 plugging and abandoning (in accordance with TCEQ requirements) the existing wells.  
11 The estimated capital cost for this alternative is \$1,337,100, and the estimated annual  
12 O&M cost is \$12,400.

13 The reliability of adequate amounts of compliant water under this alternative should  
14 be good, since water wells, pump stations, and pipelines are commonly employed. From  
15 the perspective of Orbit, this alternative would be similar to operating the existing  
16 system. Orbit personnel have experience with O&M of wells, pipelines, and pump  
17 stations.

18 The feasibility of this alternative is dependent on the ability to find an adequate  
19 existing well or success in installing a well that produces an adequate supply of  
20 compliant water. It is possible that an alternate groundwater source may not be found on  
21 Sandy Meadow Estates or Orbit-controlled land, so landowner cooperation would be  
22 required.

#### 23 **4.5.15 Alternative SM-15: New Well at 1 Mile**

24 This alternative consists of installing one new well within 1 mile of Sandy Meadow  
25 Estates that would produce compliant water in place of the water produced by the current  
26 well field. At this level of study, it is not possible to positively identify an existing well  
27 or the location where a new well could be installed.

28 This alternative would require construction of one new 310-foot well, and a pipeline  
29 from the new well to the existing intake point for the Sandy Meadow Estates system. For  
30 this alternative, the pipeline is assumed to be approximately 1 mile long, and would be a  
31 4-inch PVC line that discharges to the existing Sandy Meadow Estates storage tank.

32 Depending on well location and capacity, this alternative could present some options  
33 for a more regional solution. It may be possible to share water and costs with another  
34 nearby system.

35 The estimated capital cost for this alternative includes installing the well and  
36 constructing the pipeline. The estimated O&M cost for this alternative includes O&M  
37 for the pipeline, plus an amount for plugging and abandoning (in accordance with TCEQ  
38 requirements) the existing wells at Sandy Meadow Estates. The estimated capital cost for

1 this alternative is \$290,100, and the estimated annual O&M cost is \$6,400 less than  
2 current costs.

3 The reliability of adequate amounts of compliant water under this alternative should  
4 be good, since water wells and pipelines are commonly employed. From the perspective  
5 of Orbit, this alternative would be similar to operating the existing system. Orbit  
6 personnel have experience with O&M of wells, pipelines, and pump stations.

7 The feasibility of this alternative is dependent on the ability to find an adequate  
8 existing well or success in installing a well that produces an adequate supply of  
9 compliant water. It is possible that an alternate groundwater source may not be found on  
10 Sandy Meadow Estates or Orbit-controlled land, so landowner cooperation would be  
11 required.

#### 12 **4.5.16 Alternative SM-16: Public Dispenser for Treated Drinking Water**

13 This alternative consists of the continued operation of the Sandy Meadow Estates  
14 well field, plus dispensing treated water for drinking and cooking at a publicly accessible  
15 location. Implementing this alternative would require purchasing and installing a  
16 treatment unit where customers would be able to come to fill their own containers. This  
17 alternative also includes notifying customers of the importance of obtaining drinking  
18 water from the dispenser. In this way, only a relatively small volume of water requires  
19 treatment, but customers would be required to pick up and deliver their own water.  
20 Blending is not an option in this case. It should be noted that this alternative would be  
21 considered an interim measure until a compliance alternative is implemented.

22 Orbit would be responsible for maintenance of the treatment unit, including media  
23 replacement, periodic sampling, and necessary repairs. The spent media would require  
24 disposal. This alternative relies on a great deal of cooperation and action from customers  
25 in order to be effective.

26 This alternative does not present options for a regional solution.

27 The estimated capital cost for this alternative includes purchasing and installing the  
28 treatment system to be used for the drinking water dispenser. The estimated O&M cost  
29 for this alternative includes purchase and replacement of filters and media, as well as  
30 periodic sampling and record keeping. The estimated capital cost for this alternative is  
31 \$11,600, and the estimated annual O&M cost is \$16,700.

32 The reliability of adequate amounts of compliant water under this alternative is fair,  
33 because of the large amount of effort required from customers and the associated  
34 inconvenience. Orbit has not provided this type of service in the past. From the  
35 perspective of Orbit, this alternative would be characterized as relatively easy to operate,  
36 since these types of treatment units are highly automated, and there is only one unit.

37 The feasibility of this alternative is not dependent on the cooperation, willingness, or  
38 capability of other water supply entities.

1 **4.5.17 Alternative SM-17: 100 Percent Bottled Water Delivery**

2 This alternative consists of the continued operation of the Sandy Meadow Estates  
3 well field, but compliant drinking water would be delivered to customers in containers.  
4 This alternative involves setting up and operating a bottled water delivery program to  
5 serve all customers in the system. It is expected that Orbit would find it convenient and  
6 economical to contract a bottled water service. The bottle delivery program would have  
7 to be flexible enough to allow for delivery of smaller containers should customers be  
8 incapable of lifting and manipulating 5-gallon bottles. Blending is not an option in this  
9 case. It should be noted that this alternative would be considered an interim measure  
10 until a compliance alternative is implemented.

11 This alternative does not involve capital cost for construction, but would require  
12 some initial costs for system setup, and then ongoing costs to have the bottled water  
13 furnished. It is assumed for this alternative that bottled water is provided to 100 percent  
14 of the Sandy Meadow Estates customers.

15 This alternative does not present options for a regional solution.

16 The estimated initial capital cost is for setting up the program. The estimated O&M  
17 cost for this alternative includes program administration and purchase of the bottled  
18 water. The estimated capital cost for this alternative is \$23,900, and the estimated annual  
19 O&M cost is \$123,000. For the cost estimate, it is assumed that each person requires  
20 1 gallon of bottled water per day.

21 The reliability of adequate amounts of compliant water under this alternative is fair,  
22 since it relies on the active cooperation of customers to order and utilize the water.  
23 Management and administration of the bottled water delivery program would require  
24 attention from Orbit.

25 The feasibility of this alternative is not dependent on the cooperation, willingness, or  
26 capability of other PWS entities.

27 **4.5.18 Alternative SM-18: Public Dispenser for Trucked Drinking Water**

28 This alternative consists of continued operation of the Sandy Meadow Estates well  
29 field, plus dispensing compliant water for drinking and cooking at a publicly accessible  
30 location. The compliant water would be purchased from a nearby supplier, and delivered  
31 by truck to a tank at a central location where customers would be able to fill their own  
32 containers. This alternative also includes notifying customers of the importance of  
33 obtaining drinking water from the dispenser. In this way, only a relatively small volume  
34 of water requires trucking, but customers are required to pick up and deliver their own  
35 water. Blending is not an option in this case. It should be noted that this alternative  
36 would be considered an interim measure until a compliance alternative is implemented.

37 Orbit would purchase a truck suitable for hauling potable water and install a storage  
38 tank. It is assumed the storage tank would be filled once a week, and that the chlorine

1 residual would be tested for each truckload. The truck would have to meet requirements  
2 for potable water, and each load would be treated with chlorine. This alternative relies  
3 on cooperation and action from customers for it to be effective.

4 This alternative presents limited options for a regional solution if two or more  
5 systems share the purchase and operation of the water truck.

6 The estimated capital cost for this alternative includes purchase of a water truck and  
7 construction of the storage tank to be used for the drinking water dispenser. The  
8 estimated O&M cost for this alternative includes O&M for the truck, maintenance for the  
9 tank, water quality testing, record keeping, and water purchase. The estimated capital  
10 cost for this alternative is \$103,000, and the estimated annual O&M cost is \$15,900.

11 The reliability of adequate amounts of compliant water under this alternative is fair  
12 because of the large amount of effort required from customers and the associated  
13 inconvenience. Orbit has not provided this type of service in the past. From the  
14 perspective of Orbit, this alternative would be characterized as relatively easy to operate,  
15 but the hauling and storage of water would need to be practiced with care to ensure  
16 sanitary conditions.

17 The feasibility of this alternative is not dependent on the cooperation, willingness, or  
18 capability of other PWS entities.

#### 19 **4.5.19 Summary of Alternatives**

20 Table 4.3 provides a summary of the key features of each alternative for Sandy  
21 Meadow Estates.

1 **Table 4.3 Summary of Compliance Alternatives for Sandy Meadow Estates**

Alt No.	Alternative Description	Major Components	Capital Cost <sup>1</sup>	Annual O&M Cost	Total Annualized Cost <sup>2</sup>	Reliability	System Impact	Remarks
SM-1	Purchased treated groundwater from City of Alvin	- Ground storage tanks - Pump stations with two transfer pumps at each station - 11.5-mile pipeline	\$3,192,000	\$35,600	\$313,900	Good	N	Alternative assumes City of Alvin will sell water.
SM-2	Purchase treated surface water from BWA	- Ground storage tanks - Pump stations with two transfer pumps at each station - 14.2-mile pipeline	\$3,598,300	\$37,300	\$351,100	Good	N	BWA expects to sell all excess capacity within the next 5 years.
SM-3	Drill new well near Briar Meadows	- New well (215 ft) - Ground storage tank - Pump station with two transfer pumps - 3.2-mile pipeline	\$961,400	\$11,100	\$94,900	Good	N	Alternative assumes land and adequate quantity of compliant groundwater are available.
SM-4	Purchase groundwater from J M P Utilities	- Ground storage tank - Pump station with two transfer pumps - 7.1-mile pipeline	\$1,832,400	\$17,300	\$177,100	Good	N	Alternative assumes J M P Utilities is willing to sell water.
SM-5	Drill new well near Mammoet USA, Inc.	- New well (270 ft) - Ground storage tank - Pump station with two transfer pumps - 6.6-mile pipeline	\$1,682,500	\$14,000	\$160,700	Good	N	Alternative assumes land and adequate quantity of compliant groundwater are available.
SM-6	Drill new well near Oak Bend Estates	- New well (150 ft) - Ground storage tank - Pump station with two transfer pumps - 8.3-mile pipeline	\$2,147,600	\$15,100	\$202,300	Good	N	Alternative assumes land and adequate quantity of compliant groundwater are available.

Alt No.	Alternative Description	Major Components	Capital Cost <sup>1</sup>	Annual O&M Cost	Total Annualized Cost <sup>2</sup>	Reliability	System Impact	Remarks
SM-7	Drill new well near TDCJ Darrington Unit	- New well (600 ft) - Ground storage tank - Pump station with two transfer pumps - 8.3-mile pipeline	\$2,010,000	\$15,600	\$190,900	Good	N	Alternative assumes land and adequate quantity of compliant groundwater are available.
SM-8	Drill new well near TDCJ Ramsey Area	- New well (270 ft) - Ground storage tanks - Pump stations with two transfer pumps at each station - 13.7-mile pipeline	\$3,457,900	\$34,400	\$335,900	Good	N	Alternative assumes land and adequate quantity of compliant groundwater are available.
SM-9	Continued use of existing wells with central iron-based adsorption treatment	One central iron-based adsorption treatment unit	\$376,900	\$55,700	\$88,500	Good	T	There are nearby systems that could possibly share in treatment plant cost.
SM-10	Continued use of existing wells with central coagulation/filtration treatment	One central coagulation/filtration treatment unit	\$291,600	\$125,300	\$150,700	Good	T	There are nearby systems that could possibly share in treatment plant cost.
SM-11	Continued use of existing wells with POU treatment	Small adsorption treatment unit for each customer	\$37,000	\$35,000	\$38,200	Fair	T, M	Alternative assumes cooperation from all customers for entry into houses and businesses for installation and maintenance of treatment systems. Does not provide compliant water to all taps.
SM-12	Continued use of existing wells with POE treatment	Small adsorption treatment unit for each customer	\$646,800	\$78,400	\$134,800	Good	T, M	Alternative assumes cooperation from all customers for installation and maintenance of treatment systems. Provides compliant water to all taps.
SM-13	Install new compliant well within 10 miles	- New well - Ground storage tank - Pump station with two transfer pumps - 10-mile pipeline	\$2,559,000	\$16,700	\$239,800	Good	N	Alternative assumes land and adequate quantity of compliant groundwater are available.

Alt No.	Alternative Description	Major Components	Capital Cost <sup>1</sup>	Annual O&M Cost	Total Annualized Cost <sup>2</sup>	Reliability	System Impact	Remarks
SM-14	Install new compliant well within 5 miles	- New well - Ground storage tank - Pump station with two transfer pumps - 5-mile pipeline	\$1,337,100	\$12,400	\$129,000	Good	N	Alternative assumes land and adequate quantity of compliant groundwater are available.
SM-15	Install new compliant well within 1 mile	- New well - 1-mile pipeline	\$290,100	\$(6,400)	\$18,900	Good	N	Alternative assumes land and adequate quantity of compliant groundwater are available.
SM-16	Continued use of existing wells with public dispenser for treated drinking water	- Install medium size iron-based adsorption treatment system, storage tank, and public dispenser	\$11,600	\$16,700	\$17,700	Fair / interim measure	T	INTERIM SOLUTION: Does not provide compliant water to home or building taps; requires considerable effort by customers.
SM-17	Continued use of existing wells with bottled water delivery for all customers	- Set up bottled water delivery system	\$23,900	\$123,000	\$125,000	Fair / interim measure	M	INTERIM SOLUTION: Does not provide compliant water to home or building taps; requires considerable effort by customers to order and use delivered water. Management and administration of program may be significant.
SM-18	Continued use of existing wells with public dispenser for trucked drinking water	- Install storage tank and public dispenser - Buy delivery truck	\$103,000	\$15,900	\$24,800	Fair / interim measure	M	INTERIM SOLUTION: Does not provide compliant water to building taps; requires considerable effort by customers.

1 Notes: N – No significant increase required in technical or management capability  
2 T – Implementation of alternative will require increase in technical capability  
3 M – Implementation of alternative will require increase in management capability  
4 1 – See cost breakdown in Appendix C  
5 2 – 20-year return period and 6 percent interest



1    **4.6       COST OF SERVICE AND FUNDING ANALYSIS**

2       To evaluate the financial impact of implementing compliance alternatives, a 30-year  
3   financial planning model was developed. This model can be found in Appendix D. The  
4   financial model is based on estimated cash flows, with and without implementation of the  
5   compliance alternatives. Data for such models are typically derived from established  
6   budgets, audited financial reports, published water tariffs, and consumption data. Orbit  
7   manages 33 small rural PWSs and three wastewater treatment plants. The only financial  
8   data available were a consolidated Profit and Loss Statement and a Water and  
9   Wastewater Utilities Annual Report for 2004. The Water Utility Tariff and water usage  
10  records for all 33 Orbit PWSs were also available.

11       This analysis will need to be performed in a more detailed fashion and applied to  
12  alternatives that are deemed attractive and worthy of more detailed evaluation. A more  
13  detailed analysis should include additional factors such as:

- 14           • Cost escalation,
- 15           • Price elasticity effects where increased rates may result in lower water  
16           consumption,
- 17           • Costs for other system upgrades and rehabilitation needed to maintain  
18           compliant operation.

19    **4.6.1     Financial Plan Development**

20    **4.6.1.1   Sandy Meadow Estates Financial Data**

21       Since Orbit does not keep separate financial records for each of the 33 PWSs it  
22  manages, revenues and expenses had to be estimated for Sandy Meadow Estates. Annual  
23  revenue was estimated using a base rate of \$21 per month per connection plus actual  
24  usage at a rate of \$1.90 per 1,000 gallons assuming a water loss of 11.4 percent. These  
25  values were plugged into the financial model resulting in 2004 revenue of \$24,456  
26  (operating revenue plus required reserve) for Sandy Meadow Estates compared to  
27  \$7,780,508 total 2004 revenue for Orbit Systems as summarized in Table 4.4.

1 **Table 4.4 Summary of Orbit Systems 2004 Water Revenues**

PWS Name	2004 Water Usage (gallons)	No. Connections	2004 Water Revenue
Rosharon Township	8,055,400	85	\$40,038
Rosharon Roads Estates	5,455,900	76	\$29,870
Sandy Meadow Estates	3,735,400	56	\$24,456
Mark V Estates	7,178,900	94	\$37,858
Grasslands	12,465,400	150	\$67,595
Other Systems - Water	88,671,400	1,236	\$503,096
Other Systems - Sewer	125,562,400	---	\$77,595
<b>Total</b>		<b>1,697</b>	<b>\$780,508</b>

2 Annual expenses for Sandy Meadow Estates were estimated based on its percentage  
3 water usage of 3.0 percent as shown in Appendix F. This resulted in 2004 expenses of  
4 \$22,930 (including depreciation) compared to \$770,256 total expenses for Orbit as  
5 summarized in Table 4.5.

6 **Table 4.5 Summary of Orbit Systems 2004 Expenses**

PWS Name	2004 Water Usage (gallons)	% Water Usage	2004 Water Expenses
Rosharon Township	8,055,400	6.4	\$48,917
Rosharon Roads Estates	5,455,900	4.3	\$32,866
Sandy Meadow Estates	3,735,400	3.0	\$22,930
Mark V Estates	7,178,900	5.7	\$43,566
Grasslands	12,465,400	10.3	\$79,317
Other Systems	88,671,400	70.3	\$542,660
<b>Total</b>	<b>125,562,400</b>	<b>100.0</b>	<b>\$770,256</b>

7 **4.6.1.2 Current Financial Condition**

8 **4.6.1.2.1 Cash Flow Needs**

9 Table 4.6 shows the 2004 revenues and expenses for Sandy Meadow Estates  
10 compared to other Orbit PWSs included in this study. The excess for Sandy Meadow  
11 Estates of \$1,526 is based on current operations without any capital expenditures to  
12 address the arsenic problem. This means that Orbit is currently charging its Sandy  
13 Meadow Estates customers enough for water usage to sustain this portion of the  
14 operation.

15 **Table 4.6 Summary of Orbit Systems 2004 Operations**

PWS Name	2004 Water Expenses	2004 Water Revenue	Over / (Under)
Rosharon Township	\$ 48,917	\$ 40,038	(\$ 8,879)
Rosharon Roads Estates	\$ 32,866	\$ 29,870	(\$ 2,996)
Sandy Meadow Estates	\$ 22,930	\$ 24,456	\$ 1,526
Mark V Estates	\$ 43,566	\$ 37,858	(\$ 5,708)
Grasslands	\$ 79,317	\$ 67,595	(\$11,722)

1 Table 4.7 shows the average annual bill for Sandy Meadow Estates customers as a  
2 percent of the MHI for Brazoria County compared to other Orbit PWSs included in this  
3 study. The average annual bill in Sandy Meadow Estates would stay the same at \$344  
4 based on the no action alternative.

5 **Table 4.7 Summary of Orbit Systems Required Revenue Increases**

PWS Name	Current Average Annual Bill	Current % MHI	% Increase Needed	New Average Annual Bill	New % MHI
Rosharon Township	\$ 252	0.52 %	71.4 %	\$ 432	0.89 %
Rosharon Roads Estates	\$ 373	0.77 %	1.3 %	\$ 378	0.81 %
Sandy Meadow Estates	\$ 344	0.86 %	None	\$ 295	0.74 %
Mark V Estates	\$ 381	0.78 %	6.3 %	\$ 405	0.90 %
Grasslands	\$ 375	0.77 %	8.8 %	\$ 408	0.87 %

6 **4.6.1.2.2 Ratio Analysis**

7 There is not enough financial information available for Orbit Systems or Sandy  
8 Meadow Estates to calculate the Current Ratio or the Debt to Net Worth Ratio.  
9 However, an Operating Ratio of 1.07 was calculated from available financial  
10 information. An Operating Ratio of 1.0 means that a utility is collecting just enough  
11 money to meet expenses; thus, an Operating Ratio of 1.07 is just another indication that  
12 Orbit Systems does not need to raise its water rates for its Sandy Meadow Estates  
13 customers in the near future based on the no action alternative.

14 **4.6.1.3 Financial Plan Results**

15 Each compliance alternative for Sandy Meadow Estates was evaluated using the  
16 financial model to determine overall increase in water rates that would be necessary to  
17 pay for the improvements. Each alternative was examined under the various funding  
18 options described in Section 2.4.

19 The financial model results are summarized in Table 4.8 and Figure 4.2 for all the  
20 alternatives. Figure 4.3 shows that the current average annual bill for Sandy Meadow  
21 Estates of \$344 is sufficient to fully fund existing operations. There are two bars shown  
22 for each alternative. The lowest bar is based on 100 percent grant funding of capital  
23 improvements for the compliance alternative. Thus, the higher average annual water bill  
24 reflects only higher O&M costs associated with the compliance alternative. The highest  
25 bar is based on entirely funding capital requirements with either loans or bonds, which  
26 represents the highest cost scenario. Therefore, the higher average annual water bill in  
27 this case reflects both higher O&M costs and the principal and interests costs to service  
28 debt associated with the compliance alternative. Figure 4.2 also shows the annual  
29 residential water bill as a percent of MHI for Brazoria County.

1


**Table 4.8 Financial Impact on Households for Sandy Meadow Estates Alternatives**

		Funding Source #	0	1	2	3	4	5
#	ALTERNATIVES		All Revenue	100% Grant	75% Grant	50% Grant	SRF	Loan/Bond
SM-1	Alvin	Average Annual Water Bill	\$45,586.08	\$1,264.61	\$2,987.03	\$4,709.44	\$7,322.17	\$8,154.27
		Maximum % of HH Income	100%	3%	7%	11%	16%	18%
		Percentage Rate Increase Compared to Current	14045%	302%	846%	1390%	2215%	2477%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-2	Brazosport Water Authority	Average Annual Water Bill	\$51,313.35	\$1,311.23	\$3,252.88	\$5,194.54	\$8,139.83	\$9,077.84
		Maximum % of HH Income	113%	3%	7%	12%	18%	20%
		Percentage Rate Increase Compared to Current	15822%	317%	930%	1543%	2473%	2770%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-3	Briar Meadows	Average Annual Water Bill	\$13,941.82	\$613.37	\$1,132.16	\$1,650.94	\$2,437.89	\$2,688.52
		Maximum % of HH Income	31%	1%	2%	4%	5%	6%
		Percentage Rate Increase Compared to Current	4221%	89%	253%	416%	665%	744%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-4	J M P Utilities	Average Annual Water Bill	\$26,252.02	\$777.75	\$1,766.51	\$2,755.27	\$4,255.12	\$4,732.79
		Maximum % of HH Income	58%	2%	4%	6%	9%	11%
		Percentage Rate Increase Compared to Current	8042%	143%	455%	767%	1241%	1391%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-5	Mammoet USA, Inc.	Average Annual Water Bill	\$24,104.36	\$691.11	\$1,599.02	\$2,506.92	\$3,884.11	\$4,322.72
		Maximum % of HH Income	53%	2%	4%	6%	9%	10%
		Percentage Rate Increase Compared to Current	7375%	114%	401%	688%	1123%	1261%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-6	Oak Bend	Average Annual Water Bill	\$30,646.44	\$718.99	\$1,877.82	\$3,036.64	\$4,794.47	\$5,354.30
		Maximum % of HH Income	67%	2%	4%	7%	11%	12%
		Percentage Rate Increase Compared to Current	9405%	123%	489%	855%	1410%	1587%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-7	TDCJ Darrington	Average Annual Water Bill	\$28,722.37	\$733.55	\$1,818.14	\$2,902.72	\$4,547.92	\$5,071.88
		Maximum % of HH Income	63%	2%	4%	6%	10%	11%
		Percentage Rate Increase Compared to Current	8808%	128%	471%	813%	1333%	1498%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006

		Funding Source #	0	1	2	3	4	5
#	ALTERNATIVES		All Revenue	100% Grant	75% Grant	50% Grant	SRF	Loan/Bond
SM-8	TDCJ Ramsey	Average Annual Water Bill	\$49,302.55	\$1,234.05	\$3,099.92	\$4,965.79	\$7,796.13	\$8,697.53
		Maximum % of HH Income	108%	3%	7%	11%	17%	19%
		Percentage Rate Increase Compared to Current	15198%	292%	881%	1470%	2364%	2649%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-9	Central Adsorption	Average Annual Water Bill	\$6,339.67	\$1,799.69	\$2,003.04	\$2,206.40	\$2,514.86	\$2,613.10
		Maximum % of HH Income	14%	4%	5%	5%	6%	6%
		Percentage Rate Increase Compared to Current	1869%	477%	541%	605%	703%	734%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-10	Central Coagulation	Average Annual Water Bill	\$6,086.69	\$3,653.76	\$3,811.10	\$3,968.45	\$4,207.12	\$4,283.14
		Maximum % of HH Income	13%	8%	9%	9%	10%	10%
		Percentage Rate Increase Compared to Current	1801%	1084%	1133%	1183%	1259%	1283%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-11	POU-Adsorption	Average Annual Water Bill	\$1,287.88	\$1,248.93	\$1,268.87	\$1,288.82	\$1,319.07	\$1,328.71
		Maximum % of HH Income	3%	3%	3%	3%	3%	3%
		Percentage Rate Increase Compared to Current	298%	297%	303%	309%	319%	322%
		Year First Rate Increase Needed	2006	2007	2007	2007	2007	2007
SM-12	POE-Adsorption	Average Annual Water Bill	\$10,436.97	\$2,404.39	\$2,753.41	\$3,102.42	\$3,631.84	\$3,800.45
		Maximum % of HH Income	23%	5%	6%	7%	8%	9%
		Percentage Rate Increase Compared to Current	3144%	675%	785%	895%	1063%	1116%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-13	New well 10 mi	Average Annual Water Bill	\$36,443.93	\$762.76	\$2,143.58	\$3,524.40	\$5,618.97	\$6,286.04
		Maximum % of HH Income	80%	2%	5%	8%	13%	14%
		Percentage Rate Increase Compared to Current	11205%	138%	574%	1010%	1671%	1882%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-14	New well 5 mi	Average Annual Water Bill	\$19,233.20	\$648.49	\$1,369.98	\$2,091.48	\$3,185.91	\$3,534.47
		Maximum % of HH Income	42%	1%	3%	5%	7%	8%
		Percentage Rate Increase Compared to Current	5863%	100%	328%	556%	902%	1012%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006

		Funding Source #	0	1	2	3	4	5
#	ALTERNATIVES		All Revenue	100% Grant	75% Grant	50% Grant	SRF	Loan/Bond
SM-15	New well 1 mi	Average Annual Water Bill	\$4,378.97	\$344.47	\$386.91	\$520.94	\$758.35	\$833.96
		Maximum % of HH Income	10%	1%	1%	1%	2%	2%
		Percentage Rate Increase Compared to Current	1252%	0%	13%	55%	130%	154%
		Year First Rate Increase Needed	2006	2007	2006	2006	2006	2006
SM-16	Dispenser	Average Annual Water Bill	\$771.62	\$760.39	\$766.65	\$772.91	\$782.40	\$785.43
		Maximum % of HH Income	2%	2%	2%	2%	2%	2%
		Percentage Rate Increase Compared to Current	137%	137%	139%	141%	144%	145%
		Year First Rate Increase Needed	2006	2007	2007	2007	2007	2007
SM-17	100% Bottled	Average Annual Water Bill	\$3,613.73	\$3,590.55	\$3,603.47	\$3,616.39	\$3,635.98	\$3,642.22
		Maximum % of HH Income	8%	8%	8%	8%	8%	8%
		Percentage Rate Increase Compared to Current	1063%	1063%	1067%	1071%	1077%	1079%
		Year First Rate Increase Needed	2006	2007	2007	2007	2007	2007
SM-18	Central Trucked	Average Annual Water Bill	\$1,955.43	\$739.57	\$795.14	\$850.71	\$935.01	\$961.85
		Maximum % of HH Income	4%	2%	2%	2%	2%	2%
		Percentage Rate Increase Compared to Current	502%	130%	148%	165%	192%	200%
		Year First Rate Increase Needed	2006	2007	2007	2007	2006	2006

**Figure 4-2 Alternative Cost Summary**



Current Rates:  
 Monthly: \$28.67  
 Median Household Income: \$48,632  
 Average Monthly Residential Usage: 4,056 gallons

1 **SECTION 5**  
2 **REFERENCES**

- 3 Ashworth J. B., and Hopkins, J. 1992. Aquifers of Texas: Texas Water Development Board  
4 Report 345, 68 p.
- 5 Kasmerek, M.C. and J.L. Robinson. 2004. Hydrogeology and simulation of ground-water flow  
6 and land-surface subsidence in the northern part of the Gulf Coast Aquifer system, Texas:  
7 U.S. Geological Survey Scientific Investigations Report 2004-5102, 111 p.
- 8 Kasmerek, M.C., B.D. Reece, B.D., and N.A. Houston. 2005. Evaluation of ground-water flow  
9 and land-surface subsidence caused by hypothetical withdrawals in the northern part of  
10 the Gulf Coast aquifer system, Texas: U.S. Geological Survey Scientific Investigations  
11 Report 2005-5024, 70 p.
- 12 Raucher, *et al.* 2004. Conventional and Unconventional Approaches to Water Service Provision  
13 [Project #2761]. Robert Raucher, Marca L. Hagenstad, Joseph Cotruvo, Ramesh  
14 Narasimhan, Kate Martin, Harish Arora, R. Nathan, Joseph Drago, and Fred Pontius.  
15 AWWA Research Foundation and American Water Works Association.
- 16 TCEQ. 2004. Drinking Water Quality and Reporting Requirements for PWSs: 30 TAC 290  
17 Subchapter F (290.104. Summary of Maximum Contaminant Levels, Maximum Residual  
18 Disinfectant Levels, Treatment Techniques, and Action Levels). Revised February 2004.
- 19 USEPA. 2001. National Primary Drinking Water Regulations; Arsenic Contaminants  
20 Monitoring. Final Rule. *Federal Register*: January 22, 2001 (Volume 66, Number 14, p.  
21 6975-7066).
- 22 USEPA. 2004. Capital Costs of Arsenic Removal Technologies, U.S. EPA Arsenic Removal  
23 Technology Demonstration Program Round 1. EPA 600/R-04/201.
- 24 USEPA. 2005a. List of Drinking Water Contaminants & MCLs. Online. Last updated February  
25 23, 2005. [www.epa.gov/safewater/mcl.html](http://www.epa.gov/safewater/mcl.html).
- 26 USEPA. 2005b. Technical Fact Sheet: Final Rule for Arsenic in Drinking Water. EPA 815-F-  
27 00-016. Online. Last updated February 14, 2005.  
28 [www.epa.gov/safewater/ars/ars\\_rule\\_techfactsheet.html](http://www.epa.gov/safewater/ars/ars_rule_techfactsheet.html).



1  
2

**APPENDIX A  
PWS INTERVIEW FORM**

# CAPACITY DEVELOPMENT ASSESSMENT FORM

Prepared By \_\_\_\_\_

Date \_\_\_\_\_

## Section 1. Public Water System Information

1. PWS ID #	<input type="text"/>	2. Water System Name	<input type="text"/>
3. County	<input type="text"/>		
4. Owner	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
5. Admin	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
6. Operator	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
7. Population Served	<input type="text"/>	8. No. of Service Connections	<input type="text"/>
9. Ownership Type	<input type="text"/>	10. Metered (Yes or No)	<input type="text"/>
11. Source Type	<input type="text"/>		
12. Total PWS Annual Water Used	<input type="text"/>		
13. Number of Water Quality Violations (Prior 36 months)			
Total Coliform	<input type="text"/>	Chemical/Radiological	<input type="text"/>
Monitoring (CCR, Public Notification, etc.)	<input type="text"/>	Treatment Technique, D/DBP	<input type="text"/>

**A. Basic Information**

1. Name of Water System:
2. Name of Person Interviewed:
3. Position:
4. Number of years at job:
5. Number of years experience with drinking water systems:
6. Percent of time (day or week) on drinking water system activities, with current position (how much time is dedicated exclusively to the water system, not wastewater, solid waste or other activities):
7. Certified Water Operator (Yes or No):  
  
    If Yes,  
    7a. Certification Level (water):  
  
    7b. How long have you been certified?
8. Describe your water system related duties on a typical day.

**B. Organization and Structure**

1. Describe the organizational structure of the Utility. Please provide an organizational chart. (Looking to find out the governance structure (who reports to whom), whether or not there is a utility board, if the water system answers to public works or city council, etc.)

2. If not already covered in Question 1, to whom do you report?
3. Do all of the positions have a written job description?
  - 3a. If yes, is it available to employees?
  - 3b. May we see a copy?

<b>C. Personnel</b>
---------------------

1. What is the current staffing level (include all personnel who spend more than 10% of their time working on the water system)?
  
  
  
  
  
  
  
  
  
  
2. Are there any vacant positions? How long have the positions been vacant?
  
  
  
  
  
  
  
  
  
  
3. In your opinion, is the current staffing level adequate? If not adequate, what are the issues or staffing needs (how many and what positions)?
  
  
  
  
  
  
  
  
  
  
4. What is the rate of employee turnover for management and operators? What are the major issues involved in the turnover (e.g., operator pay, working conditions, hours)?
  
  
  
  
  
  
  
  
  
  
5. Is the system staffed 24 hours a day? How is this handled (on-site or on-call)? Is there an alarm system to call an operator if an emergency occurs after hours?

<b>D. Communication</b>
-------------------------

1. Does the utility have a mission statement? If yes, what is it?
2. Does the utility have water quality goals? What are they?
3. How are your work priorities set?
4. How are work tasks delegated to staff?
5. Does the utility have regular staff meetings? How often? Who attends?
6. Are there separate management meetings? If so, describe.
7. Do management personnel ever visit the treatment facility? If yes, how often?
8. Is there effective communication between utility management and state regulators (e.g., NMED)?
9. Describe communication between utility and customers.

**E. Planning and Funding**

1. Describe the rate structure for the utility.
  
2. Is there a written rate structure, such as a rate ordinance? May we see it?
  - 2a. What is the average rate for 6,000 gallons of water?
  
3. How often are the rates reviewed?
  
4. What process is used to set or revise the rates?
  
5. In general, how often are the new rates set?
  
6. Is there an operating budget for the water utility? Is it separate from other activities, such as wastewater, other utilities, or general city funds?
  
7. Who develops the budget, how is it developed and how often is a new budget created or the old budget updated?
  
8. How is the budget approved or adopted?

9. In the last 5 years, how many budget shortfalls have there been (i.e., didn't collect enough money to cover expenses)? What caused the shortfall (e.g., unpaid bills, an emergency repair, weather conditions)?  
  
9a. How are budget shortfalls handled?
10. In the last 5 years how many years have there been budget surpluses (i.e., collected revenues exceeded expenses)?  
  
10a. How are budget surpluses handled (i.e., what is done with the money)?
11. Does the utility have a line-item in the budget for emergencies or some kind of emergency reserve account?
12. How do you plan and pay for short-term system needs?
13. How do you plan and pay for long- term system needs?
14. How are major water system capital improvements funded? Does the utility have a written capital improvements plan?
15. How is the facility planning for future growth (either new hook-ups or expansion into new areas)?
16. Does the utility have and maintain an annual financial report? Is it presented to policy makers?

17. Has an independent financial audit been conducted of the utility finances? If so, how often? When was the last one?
18. Will the system consider any type of regionalization with any other PWS, such as system interconnection, purchasing water, sharing operator, emergency water connection, sharing bookkeeper/billing or other?

<b>F. Policies, Procedures, and Programs</b>
--

1. Are there written operational procedures? Do the employees use them?
2. Who in the utility department has spending authorization? What is the process for obtaining needed equipment or supplies, including who approves expenditures?
3. Does the utility have a source water protection program? What are the major components of the program?
4. Are managers and operators familiar with current SDWA regulations?
5. How do the managers and operators hear about new or proposed regulations, such as arsenic, DBP, Groundwater Rule? Are there any new regulations that will be of particular concern to the utility?
6. What are the typical customer complaints that the utility receives?
7. Approximately how many complaints are there per month?



8. How are customer complaints handled? Are they recorded?
9. (If not specifically addressed in Question 7) If the complaint is of a water quality nature, how are these types of complaints handled?
10. Does the utility maintain an updated list of critical customers?
11. Is there a cross-connection control plan for the utility? Is it written? Who enforces the plan's requirements?
12. Does the utility have a written water conservation plan?
13. Has there been a water audit of the system? If yes, what were the results?
14. (If not specifically answered in 11 above) What is the estimated percentage for loss to leakage for the system?
15. Are you, or is the utility itself, a member of any trade organizations, such as AWWA or Rural Water Association? Are you an active member (i.e., attend regular meetings or participate in a leadership role)? Do you find this membership helpful? If yes, in what ways does it help you?

<b>G. Operations and Maintenance</b>
--------------------------------------

1. How is decision-making authority split between operations and management for the following items:
  - a. Process Control
  - b. Purchases of supplies or small equipment
  - c. Compliance sampling/reporting
  - d. Staff scheduling
  
2. Describe your utility's preventative maintenance program.
  
3. Do the operators have the ability to make changes or modify the preventative maintenance program?
  
4. How does management prioritize the repair or replacement of utility assets? Do the operators play a role in this prioritization process?
  
5. Does the utility keep an inventory of spare parts?
  
6. Where does staff have to go to buy supplies/minor equipment? How often?
  - 6a. How do you handle supplies that are critical, but not in close proximity (for example if chlorine is not available in the immediate area or if the components for a critical pump are not in the area)

7. Describe the system's disinfection process. Have you had any problems in the last few years with the disinfection system?

7a. Who has the ability to adjust the disinfection process?

8. How often is the disinfectant residual checked and where is it checked?

8a. Is there an official policy on checking residuals or is it up to the operators?

9. Does the utility have an O & M manual? Does the staff use it?

10. Are the operators trained on safety issues? How are they trained and how often?

11. Describe how on-going training is handled for operators and other staff. How do you hear about appropriate trainings? Who suggests the trainings – the managers or the operators? How often do operators, managers, or other staff go to training? Who are the typical trainers used and where are the trainings usually held?

12. In your opinion is the level of your on-going training adequate?

13. In your opinion is the level of on-going training for other staff members, particularly the operators, adequate?

14. Does the facility have mapping of the water utility components? Is it used on any routine basis by the operators or management? If so, how is it used? If not, what is the process used for locating utility components?
15. In the last sanitary survey, were any deficiencies noted? If yes, were they corrected?
16. How often are storage tanks inspected? Who does the inspection?
  - 16a. Have you experienced any problems with the storage tanks?

<b>H. SDWA Compliance</b>
---------------------------

1. Has the system had any violations (monitoring or MCL) in the past 3 years? If so, describe.
2. How were the violations handled?
3. Does the system properly publish public notifications when notified of a violation?
4. Is the system currently in violation of any SDWA or state regulatory requirements, including failure to pay fees, fines, or other administrative type requirements?
5. Does the utility prepare and distribute a Consumer Confidence Report (CCR)? Is it done every year? What type of response does the utility get to the CCR from customers?

<b>I. Emergency Planning</b>
------------------------------

1. Does the system have a written emergency plan to handle emergencies such as water outages, weather issues, loss of power, loss of major equipment, etc?
2. When was the last time the plan was updated?
3. Do all employees know where the plan is? Do they follow it?
4. Describe the last emergency the facility faced and how it was handled.

## Attachment A

### A. Technical Capacity Assessment Questions

1. Based on available information of water rights on record and water pumped has the system exceeded its water rights in the past year? YES  NO

In any of the past 5 years? YES  NO  How many times? \_\_\_\_\_

2. Does the system have the proper level of certified operator? *(Use questions a – c to answer.)*  
 YES  NO

a. What is the Classification Level of the system by NMED? \_\_\_\_\_

b. Does the system have one or more certified operator(s)? [20 NMAC 7.4.20]

YES  NO

c. If YES, provide the number of operators at each New Mexico Certification Level. [20 NMAC 7.4.12]

\_\_\_\_\_ NM Small System \_\_\_\_\_ Class 2

\_\_\_\_\_ NM Small System Advanced \_\_\_\_\_ Class 3

\_\_\_\_\_ Class 1 \_\_\_\_\_ Class 4

3. Did the system correct any sanitary deficiency noted on the most recent sanitary survey within 6 months of receiving that information? [20 NMAC 7.20.504]

YES  NO  No Deficiencies

What was the type of deficiency? *(Check all that are applicable.)*

Source  Storage

Treatment  Distribution

Other \_\_\_\_\_

From the system's perspective, were there any other deficiencies that were not noted on the sanitary survey?  
 Please describe.

4. Will the system's current treatment process meet known future regulations?

Radionuclides YES  NO  Doesn't Apply

Arsenic YES  NO  Doesn't Apply

Stage 1 Disinfectants and Disinfection By-Product (DBP)

YES  NO  Doesn't Apply

Surface Water Treatment Rule YES  NO  Doesn't Apply

5. Does the system have a current site plan/map? [20 NMAC 7.10.302 A.1.]

YES  NO

6. Has the system had a water supply outage in the prior 24 months?

YES  NO

What were the causes of the outage(s)? (Include number of outages for each cause.)

Drought \_\_\_\_\_ Limited Supply \_\_\_\_\_

System Failure \_\_\_\_\_ Other \_\_\_\_\_

7. Has the system ever had a water audit or a leak evaluation?

YES  NO  Don't Know

If YES, please complete the following table.

Type of Investigation	Date Done	Water Loss (%)	What approach or technology was used to complete the investigation?	Was any follow-up done? If so, describe

8. Have all drinking water projects received NMED review and approval? [20 NMAC 7.10.201]

YES  NO

If NO, what types of projects have not received NMED review and approval.

Source  Storage

Treatment  Distribution

Other  \_\_\_\_\_

9. What are the typical customer complaints that the utility receives?

10. Approximately how many complaints are there per month? \_\_\_\_\_

11. How are customer complaints handled? Are they recorded?

12. What is the age and composition of the distribution system? *(Collect this information from the Sanitary Survey)*

Pipe Material	Approximate Age	Percentage of the system	Comments
			Sanitary Survey Distribution System Records Attached

13. Are there any dead end lines in the system?  
 YES  NO

14. Does the system have a flushing program?  
 YES  NO   
 If YES, please describe.

15. Are there any pressure problems within the system?  
 YES  NO   
 If YES, please describe.

16. Does the system disinfect the finished water?  
 YES  NO   
 If yes, which disinfectant product is used? \_\_\_\_\_

Interviewer Comments on Technical Capacity:

**B. Managerial Capacity Assessment Questions**

17. Has the system completed a 5-year Infrastructure Capital Improvement Plan (ICIP) plan?  
 YES  NO

If YES, has the plan been submitted to Local Government Division?  
 YES  NO

18. Does the system have written operating procedures?  
 YES  NO

19. Does the system have written job descriptions for all staff?  
 YES  NO



20. Does the system have:
- A preventative maintenance plan?  
YES  NO
  - A source water protection plan?  
YES  NO  N/A
  - An emergency plan?  
YES  NO
  - A cross-connection control program?  
YES  NO
  - An emergency source?  
YES  NO
  - System security measures?  
YES  NO
21. Does the system report and maintain records in accordance with the drinking water regulations concerning:
- Water quality violations  
YES  NO
  - Public notification  
YES  NO
  - Sampling exemptions  
YES  NO
22. Please describe how the above records are maintained:
23. Describe the management structure for the water system, including board and operations staff. Please include examples of duties, if possible.
24. Please describe type and quantity of training or continuing education for staff identified above.
25. Describe last major project undertaken by the water system, including the following: project in detail, positive aspects, negative aspects, the way in which the project was funded, any necessary rate increases, the public response to the project, whether the project is complete or not, and any other pertinent information.

26. Does the system have any debt? YES  NO

If yes, is the system current with all debt payments?

YES  NO

If no, describe the applicable funding agency and the default.

27. Is the system currently contemplating or actively seeking funding for any project?

YES  NO

If yes, from which agency and how much?

Describe the project?

Is the system receiving assistance from any agency or organization in its efforts?

28. Will the system consider any type of regionalization with other PWS? (Check YES if the system has already regionalized.)

YES  NO

If YES, what type of regionalization has been implemented/considered/discussed? (Check all that apply.)

System interconnection

Sharing operator

Sharing bookkeeper

Purchasing water

Emergency water connection

Other: \_\_\_\_\_

29. Does the system have any of the following? (Check all that apply.)

Water Conservation Policy/Ordinance  Current Drought Plan

Water Use Restrictions  Water Supply Emergency Plan

Interviewer Comments on Managerial Capacity:

**C. Financial Capacity Assessment**

30. Does the system have a budget?  
 YES  NO   
 If YES, what type of budget?  
 Operating Budget   
 Capital Budget
31. Have the system revenues covered expenses and debt service for the past 5 years?  
 YES  NO   
 If NO, how many years has the system had a shortfall? \_\_\_\_\_
32. Does the system have a written/adopted rate structure?  
 YES  NO
33. What was the date of the last rate increase? \_\_\_\_\_
34. Are rates reviewed annually?  
 YES  NO   
 IF YES, what was the date of the last review? \_\_\_\_\_
35. Did the rate review show that the rates covered the following expenses? *(Check all that apply.)*
- |                                     |                          |
|-------------------------------------|--------------------------|
| Operation & Maintenance             | <input type="checkbox"/> |
| Infrastructure Repair & replacement | <input type="checkbox"/> |
| Staffing                            | <input type="checkbox"/> |
| Emergency/Reserve fund              | <input type="checkbox"/> |
| Debt payment                        | <input type="checkbox"/> |
36. Is the rate collection above 90% of the customers?  
 YES  NO
37. Is there a cut-off policy for customers who are in arrears with their bill or for illegal connections?  
 YES  NO   
 If yes, is this policy implemented?
38. What is the residential water rate for 6,000 gallons of usage in one month. \_\_\_\_\_
39. In the past 12 months, how many customers have had accounts frozen or dropped for non-payment? \_\_\_\_\_  
 [Convert to % of active connections  
 Less than 1%  1% - 3%  4% - 5%  6% - 10%   
 11% - 20%  21% - 50%  Greater than 50%  ]

40. The following questions refer to the process of obtaining needed equipment and supplies.

a. Can the water system operator buy or obtain supplies or equipment when they are needed?

YES  NO

b. Is the process simple or burdensome to the employees?

c. Can supplies or equipment be obtained quickly during an emergency?

YES  NO

d. Has the water system operator ever experienced a situation in which he/she couldn't purchase the needed supplies?

YES  NO

e. Does the system maintain some type of spare parts inventory?

YES  NO

If yes, please describe.

41. Has the system ever had a financial audit?

YES  NO

If YES, what is the date of the most recent audit? \_\_\_\_\_

42. Has the system ever had its electricity or phone turned off due to non-payment? Please describe.

Interviewer Comments on Financial Assessment:
---

43. What do you think the system capabilities are now and what are the issues you feel your system will be facing in the future? In addition, are there any specific needs, such as types of training that you would like to see addressed by NMED or its contractors?

**APPENDIX B  
COST BASIS**

This section presents the basis for unit costs used to develop the conceptual cost estimates for the compliance alternatives. Cost estimates are conceptual in nature (+50%/-30%), and are intended to make comparisons between compliance options and to provide a preliminary indication of possible rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. Capital cost includes an allowance for engineering and construction management. It is assumed that adequate electrical power is available near the site. The cost estimates specifically do not include costs for the following:

- Obtaining land or easements.
- Surveying.
- Mobilization/demobilization for construction.
- Insurance and bonds.

In general, unit costs are based on recent construction bids for similar work in the area; when possible, consultations with vendors or other suppliers; published construction and O&M cost data; and USEPA cost guidance. Unit costs used for the cost estimates are summarized in Table B.1.

Unit costs for pipeline components are based on recent bids on Texas Department of Highways projects. The amounts of boring and encasement and open cut and encasement were estimated by counting the road, highway, railroad, stream, and river crossings for a conceptual routing of the pipeline. The number of air release valves is estimated by examining the land surface profile along the conceptual pipeline route. It is assumed gate valves and flush valves would be installed on average every 5,000 feet along the pipeline. Pipeline cost estimates are based on use of C-900 PVC pipe. Other pipe materials could be considered for more detailed development of attractive alternatives.

Pump station unit costs are based on experience with similar installations. The cost estimate for the pump stations include two pumps, station piping and valves, station electrical and instrumentation, minor site improvement, installation of a concrete pad and building, and tools. Construction cost of a storage tank is based on similar recent installations.

Electrical power cost is estimated to be \$0.136 per kWh, as supplied by Reliant Energy, Houston, Texas. The annual cost for power to a pump station is calculated based on the pumping head and volume, and includes 11,800 kWh for pump building heating, cooling, and lighting, as recommended in USEPA publication, *Standardized Costs for Water Supply Distribution Systems* (1992).

In addition to the cost of electricity, pump stations have other maintenance costs. These costs cover: materials for minor repairs to keep the pumps operating; purchase of

1 a maintenance vehicle, fuel costs, and vehicle maintenance costs; utilities; office  
2 supplies, small tools and equipment; and miscellaneous materials such as safety, clothing,  
3 chemicals, and paint. The non-power O&M costs are estimated based on the USEPA  
4 publication, *Standardized Costs for Water Supply Distribution Systems* (1992), which  
5 provides cost curves for O&M components. Costs from the 1992 report are adjusted to  
6 2005 dollars based on the ENR construction cost index.

7 Pipeline maintenance costs include routine cleaning and flushing, as well as minor  
8 repairs to lines. The unit rate for pipeline maintenance is calculated based on the USEPA  
9 technical report, *Innovative and Alternate Technology Assessment Manual MCD 53*  
10 (1978). Costs from the 1978 report are adjusted to 2005 dollars based on the ENR  
11 construction cost index.

12 Storage tank maintenance costs include cleaning and renewal of interior lining and  
13 exterior coating. Unit costs for storage tank O&M are based on USEPA publication  
14 *Standardized Costs for Water Supply Distribution Systems* (1992). Costs from the 1992  
15 report are adjusted to 2005 dollars based on the ENR construction cost index.

16 The purchase price for point-of-use (POU) water treatment units is based on vendor  
17 price lists for treatment units, plus installation. O&M costs for POU treatment units are  
18 also based on vendor price lists. It is assumed that a yearly water sample would be  
19 analyzed for the contaminant of concern.

20 The purchase price for point-of-entry (POE) water treatment units is based on vendor  
21 price lists for treatment units, plus an allowance for installation, including a concrete pad  
22 and shed, piping modifications, and electrical connection. O&M costs for POE treatment  
23 units are also based on vendor price lists. It is assumed that a yearly water sample would  
24 be analyzed for the contaminant of concern.

25 Central treatment plant costs, for both adsorption and coagulation/filtration, include  
26 pricing for buildings, utilities, and site work. Costs are based on pricing given in the  
27 various R.S. Means Construction Cost Data References, as well as prices obtained from  
28 similar work on other projects. Pricing for treatment equipment is from a USEPA arsenic  
29 removal demonstration project (USEPA 2004).

30 Well installation costs are based on quotations from drillers for installation of similar  
31 depth wells in the area. Well installation costs include drilling, a well pump, electrical  
32 and instrumentation installation, well finishing, piping, and water quality testing. O&M  
33 costs for water wells include power, materials, and labor. It is assumed that new wells  
34 located more than 1 mile from the intake point of an existing system would require a  
35 storage tank and pump station.

36 Purchase price for the treatment unit dispenser is based on vendor price lists, plus an  
37 allowance for installation at a centralized public location. The O&M costs are also based  
38 on vendor price lists. It is assumed that weekly water samples would be analyzed for the  
39 contaminant of concern.

1           Costs for bottled water delivery alternatives are based on consultation with vendors  
2 that deliver residential bottled water. The cost estimate includes an initial allowance for  
3 set-up of the program, and a yearly allowance for program administration.

4           The cost estimate for a public dispenser for trucked water includes the purchase price  
5 for a water truck and construction of a storage tank. Annual costs include labor for  
6 purchasing the water, picking up and delivering the water, truck maintenance, and water  
7 sampling and testing. It is assumed the water truck would be required to make one trip  
8 each week, and that chlorine residual would be determined for each truck load.



**Table B.1**  
**Summary of General Data**  
**Orbit Systems, Inc. - Sandy Meadow**  
**PWS #0200335**  
**General PWS Information**

**Service Population** 170  
**Total PWS Daily Water Usage** 0.016 (mgd)

**Number of Connections** 56  
**Source** 2005 Report

**Unit Cost Data**  
**East Texas**

<b>General Items</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Central Treatment Unit Costs</b>	<b>Unit</b>	<b>Unit Cost</b>
Treated water purchase cost	<i>See alternative</i>		Site preparation	acre	\$ 4,000
Water purchase cost (trucked)	\$/1,000 gals	\$ 1.80	Slab	CY	\$ 1,000
			Building	SF	\$ 60
Contingency	20%	n/a	Building electrical	SF	\$ 8
Engineering & Constr. Management	25%	n/a	Building plumbing	SF	\$ 8
Procurement/admin (POU/POE)	20%	n/a	Heating and ventilation	SF	\$ 7
			Fence	LF	\$ 15
<b>Pipeline Unit Costs</b>	<b>Unit</b>	<b>Unit Cost</b>	Paving	SF	\$ 2
PVC water line, Class 200, 04"	LF	\$ 27	Electrical, Adsorption	JOB	\$ 50,000
Bore and encasement, 10"	LF	\$ 60	Electrical, Coagulation	JOB	\$ 30,000
Open cut and encasement, 10"	LF	\$ 35	Piping, Adsorption	JOB	\$ 20,000
Gate valve and box, 04"	EA	\$ 370	Piping, Coagulation	JOB	\$ 10,000
Air valve	EA	\$ 1,000	Adsorption package	UNIT	\$ 115,000
Flush valve	EA	\$ 750	Coagulation package	UNIT	\$ 89,700
Metal detectable tape	LF	\$ 0.15	Sewer connection fee	EA	\$ 15,000
			Chlorination point	EA	\$ 2,000
Bore and encasement, length	Feet	200	Backwash recycle pumpset	EA	\$ 5,000
Open cut and encasement, length	Feet	50	Coagulant tank	GAL	\$ 3.00
			Backwash tank	GAL	\$ 2.00
<b>Pump Station Unit Costs</b>	<b>Unit</b>	<b>Unit Cost</b>	Tank, 20,000 GAL	GAL	\$ 1.00
Pump	EA	\$ 7,500	Tank, 10,000 GAL	GAL	\$ 1.50
Pump Station Piping, 04"	EA	\$ 4,000	Excavation	CYD	\$ 3.00
Gate valve, 04"	EA	\$ 405	Compacted fill	CYD	\$ 7.00
Check valve, 04"	EA	\$ 595	Lining	SF	\$ 0.50
Electrical/Instrumentation	EA	\$ 10,000	Vegetation	SY	\$ 1.00
Site work	EA	\$ 2,000	Access road	LF	\$ 30
Building pad	EA	\$ 4,000			
Pump Building	EA	\$ 10,000	Building Power	kwh/yr	\$ 0.136
Fence	EA	\$ 5,870	Equipment power	kwh/yr	\$ 0.136
Tools	EA	\$ 1,000	Labor	hr	\$ 40
			Adsorption Materials	year	\$ 14,000
<b>Well Installation Unit Costs</b>	<b>Unit</b>	<b>Unit Cost</b>	Coagulation/Filtration Materials	year	\$ 2,000
Well installation	<i>See alternative</i>		Backwash discharge to sewer	MG/year	\$ 2,000
Water quality testing	EA	\$ 1,500	Chemicals, Coagulation	year	\$ 2,000
Well pump	EA	\$ 7,500	Analyses	test	\$ 200
Well electrical/instrumentation	EA	\$ 5,000	Spent media disposal	CY	\$ 20
Well cover and base	EA	\$ 3,000	Truck rental	day	\$ 700
Piping	EA	\$ 2,500	Mileage	mile	\$ 1.00
Storage Tank - 5,000 gals	EA	\$ 7,025	Disposal fee	kgal	\$ 5.00
Electrical Power	\$/kWH	\$ 0.136			
Building Power	kWH	11,800			
Labor	\$/hr	\$ 30			
Materials	EA	\$ 1,200			
Transmission main O&M	\$/mile	\$ 200			
Tank O&M	EA	\$ 1,000			
<b>POU/POE Unit Costs</b>					
POU treatment unit purchase	EA	\$ 250			
POU treatment unit installation	EA	\$ 150			
POE treatment unit purchase	EA	\$ 3,000			
POE - pad and shed, per unit	EA	\$ 2,000			
POE - piping connection, per unit	EA	\$ 1,000			
POE - electrical hook-up, per unit	EA	\$ 1,000			
POU treatment O&M, per unit	\$/year	\$ 225			
POE treatment O&M, per unit	\$/year	\$ 1,000			
Contaminant analysis	\$/year	\$ 100			
POU/POE labor support	\$/hr	\$ 30			
<b>Dispenser/Bottled Water Unit Costs</b>					
Treatment unit purchase	EA	\$ 3,000			
Treatment unit installation	EA	\$ 5,000			
Treatment unit O&M	EA	\$ 500			
Administrative labor	hr	\$ 40			
Bottled water cost (inc. delivery)	gallon	\$ 1.60			
Water use, per capita per day	gpcd	1.0			
Bottled water program materials	EA	\$ 5,000			
Storage Tank - 5,000 gals	EA	\$ 7,025			
Site improvements	EA	\$ 4,000			
Potable water truck	EA	\$ 60,000			
Water analysis, per sample	EA	\$ 100			
Potable water truck O&M costs	\$/mile	\$ 1.00			

1  
2

**APPENDIX C**  
**COMPLIANCE ALTERNATIVE CONCEPTUAL COST ESTIMATES**

3        This appendix presents the conceptual cost estimates developed for the compliance  
4 alternatives. The conceptual cost estimates are given in Tables C.1 through C.18. The  
5 cost estimates are conceptual in nature (+50%/-30%), and are intended for making  
6 comparisons between compliance options and to provide a preliminary indication of  
7 possible water rate impacts. Consequently, these costs are pre-planning level and should  
8 not be viewed as final estimated costs for alternative implementation.

## Table C.1

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *Purchase Water from City of Alvin*  
**Alternative Number** *SM-1*

**Distance from Alternative to PWS (along pipe)** 11.5 miles  
**Total PWS annual water usage** 5,840 MG  
**Treated water purchase cost** \$ 1.65 per 1,000 gals  
**Number of Pump Stations Needed** 2

### Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	35	n/a	n/a	n/a
Number of Crossings, open cut	4	n/a	n/a	n/a
PVC water line, Class 200, 04"	60,458	LF	\$ 27.00	\$ 1,632,366
Bore and encasement, 10"	7,000	LF	\$ 60.00	\$ 420,000
Open cut and encasement, 10"	200	LF	\$ 35.00	\$ 7,000
Gate valve and box, 04"	12	EA	\$ 370.00	\$ 4,474
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	12	EA	\$ 750.00	\$ 9,069
Metal detectable tape	60,458	LF	\$ 0.15	\$ 9,069
<b>Subtotal</b>				<b>\$ 2,092,977</b>

### *Pump Station(s) Installation*

Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	8	EA	\$ 405	\$ 3,240
Check valve, 04"	4	EA	\$ 595	\$ 2,380
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 5,000 gals	2	EA	\$ 7,025	\$ 14,050
<b>Subtotal</b>				<b>\$ 108,410</b>

**Subtotal of Component Costs** **\$ 2,201,387**

Contingency 20% \$ 440,277  
 Design & Constr Management 25% \$ 550,347

**TOTAL CAPITAL COSTS** **\$ 3,192,012**

### Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	11.5	mile	\$ 200	\$ 2,290
<b>Subtotal</b>				<b>\$ 2,290</b>
<i>Water Purchase Cost</i>				
From BWA	5,840	1,000 gal	\$ 1.65	\$ 9,636
<b>Subtotal</b>				<b>\$ 9,636</b>

### *Pump Station(s) O&M*

Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	54,700	kWH	\$ 0.136	\$ 7,439
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 30	\$ 21,900
Tank O&M	2	EA	\$ 1,000	\$ 2,000
<b>Subtotal</b>				<b>\$ 36,949</b>

### *O&M Credit for Existing Well Closure*

Pump power	635	kWH	\$ 0.136	\$ (86)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 30	\$ (10,800)
<b>Subtotal</b>				<b>\$ (13,286)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 35,589**

## Table C.2

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *Purchase Water from Brazos Water Authority*  
**Alternative Number** *SM-2*

**Distance from Alternative to PWS (along pipe)** 14.2 miles  
**Total PWS annual water usage** 5,840 MG  
**Treated water purchase cost** \$ 1.60 per 1,000 gals  
**Number of Pump Stations Needed** 2

### Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	24	n/a	n/a	n/a
Number of Crossings, open cut	9	n/a	n/a	n/a
PVC water line, Class 200, 04"	75,087	LF	\$ 27.00	\$ 2,027,349
Bore and encasement, 10"	4,800	LF	\$ 60.00	\$ 288,000
Open cut and encasement, 10"	450	LF	\$ 35.00	\$ 15,750
Gate valve and box, 04"	15	EA	\$ 370.00	\$ 5,556
Air valve	14	EA	\$ 1,000.00	\$ 14,000
Flush valve	15	EA	\$ 750.00	\$ 11,263
Metal detectable tape	75,087	LF	\$ 0.15	\$ 11,263
<b>Subtotal</b>				<b>\$ 2,373,182</b>

### *Pump Station(s) Installation*

Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	8	EA	\$ 405	\$ 3,240
Check valve, 04"	4	EA	\$ 595	\$ 2,380
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 5,000 gals	2	EA	\$ 7,025	\$ 14,050
<b>Subtotal</b>				<b>\$ 108,410</b>

**Subtotal of Component Costs** **\$ 2,481,592**

Contingency 20% \$ 496,318  
 Design & Constr Management 25% \$ 620,398

**TOTAL CAPITAL COSTS** **\$ 3,598,308**

### Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	14.2	mile	\$ 200	\$ 2,844
<b>Subtotal</b>				<b>\$ 2,844</b>
<i>Water Purchase Cost</i>				
From BWA	5,840	1,000 gal	\$ 1.60	\$ 9,344
<b>Subtotal</b>				<b>\$ 9,344</b>

### *Pump Station(s) O&M*

Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	65,650	kWH	\$ 0.136	\$ 8,928
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 30	\$ 21,900
Tank O&M	2	EA	\$ 1,000	\$ 2,000
<b>Subtotal</b>				<b>\$ 38,438</b>

### *O&M Credit for Existing Well Closure*

Pump power	635	kWH	\$ 0.136	\$ (86)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 30	\$ (10,800)
<b>Subtotal</b>				<b>\$ (13,286)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 37,340**

**Table C.3**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *New Well at Briar Meadows*  
**Alternative Number** *SM-3*

**Distance from PWS to new well location** 3.17 miles  
**Estimated well depth** 215 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	10	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	16,721	LF	\$ 27.00	\$ 451,467
Bore and encasement, 10"	2,000	LF	\$ 60.00	\$ 120,000
Open cut and encasement, 10"	50	LF	\$ 35.00	\$ 1,750
Gate valve and box, 04"	3	EA	\$ 370.00	\$ 1,237
Air valve	3	EA	\$ 1,000.00	\$ 3,000
Flush valve	3	EA	\$ 750.00	\$ 2,508
Metal detectable tape	16,721	LF	\$ 0.15	\$ 2,508
<b>Subtotal</b>				<b>\$ 582,471</b>

*Pump Station(s) Installation*

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>

*Well Installation*

Well installation	215	LF	\$ 25	\$ 5,375
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 26,375</b>

**Subtotal of Component Costs** **\$ 663,051**

Contingency 20% \$ 132,610  
 Design & Constr Management 25% \$ 165,763

**TOTAL CAPITAL COSTS** **\$ 961,423**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	3.2	mile	\$ 200	\$ 633
<b>Subtotal</b>				<b>\$ 633</b>

*Pump Station(s) O&M*

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	17,400	kWH	\$ 0.136	\$ 2,366
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 30	\$ 10,950
Tank O&M	1	EA	\$ 1,000	\$ 1,000
<b>Subtotal</b>				<b>\$ 17,121</b>

*Well O&M*

Pump power	440	kWH	\$ 0.136	\$ 60
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 30	\$ 5,400
<b>Subtotal</b>				<b>\$ 6,660</b>

*O&M Credit for Existing Well Closure*

Pump power	635	kWH	\$ 0.136	\$ (86)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 30	\$ (10,800)
<b>Subtotal</b>				<b>\$ (13,286)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 11,128**

## Table C.4

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *Purchase Water from JMP Utilities*  
**Alternative Number** *SM-4*

**Distance from Alternative to PWS (along pipe)** 7.1 miles  
**Total PWS annual water usage** 5.840 MG  
**Treated water purchase cost** \$ 1.65 per 1,000 gals  
**Number of Pump Stations Needed** 1

### Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	14	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	37,600	LF	\$ 27.00	\$ 1,015,200
Bore and encasement, 10"	2,800	LF	\$ 60.00	\$ 168,000
Open cut and encasement, 10"	150	LF	\$ 35.00	\$ 5,250
Gate valve and box, 04"	8	EA	\$ 370.00	\$ 2,782
Air valve	7	EA	\$ 1,000.00	\$ 7,000
Flush valve	8	EA	\$ 750.00	\$ 5,640
Metal detectable tape	37,600	LF	\$ 0.15	\$ 5,640
<b>Subtotal</b>				<b>\$ 1,209,512</b>

### *Pump Station(s) Installation*

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>

**Subtotal of Component Costs** **\$ 1,263,717**

Contingency 20% \$ 252,743  
 Design & Constr Management 25% \$ 315,929

**TOTAL CAPITAL COSTS** **\$ 1,832,390**

### Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	7.1	mile	\$ 200	\$ 1,424
<b>Subtotal</b>				<b>\$ 1,424</b>
<i>Water Purchase Cost</i>				
From BWA	5,840	1,000 g	\$ 1.65	\$ 9,636
<b>Subtotal</b>				<b>\$ 9,636</b>

### *Pump Station(s) O&M*

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	35,100	kWH	\$ 0.136	\$ 4,774
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 30	\$ 10,950
Tank O&M	1	EA	\$ 1,000	\$ 1,000
<b>Subtotal</b>				<b>\$ 19,528</b>

### *O&M Credit for Existing Well Closure*

Pump power	635	kWH	\$ 0.136	\$ (86)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 30	\$ (10,800)
<b>Subtotal</b>				<b>\$ (13,286)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 17,302**

**Table C.5**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *New Well at Mammoet LLC*  
**Alternative Number** *SM-5*

**Distance from PWS to new well location** 6.61 miles  
**Estimated well depth** 270 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	9	n/a	n/a	n/a
Number of Crossings, open cut	5	n/a	n/a	n/a
PVC water line, Class 200, 04"	34,875	LF	\$ 27.00	\$ 941,625
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	250	LF	\$ 35.00	\$ 8,750
Gate valve and box, 04"	7	EA	\$ 370.00	\$ 2,581
Air valve	7	EA	\$ 1,000.00	\$ 7,000
Flush valve	7	EA	\$ 750.00	\$ 5,231
Metal detectable tape	34,875	LF	\$ 0.15	\$ 5,231
<b>Subtotal</b>				<b>\$ 1,078,418</b>

*Pump Station(s) Installation*

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>

*Well Installation*

Well installation	270	LF	\$ 25	\$ 6,750
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 27,750</b>

**Subtotal of Component Costs \$ 1,160,373**

Contingency 20% \$ 232,075  
 Design & Constr Management 25% \$ 290,093

**TOTAL CAPITAL COSTS \$ 1,682,541**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	6.6	mile	\$ 200	\$ 1,321
<b>Subtotal</b>				<b>\$ 1,321</b>

*Pump Station(s) O&M*

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	33,700	kWH	\$ 0.136	\$ 4,583
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 30	\$ 10,950
Tank O&M	1	EA	\$ 1,000	\$ 1,000
<b>Subtotal</b>				<b>\$ 19,338</b>

*Well O&M*

Pump power	553	kWH	\$ 0.136	\$ 75
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 30	\$ 5,400
<b>Subtotal</b>				<b>\$ 6,675</b>

*O&M Credit for Existing Well Closure*

Pump power	635	kWH	\$ 0.136	\$ (86)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 30	\$ (10,800)
<b>Subtotal</b>				<b>\$ (13,286)</b>

**TOTAL ANNUAL O&M COSTS \$ 14,048**

**Table C.6**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *New Well at Oak Bend*  
**Alternative Number** *SM-6*

**Distance from PWS to new well location** 8.27 miles  
**Estimated well depth** 150 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	16	n/a	n/a	n/a
Number of Crossings, open cut	4	n/a	n/a	n/a
PVC water line, Class 200, 04"	43,659	LF	\$ 27.00	\$ 1,178,793
Bore and encasement, 10"	3,200	LF	\$ 60.00	\$ 192,000
Open cut and encasement, 10"	200	LF	\$ 35.00	\$ 7,000
Gate valve and box, 04"	9	EA	\$ 370.00	\$ 3,231
Air valve	8	EA	\$ 1,000.00	\$ 8,000
Flush valve	9	EA	\$ 750.00	\$ 6,549
Metal detectable tape	43,659	LF	\$ 0.15	\$ 6,549
<b>Subtotal</b>				<b>\$ 1,402,121</b>

*Pump Station(s) Installation*

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>

*Well Installation*

Well installation	150	LF	\$ 25	\$ 3,750
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 24,750</b>

**Subtotal of Component Costs \$ 1,481,076**

Contingency 20% \$ 296,215  
 Design & Constr Management 25% \$ 370,269

**TOTAL CAPITAL COSTS \$ 2,147,561**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	8.3	mile	\$ 200	\$ 1,654
<b>Subtotal</b>				<b>\$ 1,654</b>

*Pump Station(s) O&M*

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	39,200	kWH	\$ 0.136	\$ 5,331
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 30	\$ 10,950
Tank O&M	1	EA	\$ 1,000	\$ 1,000
<b>Subtotal</b>				<b>\$ 20,086</b>

*Well O&M*

Pump power	307	kWH	\$ 0.136	\$ 42
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 30	\$ 5,400
<b>Subtotal</b>				<b>\$ 6,642</b>

*O&M Credit for Existing Well Closure*

Pump power	635	kWH	\$ 0.136	\$ (86)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 30	\$ (10,800)
<b>Subtotal</b>				<b>\$ (13,286)</b>

**TOTAL ANNUAL O&M COSTS \$ 15,095**



**Table C.7**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *New Well at TCDJ Darrington*  
**Alternative Number** *SM-7*

**Distance from PWS to new well location** 8.27 miles  
**Estimated well depth** 600 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	7	n/a	n/a	n/a
Number of Crossings, open cut	5	n/a	n/a	n/a
PVC water line, Class 200, 04"	43,663	LF	\$ 27.00	\$ 1,178,901
Bore and encasement, 10"	1,400	LF	\$ 60.00	\$ 84,000
Open cut and encasement, 10"	250	LF	\$ 35.00	\$ 8,750
Gate valve and box, 04"	9	EA	\$ 370.00	\$ 3,231
Air valve	8	EA	\$ 1,000.00	\$ 8,000
Flush valve	9	EA	\$ 750.00	\$ 6,549
Metal detectable tape	43,663	LF	\$ 0.15	\$ 6,549
<b>Subtotal</b>				<b>\$ 1,295,981</b>

*Pump Station(s) Installation*

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>

*Well Installation*

Well installation	600	LF	\$ 25	\$ 15,000
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 36,000</b>

**Subtotal of Component Costs** **\$ 1,386,186**

Contingency 20% \$ 277,237  
 Design & Constr Management 25% \$ 346,546

**TOTAL CAPITAL COSTS** **\$ 2,009,970**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	8.3	mile	\$ 200	\$ 1,654
<b>Subtotal</b>				<b>\$ 1,654</b>

*Pump Station(s) O&M*

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	42,300	kWH	\$ 0.136	\$ 5,753
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 30	\$ 10,950
Tank O&M	1	EA	\$ 1,000	\$ 1,000
<b>Subtotal</b>				<b>\$ 20,508</b>

*Well O&M*

Pump power	1,229	kWH	\$ 0.136	\$ 167
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 30	\$ 5,400
<b>Subtotal</b>				<b>\$ 6,767</b>

*O&M Credit for Existing Well Closure*

Pump power	635	kWH	\$ 0.136	\$ (86)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 30	\$ (10,800)
<b>Subtotal</b>				<b>\$ (13,286)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 15,642**

**Table C.8**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *New Well at TCDJ Ramsey*  
**Alternative Number** *SM-8*

**Distance from PWS to new well location** 13.75 miles  
**Estimated well depth** 270 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 2

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	19	n/a	n/a	n/a
Number of Crossings, open cut	11	n/a	n/a	n/a
PVC water line, Class 200, 04"	72,599	LF	\$ 27.00	\$ 1,960,173
Bore and encasement, 10"	3,800	LF	\$ 60.00	\$ 228,000
Open cut and encasement, 10"	550	LF	\$ 35.00	\$ 19,250
Gate valve and box, 04"	15	EA	\$ 370.00	\$ 5,372
Air valve	14	EA	\$ 1,000.00	\$ 14,000
Flush valve	15	EA	\$ 750.00	\$ 10,890
Metal detectable tape	72,599	LF	\$ 0.15	\$ 10,890
<b>Subtotal</b>				<b>\$ 2,248,575</b>

*Pump Station(s) Installation*

Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	8	EA	\$ 405	\$ 3,240
Check valve, 04"	4	EA	\$ 595	\$ 2,380
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 5,000 gals	2	EA	\$ 7,025	\$ 14,050
<b>Subtotal</b>				<b>\$ 108,410</b>

*Well Installation*

Well installation	270	LF	\$ 25	\$ 6,750
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 27,750</b>

**Subtotal of Component Costs \$ 2,384,735**

Contingency 20% \$ 476,947  
 Design & Constr Management 25% \$ 596,184

**TOTAL CAPITAL COSTS \$ 3,457,866**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	13.7	mile	\$ 200	\$ 2,750
<b>Subtotal</b>				<b>\$ 2,750</b>

*Pump Station(s) O&M*

Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	64,650	kWH	\$ 0.136	\$ 8,792
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 30	\$ 21,900
Tank O&M	2	EA	\$ 1,000	\$ 2,000
<b>Subtotal</b>				<b>\$ 38,302</b>

*Well O&M*

Pump power	553	kWH	\$ 0.136	\$ 75
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 30	\$ 5,400
<b>Subtotal</b>				<b>\$ 6,675</b>

*O&M Credit for Existing Well Closure*

Pump power	635	kWH	\$ 0.136	\$ (86)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 30	\$ (10,800)
<b>Subtotal</b>				<b>\$ (13,286)</b>

**TOTAL ANNUAL O&M COSTS \$ 34,441**

**Table C.9**

**PWS Name**  
**Alternative Name**  
**Alternative Number**

**Orbit Systems, Inc. - Sandy Meadow**  
**Central Treatment - Adsorption**  
**SM-9**

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<b>Adsorption</b>				
Site preparation	0.50	acre	\$ 4,000	\$ 2,000
Slab	15	CY	\$ 1,000	\$ 15,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8	\$ 3,200
Building plumbing	400	SF	\$ 8	\$ 3,200
Heating and ventilation	400	SF	\$ 7	\$ 2,800
Fence	300	LF	\$ 15	\$ 4,500
Paving	1,600	SF	\$ 2	\$ 3,200
Electrical	1	JOB	\$ 50,000	\$ 50,000
Piping	1	JOB	\$ 20,000	\$ 20,000
Adsorption package including:				
4 Adsorption vessels				
E33 Iron oxide media				
Controls & instruments	1	UNIT	\$ 115,000	\$ 115,000
Backwash Tank	5,000	GAL	\$ 2.00	\$ 10,000
Chlorination Point	1	EA	\$ 2,000	\$ 2,000
Backwash Recycle Pumpset	1	EA	\$ 5,000	\$ 5,000
	<b>Subtotal</b>			<b>\$ 259,900</b>
Contingency	20%			51,980
Design & CM	25%			64,975
	<b>Total</b>			<b>\$ 376,855</b>

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<b>O&amp;M</b>				
Building Power	6,000	kwh/yr	\$ 0.136	\$ 816
Equipment power	1000	kwh/yr	\$ 0.136	\$ 136
Labor	500	hrs/yr	\$ 40	\$ 20,000
Materials	1	year	\$ 14,000	\$ 14,000
Analyses	24	test	\$ 200	\$ 4,800
Spent Media Disposal	6	CY	\$ 20	\$ 120
	<b>Total</b>			<b>\$ 39,872</b>
<b>Backwash Disposal</b>				
Truck rental	21	days	\$ 700	\$ 14,700
Mileage	800	miles	\$ 1.00	\$ 800
Disposal fee	63	kgal/yr	\$ 5.00	\$ 315
	<b>Subtotal</b>			<b>\$ 15,815</b>
	<b>Total</b>			<b>\$ 55,687</b>

**Table C.10**

**PWS Name**  
**Alternative Name**  
**Alternative Number**

**Orbit Systems, Inc. - Sandy Meadow**  
**Central Treatment - Coag-Filt**  
**SM-10**

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<b>Central-Coagulation/Filtration</b>				
Site preparation	0.50	acre	\$ 4,000	\$ 2,000
Slab	15	CY	\$ 1,000	\$ 15,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8.00	\$ 3,200
Building plumbing	400	SF	\$ 8.00	\$ 3,200
Heating and ventilation	400	SF	\$ 7.00	\$ 2,800
Fence	300	LF	\$ 15	\$ 4,500
Paving	1,600	SF	\$ 2.00	\$ 3,200
Electrical	1	JOB	\$ 30,000	\$ 30,000
Piping	1	JOB	\$ 10,000	\$ 10,000
Coagulant/Filter package including:				
Chemical feed system				
Pressure ceramic filters				
Controls & Instruments	1	UNIT	\$ 89,700	\$ 89,700
Backwash Tank	5,000	GAL	\$ 2.00	\$ 10,000
Chlorination Point	1	EA	\$ 2,000	\$ 2,000
Coagulant Tank	500	GAL	\$ 3.00	\$ 1,500
<b>Subtotal</b>				<b>\$ 201,100</b>
Contingency	20%			40,220
Design & CM	25%			50,275
<b>Total</b>				<b>\$ 291,595</b>

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<b>O&amp;M</b>				
Building Power	6,000	kwh/yr	\$ 0.136	\$ 816
Equipment power	1000	kwh/yr	\$ 0.136	\$ 136
Labor	1,000	hrs/yr	\$ 40	\$ 40,000
Materials	1	year	\$ 2,000	\$ 2,000
Chemicals	1	year	\$ 2,000	\$ 2,000
Analyses	24	test	\$ 200	\$ 4,800
<b>Total</b>				<b>\$ 49,752</b>
<b>Backwash Disposal</b>				
Truck rental	100	days	\$ 700	\$ 70,000
Mileage	4000	miles	\$ 1.00	\$ 4,000
Disposal fee	315	kgal/yr	\$ 5.00	\$ 1,575
<b>Subtotal</b>				<b>\$ 75,575</b>
<b>Total</b>				<b>\$ 125,327</b>

**Table C.11**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *Point-of-Use Treatment*  
**Alternative Number** *SM-11*

**Number of Connections for POU Unit Installation** 56

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>POU-Treatment - Purchase/Installation</i>				
POU treatment unit purchase	56	EA	\$ 250	\$ 14,000
POU treatment unit installation	56	EA	\$ 150	\$ 8,400
<b>Subtotal</b>				<b>\$ 22,400</b>
<b>Subtotal of Component Costs</b>				<b>\$ 22,400</b>
Contingency	20%		\$	4,480
Design & Constr Management	25%		\$	5,600
Procurement & Administration	20%		\$	4,480
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 36,960</b>

**Annual Operations and Maintenance Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>O&amp;M</i>				
POU materials, per unit	56	EA	\$ 225	\$ 12,600
Contaminant analysis, 1/yr per unit	56	EA	\$ 100	\$ 5,600
Program labor, 10 hrs/unit	560	hrs	\$ 30	\$ 16,800
<b>Subtotal</b>				<b>\$ 35,000</b>
<b>TOTAL ANNUAL O&amp;M COSTS</b>				<b>\$ 35,000</b>

**Table C.12**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *Point-of-Entry Treatment*  
**Alternative Number** *SM-12*

**Number of Connections for POE Unit Installation** 56

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>POE-Treatment - Purchase/Installation</i>				
POE treatment unit purchase	56	EA	\$ 3,000	\$ 168,000
Pad and shed, per unit	56	EA	\$ 2,000	\$ 112,000
Piping connection, per unit	56	EA	\$ 1,000	\$ 56,000
Electrical hook-up, per unit	56	EA	\$ 1,000	\$ 56,000
<b>Subtotal</b>				<b>\$ 392,000</b>

**Subtotal of Component Costs** **\$ 392,000**

Contingency	20%	\$ 78,400
Design & Constr Management	25%	\$ 98,000
Procurement & Administration	20%	\$ 78,400

**TOTAL CAPITAL COSTS** **\$ 646,800**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>O&amp;M</i>				
POE materials, per unit	56	EA	\$ 1,000	\$ 56,000
Contaminant analysis, 1/yr per unit	56	EA	\$ 100	\$ 5,600
Program labor, 10 hrs/unit	560	hrs	\$ 30	\$ 16,800
<b>Subtotal</b>				<b>\$ 78,400</b>

**TOTAL ANNUAL O&M COSTS** **\$ 78,400**

**Table C.13**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *New Well at 10 Miles*  
**Alternative Number** *SM-13*

**Distance from PWS to new well location** 10.0 miles  
**Estimated well depth** 310 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	18	n/a	n/a	n/a
Number of Crossings, open cut	6	n/a	n/a	n/a
PVC water line, Class 200, 04"	52,800	LF	\$ 27.00	\$ 1,425,600
Bore and encasement, 10"	3,600	LF	\$ 60.00	\$ 216,000
Open cut and encasement, 10"	300	LF	\$ 35.00	\$ 10,500
Gate valve and box, 04"	11	EA	\$ 370.00	\$ 3,907
Air valve	10	EA	\$ 1,000.00	\$ 10,000
Flush valve	11	EA	\$ 750.00	\$ 7,920
Metal detectable tape	52,800	LF	\$ 0.15	\$ 7,920
<b>Subtotal</b>				<b>\$ 1,681,847</b>

*Pump Station(s) Installation*

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>

*Well Installation*

Well installation	310	LF	\$ 25	\$ 7,750
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 28,750</b>

**Subtotal of Component Costs** **\$ 1,764,802**

Contingency 20% \$ 352,960  
 Design & Constr Management 25% \$ 441,201

**TOTAL CAPITAL COSTS** **\$ 2,558,963**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	10.0	mile	\$ 200	\$ 2,000
<b>Subtotal</b>				<b>\$ 2,000</b>

*Pump Station(s) O&M*

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	48,413	kWH	\$ 0.136	\$ 6,584
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 30	\$ 10,950
Tank O&M	1	EA	\$ 1,000	\$ 1,000
<b>Subtotal</b>				<b>\$ 21,339</b>

*Well O&M*

Pump power	635	kWH	\$ 0.136	\$ 86
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 30	\$ 5,400
<b>Subtotal</b>				<b>\$ 6,686</b>

*O&M Credit for Existing Well Closure*

Pump power	635	kWH	\$ 0.136	\$ (86)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 30	\$ (10,800)
<b>Subtotal</b>				<b>\$ (13,286)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 16,739**

**Table C.14**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *New Well at 5 Miles*  
**Alternative Number** *SM-14*

**Distance from PWS to new well location** 5.0 miles  
**Estimated well depth** 310 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	9	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	26,400	LF	\$ 27.00	\$ 712,800
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	100	LF	\$ 35.00	\$ 3,500
Gate valve and box, 04"	5	EA	\$ 370.00	\$ 1,954
Air valve	5	EA	\$ 1,000.00	\$ 5,000
Flush valve	5	EA	\$ 750.00	\$ 3,960
Metal detectable tape	26,400	LF	\$ 0.15	\$ 3,960
<b>Subtotal</b>				<b>\$ 839,174</b>

*Pump Station(s) Installation*

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>

*Well Installation*

Well installation	310	LF	\$ 25	\$ 7,750
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 28,750</b>

**Subtotal of Component Costs** **\$ 922,129**

Contingency 20% \$ 184,426  
 Design & Constr Management 25% \$ 230,532

**TOTAL CAPITAL COSTS** **\$ 1,337,086**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	5.0	mile	\$ 200	\$ 1,000
<b>Subtotal</b>				<b>\$ 1,000</b>

*Pump Station(s) O&M*

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	24,206	kWH	\$ 0.136	\$ 3,292
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 30	\$ 10,950
Tank O&M	1	EA	\$ 1,000	\$ 1,000
<b>Subtotal</b>				<b>\$ 18,047</b>

*Well O&M*

Pump power	635	kWH	\$ 0.136	\$ 86
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 30	\$ 5,400
<b>Subtotal</b>				<b>\$ 6,686</b>

*O&M Credit for Existing Well Closure*

Pump power	635	kWH	\$ 0.136	\$ (86)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 30	\$ (10,800)
<b>Subtotal</b>				<b>\$ (13,286)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 12,447**



**Table C.15**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *New Well at 1 Mile*  
**Alternative Number** *SM-15*

**Distance from PWS to new well location** 1.0 miles  
**Estimated well depth** 310 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 0

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	5,280	LF	\$ 27.00	\$ 142,560
Bore and encasement, 10"	400	LF	\$ 60.00	\$ 24,000
Open cut and encasement, 10"	50	LF	\$ 35.00	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370.00	\$ 391
Air valve	1.00	EA	\$ 1,000.00	\$ 1,000
Flush valve	1	EA	\$ 750.00	\$ 792
Metal detectable tape	5,280	LF	\$ 0.15	\$ 792
<b>Subtotal</b>				<b>\$ 171,285</b>

*Pump Station(s) Installation*

Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
<b>Subtotal</b>				<b>\$ -</b>

*Well Installation*

Well installation	310	LF	\$ 25	\$ 7,750
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 28,750</b>

**Subtotal of Component Costs \$ 200,035**

Contingency 20% \$ 40,007  
 Design & Constr Management 25% \$ 50,009

**TOTAL CAPITAL COSTS \$ 290,050**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	1.0	mile	\$ 200	\$ 200
<b>Subtotal</b>				<b>\$ 200</b>

*Pump Station(s) O&M*

Building Power	-	kWH	\$ 0.136	\$ -
Pump Power	-	kWH	\$ 0.136	\$ -
Materials	-	EA	\$ 1,200	\$ -
Labor	-	Hrs	\$ 30	\$ -
Tank O&M	-	EA	\$ 1,000	\$ -
<b>Subtotal</b>				<b>\$ -</b>

*Well O&M*

Pump power	635	kWH	\$ 0.136	\$ 86
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 30	\$ 5,400
<b>Subtotal</b>				<b>\$ 6,686</b>

*O&M Credit for Existing Well Closure*

Pump power	635	kWH	\$ 0.136	\$ (86)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 30	\$ (10,800)
<b>Subtotal</b>				<b>\$ (13,286)</b>

**TOTAL ANNUAL O&M COSTS \$ (6,400)**

**Table C.16**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *Public Dispenser for Treated Drinking Water*  
**Alternative Number** *SM-16*

**Number of Treatment Units Recommended** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Public Dispenser Unit Installation</i>				
POE-Treatment unit(s)	1	EA	\$ 3,000	\$ 3,000
Unit installation costs	1	EA	\$ 5,000	\$ 5,000
<b>Subtotal</b>				<b>\$ 8,000</b>
<b>Subtotal of Component Costs</b>				<b>\$ 8,000</b>
Contingency	20%			\$ 1,600
Design & Constr Management	25%			\$ 2,000
<b>TOTAL CAPITAL COSTS</b>				<b>11,600</b>

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Treatment unit O&M, 1 per unit	1	EA	\$ 500	\$ 500
Contaminant analysis, 1/wk per unit	52	EA	\$ 100	\$ 5,200
Sampling/reporting, 1 hr/day	365	HRS	\$ 30	\$ 10,950
<b>Subtotal</b>				<b>\$ 16,650</b>
<b>TOTAL ANNUAL O&amp;M COSTS</b>				<b>\$ 16,650</b>

**Table C.17**

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *Supply Bottled Water to Population*  
**Alternative Number** *SM-17*

**Service Population** 170  
**Percentage of population requiring supply** 100%  
**Water consumption per person** 1.00 gpcd  
**Calculated annual potable water needs** 62,050 gallons

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Implementation</i>				
Initial program set-up	500	hours	\$ 40	\$ 19,950
<b>Subtotal</b>				<b>\$ 19,950</b>
<b>Subtotal of Component Costs</b>				<b>\$ 19,950</b>
Contingency	20%			\$ 3,990

**TOTAL CAPITAL COSTS** **\$ 23,940**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water purchase costs	62,050	gals	\$ 1.60	\$ 99,280
Program admin, 9 hrs/wk	468	hours	\$ 40	\$ 18,673
Program materials	1	EA	\$ 5,000	\$ 5,000
<b>Subtotal</b>				<b>\$ 122,953</b>

**TOTAL ANNUAL O&M COSTS** **\$ 122,953**

### Table C.18

**PWS Name** *Orbit Systems, Inc. - Sandy Meadow*  
**Alternative Name** *Central Trucked Drinking Water*  
**Alternative Number** *SM-18*

**Service Population** 170  
**Percentage of population requiring supply** 100%  
**Water consumption per person** 1.00 gpcd  
**Calculated annual potable water needs** 62,050 gallons  
**Travel distance to compliant water source (roundtrip)** 23 miles

#### Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Storage Tank Installation</i>				
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Site improvements	1	EA	\$ 4,000	\$ 4,000
Potable water truck	1	EA	\$ 60,000	\$ 60,000
<b>Subtotal</b>				<b>\$ 71,025</b>
<b>Subtotal of Component Costs</b>				<b>\$ 71,025</b>
Contingency	20%		\$	14,205
Design & Constr Management	25%		\$	17,756
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 102,986</b>

#### Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water delivery labor, 4 hrs/wk	208	hrs	\$ 30	\$ 6,240
Truck operation, 1 round trip/wk	1196	miles	\$ 1.00	\$ 1,196
Water purchase	62	1,000 gals	\$ 1.80	\$ 112
Water testing, 1 test/wk	52	EA	\$ 100	\$ 5,200
Sampling/reporting, 2 hrs/wk	104	hrs	\$ 30	\$ 3,120
<b>Subtotal</b>				<b>\$ 15,868</b>
<b>TOTAL ANNUAL O&amp;M COSTS</b>				<b>\$ 15,868</b>

1  
2

**APPENDIX D  
EXAMPLE FINANCIAL MODEL**

Table D.1 Example Financial Model

Step 1		Sandy Meadows	
Water System:			
Step 2		<a href="#">Click Here to Update Verification and Raw Tables</a>	
Water System		Sandy Meadows	
Alternative Description		Dispenser	
Sum of Amount		Year	Funding Alternative
		2007	
Group	Type	100% Grant	Bond
Capital Expenditures	Capital Expenditures-Funded from Bonds	\$ 500	\$ 12,100
	Capital Expenditures-Funded from Grants	\$ 11,600	\$ -
	Capital Expenditures-Funded from Revenue/Reserves	\$ -	\$ -
	Capital Expenditures-Funded from SRF Loans	\$ -	\$ -
Capital Expenditures Sum		\$ 12,100	\$ 12,100
Debt Service	Revenue Bonds	\$ 39	\$ 947
	State Revolving Funds	\$ -	\$ -
Debt Service Sum		\$ 39	\$ 947
Operating Expenditures	Administrative Expenses	\$ 2,052	\$ 2,052
	Chemicals, Treatment	\$ 608	\$ 608
	Contract Labor	\$ 715	\$ 715
	Insurance	\$ 417	\$ 417
	Other Operating Expenditures 1	\$ 479	\$ 479
	Other Operating Expenditures 2	\$ 5,835	\$ 5,835
	Professional and Directors Fees	\$ 90	\$ 90
	Repairs	\$ 487	\$ 487
	Salaries & Benefits	\$ 5,880	\$ 5,880
	Supplies	\$ 487	\$ 487
	Utilities	\$ 2,462	\$ 2,462
	Maintenance	\$ 487	\$ 487
	Accounting and Legal Fees	\$ 35	\$ 35
	Auto and Travel	\$ 8	\$ 8
Operating Expenditures Sum		\$ 20,041	\$ 20,041
Residential Operating Revenue	Residential Base Monthly Rate	\$ 16,793	\$ 16,793
	Residential Tier 1 Monthly Rate	\$ 6,162	\$ 6,162
	Residential Tier2 Monthly Rate	\$ -	\$ -
	Residential Tier3 Monthly Rate	\$ -	\$ -
	Residential Tier4 Monthly Rate	\$ -	\$ -
	Residential Unmetered Monthly Rate	\$ -	\$ -
Residential Operating Revenues Sum		\$ 22,956	\$ 22,956


Location Name		Sandy Meadows		
Alt_Desc		Dispenser		
		Current_Year		
Funding_Alt	Data	2007		
100% Grant	Sum of Beginning_Cash_Bal	\$	1,718	
	Sum of Total_Expenditures	\$	32,180	
	Sum of Total_Receipts	\$	34,556	
	Sum of Net_Cash_Flow	\$	2,376	
	Sum of Ending_Cash_Bal	\$	4,093	
	Sum of Working_Cap	\$	-	
	Sum of Repl_Resv	\$	1,444	
	Sum of Total_Reqd_Resv	\$	1,444	
	Sum of Net_Avail_Bal	\$	2,649	
	Sum of Add_Resv_Needed	\$	-	
	Sum of Rate_Inc_Needed	\$	0%	
	Sum of Percent_Rate_Increase	\$	0%	
	Bond	Sum of Beginning_Cash_Bal	\$	1,718
		Sum of Total_Expenditures	\$	33,088
Sum of Total_Receipts		\$	34,556	
Sum of Net_Cash_Flow		\$	1,468	
Sum of Ending_Cash_Bal		\$	3,186	
Sum of Working_Cap		\$	-	
Sum of Repl_Resv		\$	1,444	
Sum of Total_Reqd_Resv		\$	1,444	
Sum of Net_Avail_Bal		\$	1,742	
Sum of Add_Resv_Needed		\$	-	
Sum of Rate_Inc_Needed		\$	0%	
Sum of Percent_Rate_Increase		\$	0%	

1 **APPENDIX E**  
2 **GENERAL ARSENIC GEOCHEMISTRY**

3 Geochemistry of arsenic is complex because of (1) the possible coexistence of two or  
4 even three redox states, (2) the complex chemistry of organo-arsenicals, and (3) the  
5 strong interaction of most arsenic compounds with soil particles, particularly iron oxides  
6 (and to a lesser degree, aluminum and manganese oxides). Fully deprotonated arsenate  
7  $\text{AsO}_4^{-3}$  is the expected form of arsenic in most soil under aerobic conditions only at high  
8 pH (Figure E.1). At more neutral and acid pH's,  $\text{HAsO}_4^{-2}$  and  $\text{H}_2\text{AsO}_4^{-1}$  forms,  
9 respectively, are dominant. General understanding of arsenic mobility in soil and  
10 aquifers is that it increases with increasing pH and phosphate concentration and with  
11 decreasing clay and iron oxide content. As pH increases, the negative charge of the  
12 arsenate ion increases, making it less likely to sorb on negatively charged soil particles.  
13 Phosphates have a chemical structure similar to that of arsenates and sorb to soil  
14 preferentially in some conditions. Nitrogen also belongs to the same group in the  
15 periodic table but does not show the same competing behavior as phosphate. Other  
16 structurally similar oxyanions, sulfate and selenate, are also weak sorbers. Under less  
17 oxidizing conditions, arsenite ion  $\text{H}_3\text{AsO}_3$  is most stable. Lack of charge renders the ion  
18 more mobile and less likely to sorb to soil particles. Its pH stability spread ranges from  
19 acid to alkaline. The first deprotonated form,  $\text{H}_2\text{AsO}_3^{-1}$ , exists at significant  
20 concentrations only above a pH of approximately 9. Redox processes seem to be  
21 mediated by microorganisms (Welch, *et al.*, 2000) and to take place next to mineral  
22 surfaces.

23 Under even more reducing conditions, arsenide is the stable ionic form of arsenic.  
24 Arsenic has a complex geochemistry with sulfur, both in solution where several  
25 thioarsenic ions can form and in associated minerals. Arsenic metal –As(0)- rarely  
26 occurs. Methylated arsenic compounds are generally present at low aqueous  
27 concentrations (<1ppb), if at all, except perhaps when there is an abundance of organic  
28 matter (Welch, *et al.*, 2000).

29 As(V) and As(III) minerals are fairly soluble and do not control arsenic solubility in  
30 oxidizing or mildly reducing conditions, except, perhaps, if barium is present (Henry, *et*  
31 *al.* 1982). This situation is in contrast to that of other companion oxyanions which are  
32 not as mobile under reducing conditions, except vanadium. In reducing conditions,  
33 arsenic precipitates as arsenopyrite ( $\text{FeAsS}$ ), although more commonly in solid solution  
34 with pyrite. Realgar ( $\text{AsS}$ ) and orpiment ( $\text{As}_2\text{S}_3$ ) require high sulfur activity and are  
35 unlikely in the southern Gulf Coast.



2

3

4

5

**Figure E.1**  
**Eh-pH Diagram for Arsenic Aqueous Species in the As-O<sub>2</sub>-H<sub>2</sub>O System**  
**at 25°C and 1 bar (Smedley and Kinniburgh 2002)**



1  
2

**APPENDIX F  
ORBIT SYSTEMS WATER USAGE**

**Orbit Systems, Inc.**  
**2004 Water Usage**

No.	System Name	2004 Water Usage (gal/yr)	% Water Usage %	No. Connections #	Usage Per Connection (gal/yr)	No. Customers #	Annual Usage Per Customer (gal/yr)	Daily Usage Per Customer (gpcd)
1	Coronado Country	2,083,300	1.7	44	47,348	132	15,783	43.2
2	Country Acres	6,766,800	5.4	88	76,895	264	25,632	70.2
3	Colony Cove	4,239,800	3.4	48	88,329	144	29,443	80.7
4	Country Meadows	3,446,900	2.7	48	71,810	144	23,937	65.6
5	Blue Sage Gardens	2,976,800	2.4	43	69,228	129	23,076	63.2
6	Brandi Estates	3,524,700	2.8	43	81,970	129	27,323	74.9
7	Sandy Meadows	3,735,400	3.0	68	54,932	204	18,311	50.2
8	Rosharon Road Estates	5,455,900	4.3	76	71,788	228	23,929	65.6
9	Grasslands	12,465,400	9.9	171	72,897	513	24,299	66.6
10	Rosharon Township	8,055,400	6.4	99	81,368	297	27,123	74.3
11	Demi-John Island	3,973,000	3.2	99	40,131	297	13,377	36.6
12	San Bernard River	4,595,500	3.7	49	93,786	147	31,262	85.6
13	Angle Acres	3,330,500	2.7	44	75,693	132	25,231	69.1
14	Spanish Bait	672,000	0.5	8	84,000	24	28,000	76.7
15	Briar Meadow	5,231,700	4.2	41	127,602	123	42,534	116.5
16	Mooreland	4,605,600	3.7	48	95,950	144	31,983	87.6
17	Raynlong	2,736,600	2.2	32	85,519	96	28,506	78.1
18	Snug Harbor	2,030,600	1.6	33	61,533	99	20,511	56.2
19	Bernard Oaks	4,280,000	3.4	71	60,282	213	20,094	55.1
20	Demi-John Place	2,844,500	2.3	88	32,324	264	10,775	29.5
21	Teleview Terrace	5,997,600	4.8	47	127,609	141	42,536	116.5
22	Wolf Glen	2,809,900	2.2	35	80,283	105	26,761	73.3
23	Larkspur	420,000	0.3	5	84,000	15	28,000	76.7
24	Wilco Water	4,037,100	3.2	49	82,390	147	27,463	75.2
25	Beechwood	5,655,000	4.5	73	77,466	219	25,822	70.7
26	Oak Meadows	1,542,000	1.2	33	46,727	99	15,576	42.7
27	Mark V	7,178,900	5.7	94	76,371	282	25,457	69.7
28	Riverside Estates	3,695,400	2.9	48	76,988	144	25,663	70.3
29	Lee Ridge	1,926,900	1.5	22	87,586	66	29,195	80.0
30	Quail Valley Ranches IV	785,600	0.6	8	98,200	24	32,733	89.7
31	Paloma Acres	1,484,500	1.2	25	59,380	75	19,793	54.2
32	Colony Trails	2,254,100	1.8	45	50,091	135	16,697	45.7
33	Other	725,000	0.6	19	38,158	57	12,719	34.8
	<b>TOTAL</b>	<b>125,562,400</b>	<b>100</b>	<b>1,744</b>		<b>5,232</b>		
	<b>AVERAGE</b>				<b>74,504</b>		<b>24,835</b>	<b>68.0</b>

1 **APPENDIX G**  
2 **ANALYSIS OF SHARED SOLUTIONS FOR OBTAINING WATER FROM**  
3 **BWA AND CITY OF ALVIN**

4 **G.1 Overview of Method**

5 There are a number of small PWSs with water quality problems located in the  
6 vicinity of the Oak Meadows Estates PWS that could benefit from joining together and  
7 cooperating to share the cost for obtaining compliant drinking water. This cooperation  
8 could involve creating a formal organization of individual PWSs to address obtaining  
9 compliant drinking water, consolidating to form a single PWS, or having the individual  
10 PWSs be taken over or bought out by a larger regional entity.

11 The small PWSs with water quality problems near the Oak Meadows Estates PWS  
12 are summarized in Table G.1. Most of them are owned by Orbit. It is assumed for this  
13 analysis that all of the systems would participate in a shared solution.

14 This analysis focuses on compliance alternatives related to obtaining water from  
15 large water providers that are interested in providing water outside their current area,  
16 either by wholesaling to PWSs, or by expanding their service areas. This type of solution  
17 is most likely to have the best prospects for sustainability, and a reliable provision of  
18 compliant drinking water.

19 The purpose of this analysis is to approximate the level of capital cost savings that  
20 could be expected from pursuing a shared solution versus a solution where the study  
21 PWS obtains compliant drinking water on its own. Regardless of the form a group  
22 solution would take, one way or another the water consumers would have to pay for the  
23 infrastructure needed for obtaining compliant water. In order to keep this analysis as  
24 straightforward and realistic as possible, it is assumed the individual PWSs would remain  
25 independent, and would share the capital cost for the infrastructure required. Also, to  
26 maintain simplicity, this analysis is limited to estimating capital cost savings. A shared  
27 solution could also produce savings in O&M expenses as a result of reduction in  
28 redundant facilities and the potential for shared O&M resources, and these savings would  
29 have to be evaluated if the PWSs are interested in implementing a shared solution.

30 There are many ways capital costs could be divided between participating PWSs and  
31 the final apportioning of costs would likely be based on negotiation between the  
32 participating entities. At this preliminary stage of analysis it is not possible to project  
33 results from negotiations regarding cost sharing. For this reason, two methods are used  
34 to allocate cost between PWSs in an effort to give an approximation of the range of  
35 savings that might be attainable for an individual PWS. This range is considered to be  
36 representative of possible savings that could result from an agreement that should be fair  
37 and equitable to all parties involved.

38 Method A is based on allocating capital cost of the shared solution proportionate to  
39 the amount of water used by the PWSs. In this case, the total capital cost for the pipeline

1 and the necessary pump stations is estimated, and then capital cost for each component is  
2 allocated based on the fraction of the total water used by each PWS. This method is a  
3 reasonable method for allocating cost when all of the PWSs are different in size but are  
4 relatively equidistant from the shared water source.

5 Method B is based on allocating capital cost of the shared solution proportionate to  
6 the cost each PWS would have to pay to obtain compliant water if it were to implement  
7 an individual solution. In this case, the total capital cost for the shared pipeline and the  
8 necessary pump stations is estimated as well as the capital cost each PWS would have for  
9 obtaining its own pipeline. The total capital cost for the shared solution is then allocated  
10 between the participating PWSs based on what each PWS would have to pay to construct  
11 its own pipeline. This method is a reasonable method for allocating cost when the PWSs  
12 are not equidistant from the water source.

### 13 **G.2 Shared Solution for Obtaining Water from City of Alvin**

14 This alternative would consist of constructing a main pipeline from the southwest  
15 part of the City of Alvin that would run southwest and west along FM 1462 to Rosharon  
16 Township. Each PWS would connect to this main with a spur line. Spur lines would  
17 convey the water from the main line to the storage tanks of each PWS. The main  
18 pipeline would start out as 6 inches in diameter, and reduce to 4 inches in diameter at the  
19 end. All of the spur pipelines would be 4 inches in diameter. It is assumed two pump  
20 stations would be required to transfer the water from the City of Alvin to the end of the  
21 pipeline. The pipeline routing is shown on Figure G.1.

22 The capital costs for each pipe segment and the total capital cost for the shared  
23 pipeline are summarized in Table G.2. Tables G.3, G.4 and G.5 show the capital costs  
24 allocated to each PWS using Methods A, B and C respectively while Table G.6 compares  
25 the found values from each method. More detailed cost estimates for the pipe segments  
26 are shown in Tables G.12 through G.22 and G.35 through G.40.


27 Based on these estimates, the range of capital cost savings to the Sandy Meadow  
28 Estates Subdivision PWS could be between \$1.06 million and \$1.43 million, or 57 and  
29 76 percent if it implemented a shared solution like this. These estimates are hypothetical  
30 and are only provided to approximate the magnitude of potential savings if this shared  
31 solution is implemented as described.

### 32 **G.3 Group Solution for Obtaining Water from Brazosport Water Authority**

33 This alternative would consist of constructing a main pipeline that starts at the north  
34 part of the City of Angleton where the Brazosport Water Authority line currently  
35 terminates. The line would run north along Highway 288 to Rosharon Township and turn  
36 to run east along FM 1462 to Rosharon Road Estates. Spur lines would convey the water  
37 from the main line to the storage tanks. The main pipeline would start out as 6 inches in  
38 diameter, and reduce to 4 inches in diameter at the end. All of the spur pipelines would  
39 be 4 inches in diameter. It is assumed three pump stations would be required to transfer  
40 the water from the Brazosport Water Authority line to the end of the pipeline. The  
41 pipeline routing is shown on Figure G.2.

1       The capital costs for each pipe segment and the total capital cost for the shared  
2 pipeline are summarized in Table G.7. Table G.8, G.9 and G.10 show the capital costs  
3 allocated to each PWS using Methods A, B and C respectively while Table G.11  
4 compares the found values from each method. More detailed cost estimates for the pipe  
5 segments are shown in Tables G.23 through G.17 and G.41 through G.46.

6       Based on these estimates, the range of capital cost savings to the Sandy Meadow  
7 Estates Subdivision PWS could be between \$2.25 million and \$2.53 million, or 70 and 78  
8 percent, if they were to implement a shared solution like this. These estimates are  
9 hypothetical and are only provided to approximate the magnitude of potential savings if  
10 this shared solution is implemented as described.



City of Alvin

Oak Meadows Estates

Rosharon Road Estates Subdivision

Rosharon Township


Grasslands

Stoneridge Lakes

Sandy Meadow Estates Subdivision





- Participating PWS
- Source Location
- Regional Pipeline
- Water Features
- Roads
- City Limits



**Figure G.1**

**Regional Solution  
Water from City of Alvin**



**Figure G.2**  
**Regional Solution**  
**Water from**  
**Brazosport Water Authority**

Table G.1

PWS	Average Water Demand (mgd)	Water Demand as Percent of Total
Rosharon Road Estates Subdivision	0.10443	28%
Sandy Meadows Estates Subdivision	0.08943	24%
Stoneridge Lakes	0.07343	19%
Grasslands	0.06485	17%
Oak Meadows	0.02585	7%
Rosharon Township	0.0191	5%
0	0	0%
0	0	0%
0	0	0%

Table G.2  
Capital Cost for Shared Pipeline from the City of Alvin

Pipe Segment	Capital Cost
Pipe 1	\$ 1,867,972
Pipe 2	\$ 231,354
Pipe 3	\$ 771,954
Pipe 4	\$ 66,985
Pipe 5	\$ 110,723
Pipe 6	\$ -
Pipe 7	\$ -
Pipe 8	\$ -
Pipe 9	\$ -
Pipe A	\$ 83,183
Pipe B	\$ 56,081
Pipe C	\$ 28,781
Pipe D	\$ 20,947
Pipe E	\$ 121,746
Pipe F	\$ 81,115
Pipe G	\$ -
Pipe H	\$ -
Pipe I	\$ -
<b>Total</b>	<b>\$ 3,440,840</b>



Table G.3  
Cost Solution A

<b>PWS</b>	<b>Percentage Based On Flow</b>	<b>Total Costs</b>
Rosharon Road Estates Subdivision	28%	\$ 952,894
Sandy Meadows Estates Subdivision	24%	\$ 816,024
Stoneridge Lakes	19%	\$ 670,028
Grasslands	17%	\$ 591,738
Oak Meadows	7%	\$ 235,874
Rosharon Township	5%	\$ 174,282
0	0%	\$ -
0	0%	\$ -
0	0%	\$ -
<b>Total</b>	<b>100%</b>	<b>\$ 3,440,840</b>

Table G.4  
Cost Solution B

<b>PWS</b>	<b>Costs Incurred due to Shared Pipeline</b>	<b>Costs Incurred due to Personal Pipeline</b>	<b>Total Costs</b>
Rosharon Road Estates Subdivision	\$ 517,310	\$ 83,183	\$ 600,493
Sandy Meadows Estates Subdivision	\$ 518,887	\$ 56,081	\$ 574,968
Stoneridge Lakes	\$ 735,416	\$ 28,781	\$ 764,196
Grasslands	\$ 689,048	\$ 20,947	\$ 709,995
Oak Meadows	\$ 338,338	\$ 121,746	\$ 460,083
Rosharon Township	\$ 249,990	\$ 81,115	\$ 331,105
0	\$ -	\$ -	\$ -
0	\$ -	\$ -	\$ -
0	\$ -	\$ -	\$ -
<b>Total</b>	<b>\$ 3,048,988</b>	<b>\$ 391,852</b>	<b>\$ 3,440,840</b>

Table G.5  
Cost Solution C

<b>PWS</b>	<b>Percentage based on Individual Solutions</b>	<b>Total Costs</b>
Rosharon Road Estates Subdivision	12%	\$ 397,613
Sandy Meadows Estates Subdivision	13%	\$ 449,660
Stoneridge Lakes	18%	\$ 614,387
Grasslands	18%	\$ 623,111
Oak Meadows	20%	\$ 673,214
Rosharon Township	20%	\$ 682,855
0	0%	\$ -
0	0%	\$ -
0	0%	\$ -
<b>Total</b>	<b>100%</b>	<b>\$ 3,440,840</b>

Table G.6  
Summation Table

<b>PWS</b>	<b>Individual Pipeline Cost</b>	<b>Capital Cost Option A</b>	<b>Capital Cost Option B</b>	<b>Capital Cost Option C</b>	<b>Percent Savings A</b>	<b>Percent Savings B</b>	<b>Percent Savings C</b>
Rosharon Road Estates Subdivision	\$ 1,660,177	\$ 952,894	\$ 600,493	\$ 397,613	43%	64%	76%
Sandy Meadows Estates Subdivision	\$ 1,877,491	\$ 816,024	\$ 574,968	\$ 449,660	57%	69%	76%
Stoneridge Lakes	\$ 2,565,286	\$ 670,028	\$ 764,196	\$ 614,387	74%	70%	76%
Grasslands	\$ 2,601,709	\$ 591,738	\$ 709,995	\$ 623,111	77%	73%	76%
Oak Meadows	\$ 2,810,908	\$ 235,874	\$ 460,083	\$ 673,214	92%	84%	76%
Rosharon Township	\$ 2,851,163	\$ 174,282	\$ 331,105	\$ 682,855	94%	88%	76%
0	\$ -	\$ -	\$ -	\$ -	false	false	false
0	\$ -	\$ -	\$ -	\$ -	false	false	false
0	\$ -	\$ -	\$ -	\$ -	false	false	false
<b>Total</b>	<b>\$ 14,366,734</b>	<b>\$ 3,440,840</b>	<b>\$ 3,440,840</b>	<b>\$ 3,440,840</b>	<b>73%</b>	<b>75%</b>	<b>76%</b>

Table G.7  
Capital Cost for Shared Pipeline from BWA

Pipe Segment	Capital Cost
Pipe 1	\$ 2,988,751
Pipe 2	\$ 92,141
Pipe 3	\$ 110,723
Pipe 4	\$ 66,985
Pipe 5	\$ 786,817
Pipe 6	\$ 231,354
Pipe 7	\$ -
Pipe 8	\$ -
Pipe 9	\$ -
Pipe A	\$ 74,108
Pipe B	\$ 121,746
Pipe C	\$ 20,947
Pipe D	\$ 28,769
Pipe E	\$ 56,085
Pipe F	\$ 83,254
Pipe G	\$ -
Pipe H	\$ -
Pipe I	\$ -
<b>Total</b>	<b>\$ 4,661,678</b>

Table G.8  
Cost Solution A

PWS	Percentage Based On Flow	Total Costs
Rosharon Township	18%	\$ 852,611
Oak Meadows	6%	\$ 301,315
Grasslands	37%	\$ 1,740,934
Stoneridge Lakes	8%	\$ 383,005
Sandy Meadows Estates Subdivision	15%	\$ 714,222
Rosharon Road Estates Subdivision	14%	\$ 669,590
0	0%	\$ -
0	0%	\$ -
0	0%	\$ -
<b>Total</b>	<b>100%</b>	<b>\$ 4,661,678</b>

Table G.9  
Cost Solution B

<b>PWS</b>	<b>Costs Incurred due to Shared Pipeline</b>	<b>Costs Incurred due to Personal Pipeline</b>	<b>Total Costs</b>
Rosharon Township	\$ 546,636	\$ 74,108	\$ 620,744
Oak Meadows	\$ 200,472	\$ 121,746	\$ 322,217
Grasslands	\$ 1,213,235	\$ 20,947	\$ 1,234,181
Stoneridge Lakes	\$ 281,432	\$ 28,769	\$ 310,202
Sandy Meadows Estates Subdivision	\$ 930,908	\$ 56,085	\$ 986,992
Rosharon Road Estates Subdivision	\$ 1,104,088	\$ 83,254	\$ 1,187,342
0	\$ -	\$ -	\$ -
0	\$ -	\$ -	\$ -
0	\$ -	\$ -	\$ -
<b>Total</b>	<b>\$ 4,276,771</b>	<b>\$ 384,908</b>	<b>\$ 4,661,678</b>

Table G.10  
Cost Solution C

<b>PWS</b>	<b>Percentage based on Individual Solutions</b>	<b>Total Costs</b>
Rosharon Township	15%	\$ 699,159
Oak Meadows	16%	\$ 744,220
Grasslands	15%	\$ 703,840
Stoneridge Lakes	15%	\$ 698,313
Sandy Meadows Estates Subdivision	19%	\$ 891,538
Rosharon Road Estates Subdivision	20%	\$ 924,609
0	0%	\$ -
0	0%	\$ -
0	0%	\$ -
<b>Total</b>	<b>100%</b>	<b>\$ 4,661,678</b>

Table G.11  
Summation Table

<b>PWS</b>	<b>Individual Pipeline Cost</b>	<b>Capital Cost Option A</b>	<b>Capital Cost Option B</b>	<b>Capital Cost Option C</b>	<b>Percent Savings A</b>	<b>Percent Savings B</b>	<b>Percent Savings C</b>
Rosharon Township	\$ 2,540,184	\$ 852,611	\$ 620,744	\$ 699,159	66%	76%	72%
Oak Meadows	\$ 2,703,899	\$ 301,315	\$ 322,217	\$ 744,220	89%	88%	72%
Grasslands	\$ 2,557,190	\$ 1,740,934	\$ 1,234,181	\$ 703,840	32%	52%	72%
Stoneridge Lakes	\$ 2,537,109	\$ 383,005	\$ 310,202	\$ 698,313	85%	88%	72%
Sandy Meadows Estates Subdivision	\$ 3,239,135	\$ 714,222	\$ 986,992	\$ 891,538	78%	70%	72%
Rosharon Road Estates Subdivision	\$ 3,359,289	\$ 669,590	\$ 1,187,342	\$ 924,609	80%	65%	72%
0	\$ -	\$ -	\$ -	\$ -	false	false	false
0	\$ -	\$ -	\$ -	\$ -	false	false	false
0	\$ -	\$ -	\$ -	\$ -	false	false	false
<b>Total</b>	<b>\$ 16,936,806</b>	<b>\$ 4,661,678</b>	<b>\$ 4,661,678</b>	<b>\$ 4,661,678</b>	<b>72%</b>	<b>73%</b>	<b>72%</b>

**Table G.12**

**Obtain Water From the City of Alvin**

**Main Link # 1**

**Total Pipe Length**

6.67 miles

**Number of Pump Stations Needed**

1

**Pipe Size**

06" inches

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	4	n/a	n/a	n/a
Number of Crossings, open cut	14	n/a	n/a	n/a
PVC water line, Class 200, 06"	35,210	LF	\$ 32	\$ 1,126,720
Bore and encasement, 10"	800	LF	\$ 60	\$ 48,000
Open cut and encasement, 10"	700	LF	\$ 35	\$ 24,500
Gate valve and box, 06"	8	EA	\$ 465	\$ 3,720
Air valve	7	EA	\$ 1,000	\$ 7,000
Flush valve	8	EA	\$ 750	\$ 6,000
Metal detectable tape	35,210	LF	\$ 0.15	\$ 5,282
<b>Subtotal</b>				<b>\$ 1,221,222</b>
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 06"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 06"	4	EA	\$ 590	\$ 2,360
Check valve, 06"	2	EA	\$ 890	\$ 1,780
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 67,035</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,288,257</b>
Contingency	20%			\$ 257,651
Design & Constr Management	25%			\$ 322,064
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 1,867,972</b>

**Table G.13**

**Obtain Water From the City of Alvin**

**Main Link # 2**

**Total Pipe Length**

0.99 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	5,251	LF	\$ 27	\$ 141,777
Bore and encasement, 10"	200	LF	\$ 60	\$ 12,000
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	2	EA	\$ 370	\$ 740
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	2	EA	\$ 750	\$ 1,500
Metal detectable tape	5,251	LF	\$ 0.15	\$ 788
<b>Subtotal</b>				<b>\$ 159,555</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
<b>Subtotal</b>				<b>\$ -</b>
<b>Subtotal of Component Costs</b>				<b>\$ 159,555</b>
Contingency	20%			\$ 31,911
Design & Constr Management	25%			\$ 39,889
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 231,354</b>

**Table G.14**

**Obtain Water From the City of Alvin**

**Main Link # 3**

**Total Pipe Length**

2.92 miles

**Number of Pump Stations Needed**

1

**Pipe Size**

04" inches

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	3	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	15,394	LF	\$ 27	\$ 415,638
Bore and encasement, 10"	600	LF	\$ 60	\$ 36,000
Open cut and encasement, 10"	150	LF	\$ 35	\$ 5,250
Gate valve and box, 04"	4	EA	\$ 370	\$ 1,480
Air valve	3	EA	\$ 1,000	\$ 3,000
Flush valve	4	EA	\$ 750	\$ 3,000
Metal detectable tape	15,394	LF	\$ 0.15	\$ 2,309
	<b>Subtotal</b>			<b>\$ 466,677</b>
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5000 gals	1	EA	\$ 7,025	\$ 7,025
	<b>Subtotal</b>			<b>\$ 65,705</b>
			<b>Subtotal of Component Costs</b>	<b>\$ 532,382</b>
Contingency	20%			\$ 106,476
Design & Constr Management	25%			\$ 133,096
			<b>TOTAL CAPITAL COSTS</b>	<b>\$ 771,954</b>



**Table G.15**

**Obtain Water From the City of Alvin**

**Main Link # 4**

**Total Pipe Length**

0.30 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,559	LF	\$ 27	\$ 42,093
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,559	LF	\$ 0.15	\$ 234
	<b>Subtotal</b>			<b>\$ 46,197</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
	<b>Subtotal</b>			<b>\$ -</b>
			<b>Subtotal of Component Costs</b>	<b>\$ 46,197</b>
Contingency	20%			\$ 9,239
Design & Constr Management	25%			\$ 11,549
			<b>TOTAL CAPITAL COSTS</b>	<b>\$ 66,985</b>

**Table G.16**

**Obtain Water From the City of Alvin**

**Main Link # 5**

**Total Pipe Length**

0.51 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	2,670	LF	\$ 27	\$ 72,090
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	2,670	LF	\$ 0.15	\$ 401
<b>Subtotal</b>				<b>\$ 76,361</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
<b>Subtotal</b>				<b>\$ -</b>
<b>Subtotal of Component Costs</b>				<b>\$ 76,361</b>
Contingency	20%			\$ 15,272
Design & Constr Management	25%			\$ 19,090
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 110,723</b>

**Table G.17**

**Segment A**

**Obtain Water From the City of Alvin**

**Rosharon Road Estates Subdivision**

<b>Private Pipe Size</b>	04"
<b>Total Pipe Length</b>	0.28 miles
<b>Total PWS annual water usage</b>	38.1 MG
<b>Treated water purchase cost</b>	\$ 1.25 per 1,000 gals
<b>Number of Pump Stations Needed</b>	0

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	2	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,464	LF	\$ 27	\$ 39,528
Bore and encasement, 10"	200	LF	\$ 60	\$ 12,000
Open cut and encasement, 10"	100	LF	\$ 35	\$ 3,500
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,464	LF	\$ 0.15	\$ 220
	<b>Subtotal</b>			<b>\$ 57,368</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
	<b>Subtotal</b>			<b>\$ -</b>
	<b>Subtotal of Component Costs</b>			<b>\$ 57,368</b>
Contingency	20%			\$ 11,474
Design & Constr Management	25%			\$ 14,342
	<b>TOTAL CAPITAL COSTS</b>			<b>\$ 83,183</b>

**Table G.18**

**Segment B**

**Obtain Water From the City of Alvin**

**Sandy Meadows Estates Subdivision**

<b>Private Pipe Size</b>	04"
<b>Total Pipe Length</b>	0.24 miles
<b>Total PWS annual water usage</b>	32.6 MG
<b>Treated water purchase cost</b>	\$ 1.25 per 1,000 gals
<b>Number of Pump Stations Needed</b>	0

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,282	LF	\$ 27	\$ 34,614
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,282	LF	\$ 0.15	\$ 192
		<b>Subtotal</b>		<b>\$ 38,676</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		<b>Subtotal</b>		<b>\$ -</b>
		<b>Subtotal of Component Costs</b>		<b>\$ 38,676</b>
Contingency	20%			\$ 7,735
Design & Constr Management	25%			\$ 9,669
		<b>TOTAL CAPITAL COSTS</b>		<b>\$ 56,081</b>

**Table G.19**

**Segment C**

**Obtain Water From the City of Alvin**

**Stoneridge Lakes**

<b>Private Pipe Size</b>	04"
<b>Total Pipe Length</b>	0.12 miles
<b>Total PWS annual water usage</b>	26.8 MG
<b>Treated water purchase cost</b>	\$ 1.25 per 1,000 gals
<b>Number of Pump Stations Needed</b>	0

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	-	n/a	n/a	n/a
PVC water line, Class 200, 04"	653	LF	\$ 27	\$ 17,631
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	-	LF	\$ 35	\$ -
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	653	LF	\$ 0.15	\$ 98
		<b>Subtotal</b>		<b>\$ 19,849</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		<b>Subtotal</b>		<b>\$ -</b>
		<b>Subtotal of Component Costs</b>		<b>\$ 19,849</b>
Contingency	20%		\$	3,970
Design & Constr Management	25%		\$	4,962
		<b>TOTAL CAPITAL COSTS</b>		<b>\$ 28,781</b>

**Table G.20**

**Segment D**

**Obtain Water From the City of Alvin**

**Grasslands**

<b>Private Pipe Size</b>	04"
<b>Total Pipe Length</b>	0.09 miles
<b>Total PWS annual water usage</b>	23.7 MG
<b>Treated water purchase cost</b>	\$ 1.25 per 1,000 gals
<b>Number of Pump Stations Needed</b>	0

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	-	n/a	n/a	n/a
PVC water line, Class 200, 04"	454	LF	\$ 27	\$ 12,258
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	-	LF	\$ 35	\$ -
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	454	LF	\$ 0.15	\$ 68
		<b>Subtotal</b>		<b>\$ 14,446</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		<b>Subtotal</b>		<b>\$ -</b>
		<b>Subtotal of Component Costs</b>		<b>\$ 14,446</b>
Contingency	20%			\$ 2,889
Design & Constr Management	25%			\$ 3,612
		<b>TOTAL CAPITAL COSTS</b>		<b>\$ 20,947</b>

**Table G.21**

**Segment E**

**Obtain Water From the City of Alvin**

**Oak Meadows**

<b>Private Pipe Size</b>	04"
<b>Total Pipe Length</b>	0.56 miles
<b>Total PWS annual water usage</b>	9.4 MG
<b>Treated water purchase cost</b>	\$ 1.25 per 1,000 gals
<b>Number of Pump Stations Needed</b>	0

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	2,950	LF	\$ 27	\$ 79,650
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	2,950	LF	\$ 0.15	\$ 443
		<b>Subtotal</b>		<b>\$ 83,963</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		<b>Subtotal</b>		<b>\$ -</b>
		<b>Subtotal of Component Costs</b>		<b>\$ 83,963</b>
Contingency	20%			\$ 16,793
Design & Constr Management	25%			\$ 20,991
		<b>TOTAL CAPITAL COSTS</b>		<b>\$ 121,746</b>

**Table G.22**

**Segment F**

**Obtain Water From the City of Alvin**

**Rosharon Township**

**Private Pipe Size**

04"

**Total Pipe Length**

0.34 miles

**Total PWS annual water usage**

7.0 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,789	LF	\$ 27	\$ 48,303
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	150	LF	\$ 35	\$ 5,250
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,789	LF	\$ 0.15	\$ 268
		<b>Subtotal</b>		<b>\$ 55,941</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		<b>Subtotal</b>		<b>\$ -</b>
		<b>Subtotal of Component Costs</b>		<b>\$ 55,941</b>
Contingency	20%			\$ 11,188
Design & Constr Management	25%			\$ 13,985
		<b>TOTAL CAPITAL COSTS</b>		<b>\$ 81,115</b>



**Table G.23**

**Obtain Water From the City of Alvin**

**Main Link # 1**

**Total Pipe Length**

11.36 miles

**Number of Pump Stations Needed**

1

**Pipe Size**

06" inches

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	9	n/a	n/a	n/a
PVC water line, Class 200, 06"	59,964	LF	\$ 32	\$ 1,918,848
Bore and encasement, 10"	400	LF	\$ 60	\$ 24,000
Open cut and encasement, 10"	450	LF	\$ 35	\$ 15,750
Gate valve and box, 06"	12	EA	\$ 465	\$ 5,580
Air valve	12	EA	\$ 1,000	\$ 12,000
Flush valve	12	EA	\$ 750	\$ 9,000
Metal detectable tape	59,964	LF	\$ 0.15	\$ 8,995
	<b>Subtotal</b>			<b>\$ 1,994,173</b>
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 06"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 06"	4	EA	\$ 590	\$ 2,360
Check valve, 06"	2	EA	\$ 890	\$ 1,780
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5000 gals	1	EA	\$ 7,025	\$ 7,025
	<b>Subtotal</b>			<b>\$ 67,035</b>
			<b>Subtotal of Component Costs</b>	<b>\$ 2,061,208</b>
Contingency	20%			\$ 412,242
Design & Constr Management	25%			\$ 515,302
			<b>TOTAL CAPITAL COSTS</b>	<b>\$ 2,988,751</b>

**Table G.24**

**Obtain Water From the City of Alvin**

**Main Link # 2**

**Total Pipe Length**

0.33 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,756	LF	\$ 27	\$ 47,412
Bore and encasement, 10"	200	LF	\$ 60	\$ 12,000
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,756	LF	\$ 0.15	\$ 263
<b>Subtotal</b>				<b>\$ 63,545</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
<b>Subtotal</b>				<b>\$ -</b>
<b>Subtotal of Component Costs</b>				<b>\$ 63,545</b>
Contingency	20%			\$ 12,709
Design & Constr Management	25%			\$ 15,886
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 92,141</b>

**Table G.25**

**Obtain Water From the City of Alvin**

**Main Link # 3**

**Total Pipe Length**

0.51 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	2,670	LF	\$ 27	\$ 72,090
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	2,670	LF	\$ 0.15	\$ 401
<b>Subtotal</b>				<b>\$ 76,361</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
<b>Subtotal</b>				<b>\$ -</b>
<b>Subtotal of Component Costs</b>				<b>\$ 76,361</b>
Contingency	20%			\$ 15,272
Design & Constr Management	25%			\$ 19,090
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 110,723</b>

**Table G.26**

**Obtain Water From the City of Alvin**

**Main Link # 4**

**Total Pipe Length**

0.30 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,559	LF	\$ 27	\$ 42,093
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,559	LF	\$ 0.15	\$ 234
	<b>Subtotal</b>			<b>\$ 46,197</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
	<b>Subtotal</b>			<b>\$ -</b>
		<b>Subtotal of Component Costs</b>		<b>\$ 46,197</b>
Contingency	20%			\$ 9,239
Design & Constr Management	25%			\$ 11,549
		<b>TOTAL CAPITAL COSTS</b>		<b>\$ 66,985</b>

**Table G.27**

**Obtain Water From the City of Alvin**

**Main Link # 5**

**Total Pipe Length**

2.92 miles

**Number of Pump Stations Needed**

1

**Pipe Size**

04" inches

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	4	n/a	n/a	n/a
Number of Crossings, open cut	2	n/a	n/a	n/a
PVC water line, Class 200, 04"	15,394	LF	\$ 27	\$ 415,638
Bore and encasement, 10"	800	LF	\$ 60	\$ 48,000
Open cut and encasement, 10"	100	LF	\$ 35	\$ 3,500
Gate valve and box, 04"	4	EA	\$ 370	\$ 1,480
Air valve	3	EA	\$ 1,000	\$ 3,000
Flush valve	4	EA	\$ 750	\$ 3,000
Metal detectable tape	15,394	LF	\$ 0.15	\$ 2,309
	<b>Subtotal</b>			<b>\$ 476,927</b>
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5000 gals	1	EA	\$ 7,025	\$ 7,025
	<b>Subtotal</b>			<b>\$ 65,705</b>
			<b>Subtotal of Component Costs</b>	<b>\$ 542,632</b>
Contingency	20%			\$ 108,526
Design & Constr Management	25%			\$ 135,658
			<b>TOTAL CAPITAL COSTS</b>	<b>\$ 786,817</b>

**Table G.28**

**Obtain Water From the City of Alvin**

**Main Link # 6**

**Total Pipe Length**

0.99 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	5,251	LF	\$ 27	\$ 141,777
Bore and encasement, 10"	200	LF	\$ 60	\$ 12,000
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	2	EA	\$ 370	\$ 740
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	2	EA	\$ 750	\$ 1,500
Metal detectable tape	5,251	LF	\$ 0.15	\$ 788
<b>Subtotal</b>				<b>\$ 159,555</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
<b>Subtotal</b>				<b>\$ -</b>
<b>Subtotal of Component Costs</b>				<b>\$ 159,555</b>
Contingency	20%			\$ 31,911
Design & Constr Management	25%			\$ 39,889
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 231,354</b>

**Table G.29**

**Segment A**

**Obtain Water From the City of Alvin**

**Rosharon Township**

**Private Pipe Size**

04"

**Total Pipe Length**

0.31 miles

**Total PWS annual water usage**

4,841.3 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,611	LF	\$ 27	\$ 43,497
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	150	LF	\$ 35	\$ 5,250
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,611	LF	\$ 0.15	\$ 242
<b>Subtotal</b>				<b>\$ 51,109</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
<b>Subtotal</b>				<b>\$ -</b>
<b>Subtotal of Component Costs</b>				<b>\$ 51,109</b>
Contingency	20%			\$ 10,222
Design & Constr Management	25%			\$ 12,777
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 74,108</b>

**Table G.30**

**Segment B**

**Obtain Water From the City of Alvin**

**Oak Meadows**

**Private Pipe Size**

04"

**Total Pipe Length**

0.56 miles

**Total PWS annual water usage**

1,710.9 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	2,950	LF	\$ 27	\$ 79,650
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	2,950	LF	\$ 0.15	\$ 443
		<b>Subtotal</b>		<b>\$ 83,963</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		<b>Subtotal</b>		<b>\$ -</b>
		<b>Subtotal of Component Costs</b>		<b>\$ 83,963</b>
Contingency	20%			\$ 16,793
Design & Constr Management	25%			\$ 20,991
		<b>TOTAL CAPITAL COSTS</b>		<b>\$ 121,746</b>



**Table G.31**

**Segment C**

**Obtain Water From the City of Alvin**

**Grasslands**

**Private Pipe Size**

04"

**Total Pipe Length**

0.09 miles

**Total PWS annual water usage**

9,885.4 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	-	n/a	n/a	n/a
PVC water line, Class 200, 04"	454	LF	\$ 27	\$ 12,258
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	-	LF	\$ 35	\$ -
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	454	LF	\$ 0.15	\$ 68
			<b>Subtotal</b>	<b>\$ 14,446</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
			<b>Subtotal</b>	<b>\$ -</b>
			<b>Subtotal of Component Costs</b>	<b>\$ 14,446</b>
Contingency	20%			\$ 2,889
Design & Constr Management	25%			\$ 3,612
			<b>TOTAL CAPITAL COSTS</b>	<b>\$ 20,947</b>

**Table G.32**

**Segment D**

**Obtain Water From the City of Alvin**

**Stoneridge Lakes**

Private Pipe Size	04"
Total Pipe Length	0.12 miles
Total PWS annual water usage	2,174.8 MG
Treated water purchase cost	\$ 1.25 per 1,000 gals
Number of Pump Stations Needed	0

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	-	n/a	n/a	n/a
PVC water line, Class 200, 04"	653	LF	\$ 27	\$ 17,623
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	-	LF	\$ 35	\$ -
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	653	LF	\$ 0.15	\$ 98
		<b>Subtotal</b>		<b>\$ 19,841</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		<b>Subtotal</b>		<b>\$ -</b>
		<b>Subtotal of Component Costs</b>		<b>\$ 19,841</b>
Contingency	20%			\$ 3,968
Design & Constr Management	25%			\$ 4,960
		<b>TOTAL CAPITAL COSTS</b>		<b>\$ 28,769</b>

**Table G.33**

**Segment E**

**Obtain Water From the City of Alvin**

**Sandy Meadows Estates Subdivision**

<b>Private Pipe Size</b>	04"
<b>Total Pipe Length</b>	0.24 miles
<b>Total PWS annual water usage</b>	4,055.5 MG
<b>Treated water purchase cost</b>	\$ 1.25 per 1,000 gals
<b>Number of Pump Stations Needed</b>	0

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,282	LF	\$ 27	\$ 34,617
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,282	LF	\$ 0.15	\$ 192
		<b>Subtotal</b>		<b>\$ 38,679</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		<b>Subtotal</b>		<b>\$ -</b>
		<b>Subtotal of Component Costs</b>		<b>\$ 38,679</b>
Contingency	20%			\$ 7,736
Design & Constr Management	25%			\$ 9,670
		<b>TOTAL CAPITAL COSTS</b>		<b>\$ 56,085</b>

**Table G.34**

**Segment F**

**Obtain Water From the City of Alvin**

**Rosharon Road Estates Subdivision**

**Private Pipe Size**

04"

**Total Pipe Length**

0.28 miles

**Total PWS annual water usage**

3,802.1 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	2	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,466	LF	\$ 27	\$ 39,577
Bore and encasement, 10"	200	LF	\$ 60	\$ 12,000
Open cut and encasement, 10"	100	LF	\$ 35	\$ 3,500
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,466	LF	\$ 0.15	\$ 220
			<b>Subtotal</b>	<b>\$ 57,416</b>
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
			<b>Subtotal</b>	<b>\$ -</b>
			<b>Subtotal of Component Costs</b>	<b>\$ 57,416</b>
Contingency	20%			\$ 11,483
Design & Constr Management	25%			\$ 14,354
			<b>TOTAL CAPITAL COSTS</b>	<b>\$ 83,254</b>

**Table G.35**

**Alvin to each PWS**

**Alternative Name** *Purchase Water from Alvin to Rosharon Road*  
**Alternative Number** *RR*

<b>Distance from Alternative to PWS (along pipe)</b>	7.0	miles
<b>Total PWS annual water usage</b>	5.475	MG
<b>Treated water purchase cost</b>	\$ 1.65	per 1,000 gals
<b>Number of Pump Stations Needed</b>	1	

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	4	n/a	n/a	n/a
Number of Crossings, open cut	17	n/a	n/a	n/a
PVC water line, Class 200, 04"	36,750	LF	\$ 27.00	\$ 992,250
Bore and encasement, 10"	800	LF	\$ 60.00	\$ 48,000
Open cut and encasement, 10"	850	LF	\$ 35.00	\$ 29,750
Gate valve and box, 04"	7	EA	\$ 370.00	\$ 2,720
Air valve	7	EA	\$ 1,000.00	\$ 7,000
Flush valve	7	EA	\$ 750.00	\$ 5,513
Metal detectable tape	36,750	LF	\$ 0.15	\$ 5,513
<b>Subtotal</b>				<b>\$ 1,090,745</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,144,950</b>
Contingency	20%		\$	228,990
Design & Constr Management	25%		\$	286,237
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 1,660,177</b>

**Table G.36**

*Alvin to each PWS*

**Alternative Name** *Purchase Water from Alvin to Sandy Meadow*  
**Alternative Number** *SM*

<b>Distance from Alternative to PWS (along pipe)</b>	7.9	miles
<b>Total PWS annual water usage</b>	5.840	MG
<b>Treated water purchase cost</b>	\$ 1.65	per 1,000 gals
<b>Number of Pump Stations Needed</b>	1	

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	5	n/a	n/a	n/a
Number of Crossings, open cut	16	n/a	n/a	n/a
PVC water line, Class 200, 04"	41,814	LF	\$ 27.00	\$ 1,128,978
Bore and encasement, 10"	1,000	LF	\$ 60.00	\$ 60,000
Open cut and encasement, 10"	800	LF	\$ 35.00	\$ 28,000
Gate valve and box, 04"	8	EA	\$ 370.00	\$ 3,094
Air valve	8	EA	\$ 1,000.00	\$ 8,000
Flush valve	8	EA	\$ 750.00	\$ 6,272
Metal detectable tape	41,814	LF	\$ 0.15	\$ 6,272
<b>Subtotal</b>				<b>\$ 1,240,616</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,294,821</b>
Contingency	20%		\$	258,964
Design & Constr Management	25%		\$	323,705
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 1,877,491</b>

**Table G.37**

**Alvin to each PWS**

**Alternative Name** *Purchase Water from Alvin to Stoneridge*  
**Alternative Number** *SR*

<b>Distance from Alternative to PWS (along pipe)</b>	10.7	miles
<b>Total PWS annual water usage</b>	3.132	MG
<b>Treated water purchase cost</b>	\$ 1.65	per 1,000 gals
<b>Number of Pump Stations Needed</b>	1	

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	10	n/a	n/a	n/a
Number of Crossings, open cut	20	n/a	n/a	n/a
PVC water line, Class 200, 04"	56,585	LF	\$ 27.00	\$ 1,527,795
Bore and encasement, 10"	2,000	LF	\$ 60.00	\$ 120,000
Open cut and encasement, 10"	1,000	LF	\$ 35.00	\$ 35,000
Gate valve and box, 04"	11	EA	\$ 370.00	\$ 4,187
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	11	EA	\$ 750.00	\$ 8,488
Metal detectable tape	56,585	LF	\$ 0.15	\$ 8,488
<b>Subtotal</b>				<b>\$ 1,714,958</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,769,163</b>
Contingency	20%		\$	353,833
Design & Constr Management	25%		\$	442,291
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 2,565,286</b>

**Table G.38**

**Alvin to each PWS**

**Alternative Name** *Purchase Water from Alvin to Grasslands*  
**Alternative Number** *Grass*

<b>Distance from Alternative to PWS (along pipe)</b>	11.0	miles
<b>Total PWS annual water usage</b>	14.235	MG
<b>Treated water purchase cost</b>	\$ 1.65	per 1,000 gals
<b>Number of Pump Stations Needed</b>	1	

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	9	n/a	n/a	n/a
Number of Crossings, open cut	20	n/a	n/a	n/a
PVC water line, Class 200, 04"	57,941	LF	\$ 27.00	\$ 1,564,407
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	1,000	LF	\$ 35.00	\$ 35,000
Gate valve and box, 04"	12	EA	\$ 370.00	\$ 4,288
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	12	EA	\$ 750.00	\$ 8,691
Metal detectable tape	57,941	LF	\$ 0.15	\$ 8,691
<b>Subtotal</b>				<b>\$ 1,740,077</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,794,282</b>
Contingency	20%		\$	358,856
Design & Constr Management	25%		\$	448,570
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 2,601,709</b>



**Table G.39**

**Alvin to each PWS**

**Alternative Name** *Purchase Water from Alvin to Oak Meadows*  
**Alternative Number** *OM*

<b>Distance from Alternative to PWS (along pipe)</b>	12.0	miles
<b>Total PWS annual water usage</b>	5.475	MG
<b>Treated water purchase cost</b>	\$ 1.65	per 1,000 gals
<b>Number of Pump Stations Needed</b>	1	

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	9	n/a	n/a	n/a
Number of Crossings, open cut	20	n/a	n/a	n/a
PVC water line, Class 200, 04"	63,175	LF	\$ 27.00	\$ 1,705,725
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	1,000	LF	\$ 35.00	\$ 35,000
Gate valve and box, 04"	13	EA	\$ 370.00	\$ 4,675
Air valve	12	EA	\$ 1,000.00	\$ 12,000
Flush valve	13	EA	\$ 750.00	\$ 9,476
Metal detectable tape	63,175	LF	\$ 0.15	\$ 9,476
<b>Subtotal</b>				<b>\$ 1,884,352</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,938,557</b>
Contingency	20%		\$	387,711
Design & Constr Management	25%		\$	484,639
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 2,810,908</b>

**Table G.40**

**Alvin to each PWS**

**Alternative Name** *Purchase Water from Alvin to Rosharon Township*  
**Alternative Number** *RT*

<b>Distance from Alternative to PWS (along pipe)</b>	12.0	miles
<b>Total PWS annual water usage</b>	6.972	MG
<b>Treated water purchase cost</b>	\$ 1.65	per 1,000 gals
<b>Number of Pump Stations Needed</b>	1	

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	10	n/a	n/a	n/a
Number of Crossings, open cut	23	n/a	n/a	n/a
PVC water line, Class 200, 04"	63,559	LF	\$ 27.00	\$ 1,716,093
Bore and encasement, 10"	2,000	LF	\$ 60.00	\$ 120,000
Open cut and encasement, 10"	1,150	LF	\$ 35.00	\$ 40,250
Gate valve and box, 04"	13	EA	\$ 370.00	\$ 4,703
Air valve	12	EA	\$ 1,000.00	\$ 12,000
Flush valve	13	EA	\$ 750.00	\$ 9,534
Metal detectable tape	63,559	LF	\$ 0.15	\$ 9,534
<b>Subtotal</b>				<b>\$ 1,912,114</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,966,319</b>
Contingency	20%		\$	393,264
Design & Constr Management	25%		\$	491,580
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 2,851,163</b>

**Table G.41**

**Angleton to each PWS  
Purchase Water from Angleton to RoshTownship  
RT**

Distance from Alternative to PWS (along pipe)	11.4 miles
Total PWS annual water usage	6.972 MG
Treated water purchase cost	\$ 1.60 per 1,000 gals
Number of Pump Stations Needed	1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	12	n/a	n/a	n/a
PVC water line, Class 200, 04"	59,971	LF	\$ 27.00	\$ 1,619,217
Bore and encasement, 10"	400	LF	\$ 60.00	\$ 24,000
Open cut and encasement, 10"	600	LF	\$ 35.00	\$ 21,000
Gate valve and box, 04"	12	EA	\$ 370.00	\$ 4,438
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	12	EA	\$ 750.00	\$ 8,996
Metal detectable tape	59,971	LF	\$ 0.15	\$ 8,996
<b>Subtotal</b>				<b>\$ 1,697,646</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,751,851</b>
Contingency	20%		\$	350,370
Design & Constr Management	25%		\$	437,963
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 2,540,184</b>

**Table G.42**

**Angleton to each PWS**  
**Purchase Water from Angleton to Oak Meadow**  
**OM**

Distance from Alternative to PWS (along pipe)	12.1 miles
Total PWS annual water usage	2,464 MG
Treated water purchase cost	\$ 1.60 per 1,000 gals
Number of Pump Stations Needed	1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	11	n/a	n/a	n/a
PVC water line, Class 200, 04"	64,123	LF	\$ 27.00	\$ 1,731,321
Bore and encasement, 10"	400	LF	\$ 60.00	\$ 24,000
Open cut and encasement, 10"	550	LF	\$ 35.00	\$ 19,250
Gate valve and box, 04"	13	EA	\$ 370.00	\$ 4,745
Air valve	12	EA	\$ 1,000.00	\$ 12,000
Flush valve	13	EA	\$ 750.00	\$ 9,618
Metal detectable tape	64,123	LF	\$ 0.15	\$ 9,618
<b>Subtotal</b>				<b>\$ 1,810,553</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,864,758</b>
Contingency	20%		\$	372,952
Design & Constr Management	25%		\$	466,190
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 2,703,899</b>

**Table G.43**

**Angleton to each PWS**

**Alternative Name** *Purchase Water from Angleton to Grasslands*  
**Alternative Number** *Grass*

Distance from Alternative to PWS (along pipe)	11.4 miles
Total PWS annual water usage	14.235 MG
Treated water purchase cost	\$ 1.60 per 1,000 gals
Number of Pump Stations Needed	1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	3	n/a	n/a	n/a
Number of Crossings, open cut	11	n/a	n/a	n/a
PVC water line, Class 200, 04"	60,025	LF	\$ 27.00	\$ 1,620,675
Bore and encasement, 10"	600	LF	\$ 60.00	\$ 36,000
Open cut and encasement, 10"	550	LF	\$ 35.00	\$ 19,250
Gate valve and box, 04"	12	EA	\$ 370.00	\$ 4,442
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	12	EA	\$ 750.00	\$ 9,004
Metal detectable tape	60,025	LF	\$ 0.15	\$ 9,004
<b>Subtotal</b>				<b>\$ 1,709,374</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,763,579</b>
Contingency	20%		\$	352,716
Design & Constr Management	25%		\$	440,895
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 2,557,190</b>

**Table G.44**

**Angleton to each PWS**

**Alternative Name** *Purchase Water from Angleton to Stoneridge*  
**Alternative Number** *SR*

<b>Distance from Alternative to PWS (along pipe)</b>	11.1 miles
<b>Total PWS annual water usage</b>	3.132 MG
<b>Treated water purchase cost</b>	\$ 1.60 per 1,000 gals
<b>Number of Pump Stations Needed</b>	1

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	4	n/a	n/a	n/a
Number of Crossings, open cut	15	n/a	n/a	n/a
PVC water line, Class 200, 04"	58,825	LF	\$ 27.00	\$ 1,588,275
Bore and encasement, 10"	800	LF	\$ 60.00	\$ 48,000
Open cut and encasement, 10"	750	LF	\$ 35.00	\$ 26,250
Gate valve and box, 04"	12	EA	\$ 370.00	\$ 4,353
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	12	EA	\$ 750.00	\$ 8,824
Metal detectable tape	58,825	LF	\$ 0.15	\$ 8,824
<b>Subtotal</b>				<b>\$ 1,695,526</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,749,731</b>
Contingency	20%		\$	349,946
Design & Constr Management	25%		\$	437,433
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 2,537,109</b>

**Table G.45**

**Angleton to each PWS**

**Alternative Name** *Purchase Water from Ang to Sandy Meadow*  
**Alternative Number** *SM*

<b>Distance from Alternative to PWS (along pipe)</b>	14.2 miles
<b>Total PWS annual water usage</b>	5.840 MG
<b>Treated water purchase cost</b>	\$ 1.60 per 1,000 gals
<b>Number of Pump Stations Needed</b>	1

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	7	n/a	n/a	n/a
Number of Crossings, open cut	15	n/a	n/a	n/a
PVC water line, Class 200, 04"	75,087	LF	\$ 27.00	\$ 2,027,349
Bore and encasement, 10"	1,400	LF	\$ 60.00	\$ 84,000
Open cut and encasement, 10"	750	LF	\$ 35.00	\$ 26,250
Gate valve and box, 04"	15	EA	\$ 370.00	\$ 5,556
Air valve	14	EA	\$ 1,000.00	\$ 14,000
Flush valve	15	EA	\$ 750.00	\$ 11,263
Metal detectable tape	75,087	LF	\$ 0.15	\$ 11,263
<b>Subtotal</b>				<b>\$ 2,179,682</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 54,205</b>
<b>Subtotal of Component Costs</b>				<b>\$ 2,233,887</b>
Contingency	20%		\$	446,777
Design & Constr Management	25%		\$	558,472
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 3,239,135</b>

**Table G.46**

**Angleton to each PWS**

**Alternative Name** *Purchase Water from Ang to Roasharon Road*  
**Alternative Number** *RR*

<b>Distance from Alternative to PWS (along pipe)</b>	14.6 miles
<b>Total PWS annual water usage</b>	5.475 MG
<b>Treated water purchase cost</b>	\$ 1.60 per 1,000 gals
<b>Number of Pump Stations Needed</b>	1

**Capital Costs**

<b>Cost Item</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<i>Pipeline Construction</i>				
Number of Crossings, bore	9	n/a	n/a	n/a
Number of Crossings, open cut	17	n/a	n/a	n/a
PVC water line, Class 200, 04"	77,073	LF	\$ 27.00	\$ 2,080,971
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	850	LF	\$ 35.00	\$ 29,750
Gate valve and box, 04"	15	EA	\$ 370.00	\$ 5,703
Air valve	15	EA	\$ 1,000.00	\$ 15,000
Flush valve	15	EA	\$ 750.00	\$ 11,561
Metal detectable tape	77,073	LF	\$ 0.15	\$ 11,561
	<b>Subtotal</b>			<b>\$ 2,262,546</b>
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
	<b>Subtotal</b>			<b>\$ 54,205</b>
	<b>Subtotal of Component Costs</b>			<b>\$ 2,316,751</b>
Contingency	20%		\$	463,350
Design & Constr Management	25%		\$	579,188
	<b>TOTAL CAPITAL COSTS</b>			<b>\$ 3,359,289</b>