


DRAFT FEASIBILITY REPORT FEASIBILITY ANALYSIS OF WATER SUPPLY FOR SMALL PUBLIC WATER SYSTEMS

WHITHARRAL WSC

PWS ID# 1100011, CCN# 12505

Prepared for:

THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



Prepared by:

THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC GEOLOGY

AND

PARSONS

Preparation of this report was financed by the Texas Commission on Environmental Quality through the Drinking Water State Revolving Fund Small Systems Assistance Program

AUGUST 2007

DRAFT FEASIBILITY REPORT

**FEASIBILITY ANALYSIS OF WATER SUPPLY
FOR SMALL PUBLIC WATER SYSTEMS**

**WHITHARRAL WSC
PWS ID# 1100011, CCN# 12505**

Prepared for:

THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Prepared by:

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC
GEOLOGY**

AND

PARSONS

*Preparation of this report was financed by the Texas Commission on Environmental
Quality through the Drinking Water State Revolving Fund Small Systems Assistance
Program*

THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF INTERIM REVIEW UNDER THE
AUTHORITY OF ERIC J. DAWSON, P.E. 79564 ON AUGUST 31, 2007. IT IS NOT TO BE USED
FOR CONSTRUCTION, BIDDING, OR PERMIT PURPOSES.

AUGUST 2007

EXECUTIVE SUMMARY

INTRODUCTION

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Infrastructure and Technology Group Inc. (Parsons), was contracted by the Texas Commission on Environmental Quality (TCEQ) to conduct a project to assist with identifying and analyzing alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

The overall goal of this project was to promote compliance using sound engineering and financial methods and data for PWSs that had recently recorded sample results exceeding maximum contaminant levels (MCL). The primary objectives of this project were to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS for future implementation.

This feasibility report provides an evaluation of water supply alternatives for the Whitharral Water Supply Corporation (WSC) PWS. Whitharral WSC PWS provides water for the City of Whitharral, Texas and is located on State Highway 385 northwest of the City of Lubbock in Lamb County, Texas. The system is operated by Lamb County Electric Cooperative, Inc. in Littlefield, Texas. The City of Whitharral anticipates little growth. The population of the city is 275 with 82 service connections and 80 active meters. Its average daily use is approximately 0.043 million gallons per day (mgd).

Fluoride has been detected in City of Wolfforth PWS between 3.7 milligrams per liter (mg/L) to 4.7 mg/L since March 1998, and the majority of measurements have exceeded the MCL of 4 mg/L. Nitrate has been detected since October 1997 with values ranging between 9.5 mg/L to 12.5 mg/L, and the majority of measurements have exceeded the MCL of 10 mg/L. Levels of fluoride and nitrate were 4.5 and 10.9 mg/L, respectively, in July 2006. Therefore, the Whitharral WSC PWS faces compliance issues under the water quality standards for fluoride and nitrate.

Basic system information for the Whitharral WSC PWS is shown in Table ES.1.

Table ES.1 Whitharral WSC PWS Basic System Information

Population served	275
Connections	82
Average daily flow rate	0.043 mgd
Peak demand flow rate	119 gallons per minute (0.172 mgd)
Water system peak capacity	0.432 mgd
Typical fluoride range	3.7 – 4.7 mg/L
Typical nitrate range	9.5 – 12.5-mg/L

1 **STUDY METHODS**

2 The methods used for this project were based on a pilot project performed in 2004 and
3 2005 by TCEQ, BEG, and Parsons. Methods for identifying and analyzing compliance
4 options were developed in the pilot project (a decision tree approach).

5 The process for developing the feasibility study used the following general steps:

- 6 • Gather data from the TCEQ and Texas Water Development Board databases, from
7 TCEQ files, and from information maintained by the PWS;
- 8 • Conduct financial, managerial, and technical (FMT) evaluations of the PWS;
- 9 • Perform a geologic and hydrogeologic assessment of the study area;
- 10 • Develop treatment and non-treatment compliance alternatives which, in general,
11 consist of the following possible options:
 - 12 • Connect to neighboring PWSs via new pipeline or by pumping water from a newly
13 installed well or an available surface water supply within the jurisdiction of the
14 neighboring PWS;
 - 15 • Install new wells within the vicinity of the PWS into other aquifers with confirmed
16 water quality standards meeting the MCLs;
 - 17 • Install a new intake system within the vicinity of the PWS to obtain water from a
18 surface water supply with confirmed water quality standards meeting the MCLs;
 - 19 • Treat the existing non-compliant water supply by various methods depending on the
20 type of contaminant; and
 - 21 • Deliver potable water by way of a bottled water program or a treated water dispenser
22 as an interim measure only.
- 23 • Assess each of the potential alternatives with respect to economic and non-economic
24 criteria;
- 25 • Prepare a feasibility report and present the results to the PWS.

26 This basic approach is summarized in Figure ES-1.

27 **HYDROGEOLOGICAL ANALYSIS**

28 The major aquifer in the study area is the High Plains or Ogallala aquifer. The main
29 geologic unit that makes up the High Plains aquifer is the Ogallala Formation, which consists
30 of coarse fluvial sandstones and conglomerates. The Whitharral PWS obtains groundwater
31 from wells designated as being within the Ogallala aquifer at depths ranging from 127 to
32 150 feet.

33 There are no obvious groundwater sources in the vicinity (10 km) of the PWS that can
34 serve as alternative sources. Because no wells in the vicinity of the PWS wells show

1 acceptable water quality, it may be necessary to look for new supplies in or near wells farther
2 from the PWS. Acceptable groundwater quality increases to the northeast, coinciding with a
3 regional change in water quality in the Ogallala aquifer. This area is a significant distance
4 away.

5 In addition, regional analyses show that water quality increases with depth. This
6 suggests that tapping deeper water by increasing the depth of one or more wells and screening
7 only the deeper portion may decrease concentrations of these constituents in drinking water.
8 However, there are not enough local data available to evaluate this option.

9 **COMPLIANCE ALTERNATIVES**

10 Overall, the system has a good level of FMT capacity. The system has some areas that
11 need improvement to be able to address future compliance issues; however, the system does
12 have several positive aspects, including knowledgeable and dedicated staff, a financial
13 accounting and adequate revenues, source water protection plan. Areas of concern for the
14 system included lack of long-term capital improvement planning, and lack of compliance with
15 water quality standards.


16 There are several PWSs within 15 miles of Whitharral WSC. Many of these nearby
17 systems also have water quality problems, but the Cities of Lubbock, Levelland, and Anton
18 have good quality water. Separate feasibility alternatives were developed based on obtaining
19 water from these three cities. The City of Lubbock uses a mix of surface water and
20 groundwater as a source of water, whereas the City of Anton uses groundwater from six wells
21 as a source of water. The City of Levelland receives water through an agreement with the
22 Canadian River Municipal Water Authority, which obtains treated water from the City of
23 Lubbock water treatment plant. Purchase treated water alternatives were developed for
24 constructing a pipeline from the Cities of Lubbock, Levelland, and Anton to Whitharral WSC.
25 If compliant groundwater can be found, developing a new well close to the Whitharral WSC
26 would likely to be the best and lowest cost solution since the PWS already possesses the
27 technical and managerial expertise needed to implement this option. The cost of new well
28 alternatives quickly increases with pipeline length, making proximity of the alternate source a
29 key concern. Developing a new compliant well or obtaining water from a neighboring
30 compliant PWS has the advantage of providing compliant water to all taps in the system.

31 Reverse osmosis and electro dialysis reversal centralized treatment alternatives for
32 fluoride and nitrate removal have been developed and were considered for this report. Point-
33 of-use (POU) and point-of-entry treatment alternatives were also considered. Temporary
34 solutions such as providing bottled water or providing a centralized dispenser for treated or
35 trucked-in water, were also considered as alternatives.

36 Central treatment can be cost-competitive with the alternative of new nearby wells, but
37 would require significant institutional changes to manage and operate. Like obtaining an
38 alternate compliant water source, central treatment would provide compliant water to all
39 water taps.

1

Figure ES-1 Summary of Project Methods



1 POU treatment can be cost competitive, but does not supply compliant water to all taps.
2 Additionally, significant efforts would be required for maintenance and monitoring of the
3 POU treatment units.

4 Providing compliant water through a central dispenser is significantly less expensive than
5 providing bottled water to 100 percent of the population, but a significant effort is required
6 for clients to fill their containers at the central dispenser.

7 **FINANCIAL ANALYSIS**

8 Financial analysis of the Whitharral WSC PWS indicated that current water rates are
9 adequately funding operations. The current annual average water bill of \$700 represents
10 approximately 2.3 percent of the median household income (MHI). Table ES.2 provides a
11 summary of the financial impact of implementing selected compliance alternatives, including
12 the rate increase necessary to meet current operating expenses. The alternatives were selected
13 to highlight results for the best alternatives from each different type or category.

14 Some of the compliance alternatives offer potential for shared or regional solutions. A
15 group of PWSs could work together to implement alternatives for developing a new
16 groundwater source or expanding an existing source, obtaining compliant water from a large
17 regional provider, or for central treatment. Sharing the cost for implementation of these
18 alternatives could reduce the cost on a per user basis. Additionally, merging PWSs or
19 management of several PWSs by a single entity offers the potential for reduction in
20 administrative costs.

21 **Table ES.2 Selected Financial Analysis Results**

Alternative	Funding Option	Average Annual Water Bill	Percent of MHI
Current	NA	\$700	2.2
To meet current expenses	NA	\$458	1.5
Purchase Water from Levelland	100% Grant	\$896	2.9
	Loan/Bond	\$4,563	14.9
Central treatment – Electro-dialysis Reversal	100% Grant	\$1,251	4.1
	Loan/Bond	\$2,065	6.8
Point-of-use	100% Grant	\$1,385	4.5
	Loan/Bond	\$1,479	4.8
Public dispenser	100% Grant	\$911	3.0
	Loan/Bond	\$928	3.0

22

TABLE OF CONTENTS

1		
2	EXECUTIVE SUMMARY	ES-1
3	LIST OF TABLES.....	iv
4	LIST OF FIGURES.....	v
5	ACRONYMS AND ABBREVIATIONS	vi
6	SECTION 1 INTRODUCTION	1-1
7	1.1 Public Health and Compliance with MCLs.....	1-4
8	1.2 Methods	1-4
9	1.3 Regulatory Perspective.....	1-5
10	1.4 Abatement Options.....	1-5
11	1.4.1 Existing Public Water Supply Systems	1-5
12	1.4.1.1 Quantity	1-6
13	1.4.1.2 Quality	1-6
14	1.4.2 Potential for New Groundwater Sources.....	1-7
15	1.4.2.1 Existing Non-Public Supply Wells.....	1-7
16	1.4.2.2 Develop New Wells.....	1-8
17	1.4.3 Potential for Surface Water Sources.....	1-8
18	1.4.3.1 Existing Surface Water Sources	1-8
19	1.4.3.2 New Surface Water Sources.....	1-9
20	1.4.4 Identification of Treatment Technologies	1-9
21	1.4.4.1 Treatment Technologies for Fluoride.....	1-10
22	1.4.4.2 Treatment Technologies for Nitrate	1-10
23	1.4.5 Treatment Technologies Description	1-10
24	1.4.5.1 Reverse Osmosis	1-10
25	1.4.5.2 Electrodialysis Reversal	1-12
26	1.4.6 Point-of-Entry and Point-of-Use Treatment Systems.....	1-13
27	1.4.7 Water Delivery or Central Drinking Water Dispensers	1-15
28	SECTION 2 EVALUATION METHODS.....	2-1
29	2.1 Decision Tree.....	2-1
30	2.2 Data Sources and Data Collection.....	2-1
31	2.2.1 Data Search.....	2-1
32	2.2.1.1 Water Supply Systems.....	2-1
33	2.2.1.2 Existing Wells	2-6
34	2.2.1.3 Surface Water Sources	2-6

1	2.2.1.4	Groundwater Availability Model	2-6
2	2.2.1.5	Water Availability Model.....	2-6
3	2.2.1.6	Financial Data.....	2-7
4	2.2.1.7	Demographic Data.....	2-7
5	2.2.2	PWS Interviews	2-7
6	2.2.2.1	PWS Capacity Assessment Process.....	2-7
7	2.2.2.2	Interview Process.....	2-9
8	2.3	Alternative Development and Analysis.....	2-10
9	2.3.1	Existing PWS.....	2-10
10	2.3.2	New Groundwater Source	2-11
11	2.3.3	New Surface Water Source	2-11
12	2.3.4	Treatment.....	2-11
13	2.4	Cost of Service and Funding Analysis	2-12
14	2.4.1	Financial Feasibility	2-12
15	2.4.2	Median Household Income.....	2-12
16	2.4.3	Annual Average Water Bill.....	2-13
17	2.4.4	Financial Plan Development.....	2-13
18	2.4.5	Financial Plan Results	2-14
19	2.4.5.1	Funding Options	2-14
20	2.4.5.2	General Assumptions Embodied in Financial Plan Results	2-15
21	2.4.5.3	Interpretation of Financial Plan Results	2-15
22	2.4.5.4	Potential Funding Sources.....	2-16
23	SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS		3-1
24	3.1	Regional Hydrogeology.....	3-1
25	3.2.	Contaminants of Concern in the Study Area.....	3-3
26	3.3	Regional Geology.....	3-12
27	3.4	Detailed Assessment.....	3-13
28	3.4.1	Summary of Alternative Groundwater Sources	3-16
29	SECTION 4 ANALYSIS OF THE WHITHARRAL WSC PWS.....		4-1
30	4.1	Description of Existing System	4-1
31	4.1.1	Existing System.....	4-1
32	4.1.2	Capacity Assessment.....	4-3
33	4.1.2.1	General Structure.....	4-4
34	4.1.2.2	General Assessment of Capacity	4-4
35	4.1.2.3	Positive Aspects of Capacity	4-5

1	4.1.2.4	Capacity Deficiencies	4-5
2	4.1.2.5	Potential Capacity Concerns	4-6
3	4.2	Alternative Water Source Development	4-6
4	4.2.1	Identification of Alternative Existing Public Water Supply Sources	4-6
5	4.2.1.1	City of Lubbock Water System	4-8
6	4.2.1.2	Canadian River Municipal Water Authority	4-9
7	4.2.1.3	City of Anton Water System	4-10
8	4.2.1.4	City of Levelland	4-10
9	4.2.2	Potential for New Groundwater Sources	4-10
10	4.2.2.1	Installing New Compliant Wells	4-10
11	4.2.2.2	Results of Groundwater Availability Modeling	4-11
12	4.2.3	Potential for New Surface Water Sources	4-12
13	4.2.4	Options for Detailed Consideration	4-12
14	4.3	Treatment Options	4-13
15	4.3.1	Centralized Treatment Systems	4-13
16	4.3.2	Point-of-Use Systems	4-13
17	4.3.3	Point-of-Entry Systems	4-13
18	4.4	Bottled Water	4-13
19	4.5	Alternative Development and Analysis	4-13
20	4.5.1	Alternative WR-1: Purchase Water from the City of Lubbock	4-14
21	4.5.2	Alternative WR-2: Purchase Water from CRMWA Water Line from Lubbock to	
22		Levelland	4-15
23	4.5.3	Alternative WR-3: Purchase Water from the City of Anton	4-16
24	4.5.4	Alternative WR-4: New Well at 10 Miles	4-17
25	4.5.5	Alternative WR-5: New Well at 5 Miles	4-18
26	4.5.6	Alternative WR-6: New Well at 1 Mile	4-18
27	4.5.7	Alternative WR-7: Central RO Treatment	4-19
28	4.5.8	Alternative WR-8: Central EDR Treatment	4-20
29	4.5.9	Alternative WR-9: Point-of-Use Treatment	4-20
30	4.5.10	Alternative WR-10: Point-of-Entry Treatment	4-22
31	4.5.11	Alternative WR-11: Public Dispenser for Treated Drinking Water	4-23
32	4.5.12	Alternative WR-12: 100 Percent Bottled Water Delivery	4-24
33	4.5.13	Alternative WR-13: Public Dispenser for Trucked Drinking Water	4-24
34	4.5.14	Summary of Alternatives	4-25
35	4.6	Major Regional Solutions	4-25

1	4.7	Cost of Service and Funding Analysis	4-28
2	4.7.1	Financial Plan Development.....	4-28
3	4.7.2	Current Financial Condition.....	4-28
4	4.7.2.1	Cash Flow Needs.....	4-28
5	4.7.2.2	Ratio Analysis	4-29
6	4.7.3	Financial Plan Results	4-29
7	SECTION 5	REFERENCES	5-1
8	APPENDICES		
9	Appendix A	PWS Interview Forms	
10	Appendix B	Cost Basis	
11	Appendix C	Compliance Alternative Conceptual Cost Estimates	
12	Appendix D	Example Financial Models	
13	Appendix E	Regional Solutions	
14	Appendix F	General Contaminant Geochemistry	
15			
16		LIST OF TABLES	
17	Table ES.1	Whitharral WSC PWS Basic System Information	ES-1
18	Table ES.2	Selected Financial Analysis Results.....	ES-5
19	Table 3.1	Summary of Arsenic Concentrations by Aquifer	3-4
20	Table 3.2	Summary of Nitrate Concentrations by Aquifer	3-5
21	Table 3.3	Summary of Fluoride Concentrations by Aquifer	3-8
22	Table 3.4	Summary of Selenium Concentrations by Aquifer	3-9
23	Table 3.5	Fluoride and Nitrate Concentrations in the Whitharral WSC PWS	3-13
24	Table 3.6	Characteristics of Wells Near the Whitharral WSC PWS Wells that have Acceptable Levels of Fluoride	3-16
25			
26	Table 3.7	Most Recent Concentrations in Potential Alternative Sources	3-16
27	Table 4.1	Selected Public Water Systems within 20 Miles of the Whitharral WSC PWS.....	4-7
28			
29	Table 4.2	Public Water Systems Within the Vicinity of the Whitharral WSC PWS Selected for Further Evaluation.....	4-7
30			
31	Table 4.3	Summary of Compliance Alternatives for Whitharral WSC PWS.....	4-26
32	Table 4.4	Financial Impact on Households for Whitharral WSC PWS	4-31
33			

LIST OF FIGURES

1		
2	Figure ES-1	Summary of Project Methods ES-4
3	Figure 1.1	Whitharral WSC Location Map..... 1-2
4	Figure 1.2	Groundwater Districts, Conservation Areas, Municipal Authorities, 5 and Planning Groups 1-3
6	Figure 2.1	Decision Tree – Tree 1 Existing Facility Analysis..... 2-2
7	Figure 2.2	Decision Tree – Tree 2 Develop Treatment Alternatives..... 2-3
8	Figure 2.3	Decision Tree – Tree 3 Preliminary Analysis 2-4
9	Figure 2.4	Decision Tree – Tree 4 Financial and Managerial 2-5
10	Figure 3.1	Nine Counties Study Area and PWS Well Locations 3-1
11	Figure 3.2	Major and Minor Aquifers in the Study Area 3-2
12	Figure 3.3	Water Quality Zones in the Study Area 3-2
13	Figure 3.4	Arsenic Concentrations in the Ogallala Aquifer Within the Study Area 3-3
14	Figure 3.5	Stratification of Arsenic Concentrations with Depth in 15 the Ogallala-South..... 3-4
16	Figure 3.6	Nitrate Concentrations in the Ogallala Aquifer within the Study Area 3-5
17	Figure 3.7	Stratification of Nitrate-N Concentrations with Depth in 18 the Ogallala-South..... 3-6
19	Figure 3.8	Relationship between Nitrate Concentrations and Cultivated Land 3-7
20	Figure 3.9	Spatial Distribution of Fluoride Concentrations in the Study Area 3-7
21	Figure 3.10	Stratification of Fluoride Concentrations with Depth in the 22 Ogallala-South Area..... 3-8
23	Figure 3.11	Spatial Distribution of Selenium Concentrations in the Study Area..... 3-9
24	Figure 3.12	Stratification of Selenium Concentrations with Depth in 25 the Ogallala-South Area 3-10
26	Figure 3.13	Spatial Distribution of Uranium Concentrations in the Study Area..... 3-11
27	Figure 3.14	Stratification of Uranium Concentrations with Depth in 28 the Ogallala-South Area 3-11
29	Figure 3.15	Fluoride Concentrations Within 5- and 10-Km Buffers of 30 the Whitharral WSC PWS Wells..... 3-14
31	Figure 3.16	Nitrate Concentrations Within 5- and 10-Km Buffers of 32 the Whitharral WSC PWS Wells..... 3-15
33	Figure 4.1	Whitharral WSC Pipeline Alternatives 4-2
34	Figure 4.2	Alternative Cost Summary: Whitharral WSC PWS 4-32
35		

1

ACRONYMS AND ABBREVIATIONS

°F	degrees Fahrenheit
µg/L	micrograms per liter
BAT	best available technology
BEG	Bureau of Economic Geology
CA	chemical analysis
CCN	Certificate of Convenience and Necessity
CFR	Code of Federal Regulations
CRMWA	Canadian River Municipal Water Authority
EDR	electrodialysis reversal
FMT	financial, managerial, and technical
GAM	groundwater availability model
gpd	gallons per day
gpm	gallons per minute
IX	ion exchange
LCEC	Lamb County Electric Cooperative, Inc.
MCL	maximum contaminant level
MF	microfiltration
mg/L	milligram per liter
mgd	million gallons per day
MHI	median household income
NF	nanofiltration
NMEFC	New Mexico Environmental Financial Center
NURE	National Uranium Resource Evaluation
O&M	operation and maintenance
Parsons	Parsons Infrastructure and Technology, Inc.
POE	point-of-entry
POU	point-of-use
psi	pounds per square inch
PWS	public water system
RO	reverse osmosis
SDWA	Safe Drinking Water Act
SRF	state revolving fund
TCEQ	Texas Commission on Environmental Quality
TDS	total dissolved solids
TFC	thin film composite
TWDB	Texas Water Development Board
USEPA	United States Environmental Protection Agency
WAM	water availability model
WSC	water supply corporation

2


SECTION 1 INTRODUCTION

3 The University of Texas Bureau of Economic Geology (BEG) and its subcontractor,
4 Parsons Infrastructure and Technology Group Inc. (Parsons), have been contracted by the
5 Texas Commission on Environmental Quality (TCEQ) to assist with identifying and
6 analyzing compliance alternatives for use by Public Water Systems (PWS) to meet and
7 maintain Texas drinking water standards.



8 The overall goal of this project is to promote compliance using sound engineering and
9 financial methods and data from PWSs that have recently had sample results that exceed
10 maximum contaminant levels (MCL). The primary objectives of this project are to provide
11 feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply
12 compliance options, and to suggest a list of compliance alternatives that may be further
13 investigated by the subject PWS with regard to future implementation. The feasibility studies
14 identify a range of potential compliance alternatives and present basic data that can be used
15 for evaluating feasibility. The compliance alternatives addressed include a description of
16 what would be required for implementation, conceptual cost estimates for implementation,
17 and non-cost factors that could be used to differentiate between alternatives. The cost
18 estimates are intended for comparing compliance alternatives and to give a preliminary
19 indication of potential impacts on water rates resulting from implementation.

20 It is anticipated that the PWS will review the compliance alternatives in this report to
21 determine if there are promising alternatives, and then select the most attractive alternative(s)
22 for more detailed evaluation and possible subsequent implementation. This report contains a
23 decision tree approach that guided the efforts for this project and also contains steps to guide
24 a PWS through the subsequent evaluation, selection, and implementation of a compliance
25 alternative.

26 This feasibility report provides an evaluation of water supply compliance options for the
27 Whitharral WSC Water System, PWS ID# 1100011, Certificate of Convenience and
28 Necessity (CCN) #12505, located in Hockley County. Recent sample results from the
29 Whitharral WSC water system exceeded the MCL for fluoride of 4.0 milligrams per liter
30 (mg/L) and the MCL for nitrate of 10 milligrams per liter (mg/L) (USEPA 2007a;
31 TCEQ 2004). The location of the Whitharral WSC Water System is shown on Figure 1.1.
32 Various water supply and planning jurisdictions are shown on Figure 1.2. These water supply
33 and planning jurisdictions are used in the evaluation of alternate water supplies that may be
34 available in the area.




Lamb	Hale	Floyd
Hooker	Lubbock	Crosby
Terry	Lynn	Garza





- Legend**
- Study System
 - PWS's
 - ▲ Cities
 - City Limits
 - Counties
 - Interstate
 - Highway
 - Major Road
 - Minor Road

Figure 1.1
WHITHARRAL WATER SUPPLY CORP
Location Map



Lamb	Hale	Floyd
Howe	Lubbock	Crosby
Terry	Lynn	Garza



Legend

- Study System
- Interstate
- Highway
- Cities
- Major Road
- Garza County UFWCD
- City Limits
- Minor Road
- High Plains UWCDC No. 1
- Mesa UWCDC
- Counties
- South Plains UWCDC

Figure 1.2

WHITHARRAL WATER SUPPLY CORP
Groundwater Conservation Districts

1.1 PUBLIC HEALTH AND COMPLIANCE WITH MCLS

The goal of this project is to promote compliance for PWSs that supply drinking water exceeding regulatory MCLs. This project only addresses those contaminants and does not address any other violations that may exist for a PWS. As mentioned above, the Whitharral WSC water system had recent sample results exceeding the MCL for fluoride and nitrate. Health concerns related to drinking water above MCLs for these two chemicals are briefly described below.

In general, contaminant(s) in drinking water above the MCL(s) can have both short-term (acute) and long-term or lifetime (chronic) effects. Short-term effects of nitrate in drinking water above the MCL have caused serious illness and sometimes death. Drinking water health publications conclude that the most susceptible population to adverse nitrate health effects includes infants less than 6 months of age; women who are pregnant or nursing; and individuals with enzyme deficiencies or a lack of free hydrochloric acid in the stomach. The serious illness in infants is due to the conversion of nitrate to nitrite by the body, which can interfere with the oxygen-carrying capacity of the child's blood. Symptoms include shortness of breath and blue-baby syndrome. Lifetime exposure to nitrates at levels above the MCL has the potential to cause the following effects: diuresis, increased starchy deposits, and hemorrhaging of the spleen (USEPA 2007b).

Potential health effects from the ingestion of water with levels of fluoride above the MCL (4 mg/L) over many years include bone disease, including pain and tenderness of the bones. Additionally, the U.S. Environmental Protection Agency (USEPA) has set a secondary fluoride standard of 2 mg/L to protect against dental fluorosis, which in its moderate or severe forms may result in a brown staining and/or pitting of the permanent teeth in children under 9 years (USEPA 2007c).

1.2 METHODS

The methods for this project follow those of a pilot project performed by TCEQ, BEG, and Parsons. The pilot project evaluated water supply alternatives for PWSs that supply drinking water with fluoride and nitrate concentrations above USEPA and Texas drinking water standards. Three PWSs were evaluated in the pilot project to develop the methods (*i.e.*, decision tree approach) for analyzing options for provision of compliant drinking water. This project is performed using the decision tree approach that was developed for the pilot project, and which was also used for subsequent projects in 2005 and 2006.

Other tasks of the feasibility study are as follows:

- Identifying available data sources;
- Gathering and compiling data;
- Conducting financial, managerial, and technical (FMT) evaluations of the selected PWSs;
- Performing a geologic and hydrogeologic assessment of the area;

- 1 • Developing treatment and non-treatment compliance alternatives;
- 2 • Assessing potential alternatives with respect to economic and non-economic criteria;
- 3 • Preparing a feasibility report; and
- 4 • Suggesting refinements to the approach for future studies.

5 The remainder of Section 1 of this report addresses the regulatory background, and
6 provides a summary of fluoride and nitrate abatement options. Section 2 describes the
7 methods used to develop and assess compliance alternatives. The groundwater sources of
8 fluoride and nitrate are addressed in Section 3. Findings for the Whitharral WSC PWS, along
9 with compliance alternatives development and evaluation, can be found in Section 4.
10 Section 5 references the sources used in this report.

11 **1.3 REGULATORY PERSPECTIVE**

12 The Utilities & Districts and Public Drinking Water Sections of the TCEQ Water Supply
13 Division are responsible for implementing requirements of the Federal Safe Drinking Water
14 Act (SDWA) which include oversight of PWSs and water utilities. These responsibilities
15 include:

- 16 • Monitoring public drinking water quality;
- 17 • Processing enforcement referrals for MCL violators;
- 18 • Tracking and analyzing compliance options for MCL violators;
- 19 • Providing FMT assessment and assistance to PWSs;
- 20 • Participating in the Drinking Water State Revolving Fund (SRF) program to assist
21 PWSs in achieving regulatory compliance; and
- 22 • Setting rates for privately-owned water utilities.

23 This project was conducted to assist in achieving these responsibilities.

24 **1.4 ABATEMENT OPTIONS**

25 When a PWS exceeds a regulatory MCL, the PWS must take action to correct the
26 violation. The MCL exceedances at the Whitharral WSC PWS involve fluoride and nitrate.
27 The following subsections explore alternatives considered as potential options for
28 obtaining/providing compliant drinking water.

29 **1.4.1 Existing Public Water Supply Systems**

30 A common approach to achieving compliance is for the PWS to make arrangements with
31 a neighboring PWS for water supply. For this arrangement to work, the PWS from which
32 water is being purchased (supplier PWS) must have water in sufficient quantity and quality,
33 the political will must exist, and it must be economically feasible.

1 1.4.1.1 Quantity

2 For purposes of this report, quantity refers to water volume, flow rate, and pressure.
3 Before approaching a potential supplier PWS, the non-compliant PWS should determine its
4 water demand on the basis of average day and maximum day. Peak instantaneous demands
5 can be met through proper sizing of storage facilities. Further, the potential for obtaining the
6 appropriate quantity of water to blend to achieve compliance should be considered. The
7 concept of blending involves combining water with low levels of contaminants with non-
8 compliant water in sufficient quantity that the resulting blended water is compliant. The exact
9 blend ratio would depend on the quality of the water a potential supplier PWS can provide,
10 and would likely vary over time. If high quality water is purchased, produced or otherwise
11 obtained, blending can reduce the amount of high quality water required. Implementation of
12 blending will require a control system to ensure the blended water is compliant.

13 If the supplier PWS does not have sufficient quantity, the non-compliant community
14 could pay for the facilities necessary to increase the quantity to the extent necessary to supply
15 the needs of the non-compliant PWS. Potential improvements might include, but are not
16 limited to:

- 17 • Additional wells;
- 18 • Developing a new surface water supply,
- 19 • Additional or larger-diameter piping;
- 20 • Increasing water treatment plant capacity
- 21 • Additional storage tank volume;
- 22 • Reduction of system losses,
- 23 • Higher-pressure pumps; or
- 24 • Upsized, or additional, disinfection equipment.

25 In addition to the necessary improvements, a transmission pipeline would need to be
26 constructed to tie the two PWSs together. The pipeline must tie-in at a point in the supplier
27 PWS where all the upstream pipes and appurtenances are of sufficient capacity to handle the
28 new demand. In the non-compliant PWS, the pipeline must tie in at a point where no down
29 stream bottlenecks are present. If blending is the selected method of operation, the tie-in
30 point must be at the proper point of the existing non-compliant PWS to ensure that all the
31 water in the system is blended to achieve regulatory compliance.

32 1.4.1.2 Quality

33 If a potential supplier PWS obtains its water from the same aquifer (or same portion of
34 the aquifer) as the non-compliant PWS, the quality of water may not be significantly better.
35 However, water quality can vary significantly due to well location, even within the same
36 aquifer. If localized areas with good water quality cannot be identified, the non-compliant
37 PWS would need to find a potential supplier PWS that obtains its water from a different

1 aquifer or from a surface water source. Additionally, a potential supplier PWS may treat non-
2 compliant raw water to an acceptable level.

3 Surface water sources may offer a potential higher-quality source. Since there are
4 significant treatment requirements, utilization of surface water for drinking water is typically
5 most feasible for larger local or regional authorities or other entities that may provide water to
6 several PWSs. Where PWSs that obtain surface water are neighbors, the non-compliant PWS
7 may need to deal with those systems as well as with the water authorities that supply the
8 surface water.

9 **1.4.2 Potential for New Groundwater Sources**

10 **1.4.2.1 Existing Non-Public Supply Wells**

11 Often there are wells not associated with PWSs that are located in the vicinity of the non-
12 compliant PWS. The current use of these wells may be for irrigation, industrial purposes,
13 domestic supply, stock watering, and other purposes. The process for investigating existing
14 wells is as follows:

- 15 • Existing data sources (see below) are used to identify wells in the areas that have
16 satisfactory quality. For the Whitharral WSC PWS, the following standards could be
17 used in a rough screening to identify compliant groundwater in surrounding systems:
 - 18 ○ Nitrate (measured as nitrogen) concentrations less than 8-mg/L (below the
19 MCL of 10 mg/L);
 - 20 ○ Fluoride concentration less than 2.0 mg/L (below the Secondary MCL of
21 2 mg/L);
 - 22 ○ Arsenic concentration less than 0.008 mg/L (below the MCL of 0.01 mg/L);
 - 23 ○ Uranium concentration less than 24 µg/L (below the MCL of 30 µg/L; and
 - 24 ○ Selenium concentration less than 0.04 mg/L (below the MCL of 0.05 mg/L).
- 25 • The recorded well information are reviewed to eliminate those wells that appear to be
26 unsuitable for the application. Often, the “Remarks” column in the Texas Water
27 Development Board (TWDB) hard-copy database provides helpful information. Wells
28 eliminated from consideration generally include domestic and stock wells, dug wells,
29 test holes, observation wells, seeps and springs, destroyed wells, wells used by other
30 communities, *etc*;
- 31 • Wells of sufficient size are identified. Some may be used for industrial or irrigation
32 purposes. Often the TWDB database will include well yields, which may indicate the
33 likelihood that a particular well is a satisfactory source;
- 34 • At this point in the process, the local groundwater control district (if one exists)
35 should be contacted to obtain information about pumping restrictions. Also,
36 preliminary cost estimates should be made to establish the feasibility of pursuing
37 further well development options;

- 1 • If particular wells appear to be acceptable, the owner(s) should be contacted to
2 ascertain their willingness to work with the PWS. Once the owner agrees to
3 participate in the program, questions should be asked about the wells. Many owners
4 have more than one well, and would probably be the best source of information
5 regarding the latest test dates, who tested the water, flow rates, and other well
6 characteristics;
- 7 • After collecting as much information as possible from cooperative owners, the PWS
8 would then narrow the selection of wells and sample and analyze them for quality.
9 Wells with good quality would then be potential candidates for test pumping. In some
10 cases, a particular well may need to be refurbished before test pumping. Information
11 obtained from test pumping would then be used in combination with information
12 about the general characteristics of the aquifer to determine whether a well at this
13 location would be suitable as a supply source;
- 14 • It is recommended that new wells be installed instead of using existing wells to ensure
15 the well characteristics are known and the well meets construction standards; and
- 16 • Permit(s) would then be obtained from the groundwater control district or other
17 regulatory authority, and an agreement with the owner (purchase or lease, access
18 easements, *etc.*) would then be negotiated.

19 **1.4.2.2 Develop New Wells**

20 If no existing wells are available for development, the PWS or group of PWSs has an
21 option of developing new wells. Records of existing wells, along with other hydrogeologic
22 information and modern geophysical techniques, should be used to identify potential locations
23 for new wells. In some areas, the TWDB’s Groundwater Availability Model (GAM) may be
24 applied to indicate potential sources. Once a general area has been identified, land owners
25 and regulatory agencies should be contacted to determine an exact location for a new well or
26 well field. Pump tests and water quality tests would be required to determine if a new well
27 will produce an adequate quantity of good quality water. Permits from the local groundwater
28 control district or other regulatory authority could also be required for a new well.

29 **1.4.3 Potential for Surface Water Sources**

30 Water rights law dominates the acquisition of water from surface water sources. For a
31 PWS, 100 percent availability of water is required, except where a back-up source is
32 available. For PWSs with an existing water source, although it may be non-compliant
33 because of elevated concentrations of one or more parameters, water rights may not need to
34 be 100 percent available.

35 **1.4.3.1 Existing Surface Water Sources**

36 “Existing surface water sources” of water refers to municipal water authorities and cities
37 that obtain water from surface water sources. The process of obtaining water from such a
38 source is generally less time consuming and less costly than the process of developing a new

1 source; therefore, it should be a primary course of investigation. An existing source would be
2 limited by its water rights, the safe yield of a reservoir or river, or by its water treatment or
3 water conveyance capability. The source must be able to meet the current demand and honor
4 contracts with communities it currently supplies. In many cases, the contract amounts reflect
5 projected future water demand based on population or industrial growth.

6 A non-compliant PWS would look for a source with sufficient spare capacity. Where no
7 such capacity exists, the non-compliant PWS could offer to fund the improvements necessary
8 to obtain the capacity. This approach would work only where the safe yield could be
9 increased (perhaps by enlarging a reservoir) or where treatment capacity could be increased.
10 In some instances water rights, where they are available, could possibly be purchased.

11 In addition to securing the water supply from an existing source, the non-compliant PWS
12 would need to arrange for transmission of the water to the PWS. In some cases, that could
13 require negotiations with, contracts with, and payments to an intermediate PWS (an
14 intermediate PWS is one where the infrastructure is used to transmit water from a “supplier”
15 PWS to a “supplied” PWS, but does not provide any additional treatment to the supplied
16 water). The non-compliant PWS could be faced with having to fund improvements to the
17 intermediate PWS in addition to constructing its own necessary transmission facilities.

18 **1.4.3.2 New Surface Water Sources**

19 Communication with the TCEQ and relevant planning groups from the beginning is
20 essential in the process of obtaining a new surface water source. Preliminary assessment of
21 the potential for acquiring new rights may be based on surface water availability maps located
22 on the TWDB website. Where water rights appear to be available, the following activities
23 need to occur:

- 24 • Discussions with TCEQ to indicate the likelihood of obtaining those rights. The
25 TCEQ may use the Water Availability Model (WAM) to assist in the determination.
- 26 • Discussions with land owners to indicate potential treatment plant locations.
- 27 • Coordination with US Army Corps of Engineers and local river authorities.
- 28 • Preliminary engineering design to determine the feasibility, costs, and environmental
29 issues of a new treatment plant.

30 Should these discussions indicate that a new surface water source is the best option, the
31 community would proceed with more intensive planning (initially obtaining funding),
32 permitting, land acquisition, and detailed designs.

33 **1.4.4 Identification of Treatment Technologies**

34 Various treatment technologies were also investigated as compliance alternatives for
35 treatment of fluoride and nitrate to regulatory levels (*i.e.*, MCLs). Numerous options have
36 been identified by the USEPA as best available technologies (BAT) for non-compliant

1 constituents. Identification and descriptions of the various BATs are provided in the
2 following sections.

3 **1.4.4.1 Treatment Technologies for Fluoride**

4 Fluoride is a soluble anion and is not easily removed by particle filtration. The secondary
5 MCL for fluoride is 2 mg/L. The USEPA BATs for fluoride removal include activated
6 alumina adsorption and reverse osmosis. Other treatment technologies that can potentially
7 remove fluoride from water include lime softening (modified), alum coagulation,
8 electro dialysis (EDR) and anion exchange.

9 **1.4.4.2 Treatment Technologies for Nitrate**

10 The MCL for nitrate (as nitrogen) was set at 10 mg/L by the USEPA on
11 January 30, 1992, as part of the Phase II Rules, and became effective on July 30, 1992
12 (USEPA 2007b). This MCL applies to all community water systems, regardless of size.

13 BATs identified by USEPA for removal of nitrates include:

- 14 • Reverse Osmosis (RO);
- 15 • Ion Exchange (IX); and
- 16 • EDR.

17 **1.4.5 Treatment Technologies Description**

18 Reverse Osmosis and EDR are identified by USEPA as BATs for removal of both
19 fluoride and nitrate. RO is also a viable option for POE and POU systems. A description of
20 these technologies follows.

21 **1.4.5.1 Reverse Osmosis**

22 Process. RO is a physical process in which contaminants are removed by applying
23 pressure on the feed water to force it through a semi-permeable membrane. RO membranes
24 reject ions based on size and electrical charge. The raw water is typically called feed; the
25 product water is called permeate; and the concentrated reject is called concentrate. Common
26 RO membrane materials include asymmetric cellulose acetate (CA) or polyamide thin film
27 composite (TFC). The TFC membrane operates at much lower pressure and can achieve
28 higher salt rejection than the CA membranes but is less chlorine resistant. Common
29 membrane construction includes spiral wound or hollow fine fiber. Each material and
30 construction method has specific benefits and limitations depending on the raw water
31 characteristics and pre-treatment. Spiral wound has been the dominant media type in typical
32 RO systems. A newer, lower pressure type membrane which is similar in operation to spiral
33 wound RO, is nanofiltration (NF) which has higher rejection for divalent ions than mono-
34 valent ions. NF is sometimes used instead of spiral wound RO for treating water with high
35 hardness and sulfate concentrations. A typical RO installation includes a high pressure feed
36 pump; parallel first and second stage membrane elements (in pressure vessels); and valves

1 and piping for feed, permeate, and concentrate streams. Factors influencing membrane
2 selection are cost, recovery, rejection, raw water characteristics, and pre-treatment. Factors
3 influencing performance are raw water characteristics, pressure, temperature, and regular
4 monitoring and maintenance. Depending on the membrane type and operating pressure, RO
5 is capable of removing 85-95 percent of fluoride, and over 95 percent of nitrate and arsenic.
6 The treatment process is relatively insensitive to pH. Water recovery is 60-80 percent,
7 depending on raw water characteristics. The concentrate volume for disposal can be
8 significant. The conventional RO treatment train for well water uses anti-scalant addition,
9 cartridge filtration, RO membranes, chlorine disinfection, and clearwell storage.

10 Pre-treatment. RO requires careful review of raw water characteristics, and pre-treatment
11 needs to prevent membranes from fouling, scaling, or other membrane degradation. Removal
12 or sequestering of suspended solids is necessary to prevent colloidal and bio-fouling, and
13 removal of sparingly soluble constituents such as calcium, magnesium, silica, sulfate, barium,
14 *etc.*, may be required to prevent scaling. Pretreatment can include media filters to remove
15 suspended particles; IX softening to remove hardness; antiscalant feed; temperature and pH
16 adjustment to maintain efficiency; acid to prevent scaling and membrane damage; activated
17 carbon or bisulfite to remove chlorine (post-disinfection may be required); and cartridge
18 filters to remove any remaining suspended particles to protect membranes from upsets.

19 Maintenance. Rejection percentages must be monitored to ensure contaminant removal
20 below MCLs. Regular monitoring of membrane performance is necessary to determine
21 fouling, scaling, or other membrane degradation. Use of monitoring equipment to track
22 membrane performance is recommended. Acidic or caustic solutions are regularly flushed
23 through the system at high volume/low pressure with a cleaning agent to remove fouling and
24 scaling. The system is flushed and returned to service. RO stages are cleaned sequentially.
25 Frequency of membrane replacement is dependent on raw water characteristics, pre-treatment,
26 and maintenance.

27 Waste Disposal. Pre-treatment waste streams, concentrate flows, and spent filters and
28 membrane elements all require approved disposal methods. Disposal of the significant
29 volume of the concentrate stream is a problem for many utilities.

30 **Advantages (RO)**

- 31 • Produces the highest water quality.
- 32 • Can effectively treat a wide range of dissolved salts and minerals, turbidity, health and
33 aesthetic contaminants, and certain organics. Some highly-maintained units are
34 capable of treating biological contaminants.
- 35 • Low pressure - less than 100 pounds per square inch (psi), compact, self-contained,
36 single membrane units are available for small installations.

37 **Disadvantages (RO)**

- 38 • Relatively expensive to install and operate.
- 39 • Frequent membrane monitoring and maintenance; pressure, temperature, and pH
40 requirements to meet membrane tolerances. Membranes can be chemically sensitive.

- Additional water usage depending on rejection rate.

A concern with RO for treatment of inorganics is that if the full stream is treated, then most of the alkalinity and hardness would also be removed. In that event, post-treatment may be necessary to avoid corrosion problems. If feasible, a way to avoid this issue is to treat a slip stream of raw water and blend the slip stream back with the raw water rather than treat the full stream. The amount of water rejected is also an issue with RO. Discharge concentrate can be between 10 and 50 percent of the influent flow.

1.4.5.2 Electrodialysis Reversal

Process. EDR is an electrochemical process in which ions migrate through ion-selective semi-permeable membranes as a result of their attraction to two electrically charged electrodes. A typical EDR system includes a membrane stack with a number of cell pairs, each consisting of a cation transfer membrane, a demineralized flow spacer, an anion transfer membrane, and a concentrate flow spacer. Electrode compartments are at opposite ends of the stack. The influent feed water (chemically treated to prevent precipitation) and the concentrated reject flow in parallel across the membranes and through the demineralized and concentrate flow spacers, respectively. The electrodes are continually flushed to reduce fouling or scaling. Careful consideration of flush feed water is required. Typically, the membranes are cation or anion exchange resins cast in sheet form; the spacers are high density polyethylene; and the electrodes are inert metal. EDR stacks are tank-contained and often staged. Membrane selection is based on review of raw water characteristics. A single-stage EDR system usually removes 40-50 percent of fluoride, nitrate, arsenic, and total dissolved solids (TDS). Additional stages are required to achieve higher removal efficiency (85-95% for fluoride). EDR uses the technique of regularly reversing the polarity of the electrodes, thereby freeing accumulated ions on the membrane surface. This process requires additional plumbing and electrical controls, but it increases membrane life, may require less added chemicals, and eases cleaning. The conventional EDR treatment train typically includes EDR membranes, chlorine disinfection, and clearwell storage. Treatment of surface water may also require pre-treatment steps such as raw water pumps, debris screens, rapid mix with addition of an anti-scalant, slow mix flocculator, sedimentation basin or clarifier, and gravity filters. Microfiltration (MF) could be used in place of flocculation, sedimentation, and filtration. Additional treatment or management of the concentrate and the removed solids would be necessary prior to disposal.

Pre-treatment. There are pretreatment requirements for pH, organics, turbidity, and other raw water characteristics. EDR typically requires chemical feed to prevent scaling, acid addition for pH adjustment, and a cartridge filter for prefiltration.

Maintenance. EDR membranes are durable, can tolerate a pH range from 1 to 10, and temperatures to 115 degrees Fahrenheit (°F) for cleaning. They can be removed from the unit and scrubbed. Solids can be washed off by turning the power off and letting water circulate through the stack. Electrode washes flush out byproducts of electrode reaction. The byproducts are hydrogen, formed in the cathode space, and oxygen and chlorine gas, formed in the anode space. If the chlorine is not removed, toxic chlorine gas may form. Depending

1 on raw water characteristics, the membranes would require regular maintenance or
2 replacement. EDR requires reversing the polarity. Flushing at high volume/low pressure
3 continuously is required to clean electrodes. If used, pre-treatment filter replacement and
4 backwashing would be required. The EDR stack must be disassembled, mechanically
5 cleaned, and reassembled at regular intervals.

6 Waste Disposal. Highly concentrated reject flows, electrode cleaning flows, and spent
7 membranes require approved disposal methods. Pre-treatment processes and spent materials
8 also require approved disposal methods.

9 **Advantages (EDR)**

- 10 • EDR can operate with minimal fouling or scaling, or chemical addition.
- 11 • Low pressure requirements; typically quieter than RO.
- 12 • Long membrane life expectancy; EDR extends membrane life and reduces
13 maintenance.
- 14 • More flexible than RO in tailoring treated water quality requirements.

15 **Disadvantages (EDR)**

- 16 • Not suitable for high levels of iron, manganese, and hydrogen sulfide.
- 17 • High energy usage for high TDS water.

18 EDR can be quite expensive to run because of the energy it uses. However, because it is
19 generally automated and allows for part-time operation, it may be an appropriate technology
20 for small systems. It can be used to simultaneously reduce fluoride, selenium, nitrate, arsenic
21 and TDS.

22 **1.4.6 Point-of-Entry and Point-of-Use Treatment Systems**

23 Point-of-entry (POE) and Point-of-use (POU) treatment devices or systems rely on many
24 of the same treatment technologies that have been used in central treatment plants. However,
25 while central treatment plants treat all water distributed to consumers to the same level, POU
26 and POE treatment devices are designed to treat only a portion of the total flow. POU devices
27 treat only the water intended for direct consumption, typically at a single tap or limited
28 number of taps, while POE treatment devices are typically installed to treat all water entering
29 a single home, business, school, or facility. POU and POE treatment systems may be an
30 option for PWSs where central treatment is not affordable. Updated USEPA guidance on use
31 of POU and POE treatment devices is provided in “*Point-of-Use or Point-of-Entry Treatment*
32 *Options for Small Drinking Water Systems*”, EPA 815-R-06-010, April 2006 (USEPA 2006).

33 Point-of-entry and POU treatment systems can be used to provide compliant drinking
34 water. For arsenic, nitrate and fluoride removal, these systems typically use small RO
35 treatment units that are installed “under the sink” in the case of point-of-use, and where water
36 enters a house or building in the case of point-of-entry. It should be noted that the POU
37 treatment units would need to be more complex than units typically found in commercial
38 retail outlets in order to meet regulatory requirements, making purchase and installation more

1 expensive. Point-of-entry and point-of-use treatment units would be purchased and owned by
2 the PWS. These solutions are decentralized in nature, and require utility personnel entry into
3 houses or at least onto private property for installation, maintenance, and testing. Due to the
4 large number of treatment units that would be employed and would be largely out of the
5 control of the PWS, it is very difficult to ensure 100 percent compliance. Prior to selection of
6 a point-of-entry or point-of-use program for implementation, consultation with TCEQ would
7 be required to address measurement and determination of level of compliance.

8 According to 40 CFR Section 141.100 (July 2005 Edition), the PWS must develop and
9 obtain TCEQ approval for a monitoring plan before POE devices are installed for compliance
10 with an MCL. Under the plan, POE devices must provide health protection equivalent to
11 central water treatment meaning the water must meet all National Primary Drinking Water
12 Regulations and would be of acceptable quality similar to water distributed by a well-operated
13 central treatment plant. In addition, monitoring must include physical measurements and
14 observations such as total flow treated and mechanical condition of the treatment equipment.
15 The system would have to track the POE flow for a given time period, such as monthly, and
16 maintain records of device inspection. The monitoring plan should include frequency of
17 monitoring for the contaminant of concern and number of units to be monitored. For
18 instance, the system may propose to monitor every POE device during the first year for the
19 contaminant of concern and then monitor one-third of the units annually, each on a rotating
20 schedule, such that each unit would be monitored every 3 years. In order to satisfy the
21 requirement that POE devices must provide health protection, the water system may be
22 required to conduct a pilot study to verify the POE device can provide treatment equivalent to
23 central treatment.

24 The SDWA [§1412(b)(4)(E)(ii)] regulates the design, management and operation of POU
25 and POE treatment units used to achieve compliance with an MCL. These restrictions,
26 relevant to MCL compliance, are:

- 27 • POU and POE treatment units must be owned, controlled, and maintained by the water
28 system, although the utility may hire a contractor to ensure proper operation and
29 maintenance (O&M) and MCL compliance. The water system must retain unit
30 ownership and oversight of unit installation, maintenance and sampling; the utility
31 ultimately is the responsible party for regulatory compliance. The water system staff
32 need not perform all installation, maintenance, or management functions, as these
33 tasks may be contracted to a third party, but the final responsibility for the quality and
34 quantity of the water supplied to the community resides with the water system, and the
35 utility must monitor all contractors closely. Responsibility for O&M of POU or POE
36 devices installed for SDWA compliance may not be delegated to homeowners.
- 37 • POU and POE units must have mechanical warning systems to automatically notify
38 customers of operational problems. Each POU or POE treatment device must be
39 equipped with a warning device (*e.g.*, alarm, light) that would alert users when their
40 unit is no longer adequately treating their water. As an alternative, units may be
41 equipped with an automatic shut-off mechanism to meet this requirement.

- If the American National Standards Institute has issued product standards for a specific type of POU or POE treatment unit, only those units that have been independently certified according to those standards may be used as part of a compliance strategy.

The following observations with regard to using POE and POU devices for SDWA compliance were made by Raucher, *et al.* (2004):

- If POU devices are used as an SDWA compliance strategy, certain consumer behavioral changes will be necessary (*e.g.*, encouraging people to drink water only from certain treated taps) to ensure comprehensive consumer health protection.
- Although not explicitly prohibited in the SDWA, USEPA indicates that POU treatment devices should not be used to treat for radon or for most volatile organic contaminants to achieve compliance, because POU devices do not provide 100 percent protection against inhalation or contact exposure to those contaminants at untreated taps (*e.g.*, shower heads).
- Liability – PWSs considering unconventional treatment options (POU, POE, or bottled water) must address liability issues. These could be meeting drinking water standards, property entry and ensuing liabilities, and damage arising from improper installation or improper function of the POU and POE devices.

1.4.7 Water Delivery or Central Drinking Water Dispensers

Current USEPA regulations 40 Code of Federal Regulations (CFR) 141.101 prohibit the use of bottled water to achieve compliance with an MCL, except on a temporary basis. State regulations do not directly address the use of bottled water. Use of bottled water at a non-compliant PWS would be on a temporary basis. Every 3 years, the PWSs that employ interim measures are required to present the TCEQ with estimates of costs for piping compliant water to their systems. As long as the projected costs remain prohibitively high, the bottled water interim measure is extended. Until USEPA amends the noted regulation, the TCEQ is unable to accept water delivery or central drinking water dispensers as compliance solutions.

Central provision of compliant drinking water would consist of having one or more dispensers of compliant water where customers could come to fill containers with drinking water. The centralized water source could be from small to medium-sized treatment units or could be compliant water delivered to the central point by truck.

Water delivery is an interim measure for providing compliant water. As an interim measure for a small impacted population, providing delivered drinking water may be cost effective. If the susceptible population is large, the cost of water delivery would increase significantly.

Water delivery programs require consumer participation to a varying degree. Ideally, consumers would have to do no more than they currently do for a piped-water delivery system. Least desirable are those systems that require maximum effort on the part of the

1 customer (*e.g.*, customer has to travel to get the water, transport the water, and physically
2 handle the bottles).

3

SECTION 2 EVALUATION METHODS

2.1 DECISION TREE

The decision tree is a flow chart for conducting feasibility studies for a non-compliant PWS. The decision tree is shown in Figures 2.1 through 2.4. The tree guides the user through a series of phases in the design process. Figure 2.1 shows Tree 1, which outlines the process for defining the existing system parameters, followed by optimizing the existing treatment system operation. If optimizing the existing system does not correct the deficiency, the tree leads to six alternative preliminary branches for investigation. The groundwater branch leads through investigating existing wells to developing a new well field. The treatment alternatives address centralized and on-site treatment. The objective of this phase is to develop conceptual designs and cost estimates for the six types of alternatives. The work done for this report follows through Tree 1 and Tree 2, as well as a preliminary pass through Tree 4.

Tree 3, which begins at the conclusion of the work for this report, starts with a comparison of the conceptual designs, selecting the two or three alternatives that appear to be most promising, and eliminating those alternatives which are obviously infeasible. It is envisaged that a process similar to this would be used by the study PWS to refine the list of viable alternatives. The selected alternatives are then subjected to intensive investigation, and highlighted by an investigation into the socio-political aspects of implementation. Designs are further refined and compared, resulting in the selection of a preferred alternative. The steps for assessing the financial and economic aspects of the alternatives (one of the steps in Tree 3) are given in Tree 4 in Figure 2.4.

2.2 DATA SOURCES AND DATA COLLECTION

2.2.1 Data Search

2.2.1.1 Water Supply Systems

The TCEQ maintains a set of files on public water systems, utilities, and districts at its headquarters in Austin, Texas. The files are organized under two identifiers: a PWS identification number and a CCN number. The PWS identification number is used to retrieve four types of files:

- CO – Correspondence,
- CA – Chemical analysis,
- MOR – Monthly operating reports (quality/quantity), and
- FMT – Financial, managerial and technical issues.

Figure 2.1
TREE 1 – EXISTING FACILITY ANALYSIS




Figure 2.2

TREE 2 – DEVELOP TREATMENT ALTERNATIVES





Figure 2.3


Tree 3 – PRELIMINARY ANALYSIS



End* -- Discard this alternative and reconsider next most-desirable alternative.

Develop financial model of top alternative:
 Existing rates, revenues, expenditures
 Existing reserves and debts
 Future rates, revenues, expenditures
 Future capital expenditures
 Future water demands

Figure 2.4
TREE 4 – FINANCIAL



1 The CCN files generally contain a copy of the system’s Certificate of Convenience and
2 Necessity, along with maps and other technical data.

3 These files were reviewed for the PWS and surrounding systems.

4 The following websites were consulted to identify the water supply systems in the area:

- 5 • Texas Commission on Environmental Quality
6 <http://www3.tceq.state.tx.us/iwud/>. Under “Advanced Search,” type in the name(s) of
7 the County(ies) in the area to get a listing of the public water supply systems.
- 8 • USEPA Safe Drinking Water Information System
9 www.epa.gov/safewater/data/getdata.html

10 Groundwater Control Districts were identified on the TWDB web site, which has a series
11 of maps covering various groundwater and surface water subjects. One of those maps shows
12 groundwater control districts in the State of Texas.

13 **2.2.1.2 Existing Wells**

14 The TWDB maintains a groundwater database available at www.twdb.state.tx.us that has
15 two tables with helpful information. The “Well Data Table” provides a physical description
16 of the well, owner, location in terms of latitude and longitude, current use, and for some
17 wells, items such as flowrate, and nature of the surrounding formation. The “Water Quality
18 Table” provides information on the aquifer and the various chemical concentrations in the
19 water.

20 The TWDB maintains a groundwater database available at www.twdb.state.tx.us that has
21 two tables with helpful information. The “Well Data Table” provides a physical description
22 of the well, owner, location in terms of latitude and longitude, current use, and for some
23 wells, items such as flowrate, and nature of the surrounding formation. The “Water Quality
24 Table” provides information on the aquifer and the various chemical concentrations in the
25 water.

26 **2.2.1.3 Surface Water Sources**

27 Regional planning documents were consulted for lists of surface water sources.

28 **2.2.1.4 Groundwater Availability Model**

29 GAMs, developed by the TWDB, are planning tools and should be consulted as part of a
30 search for new or supplementary water sources. The GAM for the Ogallala aquifer was
31 investigated as a potential tool for identifying available and suitable groundwater resources.

32 **2.2.1.5 Water Availability Model**

33 The WAM is a computer-based simulation predicting the amount of water that would be
34 in a river or stream under a specified set of conditions. WAMs are used to determine whether

1 water would be available for a newly requested water right or amendment. If water is
2 available, these models estimate how often the applicant could count on water under various
3 conditions (e.g., whether water would be available only 1 month out of the year, half the year,
4 or all year, and whether that water would be available in a repeat of the drought of record).

5 WAMs provide information that assist TCEQ staff in determining whether to recommend
6 the granting or denial of an application.

7 **2.2.1.6 Financial Data**

8 Financial data were collected through a site visit. Data sought included:

- 9 • Annual Budget
- 10 • Audited Financial Statements
 - 11 ○ Balance Sheet
 - 12 ○ Income & Expense Statement
 - 13 ○ Cash Flow Statement
 - 14 ○ Debt Schedule
- 15 • Water Rate Structure
- 16 • Water Use Data
 - 17 ○ Production
 - 18 ○ Billing
 - 19 ○ Customer Counts

20 **2.2.1.7 Demographic Data**

21 Basic demographic data were collected from the 2000 Census to establish incomes and
22 eligibility for potential low cost funding for capital improvements. Median household income
23 (MHI) and number of families below poverty level were the primary data points of
24 significance. If available, MHI for the customers of the PWS should be used. In addition,
25 unemployment data were collected from current U.S. Bureau of Labor Statistics. These data
26 were collected for the following levels: national, state, and county.

27 **2.2.2 PWS Interviews**

28 **2.2.2.1 PWS Capacity Assessment Process**

29 A capacity assessment is the industry standard term for an evaluation of a water system's
30 financial, managerial, and technical capacity to effectively deliver safe drinking water to its
31 customers now and in the future at a reasonable cost, and to achieve, maintain and plan for
32 compliance with applicable regulations. The assessment process involves interviews with

1 staff and management who have a responsibility in the operations and management of the
2 system.

3 Financial, managerial, and technical capacity are individual yet highly interrelated
4 components of a system’s capacity. A system cannot sustain capacity without maintaining
5 adequate capability in all three components.

6 **Financial capacity** is a water system’s ability to acquire and manage sufficient financial
7 resources to allow the system to achieve and maintain compliance with SDWA regulations.
8 Financial capacity refers to the financial resources of the water system, including but not
9 limited to revenue sufficiency, credit worthiness, and fiscal controls.

10 **Managerial capacity** is the ability of a water system to conduct its affairs so that the
11 system is able to achieve and maintain compliance with SDWA requirements. Managerial
12 capacity refers to the management structure of the water system, including but not limited to
13 ownership accountability, staffing and organization, and effective relationships to customers
14 and regulatory agencies.

15 **Technical capacity** is the physical and operational ability of a water system to achieve
16 and maintain compliance with the SDWA regulations. It refers to the physical infrastructure
17 of the water system, including the adequacy of the source water, treatment, storage and
18 distribution infrastructure. It also refers to the ability of system personnel to effectively
19 operate and maintain the system and to otherwise implement essential technical knowledge.

20 Many aspects of water system operations involve more than one component of capacity.
21 Infrastructure replacement or improvement, for example, requires financial resources,
22 management planning and oversight, and technical knowledge. A deficiency in any one area
23 could disrupt the entire effort. A system that is able to meet both its immediate and long-term
24 challenges demonstrates that it has sufficient financial, managerial, and technical capacity.

25 Assessment of the FMT capacity of the PWS was based on an approach developed by the
26 New Mexico Environmental Finance Center (NMEFC), which is consistent with TCEQ FMT
27 assessment process. This method was developed from work the NMEFC did while assisting
28 USEPA Region 6 in developing and piloting groundwater comprehensive performance
29 evaluations. The NMEFC developed a standard list of questions that could be asked of water
30 system personnel. The list was then tailored slightly to have two sets of questions – one for
31 managerial and financial personnel, and one for operations personnel (the questions are
32 included in Appendix A). Each person with a role in the FMT capacity of the system was
33 asked the applicable standard set of questions individually. The interviewees were not given
34 the questions in advance and were not told the answers others provided. Also, most of the
35 questions are open ended type questions so they were not asked in a fashion to indicate what
36 would be the “right” or “wrong” answer. The interviews lasted between 45 minutes to
37 75 minutes depending on the individual’s role in the system and the length of the individual’s
38 answers.

1 In addition to the interview process, visual observations of the physical components of
2 the system were made. A technical information form was created to capture this information.
3 This form is also contained in Appendix A. This information was considered supplemental to
4 the interviews because it served as a check on information provided in the interviews. For
5 example, if an interviewee stated he or she had an excellent preventative maintenance
6 schedule and the visit to the facility indicated a significant amount of deterioration (more than
7 would be expected for the age of the facility) then the preventative maintenance program
8 could be further investigated or the assessor could decide that the preventative maintenance
9 program was inadequate.

10 Following interviews and observations of the facility, answers that all personnel provided
11 were compared and contrasted to provide a clearer picture of the true operations at the water
12 system. The intent was to go beyond simply asking the question, “Do you have a budget?” to
13 actually finding out if the budget was developed and being used appropriately. For example,
14 if a water system manager was asked the question, “Do you have a budget?” he or she may
15 say, “yes” and the capacity assessor would be left with the impression that the system is doing
16 well in this area. However, if several different people are asked about the budget in more
17 detail, the assessor may find that although a budget is present, operations personnel do not
18 have input into the budget, the budget is not used by the financial personnel, the budget is not
19 updated regularly, or the budget is not used in setting or evaluating rates. With this approach,
20 the inadequacy of the budget would be discovered and the capacity deficiency in this area
21 would be noted.

22 Following the comparison of answers, the next step was to determine which items noted
23 as a potential deficiency truly had a negative effect on the system’s operations. If a system
24 had what appeared to be a deficiency, but this deficiency was not creating a problem in terms
25 of the operations or management of the system, it was not considered critical and may not
26 have needed to be addressed as a high priority. As an example, the assessment may have
27 revealed an insufficient number of staff members to operate the facility. However, it may
28 also have been revealed that the system was able to work around that problem by receiving
29 assistance from a neighboring system, so no severe problems resulted from the number of
30 staff members. Although staffing may not be ideal, the system does not need to focus on this
31 particular issue. The system needs to focus on items that are truly affecting operations. As an
32 example of this type of deficiency, a system may lack a reserve account which can then lead
33 the system to delay much-needed maintenance or repair on its storage tank. In this case, the
34 system needs to address the reserve account issue so that proper maintenance can be
35 completed.

36 The intent was to develop a list of capacity deficiencies with the greatest impact on the
37 system’s overall capacity. Those were the most critical items to address through follow-up
38 technical assistance or by the system itself.

39 **2.2.2.2 Interview Process**

40 PWS personnel were interviewed by the project team, and each was interviewed
41 separately. Interview forms were completed during each interview.

2.3 ALTERNATIVE DEVELOPMENT AND ANALYSIS

The initial objective for developing alternatives to address compliance issues is to identify a comprehensive range of possible options that can be evaluated to determine which are the most promising for implementation. Once the possible alternatives are identified, they must be defined in sufficient detail so a conceptual cost estimate (capital and O&M costs) can be developed. These conceptual cost estimates are used to compare the affordability of compliance alternatives, and to give a preliminary indication of rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. The basis for the unit costs used for the compliance alternative cost estimates is summarized in Appendix B. Other non-economic factors for the alternatives, such as reliability and ease of implementation, are also addressed

2.3.1 Existing PWS

The neighboring PWSs were identified, and the extents of their systems were investigated. PWSs farther than 15 miles from the non-compliant PWSs were not considered because the length of the pipeline required would make the alternative cost prohibitive. The quality of water provided was also investigated. For neighboring PWSs with compliant water, options for water purchase and/or expansion of existing well fields were considered. The neighboring PWSs with non-compliant water were considered as possible partners in sharing the cost for obtaining compliant water either through treatment or developing an alternate source.

The neighboring PWSs were investigated to get an idea of the water sources in use and the quantity of water that might be available for sale. They were contacted to identify key locations in their systems where a connection might be made to obtain water and to explore on a preliminary basis their willingness to partner or sell water. Then, the major system components that would be required to provide compliant water were identified. The major system components included treatment units, wells, storage tanks, pump stations, and pipelines.

Once the major components were identified, a preliminary design was developed to identify sizing requirements and routings. A capital cost estimate was then developed based on the preliminary design of the required system components. An annual O&M cost was also estimated to reflect the change in O&M expenditures that would be needed if the alternative was implemented.

Non-economic factors were also identified. Ease of implementation was considered, as well as the reliability for providing adequate quantities of compliant water. Additional factors were whether implementation of an alternative would require significant increase in the management or technical capability of the PWS, and whether the alternative had the potential for regionalization.

1 **2.3.2 New Groundwater Source**

2 It was not possible in the scope of this project to determine conclusively whether new
3 wells could be installed to provide compliant drinking water. In order to evaluate potential
4 new groundwater source alternatives, three test cases were developed based on distance from
5 the PWS intake point. The test cases were based on distances of 10 miles, 5 miles, and
6 1 mile. It was assumed that a pipeline would be required for all three test cases. A storage
7 tank and pump station would be required for the 10-mile and 5-mile alternatives. It was also
8 assumed that new wells would be installed, and that their depths would be similar to the
9 depths of the existing wells, or other existing drinking water wells in the area.

10 A preliminary design was developed to identify sizing requirements for the required
11 system components. A capital cost estimate was then developed based on the preliminary
12 design of the required system components. An annual O&M cost was also estimated to
13 reflect the change (*i.e.*, from current expenditures) in O&M expenditures that would be
14 needed if the alternative was implemented.

15 Non-economic factors were also identified. Ease of implementation was considered, as
16 well as the reliability for providing adequate quantities of compliant water. Additional factors
17 were whether implementation of an alternative would require significant increase in the
18 management or technical capability of the PWS, and whether the alternative had the potential
19 for regionalization.

20 **2.3.3 New Surface Water Source**

21 New surface water sources were investigated. Availability of adequate quality water was
22 investigated for the main rivers in the area, as well as the major reservoirs. TCEQ WAMs
23 were inspected, and the WAM was run, where appropriate.

24 **2.3.4 Treatment**

25 The only common treatment technologies considered potentially applicable for removal
26 of fluoride and nitrate are RO and EDR. RO treatment is considered for central treatment
27 alternatives, as well as POU and POE alternatives. EDR is considered for central treatment
28 only. Both RO and EDR treatment produce a liquid waste: a reject stream from RO treatment
29 and a concentrate stream from EDR treatment. As a result, the treated volume of water is less
30 than the volume of raw water that enters the treatment system. The amount of raw water used
31 increases to produce the same amount of treated water if RO or EDR treatment is
32 implemented. Partial RO treatment and blending treated and untreated water to meet the
33 fluoride MCL would reduce the amount of raw water used. The EDR operation can be
34 tailored to provide a desired fluoride effluent concentration by controlling the electrical
35 energy applied. The treatment units were sized based on flow rates, and capital and annual
36 O&M cost estimates were made based on the size of the treatment equipment required and the
37 average water consumption rate, respectively. Neighboring non-compliant PWSs were
38 identified to look for opportunities where the costs and benefits of central treatment could be
39 shared between systems.

1 Non-economic factors were also identified. Ease of implementation was considered, as
2 well as reliability for providing adequate quantities of compliant water. Additional factors
3 were whether implementation of an alternative would require significant increase in the
4 management or technical capability of the PWS, and whether the alternative had the potential
5 for regionalization.

6 **2.4 COST OF SERVICE AND FUNDING ANALYSIS**

7 The primary purpose of the cost of service and funding analysis is to determine the
8 financial impact of implementing compliance alternatives, primarily by examining the
9 required rate increases, and also the fraction of household income that water bills represent.
10 The current financial situation is also reviewed to determine what rate increases are necessary
11 for the PWS to achieve or maintain financial viability.

12 **2.4.1 Financial Feasibility**

13 A key financial metric is the comparison of average annual household water bill for a
14 PWS customer to the MHI for the area. MHI data from the 2000 Census are used, at the most
15 detailed level available for the community. Typically, county level data are used for small
16 rural water utilities due to small population sizes. Annual water bills are determined for
17 existing, base conditions, including consideration of additional rate increases needed under
18 current conditions. Annual water bills are also calculated after adding incremental capital and
19 operating costs for each of the alternatives to determine feasibility under several potential
20 funding sources.

21 Additionally, the use of standard ratios provides insight into the financial condition of
22 any business. Three ratios are particularly significant for water utilities:

- 23 • Current Ratio = current assets divided by current liabilities provides insight into the
24 ability to meet short-term payments. For a healthy utility, the value should be greater
25 than 1.0.
- 26 • Debt to Net Worth Ratio = total debt divided by net worth shows to what degree assets
27 of the company have been funded through borrowing. A lower ratio indicates a
28 healthier condition.
- 29 • Operating Ratio = total operating revenues divided by total operating expenses show
30 the degree to which revenues cover ongoing expenses. The value is greater than 1.0 if
31 the utility is covering its expenses.

32 **2.4.2 Median Household Income**

33 The 2000 U.S. Census is used as the basis for MHI. In addition to consideration of
34 affordability, the annual MHI may also be an important factor for sources of funds for capital
35 programs needed to resolve water quality issues. Many grant and loan programs are available
36 to lower income rural areas, based on comparisons of local income to statewide incomes. In
37 the 2000 Census, MHI for the State of Texas was \$39,927, compared to the U.S. level of

1 \$41,994. The census broke down MHIs geographically by block group and ZIP code. The
2 MHIs can vary significantly for the same location, depending on the geographic subdivision
3 chosen. The MHI for each PWS was estimated by selecting the most appropriate value based
4 on block group or ZIP code based on results of the site interview and a comparison with the
5 surrounding area.

6 **2.4.3 Annual Average Water Bill**

7 The annual average household water bill was calculated for existing conditions and for
8 future conditions incorporating the alternative solutions. Average residential consumption is
9 estimated and applied to the existing rate structure to estimate the annual water bill. The
10 estimates are generated from a long-term financial planning model that details annual
11 revenue, expenditure, and cash reserve requirements over a 30-year period.

12 **2.4.4 Financial Plan Development**

13 The financial planning model uses available data to establish base conditions under
14 which the system operates. The model includes, as available:

- 15 • Accounts and consumption data
- 16 • Water tariff structure
- 17 • Beginning available cash balance
- 18 • Sources of receipts:
 - 19 ○ Customer billings
 - 20 ○ Membership fees
 - 21 ○ Capital Funding receipts from:
 - 22 ❖ Grants
 - 23 ❖ Proceeds from borrowing
- 24 • Operating expenditures:
 - 25 ○ Water purchases
 - 26 ○ Utilities
 - 27 ○ Administrative costs
 - 28 ○ Salaries
- 29 • Capital expenditures
- 30 • Debt service:
 - 31 ○ Existing principal and interest payments
 - 32 ○ Future principal and interest necessary to fund viable operations

- 1 • Net cash flow
- 2 • Restricted or desired cash balances:
 - 3 ○ Working capital reserve (based on 1-4 months of operating expenses)
 - 4 ○ Replacement reserves to provide funding for planned and unplanned repairs
 - 5 and replacements

6 From the model, changes in water rates are determined for existing conditions and for
7 implementing the compliance alternatives.

8 **2.4.5 Financial Plan Results**

9 Results from the financial planning model are summarized in two areas: percentage of
10 household income and total water rate increase necessary to implement the alternatives and
11 maintain financial viability.

12 **2.4.5.1 Funding Options**

13 Results are summarized in a table that shows the following according to alternative and
14 funding source:

- 15 • Percentage of the median annual household income that the average annual residential
16 water bill represents.
- 17 • The first year in which a water rate increase would be required
- 18 • The total increase in water rates required, compared to current rates

19 Water rates resulting from the incremental capital costs of the alternative solutions are
20 examined under a number of funding options. The first alternative examined is always
21 funding from existing reserves plus future rate increases. Several funding options were
22 analyzed to frame a range of possible outcomes.

- 23 • Grant funds for 100 percent of required capital. In this case, the PWS is only
24 responsible for the associated O&M costs.
- 25 • Grant funds for 75 percent of required capital, with the balance treated as if revenue
26 bond funded.
- 27 • Grant funds for 50 percent of required capital, with the balance treated as if revenue
28 bond funded.
- 29 • SRF loan at the most favorable available rates and terms applicable to the
30 communities.
- 31 • If local MHI >75 percent of state MHI, standard terms, currently at 3.8 percent
32 interest for non-rated entities. Additionally:
 - 33 ○ If local MHI = 70-75 percent of state MHI, 1 percent interest rate on loan.
 - 34 ○ If local MHI = 60-70 percent of state MHI, 0 percent interest rate on loan.

- 1 ○ If local MHI = 50-60 percent of state MHI, 0 percent interest and 15 percent
- 2 Forgiveness of Principal.
- 3 ○ If local MHI less than 50 percent of state MHI, 0 percent interest and
- 4 35 percent Forgiveness of Principal.
- 5 • Terms of revenue bonds assumed to be 25-year term at 6.0 percent interest rate.

6 **2.4.5.2 General Assumptions Embodied in Financial Plan Results**

7 The basis used to project future financial performance for the financial plan model
8 includes:

- 9 • No account growth (either positive or negative).
- 10 • No change in estimate of uncollectible revenues over time.
- 11 • Average consumption per account unchanged over time.
- 12 • No change in unaccounted for water as percentage of total (more efficient water use
13 would lower total water requirements and costs).
- 14 • No inflation included in the analyses (although the model has provisions to add
15 escalation of O&M costs, doing so would mix water rate impacts from inflation with
16 the impacts from the alternatives being examined).
- 17 • Minimum working capital fund established for each district based on specified months
18 of O&M expenditures.
- 19 • O&M for alternatives begins 1 year after capital implementation.
- 20 • Balance of capital expenditures not funded from primary grant program is funded
21 through debt (bond equivalent).
- 22 • Cash balance drives rate increases, unless provision chosen to override where current
23 net cash flow is positive.

24 **2.4.5.3 Interpretation of Financial Plan Results**

25 Results from the financial plan model are presented in Table 4.4. The table shows the
26 percentage of MHI represented by the annual water bill that result from any rate increases
27 necessary to maintain financial viability over time. In some cases, this may require rate
28 increases even without implementing a compliance alternative (the no action alternative).
29 The table shows any increases such as these separately. The results table shows the total
30 increase in rates necessary, including both the no-action alternative increase and any increase
31 required for the alternative. For example, if the no action alternative requires a 10 percent
32 increase in rates and the results table shows a rate increase of 25 percent, then the impact
33 from the alternative is an increase in water rates of 15 percent. Likewise, the percentage of
34 household income in the table reflects the total impact from all rate increases.

1 **2.4.5.4 Potential Funding Sources**

2 A number of potential funding sources exist for rural utilities. Both state and federal
3 agencies offer grant and loan programs to assist rural communities in meeting their
4 infrastructure needs.

5 Within Texas, the following state agencies offer financial assistance if needed:

- 6 • Texas Water Development Board,
- 7 • Office of Rural Community Affairs, and
- 8 • Texas Department of Health (Texas Small Towns Environment Program).

9 Small rural communities can also get assistance from the federal government. The
10 primary agencies providing aid are:

- 11 • United States Department of Agriculture, Rural Utilities Service, and
- 12 • United States Housing and Urban Development.


13

1 **SECTION 3**
2 **UNDERSTANDING SOURCES OF CONTAMINANTS**

3 **3.1 REGIONAL HYDROGEOLOGY**

4 The assessed Public Water Supplies are located in Hockley, Lubbock, and Lynn
5 Counties. For the regional analysis, data from nine counties covering the area around
6 Lubbock were used, including: Lubbock, Lamb, Hale, Floyd, Hockley, Crosby, Terry, Lynn,
7 and Garza Counties (Figure 3.1).


8 **Figure 3.1 Nine Counties Study Area and PWS Well Locations**



10 The major aquifer in the area is the Ogallala of late Tertiary age. Other aquifers in the
11 region that may locally be hydraulically connected to the Ogallala aquifer include younger
12 alluvial/fluvial deposits of Quaternary age (Blackwater Draw Formation) and underlying
13 older aquifers, including the Edwards-Trinity High Plains aquifer of Cretaceous age, the
14 Dockum aquifer of Triassic age, and undifferentiated Permian aquifers. A small pod of the
15 Seymour aquifer is also present in southern Crosby County and northern Garza County
16 (Figure 3.2). The PWS wells of concern are mainly completed in the Ogallala aquifer (one
17 PWS well completed in the Edwards-Trinity High Plains aquifer). Contaminants of concern
18 include fluoride, nitrate, arsenic, selenium, and uranium.

1

Figure 3.2 Major and Minor Aquifers in the Study Area



2

3

4

(1) Major aquifers include the Ogallala and Seymour aquifers, and (2) minor aquifers include the Edwards-Trinity High Plains and Dockum aquifers

5


6

7

Water quality in the Ogallala aquifer varies greatly between the north-east and south-west parts of the study area (Figure 3.3). Thus, two analysis zones were defined: Ogallala-North (TDS \leq 500 mg/L), Ogallala-South (TDS $>$ 500 mg/L).

8

Figure 3.3 Water Quality Zones in the Study Area



9

10

Data in the analysis included information from three sources:

11

12

13

14

- Texas Water Development Board groundwater database available at: https://www.twdb.state.tx.us/DATA/waterwell/well_info.asp. The database includes information on well location, related aquifer, well depth, and groundwater quality information.


- 1 • Texas Commission on Environmental Quality Public Water Supply database (not
2 publicly available). The database includes water quality data collected at PWSs in
3 Texas, and information on the water sources such as location, depth, and related
4 aquifers
- 5 • National Uranium Resource Evaluation (NURE) database available at:
6 <http://tin.er.usgs.gov/nure/water/>. The NURE dataset includes groundwater quality
7 data collected between 1975 and 1980. The database provides well locations, and
8 depths with an array of analyzed chemical data. The NURE dataset covers only the
9 eastern part of the study area.

10 **3.2. CONTAMINANTS OF CONCERN IN THE STUDY AREA**

11 **ARSENIC**

12 Arsenic concentrations exceed the MCL (10 µg/L) especially in the Ogallala-South area
13 where 45 percent of the wells show arsenic above the MCL (Figure 3.4). In the Ogallala-
14 North area only 8 percent of the wells have concentrations exceeding the arsenic MCL.

15 **Figure 3.4 Arsenic Concentrations in the Ogallala Aquifer Within the Study Area**



16

17 Data are from the TWDB database. The most recent sample for each well is shown.
18 Table 3.1 gives the percentage of wells with arsenic exceeding the MCL in each of the major
19 aquifers in the study area.


1

Table 3.1 Summary of Arsenic Concentrations by Aquifer

Aquifer	Total number of wells	Arsenic > 10 µg/L	
		Number of wells	Percentage
Ogallala-South	215	96	45%
Ogallala-North	222	17	8%
Edwards-Trinity (High Plains)	11	2	18%
Dockum	28	0	0%
Other	2	0	0%

2 In the Ogallala-South area where many wells have arsenic concentrations >10 µg/L, there
 3 is a stratification of arsenic concentrations with depth, particularly at the higher percentiles
 4 (Figure 3.5). Arsenic concentrations decrease with depth, which may suggest that tapping
 5 deeper water by deepening shallow wells or screening off shallower parts of certain wells
 6 may decrease arsenic concentrations and might provide a solution for wells where arsenic
 7 exceeds the MCL.

8 **Figure 3.5 Stratification of Arsenic Concentrations with Depth in the Ogallala-South**



9


10
11

Arsenic concentrations are plotted as the 10th, 25th, 50th, 75th, and 90th percentiles and depths represent the median of 20th percentiles

1 **NITRATE**

2 Nitrate concentrations >10 mg/L nitrate-N (USEPA MCL) are abundant within the study
3 area, especially in the Ogallala-South aquifer where 20 percent of the wells exceed the MCL
4 (Figure 3.6). There is very little nitrate contamination in the Ogallala-North aquifer where
5 only about 2 percent of the wells have nitrate concentrations exceeding the MCL.

6 **Figure 3.6 Nitrate Concentrations in the Ogallala Aquifer within the Study Area**



7


8 Data are from the TWDB database. The most recent sample for each well in the Ogallala
9 aquifer is shown. Table 3.2 shows the percentage of wells with nitrate-N exceeding the MCL
10 (10 mg/L).

11 **Table 3.2 Summary of Nitrate Concentrations by Aquifer**

Aquifer	Total number of wells	Nitrate > 10 mg/L	
		Number of wells	Percentage
Ogallala-South	1026	201	20%
Ogallala-North	580	12	2%
Edwards-Trinity (High Plains)	30	0	0%
Dockum	59	2	3%
Other	23	2	9%

1 In the Ogallala-South area where many wells have nitrate concentrations >10 mg/L, there
2 is a clear stratification of nitrate-N concentrations with depth, particularly at the higher
3 percentiles (Figure 3.7). Nitrate concentrations decrease with depth. This suggests that
4 tapping deeper water by deepening shallow wells or screening off shallower parts of certain
5 wells may decrease nitrate concentrations and might provide a solution for wells where nitrate
6 exceeds the MCL.


7 **Figure 3.7 Stratification of Nitrate-N Concentrations with Depth in the Ogallala-**
8 **South**



9 Nitrate concentrations are plotted as the 10th, 25th, 50th, 75th, and 90th percentiles and depths represent the median of
10 20th percentiles.
11

12 Nitrate concentrations are correlated with land use in the study area (Figure 3.8). Median
13 nitrate concentrations were compared with percentage of cultivated land within a 500 m
14 radius around wells. Results indicate that nitrate-N concentrations generally increase with
15 increasing cultivation.

1 **Figure 3.8 Relationship between Nitrate Concentrations and Cultivated Land**




2

3 **FLUORIDE**

4 Fluoride concentrations exceeding the fluoride MCL (4 mg/L) are widespread in the
5 Ogallala-South area (Figure 3.9, 51% of wells) and are low in the Ogallala-North area (3% of
6 wells).

7 **Figure 3.9 Spatial Distribution of Fluoride Concentrations in the Study Area**



8

9 Data are from the TWDB database. The most recent sample for each well is shown.
10 Table 3.3 shows the percentage of wells with fluoride exceeding the MCL (4 mg/L)) by
11 aquifer.


1

Table 3.3 Summary of Fluoride Concentrations by Aquifer

Aquifer	Total number of wells	Fluoride \geq 4 mg/L	
		Number of wells	Percentage
Ogallala-South	848	429	51%
Ogallala-North	576	17	3%
Edwards-Trinity (High Plains)	28	9	32%
Dockum	54	2	3%
Other	12	3	25%

2 In the Ogallala-South area where there are high rate of fluoride concentrations >4 mg/L,
3 there is some stratification of fluoride concentrations with depth. Fluoride concentrations
4 decrease with depth, particularly up to a depth of 125 feet (Figure 3.10). This suggests that
5 tapping deeper water by deepening shallow wells or screening off the shallower parts of
6 certain wells may decrease fluoride concentrations and might provide a solution for wells
7 where fluoride concentrations exceed the MCL.

8 **Figure 3.10 Stratification of Fluoride Concentrations with Depth in the Ogallala-**
9 **South Area**



10


11 *Fluoride concentrations are plotted as the 10th, 25th, 50th, 75th, and 90th percentiles and depths represent the median*
12 *of 20th percentiles*

13 **SELENIUM**

14 Selenium concentrations in the study area are generally below the MCL (50 $\mu\text{g/L}$).
15 Concentrations of selenium are higher in the Ogallala-South area with 10 percent of wells
16 exceeding the MCL, and in the Dockum aquifer where 15 percent of wells exceed the MCL.
17 In the Ogallala-North and Edwards-Trinity (High Plains) aquifers, less than 1 percent of wells

1 exceed the MCL for selenium. Figure 3.11 shows the distribution of selenium concentrations
2 within the study area.

3 **Figure 3.11 Spatial Distribution of Selenium Concentrations in the Study Area**



4


5 Data are from the TWDB database. The most recent sample for each well is shown.
6 Table 3.4 shows the percentage of wells with selenium concentrations exceeding the selenium
7 MCL (50 µg/L).

8 **Table 3.4 Summary of Selenium Concentrations by Aquifer**

Aquifer	Total number of wells	Selenium > 50 µg/L	
		Number of wells	Percentage
Ogallala-South	225	22	10%
Ogallala-North	227	1	0.5%
Edwards-Trinity (High Plains)	11	0	0%
Dockum	33	5	15%
Other	2	0	0%

9 In the Ogallala-South area, where many wells have selenium concentrations >50 µg/L,
10 there is a stratification of selenium concentrations with depth, particularly in the upper
11 percentiles (Figure 3.12). Stratification of selenium is similar to that of nitrate and fluoride,
12 with a decrease in selenium levels in the upper 200 feet (Figure 3.12). This suggests that
13 tapping deeper water by deepening shallow wells or screening off the shallower parts of
14 certain wells may decrease selenium concentrations and might provide a solution for wells
15 where selenium exceeds the MCL.

1 **Figure 3.12 Stratification of Selenium Concentrations with Depth in the Ogallala-**
2 **South Area**




3
4 *Selenium concentrations are plotted as the 10th, 25th, 50th, 75th, and 90th percentiles and depths represent the median*
5 *of 20th percentiles*

6 URANIUM

7 Uranium concentrations in the study area show distinct variation between the Ogallala-
8 North and Ogallala-South areas. Concentrations of uranium are higher in the Ogallala-South
9 area with 19 percent of wells exceeding the MCL (30 µg/L). In the Ogallala-North area there
10 are no measurements that exceed the MCL for uranium (Figure 3.13). Data in the map are
11 from the NURE database.


1 **Figure 3.13 Spatial Distribution of Uranium Concentrations in the Study Area**



2

3 In the Ogallala-South area where some wells show uranium concentrations greater than
 4 30 $\mu\text{g/L}$, there is some stratification of uranium concentrations with depth, particularly in the
 5 upper percentiles (Figure 3.14). Depth stratification of uranium is similar to that of nitrate,
 6 fluoride, and selenium, with a decrease in uranium levels in the upper 150-200 feet. This
 7 suggests that tapping deeper water by deepening shallow wells or screening off the shallower
 8 parts of certain wells may decrease uranium concentrations and might provide a solution for
 9 wells where uranium exceeds the MCL.

10 **Figure 3.14 Stratification of Uranium Concentrations with Depth in the Ogallala-**
 11 **South Area**



12

1 Uranium concentrations are plotted as the 10th, 25th, 50th, 75th, and 90th percentiles and depths represent the median
2 of 20th percentiles

3 **3.3 REGIONAL GEOLOGY**

4 The major aquifer in the study area is the High Plains or Ogallala aquifer. The main
5 geologic unit that makes up the High Plains aquifer is the Ogallala Formation, which is late
6 Tertiary (Miocene-Pliocene, about 4-12 million years) (Nativ 1988). The Ogallala formation
7 consists of coarse fluvial sandstones and conglomerates that were deposited in paleovalleys in
8 a mid-Tertiary erosional surface with eolian sand in intervening upland areas (Gustavson and
9 Holliday 1985). The Ogallala-North area generally corresponds to a paleovalley where the
10 saturated thickness of the aquifer is greater and the water table is deeper. In contrast, the
11 Ogallala-South area generally corresponds to a paleoupland where the Ogallala Formation is
12 thin, the aquifer thickness is low, and the water table is shallower. The top of the Ogallala
13 Formation is marked by a resistant calcite layer termed the “caprock” caliche.

14 The Ogallala Formation is overlain by Quarternary-age (Pleistocene-Holocene) eolian,
15 fluvial, and lacustrine sediments called the Blackwater Draw Formation (Holliday 1989). The
16 texture of the formation ranges from sand and gravel along riverbeds and mostly clay in playa
17 floors.

18 The Ogallala Formation is underlain by lower Cretaceous (Comanchean) strata in the
19 southern High Plains. The top of the Cretaceous sediments is marked by an erosional surface
20 that represents the end of the Laramide orogeny. Nonuniform erosion resulted in topographic
21 relief on the Cretaceous beneath the Ogallala Formation. Cretaceous strata are absent beneath
22 the thick Ogallala paleovalley fill deposits because they were removed by erosion. The
23 Cretaceous sediments were deposited in a subsiding shelf environment and consist of (1) the
24 Trinity Group (basal sandy, permeable Antlers Formation), (2) Fredericksburg Group (limy to
25 shaly formations, including the Walnut, Comanche Peak, and Edwards Formation, as well as
26 the Kiamichi Formation), and (3) the Washita Group (low-permeability, shaly sediments of
27 Duck Creek Formation) (Nativ 1988). The sequence results in two main aquifer units: the
28 Antlers Sandstone (also termed the Trinity or Paluxy sandstone, ~ 15 m thick) and the
29 Edwards Limestone (~ 30 m thick). The term Edwards Trinity (High Plains) aquifer is
30 generally used to describe these units (Ashworth 1991). The limestone decreases in thickness
31 to the northwest and transitions into the Kiamichi Formation and Duck Creek Formation
32 (predominantly shale).

33 The Ogallala Formation is underlain by the Triassic Dockum Group in much of the
34 southern High Plains. The Dockum Group is exposed along the margins of the High Plains
35 (~150 m thick). The uppermost sediments consist of red mudstones (termed red beds) that
36 generally form an aquitard. Underlying units (Trujillo Sandstone [Upper Dockum] and Santa
37 Rosa Sandstone [Lower Dockum]) are aquifers. Water quality in the Dockum is generally
38 poor (Dutton and Simpkins 1986). The sediment of the Dockum was deposited in a
39 continental fluvio-lacustrine environment that included streams, deltas, lakes, and mud flats

1 (McGowen, *et al.* 1977) and included alternating arid and humid climatic conditions. The
2 Triassic rocks are thickest in the Midland Basin (≤ 600 m).

3 **3.4 DETAILED ASSESSMENT**

4 The Whitharral WSC PWS has three wells: G1100011A, G1100011B, and G1100011C.
5 Well depths range from 127 to 150 inch. The TCEQ database codes all three wells as being
6 within the Edwards and associated limestones and Antlers Sand (218EDAS); however,
7 aquifer names listed differ. Well G1100011A is listed as being in the Ogallala aquifer; well
8 G1100011B is listed as being in an unknown aquifer; and well G1100011C is listed as being
9 in the Edwards-Trinity (High Plains) aquifer. All wells are related to a single entry point in
10 the water supply system, making it difficult to trace contaminants back to a specific well.
11 Table 3.5 summarizes fluoride and nitrate concentrations measured at the Whitharral WSC
12 PWS.

13 **Table 3.5 Fluoride and Nitrate Concentrations in the Whitharral WSC PWS**

Date	Fluoride (mg/L)	Nitrate-N (mg/L)
10/13/1997	-	11.9
3/3/1998	3.9	10.7
1/12/1999	-	12.1
1/25/2000	-	12.4
1/23/2001	3.7	12.5
3/19/2001	4.0	14.7
8/15/2001	-	11.3
3/25/2002	4.5	10.9
6/3/2002	-	11.8
9/23/2002	-	11.9
11/19/2002	-	10.8
2/25/2003	4.4	11.4
5/7/2003	4.7	11.6
8/25/2003	4.7	11.5
9/24/2003	4.4	-
10/23/2003	4.7	11.4
10/23/2003	-	11.8
1/29/2004	4.1	11.7
5/24/2004	4.1	11.2
9/23/2004	4.4	10.2
11/8/2004	4.4	9.5
12/13/2004	-	10.1
12/27/2004	4.4	-
2/23/2005	4.2	10.5
6/7/2005	4.6	11.0
8/17/2005	4.4	10.0


10/20/2005	4.5	9.8
3/8/2006	4.6	11.0
5/23/2006	4.5	10.9
8/31/2006	4.6	10.9
11/2/2006	4.5	11.4
2/13/2007	4.4	11.4

(data from the TCEQ PWS database)

1


2 Of 23 fluoride measurements taken between 1998 and 2007, all but the first three contain
3 concentrations above the MCL (4 mg/L). Of 30 nitrate measurements taken between 1997
4 and 2007, all but three contain concentrations above the MCL (10 mg/L). The spatial
5 distributions of fluoride and nitrate concentrations within 5- and 10-km buffers of the PWS
6 wells are shown in Figures 3.15 and 3.16, respectively.

7 **Figure 3.15 Fluoride Concentrations Within 5- and 10-Km Buffers of the Whitharral**
8 **WSC PWS Wells**



9

1 **Figure 3.16 Nitrate Concentrations Within 5- and 10-Km Buffers of the Whitharral**
2 **WSC PWS Wells**



3

4 Data are from the TCEQ and TWDB databases. Two types of samples were included in
5 the analysis. Samples from the TCEQ database (shown as squares on the map) represent the
6 most recent sample taken at a PWS, which can be raw samples from a single well or entry
7 point samples that may combine water from multiple sources. Samples from the TWDB
8 database are taken from single wells (shown as circles in the map). Where more than one
9 measurement has been made in a well, the most recent concentration is shown.

10 Figure 3.15 shows a number of wells near the PWS that contain fluoride levels below the
11 MCL. Information on the well numbers, depth, use, and most recent fluoride measurements
12 for those wells with acceptable fluoride levels are in Table 3.6 and measured concentrations
13 of other constituents of concern for these wells are shown in Table 3.7. While all these wells
14 contain fluoride levels under the primary MCL (4 mg/L), some contain levels that exceed the
15 secondary MCL (2 mg/L). Of the wells in Table 3.6, the well closest to the PWS wells is well
16 2422203, an irrigation well about 2 km to the south. Well depths indicate that fluoride
17 concentrations decrease with depth and that the wells with depths of 185-200 contain
18 relatively low (<2 mg/L) fluoride concentrations.

Table 3.6 Characteristics of Wells Near the Whitharral WSC PWS Wells that have Acceptable Levels of Fluoride

State well number	Aquifer	Well depth (ft)	Primary use	Date of measurement	Fluoride (mg/L)
2414102	121OGLL	130	domestic	4/11/2000	3.3
2414501	121OGLL	143	irrigation	8/14/1975	3.8
2414605	121OGLL	unknown	domestic	8/20/1984	2.9
2414608	121OGLL	185	unused	8/29/1984	1.6
2414610	121OGLL	unknown	unused	1/30/1985	0.5
2414611	121OGLL	145	unused	7/28/1986	3.4
2414612	121OGLL	200	unused	1/18/1985	2.0
2414613	121OGLL	109	unused	8/18/1987	3.5
2414614	121OGLL	185	industrial	8/29/1984	1.6
2422203	121OGLL	Unknown	irrigation	7/23/1981	4.0

(data from the TWDB database)

As shown in Figure 3.16, all sampled wells in the vicinity of the PWS wells contain acceptable levels of nitrate. These wells range in depth from 100 to 240 feet and nearly all are classified as being within the Ogallala aquifer. The well closest to the PWS wells is well 2422203, an irrigation well about 2 km to the south. A measurement taken in July 1981 showed this well contained 8 mg/L of nitrate. Measured fluoride levels in this well (discussed above) are also below the MCL.

Table 3.7 Most Recent Concentrations in Potential Alternative Sources

Well	Fluoride (mg/L)	Nitrate-N (mg/L)	Selenium (µg/L)	Uranium (µg/L)	Arsenic (µg/L)
2414102	3.3	5.6	26.1	-	11.0
2414501	3.8	0.1	-	-	-
2414605	2.9	6.6	-	-	-
2414608	1.6	0.1	-	-	-
2414610	0.5	4.3	-	-	-
2414611	3.4	6.4	-	-	-
2414612	2.0	0.0	-	-	-
2414613	3.5	8.9	-	-	-
2414614	1.6	0.1	-	-	-
2422203	4.0	8.2	-	-	-

3.4.1 Summary of Alternative Groundwater Sources

One option is to obtain additional supplies from nearby wells. There are two locations in the vicinity of the PWS wells that might provide viable alternative groundwater sources. The first is at or near well 2422203, which is less than 5 km from the PWS and which is shown to

1 have acceptable levels of both fluoride (at or below 4 mg/L) and nitrate (at or below
2 10 mg/L). However, the most recent measurements were taken in 1981, and the fluoride
3 levels exceeded the secondary MCL (2 mg/L). The second is the area about 8 km northeast of
4 the PWS, where several wells show acceptable levels of both fluoride and nitrate. Some of
5 the acceptable fluoride levels listed exceed the secondary MCL (2 mg/L). Limited
6 information is available on the concentrations of selenium, uranium, and arsenic.
7 Figures 3.15 and 3.16 and Tables 3.6 and 3.7 provide further information about these wells.
8 Current levels of fluoride and other constituents should be measured before pursuing this
9 option.

10 Regional and local groundwater data indicate that fluoride and nitrate levels are likely to
11 decrease with depth. Therefore, deepening one or more of the PWS wells and screening only
12 the deeper portion of the wells might lower the concentrations of these constituents. This is
13 also supported by a local data (Table 3.7) that shows that the deeper wells in the range of 185-
14 200 contain relatively low (<2 mg/L) fluoride concentrations.

15

1 **SECTION 4**
2 **ANALYSIS OF THE WHITHARRAL WSC PWS**

3 **4.1 DESCRIPTION OF EXISTING SYSTEM**

4 **4.1.1 Existing System**

5 The Whitharral WSC PWS is shown in Figure 4.1. The Whitharral WSC PWS provides
6 water for the City of Whitharral, Texas, and is located northwest of the City of Lubbock on
7 State Highway (Hwy) 385 in Lamb County. The system is operated by Lamb County Electric
8 Cooperative, Inc. (LCEC) in Littlefield, Texas. Don Stubbs and James Price work for LCEC
9 and are the operators and have “C” groundwater licenses. The city anticipates little growth.
10 The community of Whitharral has a population of 275 with 82 service connections and
11 80 active meters. Its average daily use is approximately 0.043 mgd.



12 Two wells discharge to a 50,000-gallon ground storage tank where two 150 gallons per
13 minute (gpm) service pumps pump to the distribution system. The 50,000-gallon elevated
14 storage tanks floats on the system.

15 Fluoride has been detected in the Whitharral WSC PWS between 3.7 milligrams per liter
16 (mg/L) to 4.7 mg/L since March 1998, and the majority of measurements have exceeded the
17 MCL of 4 mg/L. Nitrate has been detected since October 1997 with values ranging between
18 9.5 mg/L to 12.5 mg/L, and the majority of measurements have exceeded the MCL
19 of 10 mg/L. Levels of fluoride and nitrate were 4.5 and 10.9 mg/L, respectively in July 2006.
20 Therefore, the Whitharral WSC PWS faces compliance issues under the water quality
21 standards for fluoride and nitrate.


22 The distribution system is made of transite pipe, and is in good condition. Gas
23 chlorination is provided at the pump houses.

24 Basic system information is as follows:

- 25 • Population served: 275
- 26 • Connections: 82
- 27 • Average daily flow: 0.043 mgd
- 28 • Total production capacity: 0.309 mgd
- 29 • Peak service pump capacity: 0.432 mgd



Lamb	Hale	Floyd
Hooper	Lubbock	Crosby
Terry	Lynn	Garza



Study System	Major Road	WR-1 Lubbock Public Water System
PWS's	Minor Road	WR-2 City of Levelland
Cities	CRMWA Pipeline	WR-3 City of Anton
City Limits	Lubbock Pipeline	
Counties		

Figure 4.1
WHITHARRAL WATER SUPPLY CORP
Pipeline Alternatives

1 Basic system raw water quality data are as follows:

- 2 • Typical fluoride range: 3.7- 4.7 mg/L
- 3 • Typical nitrate range: 9.5-12.47 mg/L
- 4 • Typical TDS range: 969-1221 mg/L
- 5 • Typical pH range: 7.1-7.6
- 6 • Typical calcium range: 72.4-155 mg/L
- 7 • Typical magnesium range: 75.3-121 mg/L
- 8 • Typical sodium range: 116-143 mg/L
- 9 • Typical chloride range: 107-241 mg/L
- 10 • Typical sulfate: 298-458 mg/L
- 11 • Typical manganese: 0.00124-0.00725 mg/L
- 12 • Typical bicarbonate (HCO₃) range: 247-311 mg/L
- 13 • Typical iron range: 0.01-2.82 mg/L

14 The City of Whitharral already investigated several possible solutions to its fluoride and
15 nitrate issues, including purchasing water from Levelland (approximately 12 miles away) or
16 Littlefield (approximately 18 miles away). Levelland blends groundwater with treated
17 surface water purchased from CRMWA. Littlefield has a well field in the sandhills and was
18 considered the best option.

19 **4.1.2 Capacity Assessment**

20 The project team conducted a capacity assessment of the Whitharral WSC on May
21 16, 2007. The results of this evaluation are separated into four categories: general assessment
22 of capacity, positive aspects of capacity, capacity deficiencies, and capacity concerns. The
23 general assessment of capacity describes the overall impression of FMT capability of the
24 water system. The positive aspects of capacity describe those factors that the system is doing
25 well. These factors should provide opportunities for the system to build on in order to
26 improve capacity deficiencies. The capacity deficiencies noted are those aspects that are
27 creating a particular problem for the system related to long-term sustainability. Primarily,
28 these problems are related to the system's ability to meet current or future compliance, ensure
29 proper revenue to pay the expenses of running the system, and to ensure the proper operation
30 of the system. The last category is titled capacity concerns. These are items that in general
31 are not causing significant problems for the system at this time. However, the system may
32 want to address them before these issues have the opportunity to cause problems.

33 Because of the challenges facing very small water systems, it is increasingly important
34 for them to develop the internal capacity to comply with all state and federal requirements for

1 public drinking water systems. For example, it is especially important for very small water
2 systems to develop long-term plans, set aside money in reserve accounts, and track system
3 expenses and revenues because they cannot rely on increased growth and economies of scale
4 to offset their costs. In addition, it is crucial for the owner, manager, and operator of a very
5 small water system to understand the regulations and participate in appropriate trainings.
6 Providing safe drinking water is the responsibility of every public water system, including
7 those very small water systems that face increased challenges with compliance.

8 The project team interviewed the following individual:

- 9 • Don Stubbs – Engineer, Lamb County Electric Company
- 10 • Tracy Bowman – Office Manager, LCEC

11 **4.1.2.1 General Structure**

12 The Whitharral WSC is located 12 miles south of the City of Littlefield northwest of
13 Lubbock in Hockley County. The WSC provides water and wastewater services to
14 82 connections. The WSC is governed by a 4--member board of directors and John Dukatnik
15 serves as the board president. The WSC was started in the late 1940s and early 1950s with
16 customers on individual wells and septic tanks. Water service was provided in the 1960s and
17 wastewater in the 1980s. The WSC has been contracting with the LCEC for operations and
18 management services for both the water and the wastewater system for the past 8 years. The
19 WSC pays LCEC a management fee of \$9,600 and LCEC provide a certified operator, regular
20 maintenance, customer billing, and financial accounting. All official notices are sent to the
21 WSC, but LCEC is under contract to correct any deficiencies in the water system. Water
22 meters were replaced about 4 years ago and new touch-read meters were installed. LCEC
23 provides bottled water to customers on request. LCEC was able to assist the WSC in
24 obtaining a grant to install a SCADA system for the system, since they already had developed
25 one for the electrical system.

26 The current monthly water rate is \$35.00 for the first 3,000 gallons and \$1.80 for each
27 additional 1,000 gallons for water. The sewer rates include a \$14.00 base fee and \$1.00 for
28 each additional 1,000 gallons for wastewater. Reconnection fee are \$25.00 and there is a
29 surcharge of \$125. The system maintains \$1,500 in a savings account. Current debt is
30 estimated at \$15,000.

31 In the late 1990's, LCEC investigated the option of purchasing water from surrounding
32 communities, such as Littlefield and Levelland. The construction cost estimates showed that
33 the project was prohibitively expensive.

34 **4.1.2.2 General Assessment of Capacity**

35 Based on the team's assessment, this system has a good level of capacity. There are
36 several positive FMT aspects of the water system, but there are also some areas that need

1 improvement. The deficiencies noted could prevent the water system from being able to meet
2 compliance now or in the future and may also impact the water system’s long-term
3 sustainability.

4 **4.1.2.3 Positive Aspects of Capacity**

5 In assessing a system’s overall capacity, it is important to look at all aspects – positive
6 and negative. It is important for systems to understand those characteristics that are working
7 well, so that those activities can be continued or strengthened. In addition, these positive
8 aspects can assist the system in addressing the capacity deficiencies or concerns. The factors
9 that were particularly important for Whitharral WSC are listed below.

- 10 • **Knowledgeable and Dedicated Staff** – The water system is managed by the LCEC,
11 which has access to large equipment, such as backhoes, and a staff of 41. The LCEC
12 handles all the FMT aspects of the running the system and is available 24 hours a
13 day. The LCEC’s main business is providing electrical service to members in a six-
14 county area. The LCEC has been able to assist the WSC in obtaining a Community
15 Development Block Grant for a new lift station for the wastewater system. Because
16 most of the board members of the WSC are farmers and providing water is not their
17 main business, contracting with a professional entity helps ensure that the system is
18 sustainable.
- 19 • **Financial Accounting and Adequate Revenues** – Because the system contracts with
20 an entity that already does customer billing and financial accounting, this type of
21 expertise and information is an asset to the board. The last water rate increase was in
22 2005. LCEC is currently looking at comparably sized communities in the area to
23 assist in developing a new rate recommendation for the board.
- 24 • **Source Water Protection Plan** – The water system is registered with TCEQ under its
25 Source Water Protection Program, which is a voluntary program.

26 **4.1.2.4 Capacity Deficiencies**

27 The following capacity deficiencies were noted in conducting the assessment and
28 seriously impact the ability of the water system to meet compliance with current and future
29 regulations and to ensure long-term sustainability.

- 30 • **Lack of Long Term Capital Planning for Compliance and Sustainability** – While
31 the system does plan for needs about 2 years out, there does not appear to be a long
32 term plan in place to achieve and maintain compliance and to ensure the long-term
33 sustainability of the water system. The LCEC has estimated that water rates would
34 increase by \$15 - \$20 a month to install treatment. Without some type of planning
35 process, the system is not able to plan for the revenue needed to make system
36 improvements or add treatment processes. The system can also use the long-term
37 planning process to help identify financing strategies to pay for the long-term needs.
- 38 • **Lack of Compliance with Water Quality Standards** – The water system is not in
39 compliance with water quality standards.

1 **4.1.2.5 Potential Capacity Concerns**

2 The following items were concerns regarding capacity but no specific operational,
3 managerial, or financial problems can be attributed to these items at this time. The system
4 should address the items listed below to further improve FMT capabilities and to improve the
5 system’s long-term sustainability.

- 6 • **Inadequate Emergency Preparedness** – The water system has not undertaken the
7 necessary planning to address emergencies typical for this type of system. The system
8 does not have a written emergency plan, but it does have access to an emergency
9 generator. In the event of an emergency, it is recommended that the water system, at a
10 minimum, have an emergency contact list that includes the name, title, and phone
11 number of the people who should be contacted in the event of an emergency. It is also
12 important to have an emergency plan that outlines what actions will be taken and by
13 whom. The plan should address emergency conditions such as storms, floods, major
14 line breaks, electrical failure, drought, and system contamination or equipment failure.

15 **4.2 ALTERNATIVE WATER SOURCE DEVELOPMENT**

16 **4.2.1 Identification of Alternative Existing Public Water Supply Sources**

17 Using data drawn from the TCEQ drinking water and TWDB groundwater well
18 databases, the PWSs surrounding the Whitharral WSC PWS were reviewed with regard to
19 their reported drinking water quality and production capacity. PWSs that appeared to have
20 water supplies with water quality issues or that purchase water were ruled out from evaluation
21 as alternative sources, while those without identified water quality issues were investigated
22 further. Since there is a limited number of PWSs in the vicinity of Whitharral WSC, both
23 small (<1 mgd) water systems or large systems (capable of producing greater than four times
24 the daily volume produced by the study system) were only considered if they were within
25 15 miles for small systems and 20 miles for large systems. A distance of 20 miles was
26 considered to be the upper limit of economic feasibility for constructing a new water line.
27 Table 4.1 is a list of the selected PWSs based on these criteria for large and small PWSs
28 within 20 miles of Whitharral WSC PWS. If it was determined that these PWSs had excess
29 supply capacity and might be willing to sell the excess, or might be a suitable location for a
30 new groundwater well, the system was taken forward for further consideration and identified
31 with “EVALUATE FURTHER” in the comments column of Table 4.1.

1 **Table 4.1 Selected Public Water Systems within 20 Miles**
2 **of the Whitharral WSC PWS**

PWS ID	PWS Name	Distance from Whitharral WSC (miles)	Comments/Other Issues
1520002	LUBBOCK PUBLIC WATER SYSTEM VIA PIPELINE FROM BAILEY COUNTY WELLFIELD	8.8	Large SW/GW system. No WQ issues except sulfate. EVALUATE FURTHER
1100001	ANTON CITY OF	10.38	Large GW system. No WQ issues. EVALUATE FURTHER
1100034	WAYNEBOS INC	11.24	Small NonRes GW system. WQ issues: As, FI, Nitrate
1100030	OPDYKE WEST WATER SUPPLY	11.41	Small GW system. WQ issues: As, FI
1100002	LEVELLAND CITY OF	12.2	Large SW/GW system. No WQ issues except Sulfate. EVALUATE FURTHER
1100005	PEP SCHOOL	14.21	Small NonRes GW system. WQ issues: FI>2.
1100010	SMYER CITY OF	15.02	Small GW system. WQ issues: As, FI
1400003	LITTLEFIELD MUNICIPAL WATER SYSTEM	18.88	Large GW system. Marginal WQ issues: FI>2.
1520020	REESE CENTER	19.83	Large SW system. No WQ issues, however limited data. Purchase water

3 After the PWSs in Table 4.1 with water quality problems were eliminated from further
4 consideration, the remaining PWSs were screened by proximity to Whitharral WSC and
5 sufficient total production capacity for selling or sharing water. Based on the initial screening
6 summarized in Table 4.1 above, three alternatives were selected for further evaluation and are
7 summarized in Table 4.2. The first alternative includes connecting to a pipeline that conveys
8 water from the City of Lubbock Bailey County well field located northwest of Lubbock to the
9 distribution system in the northwest portion of Lubbock. The second alternative entails
10 connecting to the City of Anton which is located about 10 miles east of Whitharral. The third
11 alternative is installing a pipeline to the City of Levelland, a Canadian River Municipal Water
12 Authority (CRMWA) member city located 12 miles south of Whitharral. Descriptions of the
13 Lubbock PWS, Anton PWS, and the Levelland PWS, as well as a description of the
14 CRMWA, follow Table 4.2.

15 **Table 4.2 Public Water Systems Within the Vicinity of the**
16 **Whitharral WSC PWS Selected for Further Evaluation**

PWS ID	PWS Name	Pop	Conn	Total Production (mgd)	Ave Daily Usage (mgd)	Approx. Dist. from Whitharral WSC	Comments/Other Issues
1520002	Lubbock PWS	222,473	81,059	136.077	40.263	8.8 miles	Large SW/GW system that does have excess capacity. The primary source of water for the City of Lubbock in the northwestern portion of their distribution system is the Bailey County well field, The distance indicated represents distance to the pipeline conveying treated water from the Bailey County well field and is closer than connecting to the distribution system within the Lubbock city limits.
1100001	City of Anton	1200	475	1.764	0.21	10.4 miles	Large GW system with excess capacity.

PWS ID	PWS Name	Pop	Conn	Total Production (mgd)	Ave Daily Usage (mgd)	Approx. Dist. from Whitharral WSC	Comments/Other Issues
1100002	City of Levelland	15,187	5,715	9.079	1.755	12.2 miles	Large SW/GW system and CRMWA member city with excess capacity.

1

2 **4.2.1.1 City of Lubbock Water System**

3 The City of Lubbock PWS produces an average of 38 to 40 mgd for the City of Lubbock
4 and five surrounding small municipalities. The system is capable of meeting a peak demand
5 of over 90 mgd. In addition to treating water for the City of Lubbock distribution system, the
6 Lubbock water treatment plant treats about 6 mgd on average for the six CRMWA member
7 cities receiving treated water from the City of Lubbock.

8 The City of Lubbock receives water from two sources, the CRMWA and from the Bailey
9 County well field. Additional details on the CRMWA are provided in a separate description.
10 As a member of the 11-City agreement with the CRMWA, the City of Lubbock is responsible
11 for treating raw water from the Lake Meredith/Roberts County well field located 160 miles
12 north of Lubbock. A CRMWA aqueduct distributes the treated water to six other PWSs:
13 Levelland, Brownfield, Slaton, Tahoka, O'Donnell, and Lamesa. In 2006, the water from
14 CRMWA constituted about 76 percent of the water used by the City of Lubbock. The other
15 24 percent comes from a well field in Bailey County located 60 miles northwest of Lubbock.
16 The city has water rights to 82,000 surface acres at the Bailey County well field. The water
17 produced by the Bailey County well field is chlorinated before it enters the pipeline leading to
18 Lubbock. As the water reaches Lubbock, it enters directly into the distribution system
19 predominantly in the northwest section of Lubbock. It should be noted that the City of
20 Lubbock normally utilizes their total annual water allocation from CRMWA and if Lubbock
21 needs additional water, their supply is supplemented with water from the Bailey County well
22 field which consists of 150 wells capable of producing 50 mgd total (pipeline is limited to
23 40 mgd). In 2006, the City of Lubbock pumped an average of 9.3 mgd from the Bailey
24 County well field. However, most of this water was pumped during the summer months with
25 the pipeline near peak capacity at various times.

26 In addition to the population of Lubbock, five cities are connected to the City of Lubbock
27 distribution system. Shallowater and Reese Redevelopment are located northwest and west of
28 Lubbock and receive water predominantly originating in Bailey County. Buffalo Springs and
29 Ransom Canyon are located east of Lubbock and receive water mostly originating from Lake
30 Meredith/Roberts County well field. A fifth city, Littlefield, located northwest of the City has
31 an emergency water line connected to the Bailey County pipeline. The decision to add these
32 five cities to the City of Lubbock water supply was made by the Lubbock City Council.

1 Future plans for the City of Lubbock water supply system call for the construction of
2 infrastructure to obtain water from Lake Alan Henry located 65 miles southeast of Lubbock.
3 The project is still in the preliminary engineering phase. The amount of water available from
4 this system will be staged into the existing Lubbock system over several years to match
5 Lubbock’s needs. The system is estimated to be operating in 2012.

6 **4.2.1.2 Canadian River Municipal Water Authority**

7 The CRMWA has contracts to provide water to 11 member cities in west Texas including
8 Amarillo, Borger, Brownfield, Lamesa, Levelland, Lubbock, O’Donnell, Pampa, Plainview,
9 Slaton, and Tahoka. A pipeline ranging in size from 8 feet to 1.5 feet is used to convey
10 untreated water approximately 160 miles from Lake Meredith and a well field in Roberts
11 County (40 miles northeast of Lake Meredith) to the Lubbock water treatment plant. Along
12 the pipeline route, four cities (Amarillo, Borger, Pampa and Plainview) receive their allocated
13 water supply and each of these four cities treats their own water. The rest of the raw water for
14 the other seven member cities of the CRMWA is treated at the City of Lubbock water
15 treatment plant. The treated water is pumped into the City of Lubbock distribution system
16 and to the other six member cities. The raw water line flows by gravity from Amarillo to the
17 Lubbock treatment plant. The treated water leaving the City of Lubbock water treatment
18 plant flows by gravity in the east leg pipeline to Lamesa, however the water in the west leg to
19 Levelland and Brownfield is pumped.

20 The current volume of water delivered annually by the CRMWA to the member cities is
21 85,000 acre-feet (35,000 acre-feet from Lake Meredith and 50,000 acre-feet from the well
22 field in Roberts County). The available water volume is set by the CRMWA and may
23 fluctuate during the year, but the volume is based on the water levels in the well field and in
24 the lake. The allocation for each member city is based on a contracted percentage of the
25 available volume. The City of Lubbock is under contract to receive 41.6 mgd from the
26 CRMWA, and the City of Lubbock water treatment plant treats an additional 5.4 mgd for the
27 other six member cities. When the CRMWA program was established in the 1960s, the
28 system was designed to accommodate the 11 member cities at the time and there were no
29 plans to add additional member cities.

30 If a member city has excess water, that particular city can decide to sell that water to a
31 non-member PWS. If the non-member city would receive the water directly from a member
32 city’s distribution system, then the CRMWA would not be involved. However, if a non-
33 member is requesting to receive the water (essentially a portion of a member city’s allocation)
34 via a direct line from the CRMWA line, then the non-member city must get approval from the
35 CRMWA and the 11 member cities. The non-member PWS would be responsible for
36 financing the installation of the pipeline to connect to the CRMWA treated water line from
37 Lubbock. The CRMWA would be involved throughout the process of a non-member PWS
38 applying for, securing access to, and eventually receiving water through the CRMWA system.

1 **4.2.1.3 City of Anton Water System**

2 The City of Anton is located 10 miles east of Whitharral. Their production is 1.76 mgd
3 for 1200 people and 475 connections. The source of water is six groundwater wells set at
4 depths ranging from 110 feet to 160 feet in the Ogallala Formation. According to available
5 information on this PWS, there are no reported exceedances for constituents of concern above
6 the associated MCLs. Availability of this PWS to provide water to a neighboring system has
7 not been confirmed.

8 **4.2.1.4 City of Levelland**

9 The City of Levelland is located 12 miles south of Whitharral. Their production is 2.5 to
10 3 mgd for a population of about 14,200 people and they have a total capacity of 5 mgd to
11 6 mgd. The City of Levelland is one of 11 member cities that receive water through an
12 agreement with the CRMWA. The City of Levelland receives CRMWA water treated the
13 City of Lubbock water treatment plant. In addition to this water, the City of Levelland also
14 maintains wells which provide about 20 to 30 percent of the water supply. The City of
15 Levelland has 21 wells, but only nine are currently in operation. There are seven wells that
16 are near the 114th Street Plume EPA Superfund site and these are only used for emergency
17 purposes. Some of the wells have been reported to have elevated levels of iron and
18 manganese and this is monitored.

19 **4.2.2 Potential for New Groundwater Sources**

20 **4.2.2.1 Installing New Compliant Wells**

21 Developing new wells or well fields is recommended, provided good quality groundwater
22 available in sufficient quantity can be identified. Since a number of water systems in the area
23 have water quality problems with fluoride and nitrate, it should be possible to share in the
24 cost and effort of identifying compliant groundwater and constructing well fields.

25 Installation of a new well in the vicinity of the system intake point is likely to be an
26 attractive option provided compliant groundwater can be found, since the PWS is already
27 familiar with operation of a water well. As a result, existing nearby wells with good water
28 quality should be investigated. Re-sampling and test pumping would be required to verify
29 and determine the quality and quantity of water at those wells.

30 The use of existing wells should probably be limited to use as indicators of groundwater
31 quality and availability. If a new groundwater source is to be developed, it is recommended
32 that a new well or wells be installed instead of using existing wells. This would ensure well
33 characteristics are known and meet standards for drinking water wells.

1 Some of the alternatives suggest new wells be drilled in areas where existing wells have
2 acceptable water quality. In developing the cost estimates, Parsons assumed that the aquifer
3 in these areas would produce the required amount of water with only one well. Site
4 investigations and geological research, which are beyond the scope of this study, could
5 indicate whether the aquifer at a particular site and depth would provide the amount of water
6 needed or if more than one well would need to be drilled in separate areas.

7 **4.2.2.2 Results of Groundwater Availability Modeling**

8 Regional groundwater withdrawal in the Texas High Plains region is extensive and likely
9 to remain near current levels over the next decades. In Hockley County, where the PWS is
10 located, groundwater is available from two sources, the relatively shallow Ogallala aquifer,
11 and the underlying Edwards-Trinity (High Plains) aquifer. The Ogallala provides drinking
12 water to most of the communities in the Texas panhandle, as well as irrigation water. The
13 Edwards-Trinity (High Plains) is a lower yield aquifer used almost exclusively as an
14 irrigation water source. Supply wells for the Whitharral WSC system and its vicinity
15 withdraw water primarily from the southern Ogallala aquifer. Within a 10 mile radius of the
16 system, a few active irrigation wells are completed in the Edwards-Trinity (High Plains)
17 aquifer.

18 The Ogallala is the largest aquifer in the United States. The aquifer outcrop underlies
19 much of the Texas High Plains region and eastern New Mexico, and extends eastward beyond
20 Hockley County. The Ogallala provides significantly more water for users than any other
21 aquifer in the state, and is used primarily for irrigation. The aquifer saturated thickness
22 ranges up to an approximate depth of 600 feet; supply wells have an average yield of
23 approximately 500 gpm, but higher yields, up to 2,000 gpm, are found in previously eroded
24 drainage channels filled with coarse-grained sediments (TWDB 2007a). Water level declines
25 in excess of 300 feet have occurred in several aquifer areas over the last 50 to 60 years; the
26 rate of decline, however, has slowed in recent years and water levels have risen in a few areas
27 (TWDB 2007a). The Texas Water Plan anticipates 24 percent depletion in the Ogallala
28 supply over the next decades, from 5,000,097 acre-feet per year estimated in 2000 to
29 3,785,409 acre-feet per year in 2050.

30 A GAM developed for the Ogallala aquifer simulated historical conditions and provided
31 long-term groundwater projections (Blandford, *et al.*, 2003). Predictive simulations using the
32 GAM model indicated that, if estimated future withdrawals are realized, aquifer water levels
33 could decline to a point at which significant regions currently practicing irrigated agriculture
34 could be essentially dewatered by 2050. The model predicted the most critical conditions for
35 Cochran, Hockley, Lubbock, Yoakum, Terry, and Gaines Counties where the simulated
36 drawdown could exceed 100 feet. For Hockley County, the simulated drawdown by the year
37 2050 would be within a typical 50 to 100 feet range (Blandford, *et al.* 2003). The Ogallala
38 aquifer GAM was not run for the PWS because anticipated use would represent a minor
39 addition to regional withdrawal conditions, beyond the spatial resolution of the GAM model.

1 The Edwards-Trinity (High Plains) aquifer underlies the Ogallala in the south-central
2 section of the Texas panhandle. Two distinct aquifer zones are utilized as irrigation water
3 sources. One zone occurs in the basal sand and sandstone deposits of the Antlers Sands
4 Formation (Trinity Group), and is usually under artesian pressure. The other water-bearing
5 zone occurs primarily in joints, solution cavities, and bedding planes in limestone of the
6 Fredericksburg Group. Wells completed in the Edwards-Trinity aquifer have typical yields
7 from 50 to 200 gpm, and are usually also completed in the overlying Ogallala aquifer
8 (TWDB 2007b). Extensive aquifer utilization has caused water-level declines, up to 30 inch,
9 in some areas. A GAM model providing long-term groundwater projections for the Edwards-
10 Trinity (High Plains) aquifer is under development (TWDB 2007c).

11 Within a 10 mile radius of the Whitharral WSC system, a limited number of active wells
12 utilize the Edwards-Trinity (High Plains) aquifer as an irrigation water source. Those wells
13 are completed in the Edwards and Comanche Peak formations of the Fredericksburg Group.

14 **4.2.3 Potential for New Surface Water Sources**

15 There is a low potential for development of new surface water sources for the PWS
16 system as indicated by limited water availability within the river basin. Whitharral WSC
17 system is located in the upper Brazos Basin where current surface water availability is
18 expected to decrease up to 17 percent over the next 50 years according to the 2002 Texas
19 Water Plan (from approximately from 1,423,071 acre-feet per year to 1,177,277 acre-feet per
20 year during drought conditions).

21 In the vicinity of the Whitharral WSC system, there is no availability of surface water for
22 new uses. The TCEQ availability map for the Brazos Basin indicates that in the site vicinity,
23 and within the entire Hockey County, unappropriated flows for new uses are typically
24 available up to 50 percent of the time. This supply is inadequate as the TCEQ requires
25 100 percent supply availability for a PWS.

26 **4.2.4 Options for Detailed Consideration**

27 The initial review of alternative sources of water results in the following options for
28 more-detailed consideration:

- 29 1. Lubbock Public Water System. A pipeline would be constructed from the City of
30 Lubbock distribution system to the Whitharral WSC water system (Alternative
31 WR-1).
- 32 2. Levelland Public Water System. A pipeline would be constructed from the City of
33 Levelland to the Whitharral WSC water system (Alternative WR-2).
- 34 3. Anton Public Water System. A pipeline would be constructed from the City of
35 Anton to the Whitharral WSC water system (Alternative WR-3).

1 4. New Wells at 10, 5, and 1 mile. Installing a new well within 10, 5, or 1 mile of the
2 Whitharral WSC water system PWS would produce compliant water in place of
3 the water produced by the existing active well. A pipeline and pump station would
4 be constructed to transfer the water to the Whitharral WSC water system PWS
5 (Alternatives WR-4, WR-5, and WR-6).

6 **4.3 TREATMENT OPTIONS**

7 **4.3.1 Centralized Treatment Systems**

8 Centralized treatment of the well water is identified as a potential option. Reverse
9 osmosis and EDR treatment could all be potentially applicable. The central RO treatment
10 alternative is WR-7 and the central EDR treatment alternative is WR-8.

11 **4.3.2 Point-of-Use Systems**

12 POU treatment using RO is valid for fluoride and nitrate removal. The POU treatment
13 alternative is WR-9.

14 **4.3.3 Point-of-Entry Systems**

15 POE treatment using RO is valid for fluoride and nitrate removal. The POE treatment
16 alternative is WR-10.

17 **4.4 BOTTLED WATER**

18 Providing bottled water is considered an interim measure to be used until a compliance
19 alternative is implemented. Even though the community is small and people know each
20 other; it would be reasonable to require a quarterly communication advising customers of the
21 need to take advantage of the bottled water program. An alternative to providing delivered
22 bottled water is to provide a central, publicly accessible dispenser for treated drinking water.
23 Alternatives addressing bottled water are WR-11, WR-12, and WR-13.

24 **4.5 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

25 A number of potential alternatives for compliance with the MCLs for fluoride and nitrate
26 have been identified. Each of the potential alternatives is described in the following
27 subsections. It should be noted that the cost information given is the capital cost and change
28 in O&M costs associated with implementing the particular alternative. Appendix C contains
29 cost estimates for the compliance alternatives. These compliance alternatives represent a
30 range of possibilities, and a number of them are likely not feasible. However, all have been
31 presented to provide a complete picture of the range of alternatives considered. It is
32 anticipated that a PWS will be able to use the information contained herein to select the most
33 attractive alternative(s) for more detailed evaluation and possible subsequent implementation.

1 **4.5.1 Alternative WR-1: Purchase Water from the City of Lubbock**

2 This alternative involves purchasing potable water from the City of Lubbock, which will
3 be used to supply the Whitharral WSC PWS. The City of Lubbock currently has sufficient
4 excess capacity for this alternative to be feasible. Current City policy allows drinking water
5 to be provided to areas annexed by the City or PWSs identified as governmental entities. It is
6 assumed that Whitharral WSC PWS would obtain all its water from the City of Lubbock.

7 This alternative would require constructing a pipeline from a City of Lubbock water main
8 to the existing storage tank for the Whitharral WSC PWS. A 30,000-gallon feed tank would
9 be required at the point adjacent to the main distribution line to where the new pipeline would
10 connect to the Whitharral WSC PWS. Transfer pumps would be installed within a pump
11 house for the feed tank.

12 A pump station would also be required to overcome pipe friction and the elevation
13 differences between Lubbock and Whitharral WSC. The pump station would include two
14 10 horsepower pumps, including one standby, and would be housed in a building. It is
15 assumed the pumps and piping would be installed with capacity to meet all water demand for
16 Whitharral WSC.

17 The required pipeline would be 6-inches in diameter and would follow El Paso Road
18 (County Road 247) south from the City of Lubbock pipeline along Hwy 84 to Tennessee
19 Road heading west to N. Barton Road, then south along N. Barton Road to Maine Road
20 heading west to the existing Whitharral WSC intake point. Using this route, the length of
21 pipe required would be approximately 12 miles long. .

22 By definition this alternative involves regionalization, since Whitharral WSC would be
23 obtaining drinking water from an existing larger supplier. Also, other PWSs near Whitharral
24 WSC are in need of compliant drinking water and could potentially share in implementation
25 of this alternative.

26 The estimated capital cost for this alternative includes constructing the pipeline, feed
27 tank, and pump station. The estimated O&M cost for this alternative includes the purchase
28 price for the treated water minus the cost related to current operation of the Whitharral WSC
29 water system wells, plus maintenance cost for the pipeline, and power and O&M labor and
30 materials for the pump station. The estimated capital cost for this alternative is \$3.51 million,
31 and the estimated annual O&M cost is \$52,900.

32 The reliability of adequate amounts of compliant water under this alternative should be
33 good. City of Lubbock provides treated surface water on a large scale, facilitating adequate
34 O&M resources. From the perspective of Whitharral WSC PWS, this alternative would be
35 characterized as easy to operate and repair, since O&M and repair of pipelines and pump

1 stations is well understood. If the decision were made to perform blending then the
2 operational complexity would increase.

3 The feasibility of this alternative is dependent on an agreement being reached with the
4 City of Lubbock for purchase of potable water.

5 **4.5.2 Alternative WR-2: Purchase Water from CRMWA Water Line from**
6 **Lubbock to Levelland**

7 This alternative involves purchasing compliant water from the CRMWA, which will be
8 used to supply the Whitharral WSC water system PWS. As previously stated, Whitharral
9 WSC must get approval from the CRMWA and 11-member cities to construct a direct water
10 line from the CRMWA line to Whitharral WSC.

11 This alternative would require constructing a 30,000 gallon feed tank at a point adjacent
12 to the CRMWA main distribution line that runs to the City of Levelland, and a pipeline from
13 the feed tank to the existing intake point for Whitharral WSC. A pump station would also be
14 required to overcome pipe friction and the elevation differences between the feed tank and
15 Whitharral WSC.

16 The required pipeline would be 6 inches in diameter and would follow the path shown in
17 Figure 4.1 to the existing Whitharral WSC intake point. Using this route, the length of
18 required pipe would be approximately 13 miles long. The pump station would include two
19 7.5 horsepower transfer pumps, including one standby, and would be housed in a building. It
20 is assumed the pumps and piping would be installed with capacity to meet all water demand
21 for the Whitharral WSC.

22 By definition this alternative involves regionalization, since Whitharral WSC would be
23 obtaining drinking water from an existing larger supplier. Also, other PWSs near Whitharral
24 WSC are in need of compliant drinking water and could share in implementation of this
25 alternative.

26 The estimated capital cost for this alternative includes constructing the pipeline, feed
27 tank, pump house, and pump station. The estimated O&M cost for this alternative includes
28 the purchase price for the treated water minus the cost related to current operation of the
29 Whitharral WSC water system wells, plus maintenance cost for the pipeline, and power and
30 O&M labor and materials for the pump station. The estimated capital cost for this alternative
31 is \$3.84 million, and the estimated annual O&M cost is \$35,900.

32 The reliability of adequate amounts of compliant water under this alternative should be
33 good. City of Levelland provides treated surface water on a large scale, and has adequate
34 O&M resources. From the perspective of Whitharral WSC PWS, this alternative would be
35 characterized as easy to operate and repair, since O&M and repair of pipelines and pumps is

1 well understood. If the decision were made to perform blending then the operational
2 complexity would increase.

3 The feasibility of this alternative is dependent on an agreement being reached between
4 Whitharral WSC, the CRMWA, and 11 member cities for purchase of compliant drinking
5 water.

6 **4.5.3 Alternative WR-3: Purchase Water from the City of Anton**

7 This alternative involves purchasing compliant water from the City of Anton, which
8 would be used to supply the Whitharral WSC PWS. The City of Anton currently has a
9 1.76 mgd potable water system, but does have excess production capacity. However, whether
10 the PWS and is willing to consider selling water to the Whitharral WSC PWS has not been
11 confirmed. This alternative assumes that a suitable agreement could be negotiated between
12 the two PWSs. Also, it is assumed that Whitharral WSC would obtain all its water from the
13 City of Anton.

14 This alternative would require construction of a 30,000-gallon feed tank at a point
15 adjacent to the City of Anton’s water system, and a pipeline from the feed tank to the existing
16 intake point for the Whitharral WSC. The pump station would also be required to overcome
17 pipe friction and the elevation differences between the feed tank and Whitharral WSC. The
18 pump station would include two 14.5 horsepower pumps, including one standby, and would
19 be housed in a building. It is assumed the pumps and piping would be installed with capacity
20 to meet all water demand for Whitharral WSC.

21 The required pipeline would be 6-inches in diameter and would follow the route shown in
22 Figure 4.1 to the existing Whitharral WSC intake point. Using this route, the length of pipe
23 required would be approximately 14 miles. The pipeline would terminate at the existing
24 storage tanks at the Whitharral WSC PWS.

25 The estimated capital cost for this alternative includes constructing the pipeline, feed
26 tank, and pump station. The estimated O&M cost for this alternative includes the purchase
27 price for the compliant water minus the cost that Whitharral WSC currently pays to operate its
28 wells, plus maintenance cost for the pipeline, and power and O&M labor and materials for the
29 pump station. The estimated capital cost for this alternative is \$4.05 million, and the
30 estimated annual O&M cost is \$37,600. If the purchased water was used for blending rather
31 than for the full water supply, the annual O&M cost for this alternative could be reduced
32 because of reduced pumping costs and reduced water purchase costs. However, additional
33 costs would be incurred for equipment to ensure proper blending, and additional monitoring
34 to ensure the finished water is compliant.

35 The reliability of adequate amounts of compliant water under this alternative should be
36 good. The City of Anton has adequate O&M resources. From the perspective of Whitharral

1 WSC PWS, this alternative would be characterized as easy to operate and repair, since O&M
2 and repair of pipelines and pumps is well understood, and Whitharral WSC personnel
3 currently operate pipelines and pumps. If the decision were made to perform blending, then
4 the operational complexity would increase.

5 The feasibility of this alternative is dependent on an agreement being reached with the
6 City of Anton for purchase of compliant drinking water.

7 **4.5.4 Alternative WR-4: New Well at 10 Miles**

8 This alternative consists of installing one new well within 10 miles of the Whitharral
9 WSC that would produce compliant water in place of the water produced by the existing
10 wells. At this level of study, it is not possible to positively identify an existing well or the
11 location where a new well could be installed.

12 This alternative would require constructing one new 300-foot well, two new pump
13 stations with 30,000-gallon storage tanks near each pump station. One pump station would be
14 located near the well, and one would be located along the pipeline from the new well to the
15 existing intake point for the Whitharral WSC system. The pump stations would be necessary
16 to overcome pipe friction and changes in land elevation. For this alternative, the pipeline is
17 assumed to be 6-inches in diameter, approximately 10 miles long, and would discharge to an
18 existing storage tank at the Whitharral WSC. Each pump station would include two pumps,
19 including one standby, and would be housed in a building.

20 Depending on well location and capacity, this alternative could present some options for
21 a more regional solution. It may be possible to share water and costs with another nearby
22 system.

23 The estimated capital cost for this alternative includes installing the well, constructing the
24 pipeline, pump stations, the feed tanks, service pumps, and pump house. The estimated O&M
25 cost for this alternative includes O&M for the well, pipeline, and pump station. The
26 estimated capital cost for this alternative is \$3.25 million and the estimated annual O&M cost
27 for this alternative is \$39,000.

28 The reliability of adequate amounts of compliant water under this alternative should be
29 good, since water wells, pump stations and pipelines are commonly employed. For
30 operations, this alternative would be similar to the existing system. City of Whitharral
31 personnel have experience with O&M of wells, pipelines and pumps.

32 The feasibility of this alternative is dependent on the ability to find an adequate existing
33 well or success in installing a well that produces an adequate supply of compliant water. It is
34 likely that an alternate groundwater source would not be found on land owned by the City of
35 Whitharral, so landowner cooperation would likely be required.

1 **4.5.5 Alternative WR-5: New Well at 5 Miles**

2 This alternative consists of installing one new well within 5 miles of the Whitharral WSC
3 that would produce compliant water in place of the water produced by the existing wells. At
4 this level of study, it is not possible to positively identify an existing well or the location
5 where a new well could be installed.

6 This alternative would require constructing one new 300-foot well, a new pump station
7 with a 30,000-gallon feed tank near the new well, and a pipeline from the new well/feed tank
8 to the existing intake point for the Whitharral WSC system. The pump station and feed tank
9 would be necessary to overcome pipe friction and changes in land elevation. The pump
10 station would include two pumps, including one standby, and would be housed in a building.
11 For this alternative, the pipeline would be 6-inches in diameter, assumed to be approximately
12 5 miles long, and would discharge to an existing storage tank at the Whitharral WSC PWS.

13 Depending on well location and capacity, this alternative could present some options for
14 a more regional solution. It may be possible to share water and costs with another nearby
15 system.

16 The estimated capital cost for this alternative includes installing the well, constructing the
17 pipeline, pump station, feed tank, service pumps, and pump house. The estimated O&M cost
18 for this alternative includes O&M for the well, pipeline, and pump station. The estimated
19 capital cost for this alternative is \$1.71 million and the estimated annual O&M cost for this
20 alternative is \$19,800.

21 The reliability of adequate amounts of compliant water under this alternative should be
22 good, since water wells, pump stations and pipelines are commonly employed. For
23 operations, this alternative would be similar to the existing system. City of Whitharral
24 personnel have experience with O&M of wells, pipelines and pumps.

25 The feasibility of this alternative is dependent on the ability to find an adequate existing
26 well or success in installing a well that produces an adequate supply of compliant water. It is
27 likely an alternate groundwater source would not be found on land owned by the City of
28 Whitharral, so landowner cooperation would likely be required.

29 **4.5.6 Alternative WR-6: New Well at 1 Mile**

30 This alternative consists of installing one new well within 1 mile of the Whitharral WSC
31 that would produce compliant water in place of the water produced by the existing wells. At
32 this level of study, it is not possible to positively identify an existing well or the location
33 where a new well could be installed.

1 This alternative would require constructing one new 300-foot well and a pipeline from
2 the new well to the existing intake point for the Whitharral WSC system. For this alternative,
3 the required pipeline would be 6-inches in diameter, assumed to be approximately 1 mile
4 long, and would discharge to an existing storage tank at the Whitharral WSC PWS.

5 Depending on well location and capacity, this alternative could present some options for
6 a more regional solution. It may be possible to share water and costs with another nearby
7 system. The estimated capital cost for this alternative includes installing the well and
8 constructing the pipeline. The estimated O&M cost for this alternative includes O&M for the
9 pipeline. The estimated capital cost for this alternative is \$379,200 and the estimated annual
10 O&M cost for this alternative is \$800.

11 The reliability of adequate amounts of compliant water under this alternative should be
12 good, since water wells, pump stations and pipelines are commonly employed. For
13 operations, this alternative would be similar to the existing system. City of Whitharral
14 personnel have experience with O&M of wells, pipelines and pumps.

15 The feasibility of this alternative is dependent on the ability to find an adequate existing
16 well or success in installing a well that produces an adequate supply of compliant water. It is
17 possible an alternate groundwater source would not be found on land owned by Whitharral
18 WSC, so landowner cooperation may be required.

19 **4.5.7 Alternative WR-7: Central RO Treatment**

20 This system would continue to pump water from the existing wells, and would treat the
21 water through an RO system prior to distribution. For this option, 60 percent of the raw water
22 would be treated and blended with untreated water to obtain compliant water. The RO
23 process concentrates impurities in the reject stream which would require disposal. It is
24 estimated the RO reject generation would be approximately 10,800 gallons per day (gpd)
25 when the system is operated at the average daily flow rate of 0.043 mgd. The RO reject
26 would be discharged to the city sewer for disposal.

27 This alternative consists of constructing the RO treatment plant near the existing wells.
28 The plant is composed of a 500 square foot building with a paved driveway; and a skid with
29 the pre-constructed RO plant. The treated water would be chlorinated and stored in the
30 existing water storage tank prior to being pumped into the distribution system. The entire
31 facility is fenced.

32 The estimated capital cost for this alternative is \$632,900, and the estimated annual
33 O&M cost is \$67,200.

34 The reliability of adequate amount of compliant water under this alternative is good,
35 since RO treatment is a common and well-understood treatment technology. However, O&M

1 efforts required for the central RO treatment plant may be significant, and O&M personnel
2 would require training with RO. The feasibility of this alternative is not dependent on the
3 cooperation, willingness, or capability of other water supply entities.

4 **4.5.8 Alternative WR-8: Central EDR Treatment**

5 The system would continue to pump water from the existing wells, and would treat the
6 water through an EDR system prior to distribution. For this option the EDR would treat the
7 full flow without bypass as the EDR operation can be tailored for desired removal efficiency.
8 It is estimated the EDR concentrate generation would be approximately 4,700 gpd when the
9 system is operated at the average daily flow rate of 0.043 mgd. The EDR concentrate would
10 be discharged to the city sewer for disposal.

11 This alternative consists of constructing the EDR treatment plant near the existing wells.
12 The plant is composed of a 500 square foot building with a paved driveway; and a skid with
13 the pre-constructed EDR system. The treated water would be chlorinated and stored in the
14 existing water storage tank prior to being pumped into the distribution system. The entire
15 facility is fenced.

16 The estimated capital cost for this alternative is \$853,300 and the estimated annual O&M
17 cost is \$65,100.

18 The reliability of adequate amounts of compliant water under this alternative is good,
19 since EDR treatment is a common and well-understood treatment technology. However,
20 O&M efforts required for the central EDR treatment plant may be significant, and O&M
21 personnel would require training with EDR. The feasibility of this alternative is not
22 dependent on the cooperation, willingness, or capability of other water supply entities.

23 **4.5.9 Alternative WR-9: Point-of-Use Treatment**

24 This alternative consists of the continued operation of the Whitharral WSC wells, plus
25 treatment of water to be used for drinking or food preparation at the point of use to remove
26 fluoride and nitrate. The purchase, installation, and maintenance of POU treatment systems
27 to be installed “under the sink” would be necessary for this alternative. Blending is not an
28 option in this case. According to TCEQ, when PWSs use POU treatment systems for
29 compliance, they must provide programs for long-term operation, maintenance, and
30 monitoring to ensure proper performance.

31 This alternative would require installing the POU treatment units in residences and other
32 buildings that provide drinking or cooking water. Whitharral WSC staff would be responsible
33 for purchase and maintenance of the treatment units, including membrane and filter
34 replacement, periodic sampling, and necessary repairs. In houses, the most convenient point
35 for installation of the treatment units is typically under the kitchen sink, with a separate tap

1 installed for dispensing treated water. Installation of the treatment units in kitchens will
2 require the entry of Whitharral WSC or contract personnel into the houses of customers. As a
3 result, cooperation of customers would be important for success implementing this
4 alternative. The treatment units could be installed for access without house entry, but that
5 would complicate the installation and increase costs.

6 POU treatment processes for fluoride and nitrate produce a reject waste stream. The
7 reject waste stream results in a slight increase in the overall volume of water used. POU
8 systems have the advantage that only a minimum volume of water is treated (only that for
9 human consumption). This minimizes the size of the treatment units, the increase in water
10 required, and the waste for disposal. For this alternative, it is assumed that the increase in
11 water consumption would be insignificant in terms of supply cost, and that the reject waste
12 stream can be discharged to the house septic or sewer system.

13 This alternative does not present options for a regional solution.

14 The estimated capital cost for this alternative includes purchasing and installing the POU
15 treatment systems. The estimated O&M cost for this alternative includes the purchase and
16 replacement of filters and media, as well as periodic sampling and record keeping as required
17 by the Texas Administrative Code (Title 30, Part I, Chapter 290, Subchapter F, Rule
18 290.106). The estimated capital cost for this alternative is \$101,500, and the estimated annual
19 O&M cost for this alternative is \$75,900. For the cost estimate, it is assumed that one POU
20 treatment unit will be required for each of the 82 existing connections to the Whitharral WSC
21 system. It should be noted that the POU treatment units would need to be more complex than
22 units typically found in commercial retail outlets in order to meet regulatory requirements,
23 making purchase and installation more expensive. Additionally, capital cost would increase if
24 POU treatment units are placed at other taps within a home, such as refrigerator water
25 dispensers, ice makers, and bathroom sinks. In school settings, all taps where children and
26 faculty receive water may need POU treatment units or clearly mark those taps that are
27 suitable for human consumption. Additional considerations may be necessary for preschools
28 or other establishments where individuals can not read.

29 The reliability of adequate amounts of compliant water under this alternative is fair, since
30 it relies on the active cooperation of the customers for system installation, use, and
31 maintenance, and only provides compliant water to single tap within a house. Additionally,
32 the O&M efforts (including monitoring of the devices to ensure adequate performance)
33 required for the POU systems will be significant, and the current personnel are inexperienced
34 in this type of work. From the perspective of Whitharral WSC PWS, this alternative would be
35 characterized as more difficult to operate owing to the in-home requirements and the large
36 number of individual units.

37 The feasibility of this alternative is not dependent on the cooperation, willingness, or
38 capability of other water supply entities.

1 **4.5.10 Alternative WR-10: Point-of-Entry Treatment**

2 This alternative consists of the continued operation of the Whitharral WSC wells, plus
3 treatment of water as it enters residences to remove fluoride and nitrate. The purchase,
4 installation, and maintenance of the treatment systems at the point of entry to a household
5 would be necessary for this alternative. Blending is not an option in this case.

6 This alternative would require the installation of the POE treatment units at houses and
7 other buildings that provide drinking or cooking water. Every building connected to the
8 system must have a POE device installed, maintained, and adequately monitored. TCEQ
9 must be assured that the system has 100 percent participation of all property and or building
10 owners. A way to achieve 100 percent participation is through a public announcement and
11 education program. Example public programs are provided in the document “*Point-of-Use or*
12 *Point-of-Entry*” *Treatment Options for Small Drinking Water Systems*” published by USEPA.
13 The property owner’s responsibilities for the POE device must also be contained in the title to
14 the property and “run with the land” so subsequent property owners understand their
15 responsibilities (USEPA 2006).

16 Whitharral WSC would be responsible for purchase, operation, and maintenance of the
17 treatment units, including media and filter replacement, periodic sampling, and necessary
18 repairs. It may also be desirable to modify piping so water for non-consumptive uses can be
19 withdrawn upstream of the treatment unit. The POE treatment units would be installed
20 outside the residences, so entry would not be necessary for O&M. Some cooperation from
21 customers would be necessary for installation and maintenance of the treatment systems.

22 Point-of-entry fluoride and nitrate treatment processes produce a reject stream that
23 requires disposal. The reject stream results in an increase in the overall volume of water used.
24 POE systems treat a greater volume of water than POU systems. For this alternative, it is
25 assumed that the increase in water consumption would be insignificant in terms of supply
26 cost, and that the reject waste stream can be discharged to the house septic or sewer system.

27 This alternative does not present options for a regional solution.

28 The estimated capital cost for this alternative includes purchasing and installing the POE
29 treatment systems. The estimated O&M cost for this alternative includes the purchase and
30 replacement of filters and membranes, as well as periodic sampling and record keeping. The
31 estimated capital cost for this alternative is \$1.22 million, and the estimated annual O&M cost
32 for this alternative is \$180,400. For the cost estimate, it is assumed that one POU treatment
33 unit will be required for each of the existing 82 connections in the Whitharral WSC system.

34 The reliability of adequate amounts of compliant water under this alternative is fair, but
35 better than POU systems since it relies less on the active cooperation of the customers for
36 system installation, use, and maintenance, and compliant water is supplied to all taps within a

1 house. Additionally, the O&M efforts required for the POE systems will be significant, and
2 the current personnel are inexperienced in this type of work. From the perspective of
3 Whitharral WSC PWS, this alternative would be characterized as more difficult to operate
4 owing to the on-property requirements and the large number of individual units.

5 The feasibility of this alternative is not dependent on the cooperation, willingness, or
6 capability of other water supply entities.

7 **4.5.11 Alternative WR-11: Public Dispenser for Treated Drinking Water**

8 This alternative consists of the continued operation of the Whitharral WSC wells, plus
9 dispensing treated water for drinking and cooking at a publicly accessible location.
10 Implementing this alternative would require purchasing and installing a treatment unit where
11 customers would be able to come and fill their own containers. This alternative also includes
12 notifying customers of the importance of obtaining drinking water from the dispenser. In this
13 way, only a relatively small volume of water requires treatment, but customers would be
14 required to pick up and deliver their own water. Blending is not an option in this case. It
15 should be noted that this alternative would be considered an interim measure until a
16 compliance alternative is implemented.

17 City of Whitharral personnel would be responsible for maintenance of the treatment unit,
18 including membrane replacement, periodic sampling, and necessary repairs. The spent
19 membranes will require disposal. This alternative relies on a great deal of cooperation and
20 action from the customers in order to be effective.

21 This alternative does not present options for a regional solution.

22 The estimated capital cost for this alternative includes purchasing and installing the
23 treatment system to be used for the drinking water dispenser. The estimated O&M cost for
24 this alternative includes purchasing and replacing filters and membranes, as well as periodic
25 sampling and record keeping. The estimated capital cost for this alternative is \$17,400, and
26 the estimated annual O&M cost for this alternative is \$37,200.

27 The reliability of adequate amounts of compliant water under this alternative is fair,
28 because of the large amount of effort required from the customers and the associated
29 inconvenience. Whitharral WSC PWS has not provided this type of service in the past. From
30 the perspective of Whitharral WSC PWS, this alternative would be characterized as relatively
31 easy to operate, since these types of treatment units are highly automated, and there is only
32 one dispensing unit.

33 The feasibility of this alternative is not dependent on the cooperation, willingness, or
34 capability of other water supply entities.

1 **4.5.12 Alternative WR-12: 100 Percent Bottled Water Delivery**

2 This alternative consists of the continued operation of the Whitharral WSC wells, but
3 compliant drinking water will be delivered to customers in containers. This alternative
4 involves setting up and operating a bottled water delivery program to serve all customers in
5 the system. It is expected that the City of Whitharral would find it most convenient and
6 economical to contract a bottled water service. The bottle delivery program would have to be
7 flexible enough to allow the delivery of smaller containers should customers be incapable of
8 lifting and manipulating 5-gallon bottles. Blending is not an option in this case. It should be
9 noted that this alternative would be considered an interim measure until a compliance
10 alternative is implemented.

11 This alternative does not involve capital cost for construction, but would require some
12 initial costs for system setup, and then ongoing costs to have the bottled water furnished. It is
13 assumed for this alternative that bottled water is provided to 100 percent of the Whitharral
14 WSC PWS customers.

15 This alternative does not present options for a regional solution.

16 The estimated initial capital cost is for setting up the program. The estimated O&M cost
17 for this alternative includes program administration and purchase of the bottled water. The
18 estimated capital cost for this alternative is \$24,000 and the estimated annual O&M cost for
19 this alternative is \$124,100. For the cost estimate, it is assumed that each person requires
20 1 gallon of bottled water per day.

21 The reliability of adequate amounts of compliant water under this alternative is fair, since
22 it relies on the active cooperation of customers to order and utilize the water. Management
23 and administration of the bottled water delivery program will require attention from the City
24 of Whitharral.

25 The feasibility of this alternative is not dependent on the cooperation, willingness, or
26 capability of other water supply entities.

27 **4.5.13 Alternative WR-13: Public Dispenser for Trucked Drinking Water**

28 This alternative consists of continued operation of the Whitharral WSC wells, plus
29 dispensing compliant water for drinking and cooking at a publicly accessible location. The
30 compliant water would be purchased from the City of Lubbock, and delivered by truck to a
31 tank at a central location where customers would be able to fill their own containers. This
32 alternative also includes notifying customers of the importance of obtaining drinking water
33 from the dispenser. In this way, only a relatively small volume of water requires treatment,
34 but customers are required to pick up and deliver their own water. Blending is not an option

1 in this case. It should be noted that this alternative would be considered an interim measure
2 until a compliance alternative is implemented.

3 The City of Whitharral would purchase a truck suitable for hauling potable water, and
4 install a storage tank. It is assumed the storage tank would be filled once a week, and that the
5 chlorine residual would be tested for each truckload. The truck would have to meet
6 requirements for potable water, and each load would be treated with bleach. This alternative
7 relies on a great deal of cooperation and action from the customers for it to be effective.

8 This alternative presents limited options for a regional solution if two or more systems
9 share the purchase and operation of the water truck.

10 The estimated capital cost for this alternative includes purchasing a water truck and
11 construction of the storage tank to be used for the drinking water dispenser. The estimated
12 O&M cost for this alternative includes O&M for the truck, maintenance for the tank, water
13 quality testing, record keeping, and water purchase. The estimated capital cost for this
14 alternative is \$134,900, and the estimated annual O&M cost for this alternative is \$35,900.

15 The reliability of adequate amounts of compliant water under this alternative is fair
16 because of the large amount of effort required from the customers and the associated
17 inconvenience. Current personnel have not provided this type of service in the past. From
18 the perspective of Whitharral WSC PWS, this alternative would be characterized as relatively
19 easy to operate, but the water hauling and storage would have to be done with care to ensure
20 sanitary conditions.

21 The feasibility of this alternative is not dependent on the cooperation, willingness, or
22 capability of other water supply entities.

23 **4.5.14 Summary of Alternatives**

24 Table 4.3 provides a summary of the key features of each alternative for Whitharral WSC
25 PWS.

26 **4.6 MAJOR REGIONAL SOLUTIONS**

27 A concept for a regional solution to provide compliant drinking water to PWSs near
28 Lubbock and surrounding counties was developed and evaluated to investigate whether a
29 large-scale regional approach might be more cost-effective than each PWS seeking its own
30 solution. The development and evaluation of the Lubbock Area Regional Solutions is
31 described in Appendix E. It was found that a regional solution to serving non-compliant
32 PWSs in the Lubbock area presents a potentially viable solution to an existing problem. A
33 regional system could be implemented within a cost-per-connection range of \$59/month
34 (\$711/year) to \$189/month (\$2,266/year), with the actual cost depending on the source and
35 costs of capital funds needed to build a regional system.

1 **Table 4.3 Summary of Compliance Alternatives for Whitharral WSC PWS**

Alt No.	Alternative Description	Major Components	Capital Cost ¹	Annual O&M Cost ¹	Total Annualized Cost ²	Reliability	System Impact	Remarks
WR-1	Purchase water from the City of Lubbock	- Feed tank - Pump station -12.1-mile pipeline	\$3,505,700	\$52,900	\$358,500	Good	N	Agreement must be successfully negotiated with the City of Lubbock, and a pipeline easement must be obtained. Blending may be possible. Costs could possibly be shared with small systems along pipeline route.
WR-2	Purchase water from the City of Levelland	- Feed tank - Pump station -13.3-mile pipeline	\$3,844,100	\$35,900	\$371,100	Good	N	Agreement must be successfully negotiated with the CRMWA, and a pipeline easement must be obtained. Blending may be possible. Costs could possibly be shared with small systems along pipeline route.
WR-3	Purchase water from City of Anton	- Feed tank - Pump station - 13.5 mile pipeline	\$4,051,200	\$37,600	\$390,800	Good	N	Agreement must be successfully negotiated with the City of Anton, and a pipeline easement must be obtained. Blending may be possible. Costs could possibly be shared with small systems along pipeline route.
WR-4	Install new compliant well within 10 miles	- New well - 2 Feed tank - 2 Pump stations - 10-mile pipeline	\$3,248,800	\$39,000	\$322,200	Good	N	May be difficult to find well with good water quality. Costs could possibly be shared with small systems along pipeline route.
WR-5	Install new compliant well within 5 miles	- New well - Feed tank - Pump station - 5-mile pipeline	\$1,709,600	\$19,800	\$168,800	Good	N	May be difficult to find well with good water quality. Costs could possibly be shared with small systems along pipeline route.
WR-6	Install new compliant well within 1 mile	- New well - 1-mile pipeline	\$379,200	\$800	\$33,900	Good	N	May be difficult to find well with good water quality.
WR-7	Continue operation of Whitharral WSC well field with central RO treatment	- Central RO treatment plant	\$632,900	\$67,200	\$122,400	Good	T	Costs could possibly be shared with nearby small systems.
WR-8	Continue operation of Whitharral WSC well field with central EDR treatment	- Central EDR treatment plant	\$853,300	\$65,100	\$139,500	Good	T	Costs could possibly be shared with nearby small systems.
WR-9	Continue operation of Whitharral WSC well field, and POU treatment	- POU treatment units.	\$101,500	\$75,900	\$84,700	Fair	T, M	Only one compliant tap in home. Cooperation of residents required for installation, maintenance, and testing.
WR-10	Continue operation of Whitharral WSC well field, and POE treatment	- POE treatment units.	\$1,217,700	\$180,400	\$286,600	Fair (better than POU)	T, M	All home taps compliant and less resident cooperation required.
WR-11	Continue operation of Whitharral WSC well	- Water treatment and dispenser unit	\$17,400	\$37,200	\$38,700	Fair/interim measure	T	Does not provide compliant water to all taps, and requires a lot of effort by customers.

Alt No.	Alternative Description	Major Components	Capital Cost ¹	Annual O&M Cost ¹	Total Annualized Cost ²	Reliability	System Impact	Remarks
	field, but furnish public dispenser for treated drinking water							
WR-12	Continue operation of Whitharral WSC well field, but furnish bottled drinking water for all customers	- Set up bottled water system	\$24,000	\$124,100	\$126,200	Fair/interim measure	M	Does not provide compliant water to all taps, and requires customers to order and use. Management of program may be significant.
WR-13	Continue operation of Whitharral WSC well field, but furnish public dispenser for trucked drinking water.	- Construct storage tank and dispenser - Purchase potable water truck	\$134,900	\$35,900	\$47,700	Fair/interim measure	M	Does not provide compliant water to all taps, and requires a lot of effort by customers.

1
2
3
4
5
6

Notes: N – No significant increase required in technical or management capability
T – Implementation of alternative will require increase in technical capability
M – Implementation of alternative will require increase in management capability
1 – See cost breakdown in Appendix C
2 – 20-year return period and 6 percent interest

1 **4.7 COST OF SERVICE AND FUNDING ANALYSIS**

2 To evaluate the financial impact of implementing the compliance alternatives, a 30-year
3 financial planning model was developed. This model can be found in Appendix D. The
4 financial model is based on estimated cash flows, with and without implementation of the
5 compliance alternatives. Data for such models are typically derived from established budgets,
6 audited financial reports, published water tariffs, and consumption data.

7 Whitharral WSC is a small facility with 82 metered connections serving a population
8 of 275. Information that was available to complete the financial analysis included the
9 company’s 2006 Financial Statement that included 2005-2006 revenues and expenses, 2005-
10 2006 water usage records, 2006-2007 budget, and current water rates for Whitharral WSC.

11 This analysis will need to be performed in a more detailed fashion and applied to
12 alternatives that are deemed attractive and worthy of more detailed evaluation. A more
13 detailed analysis should include additional factors such as:

- 14 • Cost escalation,
- 15 • Price elasticity effects where increased rates may result in lower water consumption,
- 16 • Costs for other system upgrades and rehabilitation needed to maintain compliant
17 operation.

18 **4.7.1 Financial Plan Development**

19 The 2006-2007 Budget as presented in 2006 Financial Statement for Whitharral WSC
20 were used in determining the water revenues and expenses for this PWS. The projected
21 annual revenue was \$57,377 estimated using a base rate of \$35.00 per month per connection
22 which included the first 3,000 gallons, an actual Tier-1 usage rate of \$1.80 per 1,000 gallons,
23 and a water usage of 15,695,000 gallons. Expenses for the water system were combined with
24 the sewer activities in the Whitharral Financial Statement. In determining the water system
25 expenses, it was assumed that the expenses were proportional to the revenue generated by the
26 water system. Revenues from the sale of water accounted for 68.5 percent of the total
27 revenues generated by the Whitharral WSC.

28 **4.7.2 Current Financial Condition**

29 **4.7.2.1 Cash Flow Needs**

30 Using the base rate and water usage rates as noted above, the current average annual
31 water bill for Whitharral WSC customers is estimated at \$700 or about 2.2 percent of the Zip
32 Code median household income of \$30,586, as given in the 2000 Census.

1 According to the Whitharral 2006 Financial Statement, the water rates are high enough to
2 meet operating expenses. However, Whitharral WSC will need to raise rates in the future to
3 service the debt associated with any capital improvements for the various alternatives that
4 may be implemented to address compliance issues.

5 **4.7.2.2 Ratio Analysis**

6 Because the Whitharral WSC 2006 Financial Statement combines the assets and
7 liabilities of its water and sewer system operations, the ratios below are not reflective of the
8 water system operation. Nevertheless, it provides a reasonable portrayal of the financial
9 status of the company as a whole.

10 *Current Ratio*

11 The Current Ratio could not be determined due to a lack of information.

12 *Debt to Net Worth Ratio=0.04*

13 A Debt to Net Worth ratio is another measure of financial liquidity and stability.
14 Whitharral WSC has a Net Worth of \$690,503, and total debt of \$25,359 resulting in a Debt
15 to Net Worth ratio is 0.04. Ratios less than 1.25 are indicative of financial stability, with
16 lower ratios indicating greater financial stability and better credit risks for future borrowings.
17 Based on the present ratio, Whitharral WSC is an excellent position for obtaining loans for
18 any system improvements.

19 *Operating Ratio = 1.53*

20 The Operating Ratio is a financial term defined as a company's revenues divided by the
21 operating expenses. An Operating Ratio of 1.0 means that a utility is collecting just enough
22 money to meet expenses. In general an operating ratio of 1.252 or higher is desirable. Based
23 on the data input into the financial model, the Whitharral WSC had operating revenues of
24 \$57,377 and operating expenses (including depreciation) of \$37,519 resulting in an Operating
25 Ratio equal to 1.53.

26 **4.7.3 Financial Plan Results**

27 Each compliance alternative for the Whitharral WSC was evaluated, with emphasis on
28 the impact on affordability (expressed as a percentage of household income), and the overall
29 increase in water rates necessary to pay for the improvements. Each alternative was
30 examined under the various funding options described in Section 2.4.

31 For SRF funding options, customer MHI compared to the state average determines the
32 availability of subsidized loans. Since the MHI for customers of Whitharral WSC was not
33 available, the Zip Code data were used. The Zip Code where the Whitharral WSC is located

1 had an estimated annual median household income of \$30,586 according to the 2000 U.S.
2 Census compared to a statewide average of \$41,000, or 74.6 percent of the statewide average.
3 Since the MHI for the Zip Code is between 70 and 75 percent of the statewide average,
4 Whitharral WSC qualifies for an interest rate of 1.0 percent. Because the MHI for the
5 Whitharral WSC is in the 70 to 75 percent bracket with respect to the statewide average, it
6 does not qualify for any Loan Forgiveness.

7 Results of the financial impact analysis are provided in Table 4.4 and Figure 4.2.
8 Table 4.4 presents rate impacts assuming that any deficiencies in reserve accounts are funded
9 immediately in the year following the occurrence of the deficiency, which would cause the
10 first few years' water rates to be higher than they would be if the reserve account was built-up
11 over a longer period of time. Figure 4.2 provides a bar chart that, in terms of the yearly
12 billing to an average customer (15,950 gallons/month consumption), shows the following:

- 13 • Current annual average bill,
- 14 • Projected annual average bill including rate increase, if needed, to match existing
15 expenditures, and
- 16 • Projected annual bill including rate increases needed to fund implementation of a
17 compliance alternative (this does not include funding for reserve accounts).


18 The two bars shown for each compliance alternative represent the rate changes necessary
19 for revenues to match total expenditures assuming 100 percent grant funding and 100 percent
20 loan/bond funding. Most funding options will fall between 100 percent grant and 100 percent
21 loan/bond funding, with the exception of 100 percent revenue financing. Establishing or
22 increasing reserve accounts would require an increase in rates. If existing reserves are
23 insufficient to fund a compliance alternative, rates would need to be raised before
24 implementing the compliance alternative. This would allow for accumulation of sufficient
25 reserves to avoid larger but temporary rate increases during the years the compliance
26 alternative was being implemented.

27


Table 4.4 Whitharral - Financial Impact on Households

Alternative	Description		All Revenue	100% Grant	75% Grant	50% Grant	SRF	Bond
1	Purchase Water from Lubbock PWS	Max % of HH Income	142%	5%	10%	16%	20%	27%
		Max % Rate Increase Compared to Current	6109%	115%	354%	593%	792%	1071%
		Average Water Bill Required by Alternative	\$ 39,298.31	\$ 1,361.64	\$ 2,845.04	\$ 4,328.43	\$ 5,564.96	\$ 7,295.23
2	Purchase Water from Anton	Max % of HH Income	163%	4%	10%	16%	22%	29%
		Max % Rate Increase Compared to Current	7033%	62%	338%	614%	844%	1166%
		Average Water Bill Required by Alternative	\$ 45,144.64	\$ 1,043.18	\$ 2,757.40	\$ 4,471.61	\$ 5,900.54	\$ 7,900.04
3	Purchase Water from Levelland	Max % of HH Income	155%	4%	10%	16%	21%	28%
		Max % Rate Increase Compared to Current	6670%	56%	318%	580%	799%	1104%
		Average Water Bill Required by Alternative	\$ 42,846.05	\$ 1,008.42	\$ 2,635.02	\$ 4,261.62	\$ 5,617.50	\$ 7,514.81
4	New Well at 10 Miles	Max % of HH Income	131%	4%	9%	14%	18%	24%
		Max % Rate Increase Compared to Current	5637%	67%	288%	510%	694%	953%
		Average Water Bill Required by Alternative	\$ 36,320.77	\$ 1,072.22	\$ 2,446.90	\$ 3,821.58	\$ 4,967.48	\$ 6,570.94
5	New Well at 5 Miles	Max % of HH Income	69%	2%	5%	8%	10%	13%
		Max % Rate Increase Compared to Current	2921%	0%	116%	233%	330%	466%
		Average Water Bill Required by Alternative	\$ 19,163.44	\$ 699.72	\$ 1,395.42	\$ 2,118.80	\$ 2,721.80	\$ 3,565.58
6	New Well at 1 Mile	Max % of HH Income	16%	2%	2%	2%	2%	3%
		Max % Rate Increase Compared to Current	603%	0%	0%	0%	7%	37%
		Average Water Bill Required by Alternative	\$ 4,509.85	\$ 699.72	\$ 699.72	\$ 699.72	\$ 731.78	\$ 918.95
7	Central Treatment - Reverse Osmosis	Max % of HH Income	28%	6%	7%	8%	9%	10%
		Max % Rate Increase Compared to Current	1128%	165%	208%	251%	287%	338%
		Average Water Bill Required by Alternative	\$ 7,807.39	\$ 1,661.21	\$ 1,929.02	\$ 2,196.84	\$ 2,420.08	\$ 2,732.47
8	Central Treatment - Electro-dialysis Reversal	Max % of HH Income	37%	6%	7%	9%	10%	11%
		Max % Rate Increase Compared to Current	1508%	158%	216%	274%	322%	390%
		Average Water Bill Required by Alternative	\$ 10,212.09	\$ 1,616.07	\$ 1,977.14	\$ 2,338.22	\$ 2,639.20	\$ 3,060.36
9	Point-of-Use Treatment	Max % of HH Income	7%	7%	7%	7%	7%	7%
		Max % Rate Increase Compared to Current	216%	195%	202%	209%	215%	223%
		Average Water Bill Required by Alternative	\$ 2,045.05	\$ 1,840.91	\$ 1,883.85	\$ 1,926.79	\$ 1,962.58	\$ 2,012.66
10	Point-of-Entry Treatment	Max % of HH Income	56%	15%	17%	19%	20%	23%
		Max % Rate Increase Compared to Current	2344%	560%	643%	726%	795%	892%
		Average Water Bill Required by Alternative	\$ 15,450.69	\$ 4,020.75	\$ 4,536.00	\$ 5,051.26	\$ 5,480.76	\$ 6,081.77
11	Public Dispenser for Treated Drinking Water	Max % of HH Income	4%	4%	4%	4%	4%	4%
		Max % Rate Increase Compared to Current	61%	61%	62%	63%	64%	65%
		Average Water Bill Required by Alternative	\$ 1,049.18	\$ 1,035.49	\$ 1,042.85	\$ 1,050.21	\$ 1,056.35	\$ 1,064.94
12	Supply Bottled Water to 100% of Population	Max % of HH Income	11%	11%	11%	11%	11%	11%
		Max % Rate Increase Compared to Current	363%	363%	365%	367%	368%	370%
		Average Water Bill Required by Alternative	\$ 2,865.69	\$ 2,846.81	\$ 2,856.96	\$ 2,867.12	\$ 2,875.58	\$ 2,887.43
13	Central Trucked Drinking Water	Max % of HH Income	7%	4%	4%	4%	4%	4%
		Max % Rate Increase Compared to Current	205%	56%	65%	74%	82%	93%
		Average Water Bill Required by Alternative	\$ 1,988.65	\$ 1,008.57	\$ 1,065.63	\$ 1,122.69	\$ 1,170.25	\$ 1,236.81

Figure 4-2 Whitharral - Alternative Cost Summary



Current Rates:
 Monthly: \$58.33
 Median Household Income \$30,586
 Average Monthly Residential Usage 15,950 gallons



**SECTION 5
REFERENCES**

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34

Ashworth, J.B., and R.R. Flores. 1991. Delineation criteria for the major and minor aquifer maps of Texas. Texas Water Development Board Report LP-212, 27 p.

Blandford, T.N., D.J. Blazer, K.C. Calhoun, A.R. Dutton, T. Naing, R.C. Reedy, and B.R. Scanlon. 2003. Groundwater Availability Model of the Southern Ogallala Aquifer in Texas and New Mexico: Numerical Simulations Through 2050 [available online at <http://www.twdb.state.tx.us/gam/index.htm>].

Dutton, A.R. and W.W. Simpkins. 1986. Hydrogeochemistry and water resources of the Triassic lower Dockum Group in the Texas Panhandle and eastern New Mexico. University of Texas, Bureau of Economic Geology Report of Investigations No 161, 51p.

Gustavson, T.C. and V.T. Holliday. 1985. Depositional architecture of the Quaternary Blackwater Draw and Tertiary Ogallala Formations, Texas Panhandle and eastern New Mexico. The University of Texas at Austin Bureau of Economic Geology Open File Report of West Texas Waste Isolation 1985-23, 60 p.

Holliday, V.T. 1989. The Blackwater Draw Formation (Quaternary): a 1.4-plus-m.y. record of eolian sedimentation and soil formation on the Southern High Plains. Geological Society of America Bulletin 101:1598-1607.

McGowen, J.H., G.E. Granata, and S.J. Seni. 1977. Depositional systems, uranium occurrence and postulated ground-water history of the Triassic Dockum Group, Texas Panhandle-Eastern New Mexico. The University of Texas at Austin, Bureau of Economic Geology, report prepared for the U.S. Geological Survey under grant number 14-08-0001-G410, 104 p.

Nativ, R. 1988. Hydrogeology and hydrochemistry of the Ogallala Aquifer, Southern High Plains, Texas Panhandle and Eastern New Mexico. The University of Texas, Bureau of Economic Geology Report of Investigations No. 177, 64 p.

Raucher, Robert S., Marca Hagenstad, Joseph Cotruvo, Kate Martin, and Harish Arora. 2004. Conventional and Unconventional Approaches to Water Service Provision. AWWA Research Foundation and American Water Works Association.

TCEQ 2004. Drinking Water Quality and Reporting Requirements for PWSs: 30 TAC 290 Subchapter F (290.104. Summary of Maximum Contaminant Levels, Maximum Residual Disinfectant Levels, Treatment Techniques, and Action Levels). Revised February 2004.

- 1 TWDB 2007a. 2007 State Water Plan Aquifer Sheet, Ogallala Aquifer. [available online at
2 <http://www.twdb.state.tx.us/GwRD/GMA/PDF/OgallalaAquifer.pdf>].
- 3 TWDB 2007b. 2007 State Water Plan Aquifer Sheet, Edwards-Trinity (High Plains) Aquifer.
4 Texas Water Development Board. [available online at
5 <http://www.twdb.state.tx.us/GwRD/GMA/PDF/Edwards->
6 [Trinity\(High%20Plains\)Aquifer.pdf](http://www.twdb.state.tx.us/GwRD/GMA/PDF/Edwards-Trinity(High%20Plains)Aquifer.pdf)].
- 7 TWDB 2007c. Groundwater Management Area 2. Texas Water Development Board.
8 Reviewed online August 2007
9 [<http://www.twdb.state.tx.us/GwRD/GMA/gma2/gma2home.htm>].
- 10 USEPA 1980. Innovative and Alternative Technology Assessment Manual. 430/9-78-009.
11 MCD-53. Office of Water Program Operations, Washington D.C. and Office of
12 Research and Development, Cincinnati, OH *Innovative and Alternate Technology*
13 *Assessment Manual MCD 53*.
- 14 USEPA 1992. Standardized Costs for Water Supply Distribution Systems. Gumerman,
15 R., Burris, B., and Burris D. EPA 600/R-92/009. Cincinnati, OH.
- 16 USEPA 2006. Point-of-Use or Point-of-Entry Treatment Options for Small Drinking Water
17 Systems. EPA 815-R-06-010. April 2006 Retrieved from
18 <http://www.epa.gov/safewater/smallsys/ssinfo.htm> on August 21, 2007.
- 19 USEPA 2007a. List of Drinking Water Contaminants & MCLs. Online. November 28th,
20 2006. www.epa.gov/safewater/mcl.html.
- 21 USEPA 2007b. 2007 Consumer Factsheet on: Nitrates/Nitrites. Online at:
22 http://www.epa.gov/safewater/contaminants/dw_contamfs/nitrates.html Last updated
23 on November 28th, 2006.
- 24 USEPA 2007c. Drinking Water Contaminants (*on Fluoride*). Online at:
25 <http://www.epa.gov/safewater/hfacts.html>. Last updated on November 28th, 2006.

1
2

**APPENDIX A
PWS INTERVIEW FORM**

CAPACITY DEVELOPMENT ASSESSMENT FORM

Prepared By _____

Date _____

Section 1. Public Water System Information

1. PWS ID #	<input type="text"/>	2. Water System Name	<input type="text"/>
3. County	<input type="text"/>		
4. Owner	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
5. Admin	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
6. Operator	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
7. Population Served	<input type="text"/>	8. No. of Service Connections	<input type="text"/>
9. Ownership Type	<input type="text"/>	10. Metered (Yes or No)	<input type="text"/>
11. Source Type	<input type="text"/>		
12. Total PWS Annual Water Used	<input type="text"/>		
13. Number of Water Quality Violations (Prior 36 months)			
Total Coliform	<input type="text"/>	Chemical/Radiological	<input type="text"/>
Monitoring (CCR, Public Notification, etc.)	<input type="text"/>	Treatment Technique, D/DBP	<input type="text"/>

A. Basic Information

1. Name of Water System:
2. Name of Person Interviewed:
3. Position:
4. Number of years at job:
5. Number of years experience with drinking water systems:
6. Percent of time (day or week) on drinking water system activities, with current position (how much time is dedicated exclusively to the water system, not wastewater, solid waste or other activities):
7. Certified Water Operator (Yes or No):
 If Yes,
 7a. Certification Level (water):
 7b. How long have you been certified?
8. Describe your water system related duties on a typical day.

B. Organization and Structure

1. Describe the organizational structure of the Utility. Please provide an organizational chart. (Looking to find out the governance structure (who reports to whom), whether or not there is a utility board, if the water system answers to public works or city council, etc.)

2. If not already covered in Question 1, to whom do you report?
3. Do all of the positions have a written job description?
 - 3a. If yes, is it available to employees?
 - 3b. May we see a copy?

C. Personnel

1. What is the current staffing level (include all personnel who spend more than 10% of their time working on the water system)?

2. Are there any vacant positions? How long have the positions been vacant?

3. In your opinion, is the current staffing level adequate? If not adequate, what are the issues or staffing needs (how many and what positions)?

4. What is the rate of employee turnover for management and operators? What are the major issues involved in the turnover (e.g., operator pay, working conditions, hours)?

5. Is the system staffed 24 hours a day? How is this handled (on-site or on-call)? Is there an alarm system to call an operator if an emergency occurs after hours?

D. Communication

1. Does the utility have a mission statement? If yes, what is it?

2. Does the utility have water quality goals? What are they?

3. How are your work priorities set?

4. How are work tasks delegated to staff?

5. Does the utility have regular staff meetings? How often? Who attends?

6. Are there separate management meetings? If so, describe.

7. Do management personnel ever visit the treatment facility? If yes, how often?

8. Is there effective communication between utility management and state regulators (e.g., NMED)?

9. Describe communication between utility and customers.

E. Planning and Funding

1. Describe the rate structure for the utility.

2. Is there a written rate structure, such as a rate ordinance? May we see it?
 - 2a. What is the average rate for 6,000 gallons of water?

3. How often are the rates reviewed?

4. What process is used to set or revise the rates?

5. In general, how often are the new rates set?

6. Is there an operating budget for the water utility? Is it separate from other activities, such as wastewater, other utilities, or general city funds?

7. Who develops the budget, how is it developed and how often is a new budget created or the old budget updated?

8. How is the budget approved or adopted?

9. In the last 5 years, how many budget shortfalls have there been (i.e., didn't collect enough money to cover expenses)? What caused the shortfall (e.g., unpaid bills, an emergency repair, weather conditions)?

9a. How are budget shortfalls handled?
10. In the last 5 years how many years have there been budget surpluses (i.e., collected revenues exceeded expenses)?

10a. How are budget surpluses handled (i.e., what is done with the money)?
11. Does the utility have a line-item in the budget for emergencies or some kind of emergency reserve account?
12. How do you plan and pay for short-term system needs?
13. How do you plan and pay for long- term system needs?
14. How are major water system capital improvements funded? Does the utility have a written capital improvements plan?
15. How is the facility planning for future growth (either new hook-ups or expansion into new areas)?
16. Does the utility have and maintain an annual financial report? Is it presented to policy makers?

17. Has an independent financial audit been conducted of the utility finances? If so, how often? When was the last one?
18. Will the system consider any type of regionalization with any other PWS, such as system interconnection, purchasing water, sharing operator, emergency water connection, sharing bookkeeper/billing or other?

F. Policies, Procedures, and Programs
--

1. Are there written operational procedures? Do the employees use them?
2. Who in the utility department has spending authorization? What is the process for obtaining needed equipment or supplies, including who approves expenditures?
3. Does the utility have a source water protection program? What are the major components of the program?
4. Are managers and operators familiar with current SDWA regulations?
5. How do the managers and operators hear about new or proposed regulations, such as arsenic, DBP, Groundwater Rule? Are there any new regulations that will be of particular concern to the utility?
6. What are the typical customer complaints that the utility receives?
7. Approximately how many complaints are there per month?

8. How are customer complaints handled? Are they recorded?

9. (If not specifically addressed in Question 7) If the complaint is of a water quality nature, how are these types of complaints handled?

10. Does the utility maintain an updated list of critical customers?

11. Is there a cross-connection control plan for the utility? Is it written? Who enforces the plan's requirements?

12. Does the utility have a written water conservation plan?

13. Has there been a water audit of the system? If yes, what were the results?

14. (If not specifically answered in 11 above) What is the estimated percentage for loss to leakage for the system?

15. Are you, or is the utility itself, a member of any trade organizations, such as AWWA or Rural Water Association? Are you an active member (i.e., attend regular meetings or participate in a leadership role)? Do you find this membership helpful? If yes, in what ways does it help you?

G. Operations and Maintenance

1. How is decision-making authority split between operations and management for the following items:
 - a. Process Control
 - b. Purchases of supplies or small equipment
 - c. Compliance sampling/reporting
 - d. Staff scheduling

2. Describe your utility's preventative maintenance program.

3. Do the operators have the ability to make changes or modify the preventative maintenance program?

4. How does management prioritize the repair or replacement of utility assets? Do the operators play a role in this prioritization process?

5. Does the utility keep an inventory of spare parts?

6. Where does staff have to go to buy supplies/minor equipment? How often?
 - 6a. How do you handle supplies that are critical, but not in close proximity (for example if chlorine is not available in the immediate area or if the components for a critical pump are not in the area)

7. Describe the system's disinfection process. Have you had any problems in the last few years with the disinfection system?

7a. Who has the ability to adjust the disinfection process?

8. How often is the disinfectant residual checked and where is it checked?

8a. Is there an official policy on checking residuals or is it up to the operators?

9. Does the utility have an O & M manual? Does the staff use it?

10. Are the operators trained on safety issues? How are they trained and how often?

11. Describe how on-going training is handled for operators and other staff. How do you hear about appropriate trainings? Who suggests the trainings – the managers or the operators? How often do operators, managers, or other staff go to training? Who are the typical trainers used and where are the trainings usually held?

12. In your opinion is the level of your on-going training adequate?

13. In your opinion is the level of on-going training for other staff members, particularly the operators, adequate?

14. Does the facility have mapping of the water utility components? Is it used on any routine basis by the operators or management? If so, how is it used? If not, what is the process used for locating utility components?
15. In the last sanitary survey, were any deficiencies noted? If yes, were they corrected?
16. How often are storage tanks inspected? Who does the inspection?
 - 16a. Have you experienced any problems with the storage tanks?

H. SDWA Compliance

1. Has the system had any violations (monitoring or MCL) in the past 3 years? If so, describe.
2. How were the violations handled?
3. Does the system properly publish public notifications when notified of a violation?
4. Is the system currently in violation of any SDWA or state regulatory requirements, including failure to pay fees, fines, or other administrative type requirements?
5. Does the utility prepare and distribute a Consumer Confidence Report (CCR)? Is it done every year? What type of response does the utility get to the CCR from customers?

I. Emergency Planning

1. Does the system have a written emergency plan to handle emergencies such as water outages, weather issues, loss of power, loss of major equipment, etc?
2. When was the last time the plan was updated?
3. Do all employees know where the plan is? Do they follow it?
4. Describe the last emergency the facility faced and how it was handled.

Attachment A

A. Technical Capacity Assessment Questions

1. Based on available information of water rights on record and water pumped has the system exceeded its water rights in the past year? YES NO

In any of the past 5 years? YES NO How many times? _____

2. Does the system have the proper level of certified operator? *(Use questions a – c to answer.)*
 YES NO

a. What is the Classification Level of the system by NMED? _____

b. Does the system have one or more certified operator(s)? [20 NMAC 7.4.20]

YES NO

c. If YES, provide the number of operators at each New Mexico Certification Level. [20 NMAC 7.4.12]

_____ NM Small System _____ Class 2

_____ NM Small System Advanced _____ Class 3

_____ Class 1 _____ Class 4

3. Did the system correct any sanitary deficiency noted on the most recent sanitary survey within 6 months of receiving that information? [20 NMAC 7.20.504]

YES NO No Deficiencies

What was the type of deficiency? *(Check all that are applicable.)*

Source Storage

Treatment Distribution

Other _____

From the system's perspective, were there any other deficiencies that were not noted on the sanitary survey?
 Please describe.

4. Will the system's current treatment process meet known future regulations?

Radionuclides YES NO Doesn't Apply

Arsenic YES NO Doesn't Apply

Stage 1 Disinfectants and Disinfection By-Product (DBP)

YES NO Doesn't Apply

Surface Water Treatment Rule YES NO Doesn't Apply

5. Does the system have a current site plan/map? [20 NMAC 7.10.302 A.1.]

YES NO

6. Has the system had a water supply outage in the prior 24 months?

YES NO

What were the causes of the outage(s)? (Include number of outages for each cause.)

Drought _____ Limited Supply _____

System Failure _____ Other _____

7. Has the system ever had a water audit or a leak evaluation?

YES NO Don't Know

If YES, please complete the following table.

Type of Investigation	Date Done	Water Loss (%)	What approach or technology was used to complete the investigation?	Was any follow-up done? If so, describe

8. Have all drinking water projects received NMED review and approval? [20 NMAC 7.10.201]

YES NO

If NO, what types of projects have not received NMED review and approval.

Source Storage

Treatment Distribution

Other _____

9. What are the typical customer complaints that the utility receives?

10. Approximately how many complaints are there per month? _____

11. How are customer complaints handled? Are they recorded?

12. What is the age and composition of the distribution system? *(Collect this information from the Sanitary Survey)*

Pipe Material	Approximate Age	Percentage of the system	Comments
			Sanitary Survey Distribution System Records Attached

13. Are there any dead end lines in the system?
 YES NO

14. Does the system have a flushing program?
 YES NO
 If YES, please describe.

15. Are there any pressure problems within the system?
 YES NO
 If YES, please describe.

16. Does the system disinfect the finished water?
 YES NO
 If yes, which disinfectant product is used? _____

Interviewer Comments on Technical Capacity:

B. Managerial Capacity Assessment Questions

17. Has the system completed a 5-year Infrastructure Capital Improvement Plan (ICIP) plan?
 YES NO

If YES, has the plan been submitted to Local Government Division?
 YES NO

18. Does the system have written operating procedures?
 YES NO

19. Does the system have written job descriptions for all staff?
 YES NO

20. Does the system have:
- A preventative maintenance plan?
YES NO
 - A source water protection plan?
YES NO N/A
 - An emergency plan?
YES NO
 - A cross-connection control program?
YES NO
 - An emergency source?
YES NO
 - System security measures?
YES NO
21. Does the system report and maintain records in accordance with the drinking water regulations concerning:
- Water quality violations
YES NO
 - Public notification
YES NO
 - Sampling exemptions
YES NO
22. Please describe how the above records are maintained:
23. Describe the management structure for the water system, including board and operations staff. Please include examples of duties, if possible.
24. Please describe type and quantity of training or continuing education for staff identified above.
25. Describe last major project undertaken by the water system, including the following: project in detail, positive aspects, negative aspects, the way in which the project was funded, any necessary rate increases, the public response to the project, whether the project is complete or not, and any other pertinent information.

26. Does the system have any debt? YES NO

If yes, is the system current with all debt payments?

YES NO

If no, describe the applicable funding agency and the default.

27. Is the system currently contemplating or actively seeking funding for any project?

YES NO

If yes, from which agency and how much?

Describe the project?

Is the system receiving assistance from any agency or organization in its efforts?

28. Will the system consider any type of regionalization with other PWS? (Check YES if the system has already regionalized.)

YES NO

If YES, what type of regionalization has been implemented/considered/discussed? (Check all that apply.)

System interconnection

Sharing operator

Sharing bookkeeper

Purchasing water

Emergency water connection

Other: _____

29. Does the system have any of the following? (Check all that apply.)

Water Conservation Policy/Ordinance Current Drought Plan

Water Use Restrictions Water Supply Emergency Plan

Interviewer Comments on Managerial Capacity:

C. Financial Capacity Assessment

30. Does the system have a budget?
 YES NO
 If YES, what type of budget?
 Operating Budget
 Capital Budget
31. Have the system revenues covered expenses and debt service for the past 5 years?
 YES NO
 If NO, how many years has the system had a shortfall? _____
32. Does the system have a written/adopted rate structure?
 YES NO
33. What was the date of the last rate increase? _____
34. Are rates reviewed annually?
 YES NO
 IF YES, what was the date of the last review? _____
35. Did the rate review show that the rates covered the following expenses? *(Check all that apply.)*
- | | |
|-------------------------------------|--------------------------|
| Operation & Maintenance | <input type="checkbox"/> |
| Infrastructure Repair & replacement | <input type="checkbox"/> |
| Staffing | <input type="checkbox"/> |
| Emergency/Reserve fund | <input type="checkbox"/> |
| Debt payment | <input type="checkbox"/> |
36. Is the rate collection above 90% of the customers?
 YES NO
37. Is there a cut-off policy for customers who are in arrears with their bill or for illegal connections?
 YES NO
 If yes, is this policy implemented?
38. What is the residential water rate for 6,000 gallons of usage in one month. _____
39. In the past 12 months, how many customers have had accounts frozen or dropped for non-payment? _____
 [Convert to % of active connections
 Less than 1% 1% - 3% 4% - 5% 6% - 10%
 11% - 20% 21% - 50% Greater than 50%]

40. The following questions refer to the process of obtaining needed equipment and supplies.

a. Can the water system operator buy or obtain supplies or equipment when they are needed?

YES NO

b. Is the process simple or burdensome to the employees?

c. Can supplies or equipment be obtained quickly during an emergency?

YES NO

d. Has the water system operator ever experienced a situation in which he/she couldn't purchase the needed supplies?

YES NO

e. Does the system maintain some type of spare parts inventory?

YES NO

If yes, please describe.

41. Has the system ever had a financial audit?

YES NO

If YES, what is the date of the most recent audit? _____

42. Has the system ever had its electricity or phone turned off due to non-payment? Please describe.

Interviewer Comments on Financial Assessment:

43. What do you think the system capabilities are now and what are the issues you feel your system will be facing in the future? In addition, are there any specific needs, such as types of training that you would like to see addressed by NMED or its contractors?

APPENDIX B COST BASIS

This section presents the basis for unit costs used to develop the conceptual cost estimates for the compliance alternatives. Cost estimates are conceptual in nature (+50%/-30%), and are intended to make comparisons between compliance options and to provide a preliminary indication of possible rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. Capital cost includes an allowance for engineering and construction management. It is assumed that adequate electrical power is available near the site. The cost estimates specifically do not include costs for the following:

- Obtaining land or easements.
- Surveying.
- Mobilization/demobilization for construction.
- Insurance and bonds

In general, unit costs are based on recent construction bids for similar work in the area when possible, consultations with vendors or other suppliers, published construction and O&M cost data, and USEPA cost guidance. Unit costs used for the cost estimates are summarized in Table B.1.

Unit costs for pipeline components are based on 2007 RS Means Site Work & Landscape Cost Data. The number of borings and encasements and open cuts and encasements is estimated by counting the road, highway, railroad, stream, and river crossings for a conceptual routing of the pipeline. The number of air release valves is estimated by examining the land surface profile along the conceptual pipeline route. It is assumed that gate valves and flush valves would be installed, on average, every 5,000 feet along the pipeline. Pipeline cost estimates are based on the use of C-900 PVC pipe. Other pipe materials could be considered for more detailed development of attractive alternatives.

Pump station unit costs are based on experience with similar installations. The cost estimate for the pump stations include two pumps, station piping and valves, station electrical and instrumentation, minor site improvement, installation of a concrete pad, fence and building, and tools. The number of pump stations is based on calculations of pressure losses in the proposed pipeline for each alternative. Back-flow prevention is required in cases where pressure losses are negligible, and pump stations are not needed. Construction cost of a storage tank is based on consultations with vendors and 2007 RS Means Site Work & Landscape Cost Data.

Labor costs are estimated based on 2007 RS Means Site Work & Landscape Cost Data specific to the Lubbock County region.

1 Electrical power cost is estimated to be \$0.043 per kWh, as supplied by Xcel Energy.
2 The annual cost for power to a pump station is calculated based on the pumping head and
3 volume, and includes 11,800 kWh for pump building heating, cooling, and lighting, as
4 recommended in USEPA publication, *Standardized Costs for Water Supply Distribution*
5 *Systems* (1992).

6 In addition to the cost of electricity, pump stations have other maintenance costs. These
7 costs cover: materials for minor repairs to keep the pumps operating; purchase of a
8 maintenance vehicle, fuel costs, and vehicle maintenance costs; utilities; office supplies, small
9 tools and equipment; and miscellaneous materials such as safety, clothing, chemicals, and
10 paint. The non-power O&M costs are estimated based on the USEPA publication,
11 *Standardized Costs for Water Supply Distribution Systems* (1992), which provides cost curves
12 for O&M components. Costs from the 1992 report are adjusted to 2007 dollars based on the
13 ENR construction cost index.

14 Pipeline maintenance costs include routine cleaning and flushing, as well as minor
15 repairs to lines. The unit rate for pipeline maintenance is calculated based on the USEPA
16 technical report, *Innovative and Alternate Technology Assessment Manual MCD 53* (1980).
17 Costs from the 1980 report are adjusted to 2007 dollars based on the ENR construction cost
18 index.

19 Storage tank maintenance costs include cleaning and renewal of interior lining and
20 exterior coating. Unit costs for storage tank O&M are based on USEPA publication
21 *Standardized Costs for Water Supply Distribution Systems* (1992). Costs from the 1992
22 report are adjusted to 2007 dollars based on the ENR construction cost index.

23 The purchase price for point-of-use (POU) water treatment units is based on vendor price
24 lists for treatment units, plus installation. O&M costs for POU treatment units are also based
25 on vendor price lists. It is assumed that a yearly water sample would be analyzed for the
26 contaminant of concern.

27 The purchase price for point-of-entry (POE) water treatment units is based on vendor
28 price lists for treatment units, plus an allowance for installation, including a concrete pad and
29 shed, piping modifications, and electrical connection. O&M costs for POE treatment units
30 are also based on vendor price lists. It is assumed that a yearly water sample would be
31 analyzed for the contaminant of concern.

32 Central treatment plant costs, for both adsorption and coagulation/filtration, include
33 pricing for buildings, utilities, and site work. Costs are based on pricing given in the various
34 2007 RS Means Cost Data references, as well as prices obtained from similar work on other
35 projects. Pricing for treatment equipment was obtained from vendors.

36 Well installation costs are based on quotations from drillers for installation of similar
37 depth wells in the area. Well installation costs include drilling, a well pump, electrical and
38 instrumentation installation, well finishing, piping, and water quality testing. O&M costs for
39 water wells include power, materials, and labor.

1 Purchase price for the treatment unit dispenser is based on vendor price lists, plus an
2 allowance for installation at a centralized public location. The O&M costs are also based on
3 vendor price lists. It is assumed that weekly water samples would be analyzed for the
4 contaminant of concern.

5 Costs for bottled water delivery alternatives are based on consultation with vendors that
6 deliver residential bottled water. The cost estimate includes an initial allowance for set-up of
7 the program, and a yearly allowance for program administration.

8 The cost estimate for a public dispenser for trucked water includes the purchase price for
9 a water truck and construction of a storage tank. Annual costs include labor for purchasing
10 the water, picking up and delivering the water, truck maintenance, and water sampling and
11 testing. It is assumed the water truck would be required to make one trip per dispenser each
12 week, and that chlorine residual would be determined for each truck load.

Table B.1
Summary of General Data
Whitharral WSC
1100011
General PWS Information

Service Population 275	Number of Connections 82
Total PWS Daily Water Usage 0.043 (mgd)	Source Site visit list

Unit Cost Data

General Items	Unit	Unit Cost	Central Treatment Unit Costs	Unit	Unit Cost
Treated water purchase cost		<i>See alternative</i>	General		
Water purchase cost (trucked)	\$/1,000 gals	\$ 1.52	Site preparation	acre	\$ 4,000
			Slab	CY	\$ 1,000
Contingency	20%	n/a	Building	SF	\$ 60
Engineering & Constr. Management	25%	n/a	Building electrical	SF	\$ 8
Procurement/admin (POU/POE)	20%	n/a	Building plumbing	SF	\$ 8
			Heating and ventilation	SF	\$ 7
			Fence	LF	\$ 15
Pipeline Unit Costs	Unit	Unit Cost	Paving	SF	\$ 2
PVC water line, Class 200, 06"	LF	\$ 32	Chlorination point	EA	\$ 2,000
Bore and encasement, 10"	LF	\$ 240	Building power	\$/kWH	\$ 0.043
Open cut and encasement, 10"	LF	\$ 105	Equipment power	\$/kWH	\$ 0.043
Gate valve and box, 06"	EA	\$ 915	Labor, O&M	hr	\$ 40
Air valve	EA	\$ 2,000	Analyses	test	\$ 200
Flush valve	EA	\$ 1,000	Sewage connection fee	EA	\$ 15,000
Metal detectable tape	LF	\$ 2.00	Sewage connection construction	EA	\$ 50,000
Bore and encasement, length	Feet	200	Reverse Osmosis		
Open cut and encasement, length	Feet	50	Electrical	JOB	\$ 50,000
			Piping	JOB	\$ 20,000
Pump Station Unit Costs	Unit	Unit Cost	RO package plant	UNIT	\$ 200,000
Pump	EA	\$ 8,000	RO materials	year	\$ 6,000
Pump Station Piping, 06"	EA	\$ 815	RO chemicals	year	\$ 3,000
Gate valve, 06"	EA	\$ 915	Discharge fee	1,000 gal/yr	\$ 5
Check valve, 06"	EA	\$ 915			
Electrical/Instrumentation	EA	\$ 10,000	EDR		
Site work	EA	\$ 2,500	Electrical	JOB	\$ 60,000
Building pad	EA	\$ 5,000	Piping	JOB	\$ 30,000
Pump Building	EA	\$ 10,000	EDR package plant	UNIT	\$ 320,000
Fence	EA	\$ 6,000	Transfer pumps (5 hp)	EA	\$ 6,000
Tools	EA	\$ 1,000	EDR materials	year	\$ 6,000
			EDR chemicals	year	\$ 3,000
Well Installation Unit Costs	Unit	Unit Cost	Discharge fee	1,000 gal/yr	\$ 5
Well installation		<i>See alternative</i>			
Water quality testing	EA	\$ 1,250			
Well pump	EA	\$ 10,000			
Well electrical/instrumentation	EA	\$ 5,500			
Well cover and base	EA	\$ 3,000			
Piping	EA	\$ 3,000			
30,000 gal storage / feed tank	EA	\$ 45,000			
Electrical Power	\$/kWH	\$ 0.043			
Building Power	kWH	11,800			
Labor	\$/hr	\$ 68			
Materials	EA	\$ 1,500			
Transmission main O&M	\$/mile	\$ 250			
Tank O&M	EA	\$ 1,000			
POU/POE Unit Costs					
POU treatment unit purchase	EA	\$ 600			
POU treatment unit installation	EA	\$ 150			
POE treatment unit purchase	EA	\$ 5,000			
POE - pad and shed, per unit	EA	\$ 2,000			
POE - piping connection, per unit	EA	\$ 1,000			
POE - electrical hook-up, per unit	EA	\$ 1,000			
POU Treatment O&M, per unit	\$/year	\$ 225			
POE Treatment O&M, per unit	\$/year	\$ 1,500			
Treatment analysis	\$/year	\$ 200			
POU/POE labor support	\$/hr	\$ 50			
Dispenser/Bottled Water Unit Costs					
POE-Treatment unit purchase	EA	\$ 7,000			
POE-Treatment unit installation	EA	\$ 5,000			
Treatment unit O&M	EA	\$ 2,000			
Administrative labor	hr	\$ 40			
Bottled water cost (inc. delivery)	gallon	\$ 1			
Water use, per capita per day	gpcd	1.0			
Bottled water program materials	EA	\$ 5,000			
5,000 gal storage / feed tank	EA	\$ 15,000			
Site improvements	EA	\$ 3,000			
Potable water truck	EA	\$ 75,000			
Water analysis, per sample	EA	\$ 200			
Potable water truck O&M costs	\$/mile	\$ 2			

1
2
3
4
5
6
7
8

APPENDIX C
COMPLIANCE ALTERNATIVE CONCEPTUAL COST ESTIMATES

This appendix presents the conceptual cost estimates developed for the compliance alternatives. The conceptual cost estimates are given in Tables C.1 through C.13. The cost estimates are conceptual in nature (+50%/-30%), and are intended for making comparisons between compliance options and to provide a preliminary indication of possible water rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation.

Table C.1

PWS Name *Whitharal WSC*
Alternative Name *Purchase Water from Lubbock PWS*
Alternative Number *WR-1*

Distance from Alternative to PWS (along pipe) 12.14 miles
Total PWS annual water usage 15.695 MG
Treated water purchase cost \$ 2.61 per 1,000 gals
Pump Stations needed w/ 1 feed tank each 1
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	16	n/a	n/a	n/a
PVC water line, Class 200, 06"	64,099	LF	\$ 32	\$ 2,051,174
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	800	LF	\$ 105	\$ 84,000
Gate valve and box, 06"	13	EA	\$ 915	\$ 11,730
Air valve	14	EA	\$ 2,000	\$ 28,000
Flush valve	13	EA	\$ 1,000	\$ 12,820
Metal detectable tape	64,099	LF	\$ 2	\$ 128,198
Subtotal				\$ 2,315,923

<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 06"	1	EA	\$ 815	\$ 815
Gate valve, 06"	4	EA	\$ 915	\$ 3,660
Check valve, 06"	2	EA	\$ 915	\$ 1,830
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,500	\$ 2,500
Building pad	1	EA	\$ 5,000	\$ 5,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 6,000	\$ 6,000
Tools	1	EA	\$ 1,000	\$ 1,000
30,000 gal storage / feed tank	1	EA	\$ 45,000	\$ 45,000
Subtotal				\$ 101,805

Subtotal of Component Costs \$ 2,417,728

Contingency 20% \$ 483,546
 Design & Constr Management 25% \$ 604,432

TOTAL CAPITAL COSTS **\$ 3,505,705**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	12.14	mile	\$ 250	\$ 3,035
Subtotal				\$ 3,035
<i>Water Purchase Cost</i>				
From PWS	15,695	1,000 gal	\$ 2.61	\$ 40,964
Subtotal				\$ 40,964

<i>Pump Station(s) O&M</i>				
Building Power	11,800	kWH	\$ 0.043	\$ 507
Pump Power	11,132	kWH	\$ 0.043	\$ 479
Materials	1	EA	\$ 1,500	\$ 1,500
Labor	365	Hrs	\$ 40	\$ 14,600
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 18,086

<i>O&M Credit for Existing Well Closure</i>				
Pump power	12,130	kWH	\$ 0.043	\$ (522)
Well O&M matl	1	EA	\$ 1,500	\$ (1,500)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (9,222)

TOTAL ANNUAL O&M COSTS **\$ 52,863**

Table C.2

PWS Name *Whitharal WSC*
Alternative Name *Purchase Water from Levelland*
Alternative Number *WR-2*

Distance from Alternative to PWS (along pipe) 13.27 miles
Total PWS annual water usage 15.695 MG
Treated water purchase cost \$ 1.52 per 1,000 gals
Pump Stations needed w/ 1 feed tank each 1
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	21	n/a	n/a	n/a
PVC water line, Class 200, 06"	70,066	LF	\$ 32	\$ 2,242,099
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	1,050	LF	\$ 105	\$ 110,250
Gate valve and box, 06"	14	EA	\$ 915	\$ 12,822
Air valve	15	EA	\$ 2,000	\$ 30,000
Flush valve	14	EA	\$ 1,000	\$ 14,013
Metal detectable tape	70,066	LF	\$ 2	\$ 140,131
Subtotal				\$ 2,549,316

Pump Station(s) Installation

Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 06"	1	EA	\$ 815	\$ 815
Gate valve, 06"	4	EA	\$ 915	\$ 3,660
Check valve, 06"	2	EA	\$ 915	\$ 1,830
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,500	\$ 2,500
Building pad	1	EA	\$ 5,000	\$ 5,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 6,000	\$ 6,000
Tools	1	EA	\$ 1,000	\$ 1,000
30,000 gal storage / feed tank	1	EA	\$ 45,000	\$ 45,000
Subtotal				\$ 101,805

Subtotal of Component Costs \$ 2,651,121

Contingency 20% \$ 530,224
 Design & Constr Management 25% \$ 662,780

TOTAL CAPITAL COSTS **\$ 3,844,125**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	13.27	mile	\$ 250	\$ 3,318
Subtotal				\$ 3,318
<i>Water Purchase Cost</i>				
From PWS	15,695	1,000 gal	\$ 1.52	\$ 23,856
Subtotal				\$ 23,856

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.043	\$ 507
Pump Power	8,428	kWH	\$ 0.043	\$ 362
Materials	1	EA	\$ 1,500	\$ 1,500
Labor	365	Hrs	\$ 40	\$ 14,600
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 17,970

O&M Credit for Existing Well Closure

Pump power	12,130	kWH	\$ 0.043	\$ (522)
Well O&M matl	1	EA	\$ 1,500	\$ (1,500)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (9,222)

TOTAL ANNUAL O&M COSTS **\$ 35,922**

Table C.3

PWS Name *Whitharal WSC*
Alternative Name *Purchase Water from Anton*
Alternative Number *WR-3*

Distance from Alternative to PWS (along pipe) 13.47 miles
Total PWS annual water usage 15.695 MG
Treated water purchase cost \$ 1.60 per 1,000 gals
Pump Stations needed w/ 1 feed tank each 1
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	23	n/a	n/a	n/a
PVC water line, Class 200, 06"	71,122	LF	\$ 32	\$ 2,275,891
Bore and encasement, 10"	400	LF	\$ 240	\$ 96,000
Open cut and encasement, 10"	1,150	LF	\$ 105	\$ 120,750
Gate valve and box, 06"	14	EA	\$ 915	\$ 13,015
Air valve	15	EA	\$ 2,000	\$ 30,000
Flush valve	14	EA	\$ 1,000	\$ 14,224
Metal detectable tape	71,122	LF	\$ 2	\$ 142,243
Subtotal				\$ 2,692,124

<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 06"	1	EA	\$ 815	\$ 815
Gate valve, 06"	4	EA	\$ 915	\$ 3,660
Check valve, 06"	2	EA	\$ 915	\$ 1,830
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,500	\$ 2,500
Building pad	1	EA	\$ 5,000	\$ 5,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 6,000	\$ 6,000
Tools	1	EA	\$ 1,000	\$ 1,000
30,000 gal storage / feed tank	1	EA	\$ 45,000	\$ 45,000
Subtotal				\$ 101,805

Subtotal of Component Costs \$ 2,793,929

Contingency 20% \$ 558,786
 Design & Constr Management 25% \$ 698,482

TOTAL CAPITAL COSTS \$ 4,051,197

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	13.47	mile	\$ 250	\$ 3,368
Subtotal				\$ 3,368
<i>Water Purchase Cost</i>				
From PWS	15,695	1,000 gal	\$ 1.60	\$ 25,112
Subtotal				\$ 25,112

<i>Pump Station(s) O&M</i>				
Building Power	11,800	kWH	\$ 0.043	\$ 507
Pump Power	16,823	kWH	\$ 0.043	\$ 723
Materials	1	EA	\$ 1,500	\$ 1,500
Labor	365	Hrs	\$ 40	\$ 14,600
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 18,331

<i>O&M Credit for Existing Well Closure</i>				
Pump power	12,130	kWH	\$ 0.043	\$ (522)
Well O&M matl	1	EA	\$ 1,500	\$ (1,500)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (9,222)

TOTAL ANNUAL O&M COSTS \$ 37,589

Table C.4

PWS Name *Whitharral WSC*
Alternative Name *New Well at 10 Miles*
Alternative Number *WR-4*

Distance from PWS to new well location 10.0 miles
Estimated well depth 300 feet
Number of wells required 1
Well installation cost (location specific) \$145 per foot
Pump Stations needed w/ 1 feed tank each 2
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	16	n/a	n/a	n/a
PVC water line, Class 200, 06"	52,800	LF	\$ 32	\$ 1,689,600
Bore and encasement, 10"	200	LF	\$ 240	\$ 48,000
Open cut and encasement, 10"	800	LF	\$ 105	\$ 84,000
Gate valve and box, 06"	11	EA	\$ 915	\$ 9,662
Air valve	11	EA	\$ 2,000	\$ 22,000
Flush valve	11	EA	\$ 1,000	\$ 10,560
Metal detectable tape	52,800	LF	\$ 2	\$ 105,600
Subtotal				\$ 1,969,422
<i>Pump Station(s) Installation</i>				
Pump	4	EA	\$ 8,000	\$ 32,000
Pump Station Piping, 06"	2	EA	\$ 815	\$ 1,630
Gate valve, 06"	8	EA	\$ 915	\$ 7,320
Check valve, 06"	4	EA	\$ 915	\$ 3,660
Electrical/instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,500	\$ 5,000
Building pad	2	EA	\$ 5,000	\$ 10,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 6,000	\$ 12,000
Tools	2	EA	\$ 1,000	\$ 2,000
30,000 gal storage / feed tank	2	EA	\$ 45,000	\$ 90,000
Subtotal				\$ 203,610
<i>Well Installation</i>				
Well installation	300	LF	\$ 145	\$ 43,500
Water quality testing	2	EA	\$ 1,250	\$ 2,500
Well pump	1	EA	\$ 10,000	\$ 10,000
Well electrical/instrumentation	1	EA	\$ 5,500	\$ 5,500
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 3,000	\$ 3,000
Subtotal				\$ 67,500

Subtotal of Component Costs **\$ 2,240,532**

Contingency 20% \$ 448,106
 Design & Constr Management 25% \$ 560,133

TOTAL CAPITAL COSTS **\$ 3,248,772**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	10.0	mile	\$ 250	\$ 2,500
Subtotal				\$ 2,500
<i>Pump Station(s) O&M</i>				
Building Power	23,600	kWH	\$ 0.043	\$ 1,015
Pump Power	15,648	kWH	\$ 0.043	\$ 673
Materials	2	EA	\$ 1,500	\$ 3,000
Labor	730	Hrs	\$ 40	\$ 29,200
Tank O&M	2	EA	\$ 1,000	\$ 2,000
Subtotal				\$ 35,888
<i>Well O&M</i>				
Pump power	25,956	kWH	\$ 0.043	\$ 1,116
Well O&M matl	1	EA	\$ 1,500	\$ 1,500
Well O&M labor	180	Hrs	\$ 40	\$ 7,200
Subtotal				\$ 9,816
<i>O&M Credit for Existing Well Closure</i>				
Pump power	12,130	kWH	\$ 0.043	\$ (522)
Well O&M matl	1	EA	\$ 1,500	\$ (1,500)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (9,222)

TOTAL ANNUAL O&M COSTS **\$ 38,982**

Table C.5

PWS Name *Whitharral WSC*
Alternative Name *New Well at 5 Miles*
Alternative Number *WR-5*

Distance from PWS to new well location 5.0 miles
Estimated well depth 300 feet
Number of wells required 1
Well installation cost (location specific) \$145 per foot
Pump Stations needed w/ 1 feed tank each 1
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	8	n/a	n/a	n/a
PVC water line, Class 200, 06"	26,400	LF	\$ 32	\$ 844,800
Bore and encasement, 10"	200	LF	\$ 240	\$ 48,000
Open cut and encasement, 10"	400	LF	\$ 105	\$ 42,000
Gate valve and box, 06"	5	EA	\$ 915	\$ 4,575
Air valve	6	EA	\$ 2,000	\$ 12,000
Flush valve	5	EA	\$ 1,000	\$ 5,000
Metal detectable tape	26,400	LF	\$ 2	\$ 52,800
Subtotal				\$ 1,009,711
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 8,000	\$ 16,000
Pump Station Piping, 06"	1	EA	\$ 815	\$ 815
Gate valve, 06"	4	EA	\$ 915	\$ 3,660
Check valve, 06"	2	EA	\$ 915	\$ 1,830
Electrical/instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,500	\$ 2,500
Building pad	1	EA	\$ 5,000	\$ 5,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 6,000	\$ 6,000
Tools	1	EA	\$ 1,000	\$ 1,000
30,000 gal storage / feed tank	1	EA	\$ 45,000	\$ 45,000
Subtotal				\$ 101,805
<i>Well Installation</i>				
Well installation	300	LF	\$ 145	\$ 43,500
Water quality testing	2	EA	\$ 1,250	\$ 2,500
Well pump	1	EA	\$ 10,000	\$ 10,000
Well electrical/instrumentation	1	EA	\$ 5,500	\$ 5,500
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 3,000	\$ 3,000
Subtotal				\$ 67,500

Subtotal of Component Costs \$ 1,179,016

Contingency 20% \$ 235,803
 Design & Constr Management 25% \$ 294,754

TOTAL CAPITAL COSTS **\$ 1,709,573**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	5.0	mile	\$ 250	\$ 1,250
Subtotal				\$ 1,250
<i>Pump Station(s) O&M</i>				
Building Power	11,800	kWH	\$ 0.043	\$ 507
Pump Power	7,824	kWH	\$ 0.043	\$ 336
Materials	1	EA	\$ 1,500	\$ 1,500
Labor	365	Hrs	\$ 40	\$ 14,600
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 17,944
<i>Well O&M</i>				
Pump power	25,956	kWH	\$ 0.043	\$ 1,116
Well O&M matl	1	EA	\$ 1,500	\$ 1,500
Well O&M labor	180	Hrs	\$ 40	\$ 7,200
Subtotal				\$ 9,816
<i>O&M Credit for Existing Well Closure</i>				
Pump power	12,130	kWH	\$ 0.043	\$ (522)
Well O&M matl	1	EA	\$ 1,500	\$ (1,500)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (9,222)

TOTAL ANNUAL O&M COSTS **\$ 19,788**

Table C.6

PWS Name *Whitharral WSC*
Alternative Name *New Well at 1 Mile*
Alternative Number *WR-6*

Distance from PWS to new well location 1.0 miles
Estimated well depth 300 feet
Number of wells required 1
Well installation cost (location specific) \$145 per foot
Pump Stations needed w/ 1 feed tank each 0
On site storage tanks / pump sets needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	2	n/a	n/a	n/a
PVC water line, Class 200, 06"	5,280	LF	\$ 32	\$ 168,960
Bore and encasement, 10"	-	LF	\$ 240	\$ -
Open cut and encasement, 10"	100	LF	\$ 105	\$ 10,500
Gate valve and box, 06"	1	EA	\$ 915	\$ 966
Air valve	1	EA	\$ 2,000	\$ 2,000
Flush valve	1	EA	\$ 1,000	\$ 1,056
Metal detectable tape	5,280	LF	\$ 2	\$ 10,560
Subtotal				\$ 194,042
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 8,000	\$ -
Pump Station Piping, 06"	-	EA	\$ 815	\$ -
Gate valve, 06"	-	EA	\$ 915	\$ -
Check valve, 06"	-	EA	\$ 915	\$ -
Electrical/instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,500	\$ -
Building pad	-	EA	\$ 5,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 6,000	\$ -
Tools	-	EA	\$ 1,000	\$ -
30,000 gal storage / feed tank	-	EA	\$ 45,000	\$ -
Subtotal				\$ -
<i>Well Installation</i>				
Well installation	300	LF	\$ 145	\$ 43,500
Water quality testing	2	EA	\$ 1,250	\$ 2,500
Well pump	1	EA	\$ 10,000	\$ 10,000
Well electrical/instrumentation	1	EA	\$ 5,500	\$ 5,500
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 3,000	\$ 3,000
Subtotal				\$ 67,500

Subtotal of Component Costs \$ 261,542

Contingency 20% \$ 52,308
 Design & Constr Management 25% \$ 65,386

TOTAL CAPITAL COSTS **\$ 379,236**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	1.0	mile	\$ 250	\$ 250
Subtotal				\$ 250
<i>Pump Station(s) O&M</i>				
Building Power	-	kWH	\$ 0.043	\$ -
Pump Power	-	kWH	\$ 0.043	\$ -
Materials	-	EA	\$ 1,500	\$ -
Labor	-	Hrs	\$ 40	\$ -
Tank O&M	-	EA	\$ 1,000	\$ -
Subtotal				\$ -
<i>Well O&M</i>				
Pump power	25,956	kWH	\$ 0.043	\$ 1,116
Well O&M matl	1	EA	\$ 1,500	\$ 1,500
Well O&M labor	180	Hrs	\$ 40	\$ 7,200
Subtotal				\$ 9,816
<i>O&M Credit for Existing Well Closure</i>				
Pump power	12,130	kWH	\$ 0.043	\$ (522)
Well O&M matl	1	EA	\$ 1,500	\$ (1,500)
Well O&M labor	180	Hrs	\$ 40	\$ (7,200)
Subtotal				\$ (9,222)

TOTAL ANNUAL O&M COSTS **\$ 845**

Table C.7

PWS Name *Whitharral WSC*
Alternative Name *Central Treatment - Reverse Osmosis*
Alternative Number *WR-7*

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Reverse Osmosis Unit Purchase/Installation</i>				
Site preparation	0.60	acre	\$ 4,000	\$ 2,400
Slab	20	CY	\$ 1,000	\$ 20,000
Building	700	SF	\$ 60	\$ 42,000
Building electrical	700	SF	\$ 8	\$ 5,600
Building plumbing	700	SF	\$ 8	\$ 5,600
Heating and ventilation	700	SF	\$ 7	\$ 4,900
Fence	1,000	LF	\$ 15	\$ 15,000
Paving	3,000	SF	\$ 2	\$ 6,000
Electrical	1	JOB	\$ 50,000	\$ 50,000
Piping	1	JOB	\$ 20,000	\$ 20,000

Reverse osmosis package including:

High pressure pumps - 15hp				
Cartridge filters and vessels				
RO membranes and vessels				
Control system				
Chemical feed systems				
Freight cost				
Vendor start-up services	1	UNIT	\$ 200,000	\$ 200,000

Sewage Connection:

Connection Fee	1	EA	\$ 15,000	\$ 15,000
Construction Cost	1	EA	\$ 50,000	\$ 50,000

Subtotal of Design/Construction Costs **\$ 436,500**

Contingency	20%		\$ 87,300
Design & Constr Management	25%		\$ 109,125

TOTAL CAPITAL COSTS **\$ 632,925**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Reverse Osmosis Unit O&M</i>				
Building Power	12,000	kwh/yr	\$ 0.043	\$ 516
Equipment power	26,390	kwh/yr	\$ 0.043	\$ 1,135
Labor	1,000	hrs/yr	\$ 40	\$ 40,000
Materials	1	year	\$ 6,000	\$ 6,000
Chemicals	1	year	\$ 3,000	\$ 3,000
Analyses	24	test	\$ 200	\$ 4,800
Subtotal				\$ 55,451
<i>Discharge Costs</i>				
Discharge Fee	2,356	kgal/yr	\$ 5	\$ 11,780
Subtotal				\$ 11,780

TOTAL ANNUAL O&M COSTS **\$ 67,231**

Table C.8

PWS Name *Whitharal WSC*
Alternative Name *Central Treatment - Electro-dialysis Reversal*
Alternative Number *WR-8*

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>EDR Unit Purchase/Installation</i>				
Site preparation	0.60	acre	\$ 4,000	\$ 2,400
Slab	20	CY	\$ 1,000	\$ 20,000
Building	700	SF	\$ 60	\$ 42,000
Building electrical	700	SF	\$ 8	\$ 5,600
Building plumbing	700	SF	\$ 8	\$ 5,600
Heating and ventilation	700	SF	\$ 7	\$ 4,900
Fence	1,000	LF	\$ 15	\$ 15,000
Paving	3,000	SF	\$ 2	\$ 6,000
Electrical	1	JOB	\$ 60,000	\$ 60,000
Piping	1	JOB	\$ 30,000	\$ 30,000
Transfer Pump	2	EA	\$ 6,000	\$ 12,000
EDR package including:				
Feed and concentrate pumps				
Cartridge filters and vessels				
EDR membrane stacks				
Electrical module				
Chemical feed systems				
Freight cost				
Vendor start-up services	1	UNIT	\$ 320,000	\$ 320,000
Sewage Connection:				
Connection Fee	1	EA	\$ 15,000	\$ 15,000
Construction Cost	1	EA	\$ 50,000	\$ 50,000
Subtotal of Design/Construction Costs				\$ 588,500
Contingency	20%		\$	117,700
Design & Constr Management	25%		\$	147,125

TOTAL CAPITAL COSTS **\$ 853,325**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>EDR Unit O&M</i>				
Building Power	12,000	kwh/yr	\$ 0.043	\$ 516
Equipment power	47,100	kwh/yr	\$ 0.043	\$ 2,025
Labor	1,000	hrs/yr	\$ 40	\$ 40,000
Materials	1	year	\$ 6,000	\$ 6,000
Chemicals	1	year	\$ 3,000	\$ 3,000
Analyses	24	test	\$ 200	\$ 4,800
Subtotal				\$ 56,341
<i>Discharge Costs</i>				
Discharge Fee	1,745	kgal/yr	\$ 5	\$ 8,725
Subtotal				\$ 8,725

TOTAL ANNUAL O&M COSTS **\$ 65,066**

Table C.9

PWS Name *Whitharral WSC*
Alternative Name *Point-of-Use Treatment*
Alternative Number *WR-9*

Number of Connections for POU Unit Installation 82 connections

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>POU-Treatment - Purchase/Installation</i>				
POU treatment unit purchase	82	EA	\$ 600	\$ 49,200
POU treatment unit installation	82	EA	\$ 150	\$ 12,300
Subtotal				\$ 61,500
Subtotal of Component Costs				\$ 61,500
Contingency	20%		\$	12,300
Design & Constr Management	25%		\$	15,375
Procurement & Administration	20%		\$	12,300
TOTAL CAPITAL COSTS				\$ 101,475

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>O&M</i>				
POU materials, per unit	82	EA	\$ 225	\$ 18,450
Contaminant analysis, 1/yr per unit	82	EA	\$ 200	\$ 16,400
Program labor, 10 hrs/unit	820	hrs	\$ 50	\$ 41,000
Subtotal				\$ 75,850
TOTAL ANNUAL O&M COSTS				\$ 75,850

Table C.10

PWS Name *Whitharral WSC*
Alternative Name *Point-of-Entry Treatment*
Alternative Number *WR-10*

Number of Connections for POE Unit Installation 82 connections

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>POE-Treatment - Purchase/Installat</i>				
POE treatment unit purchase	82	EA	\$ 5,000	\$ 410,000
Pad and shed, per unit	82	EA	\$ 2,000	\$ 164,000
Piping connection, per unit	82	EA	\$ 1,000	\$ 82,000
Electrical hook-up, per unit	82	EA	\$ 1,000	\$ 82,000
Subtotal				\$ 738,000

Subtotal of Component Costs **\$ 738,000**

Contingency	20%	\$ 147,600
Design & Constr Management	25%	\$ 184,500
Procurement & Administration	20%	\$ 147,600

TOTAL CAPITAL COSTS **\$ 1,217,700**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>O&M</i>				
POE materials, per unit	82	EA	\$ 1,500	\$ 123,000
Contaminant analysis, 1/yr per unit	82	EA	\$ 200	\$ 16,400
Program labor, 10 hrs/unit	820	hrs	\$ 50	\$ 41,000
Subtotal				\$ 180,400

TOTAL ANNUAL O&M COSTS **\$ 180,400**

Table C.11

PWS Name *Whitharral WSC*
Alternative Name *Public Dispenser for Treated Drinking Water*
Alternative Number *WR-11*

Number of Treatment Units Recommended 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Public Dispenser Unit Installation</i>				
POE-Treatment unit(s)	1	EA	\$ 7,000	\$ 7,000
Unit installation costs	1	EA	\$ 5,000	\$ 5,000
Subtotal				\$ 12,000
Subtotal of Component Costs				\$ 12,000
Contingency	20%			\$ 2,400
Design & Constr Management	25%			\$ 3,000
TOTAL CAPITAL COSTS				17,400

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Treatment unit O&M, 1 per unit	1	EA	\$ 2,000	\$ 2,000
Contaminant analysis, 1/wk per u	52	EA	\$ 200	\$ 10,400
Sampling/reporting, 1 hr/day	365	HRS	\$ 68	\$ 24,820
Subtotal				\$ 37,220
TOTAL ANNUAL O&M COSTS				\$ 37,220

Table C.12

PWS Name *Whitharral WSC*
Alternative Name *Supply Bottled Water to 100% of Population*
Alternative Number *WR-12*

Service Population 275
Percentage of population requiring supply 100%
Water consumption per person 1.00 gpcd
Calculated annual potable water needs 100,375 gallons

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Implementation</i>				
Initial program set-up	500	hours	\$ 40	\$ 20,000
Subtotal				\$ 20,000
Subtotal of Component Costs				\$ 20,000
Contingency	20%			\$ 4,000
TOTAL CAPITAL COSTS				\$ 24,000

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water purchase costs	100,375	gals	\$ 1	\$ 100,375
Program admin, 9 hrs/wk	468	hours	\$ 40	\$ 18,720
Program materials	1	EA	\$ 5,000	\$ 5,000
Subtotal				\$ 124,095
TOTAL ANNUAL O&M COSTS				\$ 124,095

Table C.13

PWS Name *Whitharral WSC*
Alternative Name *Central Trucked Drinking Water*
Alternative Number *WR-13*

Service Population 275
Percentage of population requiring supply 100%
Water consumption per person 1.00 gpcd
Calculated annual potable water needs 100,375 gallons
Travel distance to compliant water source 20 miles

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Storage Tank Installation</i>				
5,000 gal storage / feed tank	1	EA	\$ 15,000	\$ 15,000
Site improvements	1	EA	\$ 3,000	\$ 3,000
Potable water truck	1	EA	\$ 75,000	\$ 75,000
Subtotal				\$ 93,000
Subtotal of Component Costs				\$ 93,000
Contingency	20%		\$	18,600
Design & Constr Management	25%		\$	23,250
TOTAL CAPITAL COSTS				\$ 134,850

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water delivery labor, 4 hrs/wk	208	hrs	\$ 68	\$ 14,144
Truck operation, 1 round trip/wk	2,080	miles	\$ 2	\$ 4,160
Water purchase	100	1,000 gals	\$ 1.52	\$ 153
Water testing, 1 test/wk	52	EA	\$ 200	\$ 10,400
Sampling/reporting, 2 hrs/wk	104	hrs	\$ 68	\$ 7,072
Subtotal				\$ 35,929
TOTAL ANNUAL O&M COSTS				\$ 35,929

1
2

**APPENDIX D
EXAMPLE FINANCIAL MODEL**

1 **APPENDIX E**
2 **CONCEPTUAL ANALYSIS OF INCREASING COMPLIANT DRINKING**
3 **WATER**

4 **E.1 Introduction**

5 **E.1.1 Overview of Drinking Water Quality in Region**

6 There are many PWSs in the Lubbock area that do not have compliant drinking water due
7 to elevated concentrations of naturally occurring contaminants in the area groundwater.
8 Largely, this is a result of the generally poor water quality associated with the Ogallala-South
9 Formation that is the water source for most of these systems (see Chapter 3 of the report to
10 which this is appended). The common groundwater contaminants in the Ogallala-South
11 Formation include arsenic, selenium, fluoride, nitrate, and uranium.

12 According to the TCEQ Water Utility Database, there are nearly 24,000 people in the
13 Lubbock area who are served by active residential PWSs that do not currently have compliant
14 drinking water. The majority of this population can be found in the area just outside the City
15 of Lubbock, and also to the south of the city. The total area population with noncompliant
16 drinking water is likely greater than 24,000, since only populations served by active PWSs are
17 included in this estimate. There is additional populations that currently obtain drinking water
18 from private wells or are served by PWSs that have too few connections to be considered
19 active PWSs in the TCEQ Water Utility Database. Additionally, while the issue of
20 noncompliant drinking water affects these area residents directly, the lack of good quality
21 drinking water may restrict growth in the entire Lubbock area.

22 This appendix presents a conceptual analysis of a possible regional solution to the
23 drinking water compliance issue in the Lubbock area. The purpose of this analysis is to
24 investigate whether a large-scale regional approach to provide compliant drinking water
25 might be more cost-effective than each PWS seeking its own solution. The objective of the
26 analysis is to provide an indication of whether there is sufficient potential benefit to a regional
27 approach to warrant further study. The conceptual analysis presented here is based on a
28 single scenario and does not attempt to evaluate or rank a range of different solutions. For
29 purposes of this report, this single scenario is referred to as the Lubbock Area Regional
30 Solution (LARS).

31 To improve readability, the tables and figures for this appendix appear in Section E.6.

32 **E.1.2 Evaluation of PWS Drinking Water Quality**

33 Drinking water quality for the PWSs in the eight counties included in and around
34 Lubbock was evaluated using TCEQ PWS drinking water quality data to identify PWSs that
35 had potential water quality compliance issues. There are a number of PWSs that do not serve
36 residential populations, such as restaurants, businesses, *etc.* Since this analysis is focused on
37 residential systems, these commercial systems were excluded from the analysis. Additionally,

1 systems listed as “inactive” were also excluded because it was not easy to determine whether
2 they were listed as inactive because of small size, or are truly inactive.

3 Once the active residential PWSs were identified, they were screened for the common
4 contaminants in the area: arsenic, selenium, fluoride, nitrate, and uranium. Systems with
5 concentrations of the identified contaminants greater than MCLs were deemed to have
6 noncompliant water. It is important to note that this screening was not an official compliance
7 determination, and a system’s compliance status determined from the screening may not
8 coincide with a system’s actual compliance status. Discrepancies may result from the data
9 available not being current, the use of simplified algorithms to give an indication of
10 compliance, *etc.*

11 The PWSs identified with potential water quality compliance issues are shown in
12 Table E.1, along with numbers of connections, the population served, and average daily
13 consumption. For the LARS, the area has been divided into three separate subareas named
14 LARS–Lubbock, LARS-Lamesa, and LARS-Brownfield. The PWSs, population,
15 connections, and average daily consumptions for these subareas are shown in Tables E.2,
16 E.3, and E.4. These systems are also shown in Figure E.1. As can be seen on the figure,
17 these systems are generally located near Lubbock and south of Lubbock.

18 **E.1.3 Existing Drinking Water Supplies and Infrastructure**

19 PWSs in the area typically obtain drinking water from wells, purchase water from the
20 City of Lubbock, or obtain water from the Canadian River Municipal Water Authority
21 (CRMWA), either as one of the 11 member cities or as customers of a member city. The City
22 of Lubbock is a member city of the CRMWA and has the largest water system in the area. As
23 well as getting water from the CRMWA, Lubbock obtains water from its own well field in
24 Bailey County. The CRMWA provides surface water and groundwater via a pipeline from
25 the north to a water treatment plant located at and operated by Lubbock, from which point the
26 treated water is distributed via transmission mains to the seven member cities west and south
27 of Lubbock. There are existing CRMWA pipelines that extend to the southeast and west and
28 southwest from Lubbock. The approximate location and extent of these lines are shown in
29 Figure E.1.

30 The CRMWA production is fully committed to the 11 member cities. In addition, the
31 transmission mains from Lubbock to the other seven member cities are at capacity during the
32 summer months. Therefore, the LARS scenario proposed here uses new wells for the water
33 source and if existing pipeline infrastructure is used for water transmission, allowances are
34 made to account for any pipeline capacity used.

35 **E.2 Description of the LARS**

36 Since existing water supplies and infrastructure do not have sufficient capacity available,
37 and the existing infrastructure does not cover the entire area projected to be served by the
38 LARS, the LARS needs to provide both a water source and a means of conveyance. To
39 accomplish this, the LARS includes several groundwater treatment plants located near
40 clusters of PWSs with water quality problems. The locations of these treatment plants include

1 one near the existing water treatment plant in Lubbock, one at Lamesa, and one at Brownfield
2 (Figure E.2).

3 In addition to the groundwater treatment plants, new well fields would also be required to
4 feed the groundwater treatment plants. The assumed water quality used to design each
5 groundwater treatment plant is based on water quality data for PWSs near the proposed plant
6 location. Groundwater treatment will be achieved using RO technology because, of the two
7 technologies best suited for treating contaminants generally found in the water of the
8 Ogallala-South aquifer (RO and EDR), RO is typically the most economical option.

9 The plant at Lubbock would tie into the Lubbock distribution system. The water would
10 be passed through the Lubbock distribution system, and pipelines would be run from the
11 Lubbock distribution system to the noncompliant PWSs around Lubbock. The location of the
12 treatment plant, required new pipelines, and potential customers for the Lubbock component
13 of the LARS are shown on Figure E.3.

14 The plant at Lamesa could tie into the Lubbock distribution system at Lamesa or could be
15 independent. If tied into the Lamesa system, it could supplement Lamesa's system to allow
16 the non-compliant PWSs upstream of Lamesa to withdraw water without impacting existing
17 customers between Lamesa and Lubbock. If not tied in, the system could serve PWSs outside
18 the Lamesa area. The location of the treatment plant, required new pipelines, and potential
19 customers for the Lamesa component of the LARS are shown on Figure E.4.

20 The plant at Brownfield could tie into the Brownfield distribution system at Brownfield
21 or could be independent. If tied into the Brownfield system, it could supplement Lubbock's
22 system to allow the non-compliant PWSs upstream of Brownfield to withdraw water without
23 impacting existing customers between Brownfield and Lubbock. If not tied in, the system
24 could serve PWSs outside the Brownfield area. The location of the treatment plant, required
25 new pipelines, and potential customers for the Brownfield component of the LARS are shown
26 on Figure E.5.

27 Pipelines could be built to connect the CRMWA lines to the other noncompliant PWSs.
28 In this way, the Lamesa and Brownfield groundwater treatment plants could provide enough
29 drinking water to meet the demands of the systems at the ends of the CRMWA lines to offset
30 water that would be taken out by noncompliant PWSs along the existing CRMWA lines.
31 Connecting pipelines for the groundwater treatment plants and noncompliant PWSs to the
32 existing City of Lubbock and CRMWA pipe systems reduces the need for added
33 infrastructure to implement the regional solution, and would provide operational flexibility.

34 **E.3 Estimated Costs**

35 Costs to implement the LARS were estimated. This includes costs for new wells,
36 pipelines, pump stations, and treatment plants. A conceptual design was developed for the
37 main infrastructure components, and was used as the basis for estimating capital and O&M
38 costs. The estimated capital and O&M costs for the major infrastructure components are
39 summarized in Table E.5. The annualized costs of these components are also shown in

1 Table E.5, using a 6 percent discount rate and a 20-year period. Details of the capital costs
2 for the three subareas are included in Tables E.6, E.7, and E.8.

3 Table E-9 presents an estimate of the cost of service to the LARS customers. If the
4 customers were to bear the total capital and operating costs of the systems for their subarea or
5 the system as a whole, the approximate monthly cost per connection would be as follows:

LARS-Lubbock:	\$111/month	\$1,336/year	4% of MHI
LARS-Lamesa:	\$277/month	\$3,327/year	9% of MHI
LARS-Brownfield:	\$226/month	\$2,716/year	8% of MHI
Combined:	\$189/month	\$2,266/year	6% of MHI

6 If the systems would be able to get 100 percent grant funding for the capital costs of
7 constructing the system, the approximate monthly cost per connection would be as follows:

LARS-Lubbock:	\$42/month	\$509/year	1% of MHI
LARS-Lamesa:	\$53/month	\$630/year	2% of MHI
LARS-Brownfield:	\$72/month	\$866/year	2% of MHI
Combined:	\$59/month	\$711/year	2% of MHI

8 This then forms the approximate range of the cost of service for the customers (per
9 connection) of a regional solution.

10 Increasing the coverage of the regional solution to include populations served by inactive
11 PWSs or those that have private wells could have the effect of reducing treatment costs on a
12 per gallon basis, but increasing the cost for distribution piping. Likewise, other sources of
13 water with associated quality aspects would affect the cost, including surface water sources,
14 better groundwater sources, and the use of reclaimed water, either for supplemental potable or
15 non-potable uses. A more detailed assessment would be required to determine whether the
16 overall effect would be an increase or decrease on the cost to the customers.

17 **E.5 Conclusion**

18 A regional solution to serving non-compliant PWSs in the Lubbock area presents a
19 potentially viable solution to an existing problem. If suitable groundwater can be found, a
20 regional system could be implemented within a cost per connection range of \$59/month to
21 \$189/month, with the actual cost depending on the source and costs of capital funds needed to
22 build a regional system.

1 A Community Development Block Grant is one possible source of funding the capital
2 costs for the regional solution. Community Development Block Grants are discussed further
3 in Attachment E1.

4 **E.6 Tables and Figures**

Table E.1
Active Residential Public Water Systems with Potential Water Quality Problems
Lubbock Area Regional Solution

PWS ID #	PWS Name	Population	Connections	Avg. Daily Consumption (mgd)	County
0170010	BORDEN COUNTY WATER SYSTEM	102	102	0.010	BORDEN
0580011	ACKERLY WATER SUPPLY CORP	230	125	0.115	DAWSON
0580013	WELCH WATER SUPPLY CORP	312	123	0.057	DAWSON
0580025	KLONDIKE HIGH SCHOOL	250	16	0.025	DAWSON
0830001	SEAGRAVES CITY OF	2400	974	0.473	GAINES
0830011	LOOP WATER SUPPLY CORP	350	117	0.053	GAINES
0830012	SEMINOLE CITY OF	6456	2641	1.531	GAINES
0850002	SOUTHLAND ISD	193	4	0.019	GARZA
1100004	ROPESVILLE CITY OF	517	196	0.094	HOCKLEY
1100010	SMYER CITY OF	480	180	0.051	HOCKLEY
1100011	WHITHARRAL WATER SUPPLY CORP	275	82	0.043	HOCKLEY
1100030	OPDYKE WEST WATER SUPPLY	140	63	0.018	HOCKLEY
1520005	WOLFFORTH CITY OF	3000	1150	0.439	LUBBOCK
1520009	BIG Q MOBILE HOME ESTATES	200	70	0.013	LUBBOCK
1520025	BUSTERS MOBILE HOME PARK	20	8	0.002	LUBBOCK
1520026	FAMILY COMMUNITY CENTER MHP	88	40	0.011	LUBBOCK
1520027	WAGON WHEEL MOBILE VILLAGE HOME PR	30	21	0.003	LUBBOCK
1520036	GREEN MOBILE HOME PARK	50	28	0.004	LUBBOCK
1520039	PECAN GROVE MOBILE HOME PARK	100	50	0.008	LUBBOCK
1520062	PLOTT ACRES	201	63	0.019	LUBBOCK
1520067	114TH STREET MOBILE HOME PARK	96	43	0.009	LUBBOCK
1520080	FRANKLIN WATER SERVICE COMPANY	152	64	0.011	LUBBOCK
1520094	TOWN NORTH VILLAGE WATER SYSTEM	330	117	0.031	LUBBOCK
1520106	COX ADDITION WATER SYSTEM	133	40	0.014	LUBBOCK
1520122	LUBBOCK COOPER ISD	1900	14	0.190	LUBBOCK
1520123	ROOSEVELT ISD	1600	11	0.048	LUBBOCK
1520149	WHORTON MOBILE HOME PARK	75	26	0.008	LUBBOCK
1520152	TOWN NORTH ESTATES	227	67	0.015	LUBBOCK
1520154	CHARLIE BROWNS LEARNING CENTER	47	3	0.005	LUBBOCK
1520155	COUNTRY SQUIRE MHP 2	75	16	0.008	LUBBOCK
1520156	ELM GROVE MOBILE HOME PARK	24	20	0.002	LUBBOCK
1520158	MILLER MOBILE HOME PARK	60	33	0.005	LUBBOCK
1520185	LUBBOCK RV PARK	133	100	0.009	LUBBOCK
1520188	CASEY ESTATES WATER	312	104	0.026	LUBBOCK
1520192	TERRELLS MOBILE HOME PARK	50	22	0.005	LUBBOCK
1520198	VALLEY ESTATES	70	36	0.007	LUBBOCK
1520199	WOLFFORTH PLACE	460	123	0.041	LUBBOCK
1520211	TEXIN ENTERPRISES	27	9	0.002	LUBBOCK
1520217	SOUTHWEST GARDEN WATER	375	125	0.028	LUBBOCK
1520223	PAUL COBB WATER SYSTEM	30	18	0.003	LUBBOCK
1520225	FAY BEN MOBILE HOME PARK	90	55	0.007	LUBBOCK
1520241	MANAGED CARE CENTER	40	5	0.003	LUBBOCK
1520247	COUNTRY VIEW MHP	67	24	0.007	LUBBOCK
1530001	ODONNELL CITY OF	1100	392	0.139	LYNN
1530004	NEW HOME CITY OF	280	125	0.055	LYNN
1530005	GRASSLAND WATER SUPPLY CORP	80	30	0.008	LYNN
2230002	MEADOW CITY OF	547	230	0.138	TERRY
2230003	WELLMAN PUBLIC WATER SYSTEM	236	95	0.046	TERRY
TOTALS		24,010	8,000	3.856	

**Table E.2
Public Water Systems associated with LARS-Lubbock Treatment Plant**

PWS ID #	PWS Name	Population	Connections	Avg. Daily Consumption (mgd)	County
0850002	SOUTHLAND ISD	193	4	0.019	GARZA
1100010	SMYER CITY OF	480	180	0.051	HOCKLEY
1100011	WHITHARRAL WATER SUPPLY CORP	275	82	0.043	HOCKLEY
1100030	OPDYKE WEST WATER SUPPLY	140	63	0.018	HOCKLEY
1520005	WOLFFORTH CITY OF	3000	1150	0.439	LUBBOCK
1520009	BIG Q MOBILE HOME ESTATES	200	70	0.013	LUBBOCK
1520025	BUSTERS MOBILE HOME PARK	20	8	0.002	LUBBOCK
1520026	FAMILY COMMUNITY CENTER MHP	88	40	0.011	LUBBOCK
1520027	WAGON WHEEL MOBILE VILLAGE HOME PR	30	21	0.003	LUBBOCK
1520036	GREEN MOBILE HOME PARK	50	28	0.004	LUBBOCK
1520039	PECAN GROVE MOBILE HOME PARK	100	50	0.008	LUBBOCK
1520062	PLOTT ACRES	201	63	0.019	LUBBOCK
1520067	114TH STREET MOBILE HOME PARK	96	43	0.009	LUBBOCK
1520080	FRANKLIN WATER SERVICE COMPANY	152	64	0.011	LUBBOCK
1520094	TOWN NORTH VILLAGE WATER SYSTEM	330	117	0.031	LUBBOCK
1520106	COX ADDITION WATER SYSTEM	133	40	0.014	LUBBOCK
1520122	LUBBOCK COOPER ISD	1900	14	0.190	LUBBOCK
1520123	ROOSEVELT ISD	1600	11	0.048	LUBBOCK
1520149	WHORTON MOBILE HOME PARK	75	26	0.008	LUBBOCK
1520152	TOWN NORTH ESTATES	227	67	0.015	LUBBOCK
1520154	CHARLIE BROWNS LEARNING CENTER	47	3	0.005	LUBBOCK
1520155	COUNTRY SQUIRE MHP 2	75	16	0.008	LUBBOCK
1520156	ELM GROVE MOBILE HOME PARK	24	20	0.002	LUBBOCK
1520158	MILLER MOBILE HOME PARK	60	33	0.005	LUBBOCK
1520185	LUBBOCK RV PARK	133	100	0.009	LUBBOCK
1520188	CASEY ESTATES WATER	312	104	0.026	LUBBOCK
1520192	TERRELLS MOBILE HOME PARK	50	22	0.005	LUBBOCK
1520198	VALLEY ESTATES	70	36	0.007	LUBBOCK
1520199	WOLFFORTH PLACE	460	123	0.041	LUBBOCK
1520211	TEXIN ENTERPRISES	27	9	0.002	LUBBOCK
1520217	SOUTHWEST GARDEN WATER	375	125	0.028	LUBBOCK
1520223	PAUL COBB WATER SYSTEM	30	18	0.003	LUBBOCK
1520225	FAY BEN MOBILE HOME PARK	90	55	0.007	LUBBOCK
1520241	MANAGED CARE CENTER	40	5	0.003	LUBBOCK
1520247	COUNTRY VIEW MHP	67	24	0.007	LUBBOCK
1530004	NEW HOME CITY OF	280	125	0.055	LYNN
TOTALS		11,430	2,959	1.167	

**Table E.3
Public Water Systems associated with LARS-Lamesa Treatment Plant**

PWS ID #	PWS Name	Population	Connections	Avg. Daily Consumption (mgd)	County
0170010	BORDEN COUNTY WATER SYSTEM	102	102	0.010	BORDEN
0580011	ACKERLY WATER SUPPLY CORP	230	125	0.115	DAWSON
0580013	WELCH WATER SUPPLY CORP	312	123	0.057	DAWSON
0580025	KLONDIKE HIGH SCHOOL	250	16	0.025	DAWSON
1530001	ODONNELL CITY OF	1100	392	0.139	LYNN
1530005	GRASSLAND WATER SUPPLY CORP	80	30	0.008	LYNN
TOTALS		2,074	788	0.354	

**Table E.4
Public Water Systems associated with LARS-Brownfield Treatment Plant**

PWS ID #	PWS Name	Population	Connections	Avg. Daily Consumption (mgd)	County
0830001	SEAGRAVES CITY OF	2400	974	0.473	GAINES
0830011	LOOP WATER SUPPLY CORP	350	117	0.053	GAINES
0830012	SEMINOLE CITY OF	6456	2641	1.531	GAINES
1100004	ROPESVILLE CITY OF	517	196	0.094	HOCKLEY
2230002	MEADOW CITY OF	547	230	0.138	TERRY
2230003	WELLMAN PUBLIC WATER SYSTEM	236	95	0.046	TERRY
TOTALS		10,506	4,253	2.335	

Table E.5
Summary of Cost Components
Lubbock Area Regional Solution (LARS)

Cost Item	Capital	O&M	Annualized 20 yr, 6%
LARS - Lamesa			
Wells	\$ 783,000	\$ 78,578	\$ 146,844
Treatment Plant	\$ 3,271,200	\$ 308,989	\$ 594,187
Pipeline and Pump Stations	\$ 20,323,892	\$ 108,939	\$ 1,880,869
Subtotal	\$ 24,378,092	\$ 496,506	\$ 2,621,899
LARS - Brownfield			
Wells	\$ 5,383,125	\$ 540,224	\$ 1,009,550
Treatment Plant	\$ 14,734,900	\$ 1,563,235	\$ 2,847,891
Pipeline and Pump Stations	\$ 70,140,452	\$ 1,578,779	\$ 7,693,944
Subtotal	\$ 90,258,477	\$ 3,682,239	\$ 11,551,384
LARS - Lubbock			
Wells	\$ 2,740,500	\$ 275,023	\$ 513,952
Treatment Plant	\$ 7,397,900	\$ 816,460	\$ 1,461,443
Pipeline and Pump Stations	\$ 17,931,065	\$ 415,323	\$ 1,978,635
Subtotal	\$ 28,069,465	\$ 1,506,807	\$ 3,954,030
TOTAL	\$ 142,706,034	\$ 5,685,551	\$ 18,127,314

Table E.6
Lubbock Area Regional Solution - Treatment Plant at Lubbock
Summary of Cost Components

Item	Quantity	Unit	Capital	O&M
<i>Wells</i>				
New wells	28	EA	\$ 1,890,000	\$ 275,023
Contingency	20%		\$ 378,000	
Design & Constr Management	25%		\$ 472,500	
Subtotal			\$ 2,740,500	\$ 275,023
<i>Treatment</i>				
RO Treatment Plant	1	EA	\$ 5,102,000	\$ 816,460
Contingency	20%		\$ 1,020,400	
Design & Constr Management	25%		\$ 1,275,500	
Subtotal			\$ 7,397,900	\$ 816,460
<i>Pipeline</i>				
4" Pipeline w/complete installation	49.07	Miles	\$ 8,636,689	\$ 11,450
6" Pipeline w/complete installation	3.66	Miles	\$ 642,002	\$ 849
10" Pipeline w/complete installation	2.17	Miles	\$ 612,761	\$ 542
Contingency	20%		\$ 1,978,290	
Design & Constr Management	25%		\$ 2,472,863	
Subtotal			\$ 14,342,605	\$ 12,841
<i>Pump Stations</i>				
Pump Stations	13	EA	\$ 2,474,800	\$ 402,482
Contingency	20%		\$ 494,960	
Design & Constr Management	25%		\$ 618,700	
Subtotal			\$ 3,588,460	\$ 402,482
TOTAL COSTS			\$ 28,069,465	\$ 1,506,807

Table E.7
Lubbock Area Regional Solution - Treatment Plant at Lamesa
Summary of Cost Components

Item	Quantity	Unit	Capital	O&M
<i>Wells</i>				
New wells	8	EA	\$ 540,000	\$ 78,578
Contingency	20%		\$ 108,000	
Design & Constr Management	25%		\$ 135,000	
Subtotal			\$ 783,000	\$ 78,578
<i>Treatment</i>				
RO Treatment Plant	1	EA	\$ 2,256,000	\$ 308,989
Contingency	20%		\$ 451,200	
Design & Constr Management	25%		\$ 564,000	
Subtotal			\$ 3,271,200	\$ 308,989
<i>Pipeline</i>				
4" Pipeline w/complete installation	33.30	Miles	\$ 5,484,498	\$ 8,326
6" Pipeline w/complete installation	15.15	Miles	\$ 2,966,562	\$ 3,787
8" Pipeline w/complete installation	22.89	Miles	\$ 5,203,212	\$ 5,722
Contingency	20%		\$ 2,730,854	
Design & Constr Management	25%		\$ 3,413,568	
Subtotal			\$ 19,798,695	\$ 17,835
<i>Pump Stations</i>				
Pump Stations	5	EA	\$ 362,205	\$ 91,104
Contingency	20%		\$ 72,441	
Design & Constr Management	25%		\$ 90,551	
Subtotal			\$ 525,197	\$ 91,104
TOTAL COSTS			\$ 24,378,092	\$ 496,506

Table E.8
Lubbock Area Regional Solution - Treatment Plant at Brownfield
Summary of Cost Components

Item	Quantity	Unit	Capital	O&M
<i>Wells</i>				
New wells	55	EA	\$ 3,712,500	\$ 540,224
Contingency	20%		\$ 742,500	
Design & Constr Management	25%		\$ 928,125	
Subtotal			\$ 5,383,125	\$ 540,224
<i>Treatment</i>				
RO Treatment Plant	1	EA	\$ 10,162,000	\$ 1,563,235
Contingency	20%		\$ 2,032,400	
Design & Constr Management	25%		\$ 2,540,500	
Subtotal			\$ 14,734,900	\$ 1,563,235
<i>Pipeline</i>				
4" Pipeline w/complete installation	3.43	Miles	\$ 543,272	\$ 857
6" Pipeline w/complete installation	16.36	Miles	\$ 3,206,887	\$ 4,090
8" Pipeline w/complete installation	1.01	Miles	\$ 284,268	\$ 251
24" Pipeline w/complete installation	16.66	Miles	\$ 15,300,032	\$ 4,166
30" Pipeline w/complete installation	24.72	Miles	\$ 28,023,581	\$ 6,180
Contingency	20%		\$ 9,471,608	
Design & Constr Management	25%		\$ 11,839,510	
Subtotal			\$ 68,669,159	\$ 15,544
<i>Pump Stations</i>				
Pump Stations	6	EA	\$ 1,014,685	\$ 137,212
Contingency	20%		\$ 202,937	
Design & Constr Management	25%		\$ 253,671	
Subtotal			\$ 1,471,293	\$ 137,212
TOTAL COSTS			\$ 90,258,477	\$ 2,256,215

Table E.9
Lubbock Area Regional Solution (LARS)
Cost of Service

Component	Lubbock	Lamesa	Brownfield	Combined
Capital Cost	\$ 28,069,465	\$ 24,378,092	\$ 90,258,477	\$ 142,706,034
Annual O&M	\$ 1,506,807	\$ 496,506	\$ 3,682,239	\$ 5,685,551
Annualized 20 yr., 6%	\$ 3,954,030	\$ 2,621,899	\$ 11,551,384	\$ 18,127,314
Population	11,430	2,074	10,506	\$ 24,010
Connections	2,959	788	4,253	\$ 8,000
Annualized/Population	\$ 345.93	\$ 1,264.18	\$ 1,099.50	\$ 754.99
Annualized/Connection	\$ 1,336.27	\$ 3,327.28	\$ 2,716.06	\$ 2,265.91
Annualized/Connection as % of MHI*	4%	9%	8%	6%
Annualized/Connection/Month	\$ 111.36	\$ 277.27	\$ 226.34	\$ 188.83
Annual O&M/Population	\$ 131.83	\$ 239.40	\$ 350.49	\$ 236.80
Annual O&M/Connection	\$ 509.23	\$ 630.08	\$ 865.80	\$ 710.69
Annual O&M/Connection as % of MHI*	1%	2%	2%	2%
Annual O&M/Connection/Month	\$ 42.44	\$ 52.51	\$ 72.15	\$ 59.22

* Percentage of MHI calculated based on the MHI for Lubbock County of \$35,189.




Figure E.1

EXISTING INFRASTRUCTURE & ACTIVE RESIDENTIAL PWS's WITH POTENTIAL WATER QUALITY PROBLEMS

Legend

- PWS
- — — CRMWA Pipeline
- — — Lubbock Pipeline
- Major Road
- City Limits
- Counties








Figure E.2

PROPOSED LUBBOCK AREA REGIONAL SOLUTION

Legend

- PWS
- CRMWA Pipeline
- Lubbock Pipeline
- Major Road
- City Limits
- Counties
- Proposed LARS Pipeline
- Ⓣ Proposed LARS Treatment Plant





- Legend**
- PWS
 - - - CRMWA Pipeline
 - - - Lubbock Pipeline
 - Major Road
 - City Limits
 - Counties
 - Proposed LARS Pipeline
 - T Proposed LARS Treatment Plant

Figure E.3
LUBBOCK PLANT & ASSOCIATED PWS's
 Lubbock Area Regional Solution




Figure E.4

LAMESA PLANT & ASSOCIATED PWS's
Lubbock Area Regional Solution

Legend

- PWS
- - - CRMWA Pipeline
- - - Lubbock Pipeline
- Major Road
- City Limits
- Counties
- Proposed LARS Pipeline
- Proposed LARS Treatment Plant







Figure E.5

BROWNFIELD PLANT & ASSOCIATED PWS's
Lubbock Area Regional Solution

Legend

- PWS
- CRMWA Pipeline
- Lubbock Pipeline
- Major Road
- City Limits
- Counties
- Proposed LARS Pipeline
- T Proposed LARS Treatment Plant



1 **Attachment E1**

2 **Texas Community Development Block Grants**

3 **Introduction**

4 Every year, the U.S. Department of Housing and Urban Development (HUD) provides
5 federal Community Development Block Grant (CDBG) funds directly to states, which, in
6 turn, provide the funds to small, rural cities with populations of less than 50,000, and to
7 counties that have a non-metropolitan population under 200,000 and are not eligible for direct
8 funding from U.S. Department of Housing and Urban Development (HUD). These small
9 communities are called “non-entitlement” areas because they must apply for CDBG dollars
10 through the Office of Rural Community Affairs (ORCA). The grants may be used for
11 community and economic development activities, but are primarily used for housing
12 rehabilitation, public infrastructure projects (e.g., wastewater and drinking water facilities),
13 and economic development. Seventy percent of grant funds must be used for activities that
14 principally benefit low- and moderate-income persons.

15 ORCA administers the State of Texas CDBG Program, called the Texas Community
16 Development Block Grant Program (Texas CDBG). The Texas Department of Agriculture
17 (TDA) administers the Texas Capital Fund through an interagency agreement between ORCA
18 and TDA.

19 ORCA’s CDBG program is the largest in the nation. The rural-focused program serves
20 approximately 1,017 eligible rural communities, 245 rural counties, and provides services to
21 over 375,000 low- to moderate-income beneficiaries each year. Of the 1,017 communities
22 eligible for CDBG funds, 740 have a population of less than 3,000, and 424 have a population
23 of less than 1,000. The demographics and rural characteristics of Texas have shaped a
24 program that focuses on providing basic human needs and sanitary infrastructure to small
25 rural communities in outlying areas.

26 **Program Administration**

27 ORCA administers the CDBG programs in accordance to funding rules and regulations
28 set by HUD. Each year, ORCA submits an Action Plan for the next fiscal year. The Action
29 Plan describes the methods ORCA will use for distributing funds among the various CDBG
30 programs, including award amounts per program, application selection process, etc. Once
31 HUD approves the Action Plan, it becomes codified into the Texas Administrative Code
32 under Title 10 TAC Chapter 255. The agency then makes applications available in
33 accordance with each program’s funding cycle. Applications received for competitive
34 funding programs are reviewed and scored using program-specific criteria and processes.
35 These processes may include scoring by Regional Review Committees and review by the
36 State Review Committees.

37 Once awards are made from ORCA’s CDBG program, contracts are executed between
38 the agency and the city or county officials, and the grantee begins the implementation of their
39 proposed project. To guide grantees in the implementation of their projects, the grantees
40 follow the 2005 CDBG Implementation Manual. The Manual describes the methods a CDBG
41 grant recipient uses to administer the CDBG contract, and includes relevant forms.

1 **Eligible Applicants**

2 Eligible applicants are nonentitlement general purpose units of local government,
3 including cities and counties that are not participating or designated as eligible to participate
4 in the entitlement portion of the federal CDBG. Nonentitlement cities that are not
5 participating in urban county programs through existing participation agreements are eligible
6 applicants (unless the city’s population is counted toward the urban county CDBG
7 allocation).

8 Nonentitlement cities are located predominately in rural areas and are cities with
9 populations less than 50,000 thousand persons; cities that are not designated as a central city
10 of a metropolitan statistical area; and cities that are not participating in urban county
11 programs. Nonentitlement counties are also predominately rural in nature and are counties
12 that generally have fewer than 200,000 persons in the nonentitlement communities and
13 unincorporated areas located in the county.

14 **Eligible Activities**

15 Eligible activities under the Texas CDBG Program are listed in 42 United States Code
16 (USC) Section 5305. The Texas CDBG staff reviews all proposed project activities included
17 in applications for all fund categories except the Texas Capital Fund (TCF), to determine
18 eligibility. The Texas Department of Agriculture determines the eligibility of activities
19 included in TCF applications.

20 All proposed activities must meet one of the following three National Program
21 Objectives:

- 22 1. Benefit principally low- and moderate-income persons; or
- 23 2. Aid in the elimination of slums or blight; or
- 24 3. Meet other community development needs of particular urgency that represent
25 an immediate threat to the health and safety of residents of the community.

26 **Ineligible Activities**

27 In general, any type of activity not described or referred to in 42 USC Section 5305 is
28 ineligible. Specific activities ineligible under the Texas CDBG Program are:

- 29 1. Construction of buildings and facilities used for the general conduct of
30 government (*e.g.* city halls, courthouses, *etc.*);
- 31 2. Construction of new housing, except as last resort housing under 49 CFR Part 24
32 or affordable housing through eligible subrecipients in accordance with 24 CFR
33 570.204;
- 34 3. Financing of political activities;

- 1 4. Purchases of construction equipment (except in limited circumstances under the
2 STEP Program);
- 3 5. Income payments, such as housing allowances; and
- 4 6. Most O&M expenses (including smoke testing, televising/video taping line work,
5 or any other investigative method to determine the overall scope and location of
6 the project work activities)

7 The TCF will not accept applications in support of public or private prisons, racetracks,
8 and projects that address job creation/retention through a government supported facility. The
9 TCF Program may be used to financially assist/facilitate the relocation of a business when
10 certain requirements, as defined in the application guidelines, are met.

11 **Primary Beneficiaries**

12 The primary beneficiaries of the Texas CDBG Program are low to moderate income
13 persons as defined under HUD, Section 8 Assisted Housing Program (Section 102(c)). Low
14 income families are defined as those earning less than 50 percent of the area MHI. Moderate
15 income families are defined as those earning less than 80 percent of the area MHI. The area
16 median family can be based on a metropolitan statistical area, a non-metropolitan county, or
17 the statewide non-metropolitan MHI figure.

18 **Section 108 Loan Guarantee Program**

19 Section 108 is the loan guarantee provision of the Texas CDBG Program. Section 108
20 provides communities with a source of financing for economic development, housing
21 rehabilitation, public facilities, and large-scale physical development projects. This makes it
22 one of the most potent and important public investment tools that HUD offers to local
23 governments. It allows these local governments to transform a small portion of their CDBG
24 funds into federally guaranteed loans large enough to pursue physical and economic
25 revitalization projects that can renew entire neighborhoods. Such public investment is often
26 needed to inspire private economic activity, providing the initial resources, or simply the
27 confidence that private firms and individuals may need to invest in distressed areas.
28 Section 108 loans are not risk-free; however, local governments borrowing funds guaranteed
29 by Section 108 must pledge their current and future CDBG allocations to cover the loan
30 amount as security for the loan.

31 The loan is made by a private lender to an eligible nonentitlement city or county. HUD
32 guarantees the loan; however, Texas CDBG must pledge the state's current and future CDBG
33 nonentitlement area funds to cover any losses. To provide eligible nonentitlement
34 communities an additional funding source, the State is authorizing a loan guarantee pilot
35 program for 2008 consisting of one application up to a maximum of \$500,000 for a particular
36 project. An application guide containing the submission date and qualifications will be
37 available for applicants interested in being selected as the pilot project under this program.

38

1 **APPENDIX F**
2 **GENERAL CONTAMINANT GEOCHEMISTRY**

3 **ARSENIC**

4 The geochemistry of arsenic is complex because of the possible coexistence of two or
5 even three redox states (-III, III, V) and because of the strong interaction of most arsenic
6 compounds with soil particles, particularly iron oxides. Because groundwater is generally
7 oxidizing in the High Plains, Edwards Trinity (Plateau), and Cenozoic Pecos Alluvium
8 aquifers, it is expected to be in the arsenate form (V). Correlations between arsenic and
9 vanadium and fluoride suggest a geologic rather than an anthropogenic source of arsenic. The
10 large number of potential geologic sources include: volcanic ashes in the Ogallala and
11 underlying units, shales in the Cretaceous, and saline lakes in the Southern High Plains that
12 were evaluated in a separate study and described in Scanlon, *et al.* (2005). Arsenic mobility
13 is generally not controlled by solubility of arsenic-bearing minerals because these minerals
14 are highly soluble. Under oxidizing conditions, arsenic mobility increases with increasing pH
15 (Smedley and Kinniburgh 2000). Phosphate can also increase arsenic mobility because
16 phosphate preferentially sorbs onto clays and iron oxides relative to arsenic.

17 **NITRATE**

18 Nitrate is negatively charged and behaves conservatively; *i.e.*, it does not sorb onto soil,
19 volatilize, precipitate readily, *etc.* Natural sources of nitrate include fixed nitrogen by shrubs
20 such as mesquite in rangeland settings. Nitrate concentrations in soil profiles in most
21 rangeland settings in the Southern High Plains are generally low (Scanlon, *et al.* 2003;
22 McMahon, *et al.* 2005). Conversion of rangeland to agriculture can result in nitrification of
23 soil organic matter. Anthropogenic sources of nitrate include chemical and organic (manure)
24 fertilizers, nitrogen fixation through growth of leguminous crops, and barnyard and septic
25 tank effluent. Nitrogen isotopes have been used to distinguish these various sources;
26 however, such a study has not been conducted in the Southern High Plains. Nitrogen profiles
27 measured in soil in Dawson County, Texas, indicated that nitrate concentrations in soil pore
28 water were generally low to moderate (Scanlon, *et al.* 2003). The highest concentrations were
29 found in irrigated areas because irrigation water contains higher nitrate concentrations than
30 rain water and irrigation rates are low enough to result in evapoconcentration of nitrate in the
31 soil.

32 **FLUORIDE**

33 Fluorine exists naturally in solution under one valence, F⁻, the fluoride ion. Fluoride
34 tends to make complexes and ion pairs with trace elements. It can also sorb significantly to
35 oxides, especially aluminum oxides, and clays (Hem 1985). Its concentration controlled by
36 calcium, as fluorite (CaF₂) is the most common fluorine mineral. Apatite (a calcium
37 phosphate) can also contain a significant amount of fluorine.

1 SELENIUM

2 Selenium has a chemistry similar to that of sulfur, existing naturally in four redox states
3 VI, IV, 0, and –II, with selenate, selenite, and selenide ions occurring in Eh-pH conditions
4 largely parallel to those of arsenic. In oxic conditions, the selenate ion, SeO_4^{-2} , is the
5 dominant species across all natural pHs. In slightly reducing conditions, the selenite ion
6 exists from the fully deprotonated form, SeO_3^{-2} , at alkaline pHs to the neutral H_2SeO_3 at acid
7 pHs and the HSeO_3^{-1} form at neutral pHs. However, here are several differences with arsenic.
8 The selenate ion is a weak sorber and its behavior resembles more that of sulfate than that of
9 arsenate ion (White and Dubrovsky 1994). Organo-selenium compounds and possibly native
10 selenium are also more widespread. All selenate and selenite minerals are highly soluble.
11 Native selenium, or more likely ferroselite (pyrite with some Se substituted for S), can
12 precipitate at relatively high Eh neutral pH. However, kinetics issues may keep selenium in
13 solution even at reducing Ehs (Henry, *et al.* 1982).

14 URANIUM

15 The geochemistry of uranium is complicated but can be summarized by the following.
16 Uranium(VI) in oxidizing conditions exists as the soluble positively charged uranyl UO_2^{+2} .
17 Solubility is higher at acid pHs, decreases at neutral pHs, and increases at alkaline pHs. The
18 uranyl ion can easily form aqueous complexes, including with hydroxyl, fluoride, carbonate,
19 and phosphate ligands. Hence, in the presence of carbonates, uranium solubility is
20 considerably enhanced in the form of uranyl-carbonate (UO_2CO_3) and other higher order
21 carbonate complexes: uranyl-di-carbonate ($\text{UO}_2(\text{CO}_3)_2^{-2}$) and uranyl-tri-carbonates
22 $\text{UO}_2(\text{CO}_3)_3^{-4}$. Adsorption of uranium is inversely related to its solubility and is highest at
23 neutral pHs (De Soto 1978). Uranium sorbs strongly to metal oxides and clays. Uranium(IV)
24 is the other commonly found redox state. In that state, however, uranium is not very soluble
25 and precipitates as uranite, UO_2 , coffinite, $\text{USiO}_4 \cdot n\text{H}_2\text{O}$ (if $\text{SiO}_2 > 60$ mg/L (Henry, *et al.* 1982),
26 or related minerals. In most aquifers, no mineral controls uranium solubility in oxidizing
27 conditions. However, uranite and coffinite are the controlling minerals if Eh drops below
28 0-100 mV.

29 APPENDIX REFERENCES

- 30 De Soto, R. H. 1978. Uranium geology and exploration: lecture notes and references: Golden, CO,
31 Colorado School of Mines, March, 396 p.
- 32 Hem, J. D. 1985. Study and interpretation of the chemical characteristics of natural waters. U.S.
33 Geological Survey Water-Supply Paper 2254. 263p.
- 34 Henry, C. D., Galloway, W. E., and Smith, G. E., Ho, C. L., Morton, J. P. and Gluck, J. K. 1982.
35 Geochemistry of ground water in the Miocene Oakville sandstone – A major aquifer and
36 uranium host of the Texas coastal plain. The University of Texas at Austin, Bureau of
37 Economic Geology Report of Investigations No. 118. 63p.
- 38 McMahon, P.B., K.F. Dennehy, B.W. Bruce, J.K. Bohlke, R.L. Michel, J.J. Gurdak, D.B. Hurlbut.
39 2005. Storage and transit time of chemicals in thick unsaturated zones under rangeland and
40 irrigated cropland, High Plains, USA. *Water Resources Research*

- 1 Scanlon, B.R., R.C. Reedy, K.E. Keese. 2003. Estimation of groundwater recharge in Texas related
2 to aquifer vulnerability to contamination. *Bureau of Economic Geology, Univ. of Texas at*
3 *Austin, Final Contract Report, 84 p.*
- 4 Scanlon, B.R., S. Nance, J.P. Nicot, R.C. Reedy, R. Smyth, A. Tachovsky, A. 2005. Evaluation of
5 arsenic concentrations in groundwater in Texas; The University of Texas Bureau of Economic
6 Geology, Final Report, Prepared for the Texas Commission on Environmental Quality.
- 7 Smedley, P.L. and D.G. Kinniburgh. 2002. A review of the source, behaviour and distribution of
8 arsenic in natural waters. *Applied Geochemistry* **17**: 517-568.
- 9 White, A. F., and Dubrovsky, N. M., 1994. Chemical oxidation-reduction controls on selenium
10 mobility in groundwater systems in Selenium in the Environment, W. T. Frankenberger, Jr.
11 and Sally Benson, Editors. Marcel Dekker, Inc., New York, 221p. p.185-221.