

# Energy in Japan

-challenge for the future ▪ ▪ ▪ A Brighter Tomorrow?-

Hisanori Nei

Professor,  
National Graduate Institute  
For Public Studies, Japan

2014, Dec. 3<sup>rd</sup> at CEE

# Energy in Japan

After the Great East Japan Earthquake and the TEPCO's Fukushima nuclear accident, the circumstance of energy in Japan has changed drastically as follows:

/No NPS operation ▪ ▪ ▪ 288Gkwh(2010) Lost



/LNG import increase ▪ ▪ ▪ 73.3Mt(2010) ➡ 85.9Mt(2011),90.1Mt(2013)

/Energy Consumption Down ▪ ▪ 15.0EJ(2010) ➡ 14.5EJ(2011),14.2(2013)

/Electricity Tariff Increase


/Increase Fuel Cost ▪ ▪ ▪ 3.6Trillion Yen (30 billion US\$)/year

## Diversification of Energy Supply after Oil Crisis mainly by Nuclear




# Increase Nuclear Energy Supply for last 4 Decades

Primary Energy Supply in Japan




Primary Energy Supply in Japan




After Fukushima Energy Figure in Japan goes back to almost 4 decades ago


PRIMARY ENERGY SUPPLY IN 1990




PRIMARY ENERGY SUPPLY IN 2010




PRIMARY ENERGY SUPPLY IN 2012



PRIMARY ENERGY SUPPLY IN 2013




## LNG is major energy source cover the loss of NPS



Mt	Long Term	Import 2011	Import 2010
UAE	4.3	5.6	5.1
Burnei	6.0	6.2	5.9
Malaysia	15.4	15.1	14.6
Indonesia	5.8	7.9	12.9
Qatar	6.0	14.3	7.7
Oman	3.0	4.2	2.7
Australia	13.3	13.6	13.2
Russia	4.9	7.8	6.0
U.S.A		0.2	0.6
Others		9.0	1.5
Total	58.8	83.2	70.6


## Coal consumption link with Total energy demand.

Changes of Power Supply Sources in Japan




# Maintain High Energy Efficiency

Energy Efficiency




Energy Efficiency Trend




Souce:IEA

Energy Demand & GDP




Energy Efficiency Trend






## After the earthquake disaster, electricity charges have risen considerably.

Transitions concerning an average model rate after the introduction of the fuel cost adjustment system  
(in case of Tokyo Electric Power Co., Inc.)




## Power generating cost of each power source (2010 model plant)





## Composition of electrical sources corresponding to electric power demand



# History of Electricity System Reform in Japan

No competition in the electricity market before 1995.

10 vertically integrated GEUs(General Electricity Utilities) dominated and controlled the market

1995

- Open the IPP (Independent Power Producer) market

2000

- Introduce partial retail competition (>2000kw)
- Accounting separation of Transmission/Distribution sector

2005

- Expand retail competition(>50kw)
- Establish the whole sale power exchange(JEPX)

(2008)


- Modify the rule of wheeling rates

# Current electricity system

- Partial liberalization : retail competition for over 50kw customers
- Retail players : 10 big GEUs(vertically integrated, regional monopoly), PPS, etc
- Situation is...
  - Share of non-GEU power producer and supplier : 3.6%
  - 0.6% of the total retail market sales is transacted at JEPX

Negative aspects of regional monopoly were revealed by 3.11

- 1.Lack of system to transmit electricity beyond regions.
- 2.Little competition and strong price control
3. Limit in digesting the change in energy mix (cf. renewables)



# Decision on Electricity System Reform in 2013

- The Cabinet decided to execute the Policy on Electricity System Reform on April 2, 2013

## Objectives:

- /Securing the stable supply
- /Suppressing electricity rates to the maximum extent possible
- /Expanding choices for consumers and business opportunities


## Process:

A bold reform will be steadily carried out step by step focusing on the 3 agendas:

- /Cross-regional Coordination of Transmission Operators(by 2015)
- /Full Retail Competition in around 2016 (regulated tariff expired by 2020)
- /Unbundle the transmission/distribution sector by 2020




# For Full Retail Competition




(Note) The scope of liberalization of Okinawa Electric Power Company was expanded in April 2004, from users of power over 20,000kW, 60,000V, to extra-high-voltage power users (over 2,000kW, in principle).

# Nuclear Power Plants in Japan







## The Accident at Fukushima Dai-ichi NPS

- The accident at Fukushima Dai-ichi NPS was caused by long lasting complete power loss due to common cause failure (CCF) of electrical equipment following tsunami, and insufficient provision against severe accident.
- It is rated at INES Level 7, and people who lived in the specific area including those within 20 km radius from the site are still not able to return home.



The moment when tsunami attacked Fukushima Dai-ichi NPS (source: TEPCO)


## Technical Knowledge acquired from the Accident

In order to address root causes in a practical manner, we have closely investigated the accident in the areas of:


- External power supply systems
- On-site power supply systems
- Cooling systems
- Confinement systems
- Communication, instrumentation and control systems, and emergency response arrangements

## Treatment of High Level Radioactive Contaminated Water

- Highly-radioactive contaminated water accumulated in the reactor building and turbine buildings is treated to reduce the concentrations of radioactive materials and reused.



## Progression of Accident (Outline of Accident Progression Common to Units 1-3)




## Max. Acceleration Values Observed in Reactor Buildings of each Unit

Loc. of seismometer (bottom floor of reactor bld.)		Record			Max. response acceleration to the design basis ground motion Ss (Gal※2)		
		Max. acceleration (Gal※2)					
		NS	EW	UD	NS	EW	UD
Fukushima Dai-ichi	Unit 1	460※1	447※1	258※1	487	489	412
	Unit 2	348※1	550※1	302※1	441	438	420
	Unit 3	322※1	507※1	231※1	449	441	429
	Unit 4	281※1	319※1	200※1	447	445	422
	Unit 5	311※1	548※1	256※1	452	452	427
	Unit 6	298※1	444※1	244	445	448	415

※1 : Each recording was interrupted at around 130-150(s) from recording start time


※2 : 1Gal=0.01m/s<sup>2</sup> , 981Gal=1G

## Assumed Height and Actual Height of Tsunami in Each NPS



Seismic intensity 4 5 5+ 6 6+ 7 JMA 1st report during the main shock

© Reference: JMA "Tohoku District-Off the Pacific Coast Earthquake in 2011(1st Report)," <http://www.jma.go.jp/jma/index.html>, partially modified by JNES



## Areas inundated by Tsunami at Each NPS




Text added by NISA to published materials from Niigata Prefectural Technology Committee and Google



# Technical Knowledge about Accident at Fukushima Dai-ichi Nuclear Power Station, TEPCO

## Direction of Countermeasures (Point) - Interim Report -




# Impact of Tsunami on On-site Power Supply and Cooling Systems

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Diesel Generator	× 1A, 1B (T/B basement)	× 2A (T/B basement) 2B (Common pool 1F)	× 3A, 3B (T/B basement)	× 4A (T/B basement) 4B (Common pool 1F)	× 5A, 5B (T/B basement)	△ 6A: R/B basement 6B: DG building 1F (Usable) HPCS: R/B basement
high-voltage switch boards	× T/B 1F	× T/B basement, etc.	× T/B basement, etc.	× T/B basement, etc.	× T/B basement, etc.	△ R/B 2F basement
Power center (note)	× T/B 1F etc.	△ T/B 1F etc.	× T/B basement, etc.	△ T/B 1F, etc.	△ T/B 2F, etc.	△ R/B 2F basement, etc.
DC power (battery)	× C/B basement, etc.	× C/B basement, etc.	○ T/B mezzanine basement	× C/B basement, etc.	○ T/B mezzanine basement	○ T/B mezzanine basement
Emergency core cooling equipment	△ However, IC required inspection	△ (RCIC usable)	△ (RCIC and HPC usable)	—	—	—


×: Unusable due to flooding or water damage △: Partially unusable ○: Usable T/B: Turbine building C/B: Control building R/B: Reactor building  
(Note) Air circuit breaker (ACB), guard relay and peripheral equipment stored in a compact manner using a motive power panel that uses low-voltage circuits within the plant

# State of Damage to On-site Power Supply Equipments (Fukushima Dai-ichi, Unit 1)




## Operating Conditions of Isolation Condenser (IC) of Unit 1

- Due to loss of DC power supply after tsunami, the indication of the valve status (open or close) went off, and the IC became uncontrollable.
- Due to loss of DC power supply, the interlock of the isolation valve in fail-safe mode closed the IC valves.



## Operating Conditions of the Isolation Condenser (IC) of Unit 1 (cont.)


- Since the valves inside the PCV are operated with AC power, both status-check and operation were impossible even when the DC power supply was temporarily restored.
- The status of the IC was misunderstood.



## Impact on Loss of Function of Confinement Systems

- Radioactive material leakage presumably occurred when the pressure of the PCV was increased before the venting because the radioactive dose had increased after increasing of the pressure of the PCV of the Unit 1. Possible location of leakage was top flange, penetration of the containment vessel and/or equipment hatches.
- It is highly possible that the leakages were caused by deterioration of the organic sealing as a result of high temperatures by thermal radiation directly from the pressure vessel.
- When venting was conducted, the standby gas treatment systems (SGTS) was not properly isolated, thus hydrogen gas back flew into the reactor building. (in particular, Unit 4)

# Places of Possible Leakage (Example of Mark-I type Reactor)




(Source) Example of Onagawa Power Station of Tohoku Electric Power Co., Inc. (The photo of the top flange is courtesy of Tokyo Electric Power Co., Inc.)



## Possibility of Back-flow to R/B by PCV Vents (Units 1-4)

- To isolate SGTS at the time of PCV vents, the outlet valves of SGTS must be closed according to the operational procedure. But the outlet valves of SGTS of Unit 3 were not isolated. Those of Unit 4 were thought not to be isolated as well.
- Because of the damper at the outlet for Units 1-3 which closes during loss of power, the flow into the reactor building was supposed to be more prevented than Unit 4. Regarding Unit 3, there are no significant backflow in one direction into the building but it is difficult to deny the occurrence of backflow itself.





# Change of Nuclear Regulatory System

## Reform of Nuclear Regulatory Organization

/Independence

Separate the functions for nuclear regulation and nuclear promotion

Establish the Nuclear Regulation Authority(NRA) as an independent commission body

## Amendments to the Nuclear Regulation Act

/New regulation on severe accidents

/Regulation based on the state-of-the art information (backfitting)

/40-years operational limit for NPPs (exceptional less-than-20 years extension)

## New Regulatory Requirement

/Strengthening of Design Basis

/Severe Accident Measures

/Enhanced Measures for Earthquake/Tsunami

## Principle of Regulation

/Place emphasis of Defense-in-Depth

/Eliminate common cause failure

/Protective measures against extreme natural hazards

## Strengthening of Design Basis

/Comprehensive consideration of natural hazards including volcano, tornado and forest fire in addition to earthquake and tsunami, etc

/Reinforcement of fire protection measures

/Enhanced reliability of SSCs important to safety (e.g. Redundancy of piping)

/Reinforcement of off-site power supply (connection to different substations through multiple lines)

/Protection of systems for Ultimate Heat Sink

## Strengthen Requirement of Counter Measures for Severe Accident (SA)

Prevention of Core Damage (ATWS, Loss of RCF ▪ RDF ▪ RCF ▪ UHF etc.)

Prevention of Containment Failure (CV spray, Filtered venting etc.)

Prevention of hydrogen explosion at reactor building etc.

Cooling at SFP

Prevention of fuel damages during shutdown

Emergency Response Center

## Enhanced Measures for Earthquake/Tsunami

### Tsunami

More Stringent Standards on Tsunami

/Define “Design Basis Tsunami” – Exceeds the largest in the historical records

Enlarged Application of Higher Seismic Resistance

/SSCs for Tsunami protective measures such as Tsunami Gate are classified as Class S equivalent to RPV etc.

### Earthquake

More Stringent Criteria for active faults

/Active faults with activities later than the Late Pleistocene be considered for seismic design  
/Active in the Middle Pleistocene be investigated if needed


More Precise methods to define seismic ground motion

/3D observation of geological structure on the site

Displacement and Deformation


Class S buildings should not be constructed on the exposure of active faults

# Process of Resuming Nuclear Power Plant in Japan



***Question: Do you still believe nuclear is needed for Japanese economy?***

# Poll for Nuclear



NPS total Capacity at the Accident	48.96Mkw	48.96
Fukushima-Daiich	4.696Mkw Decommission Process	44.264
Fukushima-Daini	4.4Mkw Too Difficult to resume	39.864
Tsuruga Unit2	1.16Mkw Fault line Issue	38.704
5 first generation NPS	difficult to fit 40years rule (Tsuruga1, Mihama 1,2, Shimane1, Genkai1)	2.216Mkw
		36.488 Max

### **Twenty NPS submit TA report to NRA 20.10Mkw**

Sendai Unit1, 2	Approved by NRA	1.78Mkw	Hamaoka	Longer Construction	1.137Mkw
Takahama Unit3, 4	Approved soon	1.74Mkw	Simane, Onagawa, Ikata	Midst of the Review	2.535Mkw
Ooi Unit3,4	Close to finish soon	2.36Mkw	Kashiwazakikariwa, Tokai Daini	Difficulty to get agreement with Local Government	3.812Mkw
Genkai Unit 3,4	Close to finish soon	2.36Mkw			
Tomari, Higashidori, Shika	Fault line issue	4.375Mkw			



Not Submit Yet NPSs 18Unit 16.388Mkw

Onagawa 1,3	1.349Mkw	Fault Issue only
Kashiwazakikariwa 1-5	5.5Mkw	Unit2-4 never operated since 2007
Hamaoka 3,5	2.48Mkw	Longer Construction
Takahama 1,2	1.652Mkw	Challenge 40years Qualify
Mihama3, Ooi 1,2	3.176Mkw	Consider 40years challenge
Shika1, Ikata 1,2 Genkai 2	1.691Mkw	40 years challenge soon , Already changed RV

## New Plant


Shimane Unit3	1.373Mkw	93.6%complete
Ohma	1.383Mkw	37.6%complete






## 40 year rule – would need permit to continue operation

### NPS Capacity under 40years Rule for Submitted NPSs Only



### Capacity 40 year Challenge Case



**NOTE: Based only on repowering approval process**

# Conclusion

- /Japanese Government has not determined the quantitative target of energy supply by sources yet.
- /It will be published after the Unified Local Election in the spring of 2015.
- /The share of nuclear would be put between 15 to 25 % of power supply .
- /It could be possible to achieve but it takes at least 4 to 5 years.
- /It reduce tentative demand for LNG to some extent but the loss of power demand would be compensate by increase demand in the field of cogeneration.
- /LNG should compete with Coal by any means.
- /FIT system for renewable energy will be redesigned soon and electricity market reform will be conducted by 2020.