

# DRAFT FEASIBILITY REPORT FEASIBILITY ANALYSIS OF WATER SUPPLY FOR SMALL PUBLIC WATER SYSTEMS

ORBIT SYSTEMS, INC. – GRASSLANDS  
PWS ID# 0200360, CCN# 11982

*Prepared for:*

**THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY**



*Prepared by:*

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC GEOLOGY**

**AND**

**PARSONS**

*Preparation of this report was financed by the Texas Commission on Environmental Quality through the Drinking Water State Revolving Fund Small Systems Assistance Program*

**AUGUST 2005**

# **DRAFT FEASIBILITY REPORT**

## **FEASIBILITY ANALYSIS OF WATER SUPPLY FOR SMALL PUBLIC WATER SYSTEMS**

**Orbit Systems, Inc. – Grasslands  
PWS ID# 0200360, CCN# 11982**

*Prepared for:*

**THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY**

*Prepared by:*

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC  
GEOLOGY**

**AND**

**PARSONS**

***PREPARATION OF THIS REPORT WAS FINANCED BY THE TEXAS  
COMMISSION ON ENVIRONMENTAL QUALITY THROUGH THE DRINKING  
WATER STATE REVOLVING FUND SMALL SYSTEMS ASSISTANCE PROGRAM***

THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF INTERIM REVIEW UNDER THE  
AUTHORITY OF ERIC J. DAWSON, P.E. 79564 ON AUGUST 31, 2005. IT IS NOT TO BE USED  
FOR CONSTRUCTION, BIDDING, OR PERMIT PURPOSES.

**August 2005**

## **EXECUTIVE SUMMARY**

### **INTRODUCTION**

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Infrastructure and Technology Group Inc. (Parsons), were contracted by the Texas Commission on Environmental Quality (TCEQ) to conduct a study to assist with identifying and analyzing alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

The overall goal of this project was to promote compliance using sound engineering and financial methods and data for PWSs that had recently recorded sample results exceeding maximum contaminant levels (MCL). The primary objectives of this project were to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS for future implementation.

This feasibility report provides an evaluation of water supply alternatives for the Grasslands PWS, located in Brazoria County. The Grasslands PWS recorded arsenic concentrations of 12 micrograms per liter ( $\mu\text{g/L}$ ) in May 2001 and 12.3  $\mu\text{g/L}$  in February 2005. While these results were below the arsenic MCL of 50  $\mu\text{g/L}$  in effect at that time, the values were above the 10  $\mu\text{g/L}$  MCL for arsenic effective beginning January 23, 2006 (USEPA 2005a; TCEQ 2004a). Therefore, it was likely that the Grasslands PWS would face potential compliance issues under the new arsenic drinking water standard.

Basic system information for the Grasslands PWS is shown in Table ES.1.

**Table ES.1**  
**Grasslands PWS**  
**Basic System Information**

|                         |                                     |
|-------------------------|-------------------------------------|
| Population served       | 450                                 |
| Connections             | 150                                 |
| Average daily flow rate | 0.039 million gallons per day (mgd) |
| Peak demand flow rate   | 62.5 gallons per minute (gpm)       |
| Typical arsenic range   | 12 to 12.3 $\mu\text{g/L}$          |

## **STUDY METHODS**

The methods used for this study were based on a pilot study performed in 2004 and 2005 by TCEQ, BEG, and Parsons. Methods for identifying and analyzing compliance options were developed in the pilot study (a decision tree approach).

The process for developing the feasibility study used the following general steps:

1. Gather data from the TCEQ and Texas Water Development Board databases, from TCEQ files, and from information maintained by the PWS;
2. Conduct financial, managerial, and technical (FMT) evaluations of the PWS;
3. Perform a geologic and hydrogeologic assessment of the study area;
4. Develop treatment and non-treatment compliance alternatives which, in general, consist of the following possible options:
  - a. Connecting to neighboring PWSs via new pipeline or by pumping water from a newly installed well or an available surface water supply within the jurisdiction of the neighboring PWS;
  - b. Installing new wells within the vicinity of the PWS into other aquifers with confirmed water quality standards meeting the MCLs;
  - c. Installing a new intake system within the vicinity of the PWS to obtain water from a surface water supply with confirmed water quality standards meeting the MCLs;
  - d. Treating the existing non-compliant water supply by various methods depending on the type of contaminant; and
  - e. Delivering potable water by way of a bottled water program or a treated water dispenser as an interim measure only.
5. Assess each of the potential alternatives with respect to economic and non-economic criteria; and
6. Prepare a feasibility report and present the results to the PWS.


This basic approach is summarized in Figure ES-1.

## **HYDROGEOLOGICAL ANALYSIS**

The Grasslands PWS obtains groundwater from the Chicot subunit of the Gulf Coast aquifer. Arsenic is commonly found in area wells at concentrations greater than the MCL. Volcanic ash incorporated into the aquifer material may be the source of arsenic. Arsenic concentrations can vary significantly over relatively short distances; as a result,

1  
2

**Figure ES-1**  
**Summary of Project Methods**



there could be good quality groundwater nearby. However, the variability of arsenic concentrations makes it difficult to determine where wells can be located to produce acceptable water. Additionally, systems with more than one well should characterize the water quality of each well. If one of the wells is found to produce compliant water, as much production as possible should be shifted to that well as a method of achieving compliance. It may also be possible to do down-hole testing on non-compliant wells to determine the source of the contaminant. If the contaminant derives primarily from a single part of the formation, that part could be excluded by modifying the existing well, or avoided altogether by completing a new well.

## **COMPLIANCE ALTERNATIVES**

The Grasslands PWS is managed by Orbit Systems, an investor-owned utility that manages 33 water systems in the region. Overall, the system had an adequate level of FMT capacity. The system had some areas that needed improvement to be able to address future compliance issues; however, the system does have many positive aspects, including staff longevity, good communication, in-house expertise, effective planning for system growth, the regional nature of the Orbit organization, and maintenance and use of up-to-date system maps. Areas of concern for the system included lack of regular training; lack of ventilation, alarms, and breathing apparatus for chlorine buildings; lack of budgeting for individual systems; lack of capital improvement planning; lack of emergency planning; and lack of independently audited financial reports.

There are numerous PWSs within 15 miles of Grasslands Estates. Many of these nearby systems also have problems with arsenic, but there are several with good quality water. In general, feasibility alternatives were developed based on obtaining water from the nearest PWSs, either by directly purchasing water, or by expanding the existing well field. There is a minimum of surface water available in the area, and obtaining a new surface water source is considered through an alternative where treated surface water is obtained from the Brazosport Water Authority (BWA). In addition to the BWA, the City of Alvin is a potential large regional water supplier, and there are plans for the Gulf Coast Water Authority to build a surface water treatment plant in Fort Bend County that could potentially supply water to Grasslands.

A number of centralized treatment alternatives for arsenic removal have been developed and were considered for this report, for example, iron-based adsorption and coagulation/filtration. Point-of-use (POU) and point-of-entry treatment alternatives were also considered. Temporary solutions such as providing bottled water or providing a centralized dispenser for treated or trucked-in water, were also considered as alternatives.

Developing a new well close to Grasslands is likely to be the best solution if compliant groundwater can be found. Having a new well close to Grasslands is likely to be one of the lower cost alternatives since the PWS already possesses the technical and managerial expertise needed to implement this option. The cost of new well alternatives quickly increases with pipeline length, making proximity of the alternate source a key

concern. A new compliant well or obtaining water from a neighboring compliant PWS has the advantage of providing compliant water to all taps in the system.

Central treatment can be cost-competitive with the alternative of new nearby wells, but would require significant institutional changes to manage and operate. Like obtaining an alternate compliant water source, central treatment would provide compliant water to all water taps.

POU treatment can be cost competitive, but does not supply compliant water to all taps. Additionally, significant efforts would be required for maintenance and monitoring of the POU treatment units.

Providing compliant water through a central dispenser is significantly less expensive than providing bottled water to 100 percent of the population, but a significant effort is required for clients to fill their containers at the central dispenser.

## **FINANCIAL ANALYSIS**

Financial analysis of the Grasslands PWS indicated that current water rates are under funding operations, and a rate increase of approximately 8.8 percent would be necessary to meet operating expenses. This increase would raise the average annual water bill from \$375 to \$408. The current average water bill represents approximately 0.8 percent of the median household income (MHI), and would represent approximately 0.9 percent of the MHI with the increase. Table ES.2 provides a summary of the financial impact of implementing selected compliance alternatives, including the rate increase necessary to meet current operating expenses. The alternatives were selected to highlight results for the best alternatives from each different type or category.

Some of the compliance alternatives offer potential for shared or regional solutions. A group of PWSs could work together to implement alternatives for developing a new groundwater source or expanding an existing source, obtaining compliant water from a large regional provider, or for central treatment. Sharing the cost for implementation of these alternatives could reduce the cost on a per user basis. Additionally, merging PWSs or management of several PWSs by a single entity offers the potential for reduction in administrative costs.

**Table ES.2**  
**Selected Financial Analysis Results**

| Alternative                             | Funding Option | Average Annual Water Bill | Percent of MHI |
|---|----------------|---------------------------|----------------|
| Current                                 | NA             | \$375                     | 0.8            |
| To meet current expenses                | NA             | \$408                     | 0.9            |
| Nearby well within approximately 1 mile | 100% Grant     | \$530                     | 1.1            |
|   | Loan/Bond      | \$742                     | 1.6            |
| Central treatment                       | 100% Grant     | \$947                     | 2.0            |
|   | Loan/Bond      | \$1,242                   | 2.6            |
| Point-of-use                            | 100% Grant     | \$1,506                   | 3.2            |
|   | Loan/Bond      | \$1,581                   | 3.4            |
| Public dispenser                        | 100% Grant     | \$690                     | 1.5            |
|   | Loan/Bond      | \$698                     | 1.5            |



## TABLE OF CONTENTS

|  |             |
|--|-------------|
| <b>EXECUTIVE SUMMARY .....</b>                                     | <b>ES-1</b> |
| Introduction.....  | ES-1        |
| Study Methods .....  | ES-2        |
| Hydrogeological Analysis.....                                      | ES-2        |
| Compliance Alternatives.....                                       | ES-4        |
| Financial Analysis.....  | ES-5        |
| <b>LIST OF TABLES .....</b>  | <b>v</b>    |
| <b>LIST OF FIGURES .....</b>                                       | <b>v</b>    |
| <b>ACRONYMS AND ABBREVIATIONS.....</b>                             | <b>vii</b>  |
| <b>SECTION 1 INTRODUCTION.....</b>                                 | <b>1-1</b>  |
| 1.1 Public Health and Compliance with MCLs .....                   | 1-2         |
| 1.2 Methodology .....  | 1-2         |
| 1.3 Regulatory Perspective .....                                   | 1-4         |
| 1.4 Abatement Options .....  | 1-4         |
| 1.4.1 Existing Public Water Supply Systems .....                   | 1-5         |
| 1.4.1.1 Quantity .....   | 1-5         |
| 1.4.1.2 Quality .....  | 1-6         |
| 1.4.2 Potential for New Groundwater Sources .....                  | 1-6         |
| 1.4.2.1 Existing Non-Public Supply Wells.....                      | 1-6         |
| 1.4.2.2 Develop New Wells.....                                     | 1-7         |
| 1.4.3 Potential for Surface Water Sources .....                    | 1-7         |
| 1.4.3.1 Existing Surface Water Sources .....                       | 1-8         |
| 1.4.3.2 New Surface Water Sources .....                            | 1-8         |
| 1.4.4 Identification of Treatment Technologies.....                | 1-9         |
| 1.4.4.1 Treatment Technologies for Arsenic .....                   | 1-9         |
| 1.4.5 Description of Treatment Technologies .....                  | 1-10        |
| 1.4.5.1 Ion Exchange .....   | 1-10        |
| 1.4.5.2 Reverse Osmosis.....                                       | 1-11        |
| 1.4.5.3 Adsorption .....   | 1-13        |
| 1.4.5.4 Coagulation/Filtration and Iron Removal Technologies ..... | 1-15        |
| 1.4.6 Point-of-Entry and Point-of-Use Treatment Systems.....       | 1-16        |
| 1.4.7 Water Delivery or Central Drinking Water Dispensers.....     | 1-17        |
| <b>SECTION 2 EVALUATION METHODOLOGY .....</b>                      | <b>2-1</b>  |
| 2.1 Decision Tree .....  | 2-1         |

|   |  |            |
|---|--|------------|
| 2.2   | Data Sources and Data Collection .....                       | 2-1        |
| 2.2.1   | Data Search .....  | 2-1        |
| 2.2.1.1   | Water Supply Systems .....                                   | 2-1        |
| 2.2.1.2   | Existing Wells.....  | 2-6        |
| 2.2.1.3   | Surface Water Sources.....                                   | 2-6        |
| 2.2.1.4   | Groundwater Availability Model.....                          | 2-6        |
| 2.2.1.5   | Water Availability Model .....                               | 2-6        |
| 2.2.1.6   | Financial Data .....   | 2-7        |
| 2.2.1.7   | Demographic Data .....                                       | 2-7        |
| 2.2.2   | PWS Interviews .....   | 2-7        |
| 2.2.2.1   | PWS Capacity Assessment Process .....                        | 2-7        |
| 2.2.2.2   | Interview Process .....                                      | 2-9        |
| 2.3   | Alternative Development and Analysis .....                   | 2-10       |
| 2.3.1   | Existing PWS .....   | 2-10       |
| 2.3.2   | New Groundwater Source.....                                  | 2-11       |
| 2.3.3   | New Surface Water Source.....                                | 2-11       |
| 2.3.4   | Treatment .....  | 2-11       |
| 2.4   | Cost of Service and Funding Analysis.....                    | 2-12       |
| 2.4.1   | Financial Feasibility.....                                   | 2-12       |
| 2.4.2   | Median Household Income .....                                | 2-12       |
| 2.4.3   | Annual Average Water Bill .....                              | 2-13       |
| 2.4.4   | Financial Plan Development.....                              | 2-13       |
| 2.4.5   | Financial Plan Results.....                                  | 2-14       |
| 2.4.5.1   | Funding Options .....  | 2-14       |
| 2.4.5.2   | General Assumptions Embodied in Financial Plan Results ..... | 2-15       |
| 2.4.5.3   | Interpretation of Financial Plan Results .....               | 2-15       |
| 2.4.5.4   | Potential Funding Sources .....                              | 2-16       |
| <b>SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS.....</b> |  | <b>3-1</b> |
| 3.1   | Arsenic in the Gulf Coast Aquifer .....                      | 3-1        |
| 3.2   | Geology of Brazoria County.....                              | 3-2        |
| 3.3   | General Trends in Arsenic Concentrations.....                | 3-4        |
| 3.4   | Arsenic and Point Sources of Contamination .....             | 3-7        |
| 3.5   | Salt Domes .....   | 3-8        |
| 3.6   | Correlation with Depth .....                                 | 3-9        |
| 3.7   | Detailed Assessment .....                                    | 3-9        |
| 3.7.1   | Grasslands (PWS 0200360) .....                               | 3-11       |

|  |            |
|--|------------|
| <b>SECTION 4 ANALYSIS OF THE GRASSLANDS PWS.....</b>                           | <b>4-1</b> |
| 4.1 Description of Existing System .....                                       | 4-1        |
| 4.1.1 Existing System .....  | 4-1        |
| 4.1.2 Capacity Assessment for the Orbit Systems, Inc. ....                     | 4-3        |
| 4.1.2.1 General Structure .....  | 4-3        |
| 4.1.2.2 General Assessment of Capacity .....                                   | 4-3        |
| 4.1.2.3 Positive Aspects of Capacity .....                                     | 4-3        |
| 4.1.2.4 Capacity Deficiencies .....  | 4-4        |
| 4.1.2.5 Potential Capacity Concerns.....                                       | 4-5        |
| 4.2 Alternative Water Source Development .....                                 | 4-6        |
| 4.2.1 Identification of Alternative Existing Public Water Supply Sources ..... | 4-6        |
| 4.2.1.1 City of Alvin .....  | 4-9        |
| 4.2.1.2 City of Angleton/Brazosport Water Authority .....                      | 4-9        |
| 4.2.1.3 Bateman Water Works.....   | 4-10       |
| 4.2.1.4 Briar Meadows.....   | 4-10       |
| 4.2.1.5 Mammoet USA, Inc.....  | 4-10       |
| 4.2.1.6 Oak Bend Estates .....   | 4-11       |
| 4.2.1.7 Sienna Plantation MUD 1 .....  | 4-11       |
| 4.2.1.8 TDCJ Darrington Unit .....   | 4-11       |
| 4.2.1.9 TDCJ Ramsey Area .....   | 4-12       |
| 4.2.2 Potential for New Groundwater Sources .....                              | 4-12       |
| 4.2.2.1 Installing New Compliant Wells .....                                   | 4-12       |
| 4.2.2.2 Results of Groundwater Availability Modeling .....                     | 4-13       |
| 4.2.3 Potential for New Surface Water Sources .....                            | 4-14       |
| 4.2.4 Options for Detailed Consideration .....                                 | 4-14       |
| 4.3 Treatment Options .....  | 4-15       |
| 4.3.1 Centralized Treatment Systems .....                                      | 4-15       |
| 4.3.2 Point-of-Use Systems.....  | 4-15       |
| 4.3.3 Point-of-Entry Systems.....  | 4-15       |
| 4.4 Bottled Water .....  | 4-15       |
| 4.5 Alternative Development and Analysis .....                                 | 4-16       |
| 4.5.1 Alternative GL-1: Purchased Water from City of Alvin .....               | 4-16       |
| 4.5.2 Alternative GL-2: Purchased Water from Brazosport Water Authority .....  | 4-17       |
| 4.5.3 Alternative GL-3: New Well near Bateman Water Works .....                | 4-17       |
| 4.5.4 Alternative GL-4: New Well near Briar Meadows.....                       | 4-18       |
| 4.5.5 Alternative GL-5: New Well near Mammoet USA, Inc. ....                   | 4-19       |

|                                  |  |            |
|----------------------------------|--|------------|
| 4.5.6                            | Alternative GL-6: New Well near Oak Bend Estates .....               | 4-20       |
| 4.5.7                            | Alternative GL-7: New Well near Sienna Plantation MUD 1 .....        | 4-20       |
| 4.5.8                            | Alternative GL-8: New Well near TDCJ Darrington Unit .....           | 4-21       |
| 4.5.9                            | Alternative GL-9: New Well near TDCJ Ramsey Area .....               | 4-22       |
| 4.5.10                           | Alternative GL-10: Central Iron-Based Adsorption Treatment.....      | 4-22       |
| 4.5.11                           | Alternative GL-11: Central Coagulation/Filtration Treatment.....     | 4-23       |
| 4.5.12                           | Alternative GL-12: Point-of-Use Treatment.....                       | 4-23       |
| 4.5.13                           | Alternative GL-13: Point-of-Entry Treatment .....                    | 4-24       |
| 4.5.14                           | Alternative GL-14: New Well at 10 Miles .....                        | 4-25       |
| 4.5.15                           | Alternative GL-15: New Well at 5 Miles .....                         | 4-26       |
| 4.5.16                           | Alternative GL-16: New Well at 1 Mile .....                          | 4-27       |
| 4.5.17                           | Alternative GL-17: Public Dispenser for Treated Drinking Water ..... | 4-28       |
| 4.5.18                           | Alternative GL-18: 100 Percent Bottled Water Delivery .....          | 4-28       |
| 4.5.19                           | Alternative GL-19: Public Dispenser for Trucked Drinking Water ..... | 4-29       |
| 4.5.20                           | Summary of Alternatives .....  | 4-30       |
| 4.6                              | Cost of Service and Funding Analysis.....                            | 4-34       |
| 4.6.1                            | Financial Plan Development .....                                     | 4-34       |
| 4.6.1.1                          | Grasslands Financial Data .....                                      | 4-34       |
| 4.6.1.2                          | Current Financial Condition .....                                    | 4-35       |
| 4.6.1.3                          | Financial Plan Results.....  | 4-36       |
| <b>SECTION 5 REFERENCES.....</b> |  | <b>5-1</b> |

## **APPENDICES**

|            |   |
|------------|---|
| Appendix A | PWS Interview Form  |
| Appendix B | Cost Basis  |
| Appendix C | Compliance Alternative Conceptual Cost Estimates                            |
| Appendix D | Example Financial Model   |
| Appendix E | General Arsenic Geochemistry  |
| Appendix F | Orbit Systems Water Usage   |
| Appendix G | Analysis of Shared Solutions for Obtaining Water from BWA and City of Alvin |

## **LIST OF TABLES**

|            |  |      |
|------------|--|------|
| Table ES.1 | Grasslands PWS Basic System Information .....  | ES-1 |
| Table ES.2 | Selected Financial Analysis Results .....  | ES-6 |
| Table 3.1  | Maximum and Minimum Arsenic Concentrations .....   | 3-11 |
| Table 3.2  | Arsenic Concentrations in the Grasslands PWS .....   | 3-11 |
| Table 3.3  | Maximum and Minimum Arsenic Concentrations in the 5- and 10-km<br>Buffers of Grasslands PWS .....    | 3-13 |
| Table 4.1  | Existing Public Water Systems within 15 miles of Grasslands .....                                    | 4-6  |
| Table 4.2  | Existing Public Water Systems within 15 miles of Grasslands Selected for<br>Further Evaluation ..... | 4-8  |
| Table 4.3  | Summary of Compliance Alternatives for Grasslands.....   | 4-31 |
| Table 4.4  | Summary of Orbit Systems 2004 Water Revenues.....  | 4-34 |
| Table 4.5  | Summary of Orbit Systems 2004 Expenses.....  | 4-35 |
| Table 4.6  | Summary of Orbit Systems 2004 Operations .....   | 4-35 |
| Table 4.7  | Summary of Orbit Systems Required Revenue Increases .....  | 4-36 |
| Table 4.8  | Financial Impact on Households for Grasslands Alternatives.....                                      | 4-37 |

## **LIST OF FIGURES**

|             |  |     |
|-------------|--|-----|
| Figure ES-1 | Summary of Project Methods .....   | 3   |
| Figure 1.1  | Location Map .....   | 1-3 |
| Figure 2.1  | Decision Tree – Tree 1 Existing Facility Analysis.....   | 2-2 |
| Figure 2.2  | Decision Tree – Tree 2 Develop Treatment Alternatives .....                                    | 2-3 |
| Figure 2.3  | Decision Tree – Tree 3 Preliminary Analysis.....   | 2-4 |
| Figure 2.4  | Decision Tree – Tree 4 Financial.....  | 2-5 |
| Figure 3.1  | Detectable Arsenic Concentrations in Groundwater (TWDB Database) .....                         | 3-1 |
| Figure 3.2  | Detectable Arsenic Concentrations in Groundwater (NURE Database) .....                         | 3-2 |
| Figure 3.3  | Spatial Distribution of Arsenic Concentrations (TWDB Database).....                            | 3-4 |
| Figure 3.4  | Spatial Distribution of Arsenic Concentrations (NURE Database).....                            | 3-5 |
| Figure 3.5  | Relationship Between Arsenic and Molybdenum (NURE Database) .....                              | 3-6 |
| Figure 3.6  | Relationship Between Arsenic and Molybdenum (TWDB Database) .....                              | 3-6 |
| Figure 3.7  | Relationship Between High Arsenic Concentrations and pH.....                                   | 3-7 |
| Figure 3.8  | Potential Sources of Arsenic Contamination and Arsenic Concentrations<br>(TWDB Database) ..... | 3-7 |
| Figure 3.9  | Potential Sources of Arsenic Contamination and Arsenic Concentrations<br>(NURE Database) ..... | 3-8 |

---

|             |   |      |
|-------------|---|------|
| Figure 3.10 | Salt Dome Locations and Arsenic Concentrations .....  | 3-8  |
| Figure 3.11 | Relationship Between Arsenic Concentrations and Well Depth .....  | 3-9  |
| Figure 3.12 | Arsenic Concentrations in the Vicinity of PWS Wells.....  | 3-10 |
| Figure 3.13 | Arsenic Concentrations in 5- and 10-km Buffers of Grasslands PWS Wells<br>(TWDB and NURE Databases) ..... | 3-12 |
| Figure 3.14 | Arsenic Concentrations in 5- and 10-km Buffers of Grasslands PWS Wells<br>(TCEQ Database).....            | 3-13 |
| Figure 4.1  | Grasslands Pipeline Alternatives .....  | 4-2  |
| Figure 4.2  | Alternative Costs Summary: Grasslands .....   | 4-40 |

## **ACRONYMS AND ABBREVIATIONS**

|                     |  |
|---------------------|--|
| ft <sup>2</sup>     | Square feet                                  |
| °F                  | Degrees Fahrenheit                           |
| AA                  | Activated Alumina                            |
| BAT                 | Best available technology                    |
| BEG                 | Bureau of Economic Geology                   |
| BWA                 | Brazosport Water Authority                   |
| CA                  | Chemical analysis                            |
| CCN                 | Certificate of Convenience and Necessity     |
| CO                  | Correspondence                               |
| DWSRF               | Drinking Water State Revolving Fund          |
| EDR                 | Electrodialysis reversal                     |
| ETJ                 | Extra-territorial jurisdiction               |
| FMT                 | Financial, managerial, and technical         |
| GAM                 | Groundwater Availability Model               |
| gpm                 | Gallons per minute                           |
| gpm/ft <sup>2</sup> | Gallons per minute per square foot           |
| gpy                 | Gallons per year                             |
| HGCSD               | Harris-Galveston Coastal Subsidence District |
| IX                  | Ion exchange                                 |
| MCL                 | Maximum contaminant level                    |
| µg/L                | Microgram per liter                          |
| µg                  | Microgram                                    |
| mg/L                | Milligram per liter                          |
| mgd                 | Million gallons per day                      |
| MHI                 | Median household income                      |
| MOR                 | Monthly operating report                     |
| MUD                 | Municipal Utility District                   |
| NMEFC               | New Mexico Environmental Financial Center    |
| NURE                | National Uranium Resource Evaluation         |
| O&M                 | Operation and Maintenance                    |
| Orbit               | Orbit Systems Inc.                           |
| POE                 | Point-of-entry                               |
| POU                 | Point-of-use                                 |
| PVC                 | Polyvinyl chloride                           |
| PWS                 | Public water system                          |
| RO                  | Reverse osmosis                              |
| SCBA                | Self-contained breathing apparatus           |
| SDWA                | Safe Drinking Water Act                      |

|       |   |
|-------|---|
| SMCL  | Secondary maximum contaminant level       |
| TCEQ  | Texas Commission on Environmental Quality |
| TDCJ  | Texas Department of Criminal Justice      |
| TDS   | Total dissolved solids                    |
| TSS   | Total suspended solids                    |
| TWDB  | Texas Water Development Board             |
| USEPA | U.S. Environmental Protection Agency      |
| WAM   | Water Availability Model                  |
| WC&ID | Water Control and Improvement District    |
| WTP   | Water treatment plant                     |



## **SECTION 1 INTRODUCTION**

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Infrastructure and Technology Group Inc. (Parsons), have been contracted by the Texas Commission on Environmental Quality (TCEQ) to assist with identifying and analyzing compliance alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards. A total of 15 PWSs were evaluated in this project and each is addressed in a separate report. The 15 systems evaluated for this project are listed below:

| <b>Public Water System</b>                  | <b>Texas County</b> |
|---|---------------------|
| City of Danbury                             | Brazoria            |
| Rosharon Road Estates                       | Brazoria            |
| Mark V Estates                              | Brazoria            |
| Rosharon Township                           | Brazoria            |
| Sandy Meadow Estates Subdivision            | Brazoria            |
| Grasslands                                  | Brazoria            |
| City of Eden                                | Concho              |
| City of Mason                               | Mason               |
| Falling Water                               | Kerr                |
| Greenwood Independent School District (ISD) | Midland             |
| Country Village Mobile Home Estates         | Midland             |
| South Midland County Water Systems          | Midland             |
| Warren Road Subdivision Water Supply        | Midland             |
| Huber Garden Estates                        | Ector               |
| Devilla Mobile Home Park                    | Ector               |

The overall goal of this project is to promote compliance using sound engineering and financial methods and data for PWSs that have recently had sample results that exceed maximum contaminant levels (MCL). The primary objectives of this project are to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS with regard to future implementation. The feasibility studies identify a range of potential compliance alternatives, and present basic data that can be used for evaluating feasibility. The compliance alternatives addressed include a description of what would be required for implementation, conceptual cost estimates for implementation, and non-cost factors that could be used to differentiate between alternatives. The cost estimates are intended for

comparing compliance alternatives, and to give a preliminary indication of potential impacts on water rates resulting from implementation.

It is anticipated that the PWS will review the compliance alternatives in this report to determine if there are promising alternatives, and then select the most attractive alternative(s) for more detailed evaluation and possible subsequent implementation. This report contains a decision tree approach that guided the efforts for this study, and also contains steps to guide a PWS through the subsequent evaluation, selection, and implementation of a compliance alternative.

This feasibility report provides an evaluation of water supply alternatives for the Grasslands PWS, located in Brazoria County. The Grasslands PWS recorded arsenic concentrations of 12 micrograms per liter ( $\mu\text{g/L}$ ) in May 2001 and 12.3  $\mu\text{g/L}$  in February 2005. While these results were below the arsenic MCL of 50  $\mu\text{g/L}$  in effect at that time, the values were above the 10  $\mu\text{g/L}$  MCL for arsenic effective beginning January 23, 2006 (USEPA 2005a; TCEQ 2004a). Therefore, it was likely that the Grasslands PWS would face potential compliance issues under the new arsenic drinking water standard.


## **1.1 PUBLIC HEALTH AND COMPLIANCE WITH MCLS**

The goal of this project is to promote compliance for PWSs that supply drinking water exceeding regulatory MCLs. This project only addresses these contaminants and does not address any other violations that may exist for a PWS. As mentioned above, the Grasslands Water System has had recent sample results that exceed the MCL for arsenic. The health concerns related to drinking water above the MCL for arsenic are briefly described below.

In general, contaminants in drinking water above MCLs can have both short-term (acute) and long-term or lifetime (chronic) effects. Potential health effects from long-term ingestion of water with levels of arsenic above the MCL (0.01 mg/L) include non-cancerous effects, such as cardiovascular, pulmonary, immunological, neurological and endocrine effects, and cancerous effects, including skin, bladder, lung, kidney, nasal passage, liver, and prostate cancer (USEPA 2005b).


## **1.2 METHODOLOGY**

The methodology for this project follows that of the pilot study performed in 2004 and 2005 by TCEQ, BEG, and Parsons. The pilot study evaluated water supply alternatives for PWSs that supply drinking water with nitrate concentrations above USEPA and Texas drinking water standards. Three PWSs were evaluated in the pilot study to develop the methodology (*i.e.*, decision tree approach) for analyzing options for provision of compliant drinking water. This project is performed using the decision tree approach developed in the pilot study.



**Figure 1.1**

**Grasslands  
Location Map**



Other tasks of the feasibility study are as follows:

- Identifying available data sources;
- Gathering and compiling data;
- Conducting financial, managerial, and technical (FMT) evaluations of the selected PWSs;
- Performing a geologic and hydrogeologic assessment of the study area;
- Developing treatment and non-treatment compliance alternatives;
- Assessing potential alternatives with respect to economic and non-economic criteria;
- Preparing a feasibility report; and
- Suggesting refinements to the approach for future studies.

The remainder of Section 1 of this report addresses the regulatory background, and provides a summary of compliance alternatives. Section 2 describes the methodology used to develop and assess compliance alternatives. The groundwater sources of arsenic are addressed in Section 3. Findings for the Grasslands Water System, along with compliance alternatives development and evaluation, can be found in Section 4. Section 5 references the sources used in this report.

### **1.3 REGULATORY PERSPECTIVE**

The Utilities & Districts and Public Drinking Water Sections of the TCEQ Water Supply Division are responsible for implementing the federal Safe Drinking Water Act (SDWA) requirements that include oversight of PWSs and water utilities. These responsibilities include:

- Monitoring public drinking water quality;
- Processing enforcement referrals for MCL violators;
- Tracking and analyzing compliance options for MCL violators;
- Providing FMT assessment and assistance to PWSs;
- Participating in the Drinking Water State Revolving Fund (DWSRF) program to assist PWSs in achieving regulatory compliance; and
- Setting rates for privately-owned water utilities.

This project was conducted to assist in achieving these responsibilities.

### **1.4 ABATEMENT OPTIONS**

When a PWS exceeds a regulatory MCL, the PWS must take action to correct the violation. The MCL exceedance at the Grasslands PWS is for arsenic. The following

subsections explore alternatives considered as potential options for obtaining/providing compliant drinking water.

### **1.4.1 Existing Public Water Supply Systems**

A common approach to achieve compliance is for the PWS to make arrangements with a neighboring PWS for water supply. For this arrangement to work, the PWS from which water is being purchased (supplier PWS) must have water in sufficient quantity and quality, the political will must exist, and it must be economically feasible.

#### **1.4.1.1 Quantity**

For purposes of this report, quantity refers to water volume, flow rate, and pressure. Before approaching a potential supplier PWS, the non-compliant PWS should determine its water demand on the basis of average day and maximum day. Peak instantaneous demands can be met through proper sizing of storage facilities. Further, the potential for obtaining the appropriate quantity of water to blend to achieve compliance should be considered. The concept of blending involves combining water with low levels of contaminants with non-compliant water in sufficient quantity that the resulting blended water is compliant. The exact blend ratio would depend on the quality of the water a potential supplier PWS can provide, and would likely vary over time. If high quality water is purchased, produced or otherwise obtained, blending can reduce the amount of high quality water required. Implementation of blending will require a control system to ensure the blended water is compliant.

If the supplier PWS does not have sufficient quantity, the non-compliant community could pay for the facilities necessary to increase the quantity to the extent necessary to supply the needs of the non-compliant PWS. Potential improvements might include, but are not limited to:

- Additional wells;
- Developing a new surface water supply;
- Additional or larger-diameter piping;
- Increasing water treatment plant capacity;
- Additional storage tank volume;
- Reduction of system losses;
- Higher-pressure pumps; or
- Upsized, or additional, disinfection equipment.

In addition to the necessary improvements, a transmission pipeline would need to be constructed to tie the two PWSs together. The pipeline must tie-in at a point in the supplier PWS where all the upstream pipes and appurtenances are of sufficient capacity to handle the new demand. In the non-compliant PWS, the pipeline must tie in at a point where no down stream bottlenecks are present. If blending is the selected method of

operation, the tie-in point must be at the proper point of the existing non-compliant PWS to ensure that all the water in the system is blended to achieve regulatory compliance.

#### **1.4.1.2 Quality**

If a potential supplier PWS obtains its water from the same aquifer (or same portion of the aquifer) as the non-compliant PWS, the quality of water may not be significantly better. However, water quality can vary significantly due to well location, even within the same aquifer. If localized areas with good water quality cannot be identified, the non-compliant PWS would need to find a potential supplier PWS that obtains its water from a different aquifer or from a surface water source. Additionally, a potential supplier PWS may treat non-compliant raw water to an acceptable level.

Surface water sources may offer a potential higher-quality source. Since there are significant treatment requirements, utilization of surface water for drinking water is typically most feasible for larger local or regional authorities or other entities that may provide water to several PWSs. Where PWSs that obtain surface water are neighbors, the non-compliant PWS may need to deal with those systems as well as with the water authorities that supply the surface water.

### **1.4.2 Potential for New Groundwater Sources**

#### **1.4.2.1 Existing Non-Public Supply Wells**

Often there are wells not associated with PWSs that are located in the vicinity of the non-compliant PWS. The current use of these wells may be for irrigation, industrial purposes, domestic supply, stock watering, and other purposes. The process for investigating existing wells is as follows:

- Use existing data sources (see below) to identify wells in the areas that have satisfactory quality. For Brazoria County, the following standards could be used in a rough screening to identify compliant groundwater:
  - Arsenic concentrations less than 0.008 mg/L (below the MCL of 0.01 mg/L); and
  - Total dissolved solids (TDS) concentrations less than 1,000 mg/L.
- Review the recorded well information to eliminate those wells that appear to be unsuitable for the application. Often, the “Remarks” column in the Texas Water Development Board (TWDB) hard-copy database provides helpful information. Wells eliminated from consideration generally include domestic and stock wells, dug wells, test holes, observation wells, seeps and springs, destroyed wells, wells used by other communities, *etc.*
- Identify wells of sufficient size and that have been used for industrial or irrigation purposes. Often the TWDB database includes well yields, which may indicate the likelihood of a particular well being a satisfactory source.

- At this point in the process, the local groundwater control district (if one exists) should be contacted to obtain information about pumping restrictions. Also, preliminary cost estimates should be made to establish the feasibility of pursuing further well development options.
- If particular wells appear to be acceptable, the owner(s) should be contacted to ascertain the willingness to work with the PWS. Once the owner agrees to participate with the program, questions should be asked about the wells. Many owners have more than one well, and would probably be the best source of information regarding the latest test dates, who tested the water, flow rates, and other well characteristics.
- After collecting as much information as possible from cooperative owners, the PWS would then narrow down the selection of wells and sample and analyze the selected wells for quality. Wells with good water quality would then be potential candidates for test pumping. In some cases, a particular well may need to be refurbished before test pumping. Information obtained from test pumping would then be used in combination with information about the general characteristics of the aquifer to determine whether a well at this location would be suitable as a supply source.
- It is recommended that new wells be installed instead of using existing wells to ensure the well characteristics are known and the well meets construction standards.
- Permit(s) would then be obtained from the groundwater control district or other regulatory authority, and an agreement with the owner (purchase or lease, access easements, *etc.*) would then be negotiated.

#### **1.4.2.2 Develop New Wells**

If no existing wells are available for development, the PWS or group of PWSs has an option of developing new wells. Records of existing wells, along with other hydrogeologic information and modern geophysical techniques, should be used to identify potential locations for new wells. In some areas, the TWDB's Groundwater Availability Model (GAM) may be applied to indicate potential sources. Once a general area has been identified, land owners and regulatory agencies should be contacted to determine an exact location for a new well or well field. Pump tests and water quality tests would be required to determine if a new well will produce an adequate quantity of good quality water. Permits from the local groundwater control district or other regulatory authority could also be required for a new well.

#### **1.4.3 Potential for Surface Water Sources**

Water rights law dominates the acquisition of water from surface water sources. For a PWS, 100 percent availability of water is required, except where a back-up source is available. For PWSs with an existing water source, although it may be non-compliant

because of elevated concentrations of one or more parameters, water rights may not need to be 100 percent available.

#### **1.4.3.1 Existing Surface Water Sources**

“Existing surface water sources” of water refers to municipal water authorities and cities that obtain water from surface water sources. The process of obtaining water from such a source is generally less time consuming and less costly than the process of developing a new source; therefore, it should be a primary course of investigation. An existing source would be limited by its water rights, the safe yield of a reservoir or river, or by its water treatment or water conveyance capability. The source must be able to meet the current demand and honor contracts with communities it currently supplies. In many cases, the contract amounts reflect projected future water demand based on population or industrial growth.

A non-compliant PWS would look for a source with sufficient spare capacity. Where no such capacity exists, the non-compliant PWS could offer to fund the improvements necessary to obtain the capacity. This approach would work only where the safe yield could be increased (perhaps by enlarging a reservoir) or where treatment capacity could be increased. In some instances, where they are available, water rights could possibly be purchased.

In addition to securing the water supply from an existing source, the non-compliant PWS would have to arrange for the transmission of the water to the PWS. In some cases, this may require negotiations with, contracts with, and payments to an intermediate PWS (an intermediate PWS is one where the infrastructure is used to transmit water from a “supplier” PWS to a “supplied” PWS, but does not provide any additional treatment to the supplied water). The non-compliant PWS could be faced with having to fund improvements to the intermediate PWS in addition to constructing its own necessary transmission facilities.

#### **1.4.3.2 New Surface Water Sources**

Communication with the TCEQ and relevant planning groups from the beginning is essential in the process of obtaining a new surface water source. Preliminary assessment of the potential for acquiring new rights may be based on surface water availability maps located on the TWDB website. Where water rights appear to be available, the following activities need to occur:

- Discussions with TCEQ to indicate the likelihood of obtaining those rights. The TCEQ may use the Water Availability Model (WAM) to assist in the determination.
- Discussions with land owners to indicate potential treatment plant locations.
- Coordination with U.S. Army Corps of Engineers and local river authorities.



- Preliminary engineering design to determine the feasibility, costs, and environmental issues of a new intake, treatment plant, and conveyance system.

Should these discussions indicate that a new surface water source is the best option, the community would proceed with more intensive planning (initially obtaining funding), permitting, land acquisition, and detailed designs.

#### **1.4.4 Identification of Treatment Technologies**

Various treatment technologies were also investigated as compliance alternatives for treatment of arsenic to its regulatory level (*i.e.*, MCL). Numerous options have been identified by the USEPA as best available technologies (BAT) for the non-compliant constituents. Identification and descriptions of the various BATs are provided in the following sections.

##### **1.4.4.1 Treatment Technologies for Arsenic**

In January 2001, the USEPA published a final rule in the Federal Register that established an MCL for arsenic of 0.01 mg/L (USEPA 2001). The regulation applies to all community water systems and non-transient, non-community water systems, regardless of size.

The new arsenic MCL of 0.01 mg/L becomes effective on January 23, 2006, at which time the running average annual arsenic level must be at or below 0.01 mg/L at each entry point to the distribution system, although point-of-use (POU) treatment can be instituted in place of centralized treatment. All groundwater systems must complete initial monitoring or have a State-approved waiver by December 31, 2007.

The following BATs were identified in the final rule for achieving compliance with the arsenic MCL:

- Reverse Osmosis (RO);
- Ion Exchange (IX);
- Electrodialysis Removal (EDR);
- Activated Alumina (AA);
- Oxidation/Filtration;
- Enhanced Coagulation/Filtration; and
- Enhanced Lime Softening.

In addition, the following technologies are listed in the final rule as Small System Compliance Technologies:

- RO (centralized and POU);
- IX;

- EDR;
- AA (centralized and POU);
- Oxidation/Filtration;
- Coagulation/Filtration, Enhanced Coagulation/Filtration, and Coagulation-Assisted Microfiltration; and
- Lime Softening and Enhanced Lime Softening.

#### 1.4.5 Description of Treatment Technologies

According to a recent USEPA report for small water systems with <10,000 customers (USEPA 2004), a number of drinking water treatment technologies are available to reduce arsenic concentrations in source water to below the new MCL of 0.01 mg/L, including IX, membrane processes such as RO, adsorption, and coagulation/filtration-related processes. Many of the most effective arsenic removal processes available are iron-based treatment technologies such as chemical coagulation/filtration with iron salts, and adsorptive media with iron-based products. These processes are particularly effective at removing arsenic from aqueous systems because iron surfaces have a strong affinity for adsorbing arsenic. Other arsenic removal processes such as AA and enhanced lime softening are more applicable to larger water systems because of their operational complexity and cost. A description and discussion of arsenic removal technologies applicable to smaller systems follows.

##### 1.4.5.1 Ion Exchange

**Process** – In solution, salts separate into positively-charged cations and negatively charged anions. Ion exchange is a reversible chemical process in which ions from an insoluble, permanent, solid resin bed are exchanged for ions in water. The process relies on the fact that certain ions are preferentially adsorbed on the ion exchange resin. Operation begins with a fully charged cation or anion bed, having enough positively or negatively charged ions to carry out the cation or anion exchange. Usually a polymeric resin bed is composed of millions of spherical beads about the size of medium sand grains. As water passes the resin bed, the charged ions are released into the water, being substituted or replaced with the contaminants in the water (ion exchange). When the resin becomes exhausted of positively or negatively charged ions, the bed must be regenerated by passing a strong, sodium chloride, solution over the resin bed, displacing the contaminant ions with sodium ions for cation exchange and chloride ions for anion exchange. Many different types of resins can be used to reduce dissolved contaminant concentrations. The IX treatment train for groundwater typically includes cation or anion resin beds with a regeneration system, chlorine disinfection, and clear well storage. Treatment trains for surface water may also include raw water pumps, debris screens, and filters for pre-treatment. Additional treatment or management of the concentrate and the removed solids would be necessary prior to disposal. For arsenic removal, an anion exchange resin in the chloride form is used to remove arsenate [As(V)]. Because arsenite [As(III)] occurs in water below pH 9 with no ionic charge, As(III) is not consistently removed by the anionic exchange process.

Pretreatment – There are pretreatment requirements for pH, organics, turbidity, and other raw water characteristics. Pretreatment may be required to reduce excessive amounts of total suspended solids (TSS), iron, and manganese, which could plug the resin bed, and typically includes media or carbon filtration. In addition, chlorination or oxidation may be required to convert As(III) to As(V) for effective removal.

Maintenance – The IX resin requires regular on-site regeneration, the frequency of which depends on raw water characteristics, the contaminant concentration, and the size and number of IX vessels. Many systems have undersized the IX vessels only to realize higher than necessary operating costs. Preparation of the sodium chloride solution is required. If used, filter replacement and backwashing would be required.

Waste Disposal – Approval from local authorities is usually required for disposal of concentrate from the regeneration cycle (highly concentrated salt solution); occasional solid wastes (in the form of broken resin beads) which are backwashed during regeneration; and if used, spent filters and backwash wastewater.

### **Advantages (IX)**

- Well established process for arsenic removal.
- Fully automated and highly reliable process.
- Suitable for small and large installations.

### **Disadvantages (IX)**

- Requires salt storage; regular regeneration.
- Concentrate disposal.
- Resins are sensitive to the presence of competing ions such as sulfate.

In considering the application of IX for removal of inorganics, it is important to understand what the effect of competing ions would be, and to what extent the brine can be recycled. Similar to AA, IX exhibits a selectivity sequence, which refers to an order in which ions are preferred. Sulfate competes with both nitrate and arsenic, but is more aggressive with arsenic in anion exchange. Source waters with TDS levels above 500 mg/L or sulfate above 50 mg/L are not amenable to IX treatment for arsenic removal. Spent regenerant is produced during IX bed regeneration, and it may have high concentrations of the sorbed contaminants which would be expensive to treat and/or dispose because of hazardous waste regulations. Research has been conducted to minimize this effect: recent research on arsenic removal shows that the brine can be reused as many as 25 times.

### **1.4.5.2 Reverse Osmosis**

Process – RO is a pressure-driven membrane separation process capable of removing dissolved solutes from water by means of particle size and electrical charge. The raw water is typically called feed, the product water is called permeate, and the concentrated

reject is called concentrate. Common RO membrane materials include asymmetric cellulose acetate and polyamide thin film composite. Common RO membrane configurations include spiral wound hollow fine fiber, but most RO systems to date are the spiral wound type. A typical RO installation includes a high pressure feed pump with chemical feed, parallel first and second stage membrane elements in pressure vessels, and valving and piping for feed, permeate, and concentrate streams. Factors influencing membrane selection are cost, recovery, rejection, raw water characteristics, and pretreatment. Factors influencing performance are raw water characteristics, pressure, temperature, and regular monitoring and maintenance. RO is capable of achieving over 97 percent removal of As(V) and 92 percent removal of As(III). The treatment process is relatively insensitive to pH. Water recovery is typically 60-80 percent, depending on the raw water characteristics. The concentrate volume for disposal can be significant.

Pretreatment – RO requires careful review of raw water characteristics and pretreatment needs to prevent membranes from fouling, scaling or other membrane degradation. Removal or sequestering of suspended and colloidal solids is necessary to prevent fouling, and removal of sparingly soluble constituents such as calcium, magnesium, silica, sulfate, barium, *etc.* may be required to prevent scaling. Pretreatment can include media filters, ion exchange softening, acid and antiscalant feed, activated carbon or bisulfite feed to dechlorinate, and cartridge filters to remove any remaining suspended solids to protect membranes from upsets.

Maintenance – Monitoring rejection percentage is required to ensure contaminant removal below MCL. Regular monitoring of membrane performance is necessary to determine fouling, scaling, or other membrane degradation. Acidic or caustic solutions are regularly flushed through the system at high volume/low pressure with a cleaning agent to remove foulants and scalants. Frequency of membrane replacement is dependent on raw water characteristics, pretreatment, and maintenance.

Waste Disposal – Pretreatment waste streams, concentrate flows, spent filters and membrane elements all require approved disposal methods.

### **Advantages (RO)**

- Can remove both As(III) and As(V) effectively.
- Can remove other undesirable dissolved constituents and excessive salts, if required.

### **Disadvantages (RO)**

- Relatively expensive to install and operate.
- Need sophisticated monitoring systems.
- Need to handle multiple chemicals.
- Waste of water because of the significant concentrate flows.
- Concentrated disposal.

RO is an expensive alternative to remove arsenic and is usually not economically competitive with other processes unless removal of nitrate and/or TDS is also required. The biggest drawback for using RO to remove arsenic is the waste of water through concentrate disposal which is also difficult or expensive because of the volume involved.

### 1.4.5.3 Adsorption

**Process** – The adsorptive media process is a fixed-bed process by which ions in solution, such as arsenic, are removed by available adsorptive sites on an adsorptive media. When the available adsorptive sites are filled, spent media may be regenerated or simply thrown away and replaced with new media. Granular AA was the first adsorptive media successfully applied for the removal of arsenic from water supplies. More recently, other adsorptive media (mostly iron-based) were developed and marketed for arsenic removal. Recent USEPA studies demonstrated that iron-based adsorption media typically have higher arsenic removal capacities compared to alumina-based media. In the USEPA-sponsored Round 1 full-scale demonstration of arsenic removal technologies for small water systems program, the selected arsenic treatment technologies included nine adsorptive media systems, one IX system, one coagulation/filtration system, and one process modification.

The selected adsorptive media systems used four different adsorptive media, including three iron-based media (*e.g.*, ADI's G2, Severn Trent and AdEdge's E33, and US Filter's GFH), and one iron-modified AA media (*e.g.*, Kinetico's AAFS50, a product of Alcan). The G2 media is a dry powder of diatomaceous earth impregnated with a coating of ferric hydroxide, developed by ADI specifically for arsenic adsorption. ADI markets G2 for both As(V) and As(III) removal, but it preferentially removes As(V). G2 media adsorbs arsenic most effectively at pH values within the 5.5 to 7.5 range, and less effectively at a higher pH value.

The Bayoxide® E33 media was developed by Bayer AG for the removal of arsenic from drinking water supplies. It is a dry granular iron oxide media designed to remove dissolved arsenic via adsorption onto its ferric oxide surface. Severn Trent markets the media in the U.S. for As(III) and As(V) removal as Sorb-33, and offers several arsenic package units with flow rates ranging from 150 to 300 gallons per minute (gpm). Another company, AdEdge, provides similar systems using the same media (marketed as AD-33) with flow rates ranging from 5 to 150 gpm. E33 adsorbs arsenic and other ions, such as antimony, cadmium, chromate, lead, molybdenum, selenium, and vanadium. The adsorption is effective at pH values ranging between 6.0 and 9.0. At greater than 8.0 to 8.5, pH adjustment is recommended to maintain adsorption capacity. Two competing ions that can reduce the adsorption capacity are silica (at levels greater than 40 mg/L) and phosphate (at levels greater than 1 mg/L).

GFH is a moist granular ferric hydroxide media produced by GEH Wasserchemie GmbH of Germany and marketed by US Filter under an exclusive marketing agreement. GFH is capable of adsorbing both As(V) and As(III). GFH media adsorb arsenic with a pH range of 5.5 to 9.0, but less effectively at the upper end of this range. Competing ions

such as silica and phosphate in source water can adsorb onto GFH media, thus reducing its arsenic removal capacity.

The AAFS50 is a dry granular media of 83 percent alumina and a proprietary iron-based additive to enhance the arsenic adsorption performance. Standard AA was the first adsorptive media successfully applied for the removal of arsenic from water supplies. However, it often requires pH adjustment to 5.5 in order to achieve optimum arsenic removal. The AAFS50 product is modified with an iron-based additive to improve its performance and to increase the pH range within which it can achieve effective removal. Optimum arsenic removal efficiency is achieved with a pH of the feed water less than 7.7. Competing ions such as fluoride, sulfate, silica, and phosphate can adsorb onto AAFS50 media, and potentially can reduce its arsenic removal capacity. The adsorption capacity of AAFS50 can be impacted by both high levels of silica (>40 mg/L) and phosphate (>1 mg/L). The vendor recommended that the system be operated in a series configuration to minimize the chance for arsenic breakthrough to impact drinking water quality.

All of the iron-based or iron-modified adsorptive media are of the throwaway type after exhaustion. The operations of these adsorption systems are quite similar and simple. Some of the technologies such as the E33 and GFH media have been operated successfully on large scale plants in Europe for several years.

Pretreatment – The adsorptive media are primarily used to remove dissolved arsenic and not for suspended solids removal. Pretreatment to remove TSS may be required if raw water turbidity is >0.3 NTU. However, most well waters are low in turbidity and hence pre-filtration is usually not required. Pre-chlorination may be required to oxidize As(III) to As(V) if the proportion of As(III) is high. No pH adjustment is required unless pH is relatively high.

Maintenance – Maintenance for the adsorption media system is minimal if no pretreatment is required. Backwash is required infrequently (monthly) and replacement and disposal of the exhausted media occurs between 1 to 3 years, depending on average water consumption, the concentrations of arsenic and competing ions in the raw water, and the media bed volume.

Waste Disposal – If no pretreatment is required there is minimal waste disposal involved with the adsorptive media system. Disposal of backwash wastewater is required especially during startup. Regular backwash is infrequent and disposal of the exhausted media occurs once every 1 to 3 years, depending on operating conditions. The exhausted media are usually considered non-hazardous wastes.

### **Advantages (Adsorption)**

- Some adsorbents can remove both As(III) and As(V).
- Very simple to operate.

### **Disadvantages (Adsorption)**

- Relatively new technology.
- Need replacement of adsorption media when exhausted.

The adsorption media process is the most simple and requires minimal operator attention, compared to other arsenic removal processes. The process is most applicable to small wellhead systems with low or moderate arsenic concentrations with no treatment process in place (*e.g.*, iron and manganese removal; if treatment facilities for iron and/or manganese removal are already in place, incorporating ferric chloride coagulation in the existing system would be a more cost-effective alternative for arsenic removal). The choice of media would depend on raw water characteristics, life cycle cost, and experience of the vendor. Many of the adsorption media are at the field-trial stage, but others are already being used in full-scale applications throughout Europe and the United States. Pilot testing may or may not be necessary prior to implementation depending on the experience of the vendor with similar water characteristics.

#### **1.4.5.4 Coagulation/Filtration and Iron Removal Technologies**

Process – Iron removal processes can be used to removal arsenic from drinking water supplies. Iron removal processes involved the oxidation of soluble iron and As(III), adsorption and/or co-precipitation of As(V) onto iron hydroxides, and filtration. The filtration can be accomplished with granular media filter or microfilter. When iron in the raw water is inadequate to accomplish arsenic removal, an iron salt such as ferric chloride is added to the water to form ferric hydroxide. The iron removal process is commonly called coagulation/filtration because iron in the form of ferric chloride is a common coagulant. The actual capacity to remove arsenic during iron removal depends on a number of factors, including the amount of arsenic present, arsenic speciation, pH, amount and form of iron present, and existence of competing ions, such as phosphate, silicate, and natural organic matter. The filters used in groundwater treatment are usually pressure filters feeding directly by the well pumps. The filter media can be regular dual media filters or proprietary media such as the engineered ceramic filtration media, Macrolite<sup>®</sup>, developed by Kinetico. Macrolite is a low-density, spherical media designed to allow for filtration rates up to 10 gpm per square foot (gpm/ft<sup>2</sup>), which is a higher loading rate than commonly used for conventional filtration media.

Pretreatment – Pre-chlorination to oxidize As(III) to As(V) is usually required for most groundwater sources. The adjustment of pH is required only for relatively high pH value. Coagulation with the feed of ferric chloride is required for this process. Sometimes a 5-minute contact tank is required ahead of the filters if the pH is high.

Maintenance – Maintenance is mainly to handle the ferric chloride chemical and feed systems, and for regular backwash of the filters. No filter replacement is required for this process.

Waste Disposal – Waste from the coagulation/filtration process is mainly iron hydroxide sludge with adsorbed arsenic in the backwash water. The backwash water can

be discharged to a public sewer if it is available. If a sewer is not available, the backwash water can be discharged to a storage and settling tank from where the supernatant is recycled in a controlled rate to the front of the treatment system and the settled sludge can be disposed of periodically to a landfill. Iron hydroxide sludge is usually not classified as hazardous waste.

### **Advantages**

- Very established technology for arsenic removal.
- Most economical process for arsenic removal.

### **Disadvantages**

- Need to handle chemical.
- Need to dispose of regular backwash wastewater.
- Sludge disposal.

The coagulation/filtration process is usually the most economical arsenic removal alternative, especially if a public sewer is available for accepting the discharge of the backwash water. However, because of the regular filter backwash requirements more operation and maintenance (O&M) attention is required from the utilities. Because of potential interference by competing ions, bench-scale or pilot testing may be required to ensure that the arsenic MCL can be met with this process alternative.

## **1.4.6 Point-of-Entry and Point-of-Use Treatment Systems**

Point-of-entry (POE) and point-of-use (POU) treatment systems can be used to provide compliant drinking water. For arsenic removal, these systems typically use small RO treatment units that are installed “under the sink” in the case of POU, and where water enters a house or building in the case of POE. It should be noted that the POU treatment units would need to be more complex than units typically found in commercial retail outlets in order to meet regulatory requirements, making purchase and installation more expensive. POE and POU treatment units would be purchased and owned by the PWS. These solutions are decentralized in nature, and require utility personnel entry into houses or at least onto private property for installation, maintenance, and testing. Due to the large number of treatment units that would be employed and would be largely out of the control of the PWS, it is very difficult to ensure 100 percent compliance. Prior to selection of a POE or POU program for implementation, consultation with TCEQ will be required to address measurement and determination of level of compliance.

The SDWA [§1412(b)(4)(E)(ii)] regulates the design, management and operation of POU and POE treatment units used to achieve compliance with an MCL. These restrictions, relevant to arsenic are:

- POU and POE treatment units must be owned, controlled, and maintained by the water system, although the utility may hire a contractor to ensure proper O&M and MCL compliance. The water system must retain unit ownership



and oversight of unit installation, maintenance and sampling; the utility ultimately is the responsible party when it comes to regulatory compliance. The water system staff need not perform all installation, maintenance, or management functions, as these tasks may be contracted to a third party, but the final responsibility for quality and quantity of the water supplied to the community resides with the water system, and the utility must monitor all contractors closely. Responsibility for the O&M of POU or POE devices installed for SDWA compliance may not be delegated to homeowners.

- POU and POE units must have mechanical warning systems to automatically notify customers of operational problems. Each POU or POE treatment device must be equipped with a warning device (*e.g.*, alarm, light) that will alert users when their unit is no longer adequately treating their water. As an alternative, units may be equipped with an automatic shut-off mechanism to meet this requirement.
- If the American National Standards Institute has issued product standards for a specific type of POU or POE treatment unit, only those units that have been independently certified according to these standards may be used as part of a compliance strategy.

The following observations with regard to using POE and POU devices for SDWA compliance were made by Raucher, *et al.* (2004):

- If POU devices are used as an SDWA compliance strategy, certain consumer behavioral changes would be necessary (*e.g.*, encouraging people to drink water only from certain treated taps) to ensure comprehensive consumer health protection.
- Although not explicitly prohibited in SDWA, USEPA indicates that POU treatment devices should not be used to treat for radon or for most volatile organic contaminants to achieve compliance, because POU devices do not provide 100 percent protection against inhalation or contact exposure to those contaminants at untreated taps (*e.g.*, shower heads).
- Liability – PWSs considering unconventional treatment options (POU, POE, or bottled water) must address liability issues. These could be meeting the drinking water standards, property entry and ensuing liabilities, and damage arising from improper installation or improper function of the POU and POE devices.

#### 1.4.7 Water Delivery or Central Drinking Water Dispensers

Current USEPA regulations 40 Code of Federal Regulations (CFR) 141.101 prohibit the use of bottled water to achieve compliance with an MCL, except on a temporary basis. State regulations do not directly address the use of bottled water. Use of bottled water at a non-compliant PWS would be on a temporary basis. Every 3 years, the PWSs that employ interim measures are required to present the TCEQ with estimates of costs

for piping compliant water to their systems. As long as the projected costs remain prohibitively high, the bottled water interim measure is extended. Until USEPA amends the noted regulation, the TCEQ is unable to accept water delivery or central drinking water dispensers as compliance solutions.

Central provision of compliant drinking water would consist of having one or more dispensers of compliant water where customers could come to fill containers with drinking water. The centralized water source could be from small to medium sized treatment units or could be compliant water delivered to the central point by truck.

Water delivery is an interim measure for providing compliant water. As an interim measure for a small impacted population, providing delivered drinking water may be cost effective. If the susceptible population is large, the cost of water delivery would increase significantly.

Water delivery programs require consumer participation to a varying degree. Ideally, the consumer would have to do no more than he/she currently does for a piped-water delivery system. Least desirable are those systems that require maximum effort on the part of the customer (*e.g.*, customer has to travel to get the water, transport the water, and physically handle the bottles). Such a system may appear to be lowest-cost to the utility; however, should a consumer experience ill effects from contaminated water and take legal action, the ultimate cost could increase significantly.

The ideal system would:

- Identify populations potentially susceptible to the health risk associated with arsenic, if any. If bottled water is only provided to customers who are part of the susceptible population, the utility should have an active means of identifying the susceptible population. Problems with illiteracy, language fluency, fear of legal authority, desire for privacy, and apathy may be reasons that some members of the susceptible population do not become known to the utility, and do not take part in the water delivery program.
- Maintain customer privacy by eliminating the need for utility personnel to enter the home.
- Have buffer capacity (*e.g.*, two bottles in service, so that when one is empty, the other is being used over a time period sufficient to allow the utility to change out the empty bottle).
- Provide for regularly scheduled delivery so that the customer would not have to notify the utility when the supply is low.
- Use utility personnel and equipment to handle water containers, without requiring customers to lift or handle bottles containing water.
- Be sanitary (*e.g.*, where an outside connection is made, contaminants from the environment must be eliminated).

- Be vandal-resistant.
- Avoid heating the water due to exterior temperatures and solar radiation.
- Avoid freezing the water.

## **SECTION 2 EVALUATION METHODOLOGY**

### **2.1 DECISION TREE**

The decision tree is a flow chart for conducting feasibility studies for a non-compliant PWS. The decision tree is shown in Figures 2.1 through 2.4. The tree guides the user through a series of phases in the design process. Figure 2.1 shows Tree 1, which outlines the process for defining the existing system parameters, followed by optimizing the existing treatment system operation. If optimizing the existing system does not correct the deficiency, the tree leads to six alternative preliminary branches for investigation. The groundwater branch leads through investigating existing wells to developing a new well field. The treatment alternatives address centralized and on-site treatment. The objective of this phase is to develop conceptual designs and cost estimates for the six types of alternatives. The work done for this report follows through Tree 1 and Tree 2, as well as a preliminary pass through Tree 4.

Tree 3, which begins at the conclusion of the work for this report, starts with a comparison of the conceptual designs, selecting the two or three alternatives that appear to be most promising, and eliminating those alternatives which are obviously infeasible. It is envisaged that a process similar to this would be used by the study PWS to refine the list of viable alternatives. The selected alternatives are then subjected to intensive investigation, and highlighted by an investigation into the socio-political aspects of implementation. Designs are further refined and compared, resulting in the selection of a preferred alternative. The steps for assessing the financial and economic aspects of the alternatives (one of the steps in Tree 3) are given in Tree 4 in Figure 2.4.

### **2.2 DATA SOURCES AND DATA COLLECTION**

#### **2.2.1 Data Search**

##### **2.2.1.1 Water Supply Systems**

The TCEQ maintains a set of files on public water systems, utilities, and districts at its headquarters in Austin, Texas. The files are organized under two identifiers: a PWS identification number and a Certificate of Convenience and Necessity (CCN) number. The PWS identification number is used to retrieve four types of files:

- CO – Correspondence,
- CA – Chemical analysis,
- MOR – Monthly operating reports (quality/quantity), and
- FMT – Financial, managerial and technical issues.

Figure 2.1  
TREE 1 – EXISTING FACILITY ANALYSIS






Figure 2.2  
TREE 2 – DEVELOP TREATMENT ALTERNATIVES





**Figure 2.4**  
**TREE 4 – FINANCIAL AND MANAGERIAL**





The CCN files generally contain a copy of the system's Certificate of Convenience and Necessity, along with maps and other technical data.

These files were reviewed for the PWS and surrounding systems.

The following websites were consulted to identify the water supply systems in the study area:

- Texas Commission on Environmental Quality  
[www.tnrc.state.tx.us/iwud/pws/index.cfm](http://www.tnrc.state.tx.us/iwud/pws/index.cfm). Under "Advanced Search", type in the name(s) of the County(ies) in the study area to get a listing of the public water supply systems.
- USEPA Safe Drinking Water Information System  
[www.epa.gov/safewater/data/getdata.html](http://www.epa.gov/safewater/data/getdata.html).

Groundwater control districts were identified on the TWDB web site, which has a series of maps covering various groundwater and surface water subjects. One of those maps shows groundwater control districts in the State of Texas.

#### **2.2.1.2 Existing Wells**

The TWDB maintains a groundwater database available at [www.twdb.state.tx.us](http://www.twdb.state.tx.us) that has two tables with helpful information. The "Well Data Table" provides a physical description of the well, owner, location in terms of latitude and longitude, current use, and for some wells, items such as flow rate, and nature of the surrounding formation. The "Water Quality Table" provides information on the aquifer and the various chemical concentrations in the water.

#### **2.2.1.3 Surface Water Sources**

Regional planning documents were consulted for lists of surface water sources.

#### **2.2.1.4 Groundwater Availability Model**

GAMs, developed by the TWDB, are planning tools and should be consulted as part of a search for new or supplementary water sources. The GAM for the northern part of the Gulf Coast aquifer was investigated as a potential tool for identifying available and suitable groundwater resources.

#### **2.2.1.5 Water Availability Model**

The WAM is a computer-based simulation predicting the amount of water that would be in a river or stream under a specified set of conditions. WAMs are used to determine whether water would be available for a newly requested water right or amendment. If water is available, these models estimate how often the applicant could count on water under various conditions (*e.g.*, whether water would be available only 1 month out of the

year, half the year, or all year, and whether that water would be available in a repeat of the drought of record).

WAMs provide information that assist TCEQ staff in determining whether to recommend the granting or denial of an application.

#### **2.2.1.6 Financial Data**

Financial data were collected through a site visit. Data sought included:

- Annual Budget
- Audited Financial Statements
  - Balance Sheet
  - Income & Expense Statement
  - Cash Flow Statement
  - Debt Schedule
- Water Rate Structure
- Water Use Data
  - Production
  - Billing
  - Customer Counts

#### **2.2.1.7 Demographic Data**

Basic demographic data were collected from the 2000 Census to establish incomes and eligibility for potential low cost funding for capital improvements. Median household income (MHI) and number of families below poverty level were the primary data points of significance. If available, MHI for the customers of the PWS should be used. In addition, unemployment data were collected from current U.S. Bureau of Labor Statistics. These data were collected for the following levels: national, state, and county.

### **2.2.2 PWS Interviews**

#### **2.2.2.1 PWS Capacity Assessment Process**

A capacity assessment is the industry standard term for an evaluation of a water system's financial, managerial, and technical capacity to effectively deliver safe drinking water to its customers now and in the future at a reasonable cost, and to achieve, maintain and plan for compliance with applicable regulations. The assessment process involves interviews with staff and management who have a responsibility in the operations and the management of the system.

Financial, managerial, and technical capacity are individual yet highly interrelated components of a system's capacity. A system cannot sustain capacity without maintaining adequate capability in all three components.

**Financial capacity** is a water system's ability to acquire and manage sufficient financial resources to allow the system to achieve and maintain compliance with the SDWA requirements. Financial capacity refers to the financial resources of the water system, including but not limited to revenue sufficiency, credit worthiness, and fiscal controls.

**Managerial capacity** is the ability of a water system to conduct its affairs so that the system is able to achieve and maintain compliance with SDWA regulations. Managerial capacity refers to the management structure of the water system, including but not limited to ownership accountability, staffing and organization, and effective relationships to customers and regulatory agencies.

**Technical capacity** is the physical and operational ability of a water system to achieve and maintain compliance with SDWA regulations. It refers to the physical infrastructure of the water system, including the adequacy of the source water, treatment, storage and distribution infrastructure. It also refers to the ability of system personnel to effectively operate and maintain the system and to otherwise implement essential technical knowledge.

Many aspects of water system operations involve more than one component of capacity. Infrastructure replacement or improvement, for example, requires financial resources, management planning and oversight, and technical knowledge. A deficiency in any one area could disrupt the entire effort. A system that is able to meet both its immediate and long-term challenges demonstrates that it has sufficient financial, managerial, and technical capacity.

Assessment of the FMT capacity of the PWS was based on an approach developed by the New Mexico Environmental Finance Center (NMEFC), which is consistent with the TCEQ FMT assessment process. This methodology was developed from work the NMEFC did while assisting USEPA Region 6 in developing and piloting groundwater comprehensive performance evaluations. The NMEFC developed a standard list of questions that could be asked of water system personnel. The list was then tailored slightly to have two sets of questions – one for managerial and financial personnel and one for operations personnel (the questions are included in Appendix A). Each person who has a role in the FMT capacity of the system is asked the applicable standard set of questions individually. The interviewees are not given the questions in advance and are not told the answers others have provided. Also, most of the questions are open ended type questions so they are not asked in a fashion to indicate what would be the “right” or “wrong” answer. The interviews last between 45 minutes to 75 minutes depending on the individual's role in the system and the length of the individual's answers.

In addition to the interview process, visual observations of the physical components of the system are made. A technical information form was created to capture this

information. This form is contained in Appendix A. This information was considered supplemental to the interviews because it could serve as a check on information provided in the interviews. For example, if an interviewee stated he or she had an excellent preventative maintenance schedule and the visit to the facility indicated a significant amount of deterioration (more than would be expected for the age of the facility) then the preventative maintenance program could be further investigated or the assessor could decide that the preventative maintenance program was inadequate.

Following interviews and the observations of the facility, answers that all personnel provided were compared and contrasted to provide a clearer picture of the true operations at the water system. The intent was to go beyond simply asking the question, “Do you have a budget?” to actually finding out if the budget was developed and being used appropriately. For example, if a water system manager is asked the question, “Do you have a budget?” he or she may say, “yes” and the capacity assessor is left with the impression that the system is doing well in this area. However, if several different people are asked about the budget in more detail, the assessor may find that although a budget is present, operations personnel do not have input into the budget, the budget is not used by the financial personnel, the budget is not updated regularly, or the budget is not used in setting or evaluating rates. With this approach, the inadequacy of the budget would be discovered and the capacity deficiency in this area would be noted.

Following the comparison of answers, the next step is to determine which items that were noted as a potential deficiency truly have a negative effect on the system’s operations. If a system has what appears to be a deficiency, but this deficiency is not creating a problem in terms of the operations or management of the system, it is not critical and may not need to be addressed as a high priority. As an example, the assessment may reveal that there appear to be insufficient staff members to operate the facility. However, it may also be revealed that the system is able to work around this problem by receiving assistance from a neighboring system so no severe problems result from the number of staff members. Although staffing may not be ideal, the system does not need to focus on this particular issue. The system needs to focus on items truly affecting operations. As an example of this type of deficiency, a system may lack a reserve account which can then lead the system to delay much-needed maintenance or repair on their storage tank. In this case, the system needs to address the reserve account issue so that proper maintenance can be completed.

The intent is to develop a list of capacity deficiencies with the greatest impact on the system’s overall capacity. These are the most critical items to address through follow-up technical assistance or by the system itself.

#### **2.2.2.2 Interview Process**

PWS personnel were interviewed by the project team, and each was interviewed separately. Interview forms were completed during each interview.

## **2.3 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

The initial objective for compliance alternative development is to identify a comprehensive range of possible options that can be evaluated to determine which are the most promising for implementation. Once the possible alternatives have been identified, they must be defined in sufficient detail so that a conceptual cost estimate (capital and O&M costs) can be developed. These conceptual cost estimates are used to compare the affordability of compliance alternatives, and to give a preliminary indication of rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. The basis for the unit costs used for the compliance alternative cost estimates is summarized in Appendix B. Other non-economic factors for the alternatives, such as reliability and ease of implementation, are also addressed. The compliance alternative conceptual cost estimates are provided in Appendix C. Cost analyses for shared solutions with other PWSs in the area are provided in Appendix G.

### **2.3.1 Existing PWS**

The neighboring PWSs were identified, and the extents of their systems were investigated. PWSs farther than 15 miles from the non-compliant PWS were not considered because the length of pipelines required would make the alternative cost prohibitive. The quality of water provided was also investigated. For neighboring PWSs with compliant water, options for water purchase and/or expansion of existing well fields were considered. The neighboring PWSs with non-compliant water were considered as possible partners in sharing the cost for obtaining compliant water either through treatment or developing an alternate source.

The neighboring PWSs were investigated to get an idea of the water sources they use and the quantity of water they might have available for sale. They were contacted to identify key locations in their systems where a connection might be made to obtain water, and to explore on a preliminary basis their willingness to partner or sell water. Then, the major system components that would be required to provide compliant water were identified. The major system components included treatment units, wells, storage tanks, pump stations, and pipelines.

Once the major components were identified, a preliminary design was developed to identify sizing requirements and routings. A capital cost estimate was then developed based on the preliminary design of the required system components. An annual O&M cost was also estimated to reflect the change in O&M expenditures that would be needed if the alternative was implemented.

Non-economic factors were also identified. Ease of implementation was considered, as well as the reliability for providing adequate quantities of compliant water. Additional factors were whether implementation of an alternative would require significant increase in the management or technical capability of the PWS, and whether the alternative had the potential for regionalization.

### **2.3.2 New Groundwater Source**

It was not possible in the scope of this study to determine conclusively whether new wells could be installed to provide compliant drinking water. In order to evaluate potential new groundwater source alternatives, three test cases were developed based on distance from the PWS intake point. The test cases were based on distances of 10 miles, 5 miles, and 1 mile. It was assumed that a pipeline would be required for all three of the test cases, and a storage tank and pump station would be required for the 10-mile and 5-mile alternatives. It was also assumed that new wells would be installed, and that their depths would be similar to the depths of the existing wells, or other existing drinking water wells in the area.

A preliminary design was developed to identify sizing requirements for the required system components. A capital cost estimate was then developed based on the preliminary design of the required system components. An annual O&M cost was also estimated to reflect the change (*i.e.*, from current expenditures) in O&M expenditures that would be needed if the alternative was implemented.

Non-economic factors were also identified. Ease of implementation was considered, as well as the reliability for providing adequate quantities of compliant water. Additional factors were whether implementation of an alternative would require significant increase in the management or technical capability of the PWS, and whether the alternative had the potential for regionalization.

### **2.3.3 New Surface Water Source**

New surface water sources were investigated. Availability of adequate quality water was investigated for the main rivers in the study area, as well as the major reservoirs. TCEQ WAMs were inspected, and the WAM was run, where appropriate.

### **2.3.4 Treatment**

Treatment technologies considered potentially applicable are adsorption and coagulation/filtration for arsenic removal since they are proven technologies with numerous successful installations that can be implemented with relatively low cost. Reverse osmosis and ion exchange were not deemed to be applicable in this study, since they are typically more expensive and more difficult to operate.

Adsorption treatment is considered for central treatment alternatives, as well as POU and POE alternatives. Coagulation/filtration treatment is considered for central treatment alternatives only. Adsorption treatment produces a spent media solid waste stream, and both adsorption and coagulation/filtration treatment produce a liquid backwash stream. The backwash volume from adsorption is much less than from coagulation/filtration. As a result, the treated volume of water is less than the volume of raw water that enters the treatment system. The treatment units were sized based on flow rates, and capital and annual O&M cost estimates were made based on the size of the treatment equipment

required. Neighboring non-compliant PWSs were identified to look for opportunities where the costs and benefits of central treatment could be shared between systems.

Non-economic factors were also identified. Ease of implementation was considered, as well as the reliability for providing adequate quantities of compliant water. Additional factors were whether implementation of an alternative would require significant increase in the management or technical capability of the PWS, and whether the alternative had the potential for regionalization.

## **2.4 COST OF SERVICE AND FUNDING ANALYSIS**

The primary purpose of the cost of service and funding analysis was to determine the financial impact of implementing compliance alternatives, primarily by examining the required rate increases, and analyzing the fraction of household income that water bills consume. The current financial situation was also reviewed to determine what rate increases were necessary for the PWS to achieve or maintain financial viability.

### **2.4.1 Financial Feasibility**

A key financial metric is comparison of the average annual household water bill for a PWS customer to the MHI for the area. MHI data from the 2000 Census were used at the most detailed level available for the community. Typically, county level data are used for small water utilities due to small population sizes. Annual water bills were determined for existing base conditions and included consideration of additional rate increases needed under current conditions. Annual water bills were also calculated after adding incremental capital and operating costs for each of the alternatives to determine feasibility under several potential funding sources.

Additionally, the use of standard ratios provided insight into the financial condition of any business. Three ratios are particularly significant for water utilities:

- Current Ratio = current assets divided by current liabilities provides insight into the ability to meet short-term payments. For a healthy utility, the value should be greater than 1.0.
- Debt to Net Worth Ratio = total debt divided by net worth shows to what degree assets of the company have been funded through borrowing. A lower ratio indicates a healthier condition.
- Operating Ratio = total operating revenues divided by total operating expenses show the degree to which revenues cover ongoing expenses. The value is greater than 1.0 if the utility is covering its expenses.

### **2.4.2 Median Household Income**

The 2000 Census was used as the basis for MHI. In addition to consideration of affordability, MHI may also be an important factor for sources of funds for capital programs needed to resolve water quality issues. Many grant and loan programs are

available to lower income rural areas, based on comparisons of local income to statewide incomes. In the 2000 Census, MHI for the State of Texas was \$39,927, compared to the U.S. level of \$41,994. For service areas with a sparse population base, county data may be the most reliable and, for many rural areas, correspond to census tract data.

### **2.4.3 Annual Average Water Bill**

The annual average household water bill was calculated for existing conditions and for future conditions incorporating the alternative solutions. Average residential consumption was estimated and applied to the existing rate structure to estimate the annual water bill. The estimates were generated from a long-term financial planning model that detailed annual revenue, expenditure and cash reserve requirements over a 30-year period.

### **2.4.4 Financial Plan Development**

The financial planning model used available data to establish base conditions under which the system operates. The model included, as available:

- Accounts and consumption data
- Water tariff structure
- Beginning available cash balance
- Sources of receipts:
  - Customer billings
  - Membership fees
  - Capital funding receipts from:
    - ❖ Grants
    - ❖ Proceeds from borrowing
- Operating expenditures:
  - Water purchases
  - Utilities
  - Administrative costs
  - Salaries
- Capital expenditures
- Debt service:
  - Existing principal and interest payments
  - Future principal and interest necessary to fund viable operations
- Net cash flow



- Restricted or desired cash balances:
  - Working capital reserves (based on 1-4 months of operating expenses)
  - Replacement reserves to provide funding for planned and unplanned repairs and replacements

From the model, changes in water rates were determined for existing conditions and for implementing the compliance alternatives.

## **2.4.5 Financial Plan Results**

Results from the financial planning were summarized in two ways: by percentage of household income and by total water rate increase necessary to implement the alternatives and maintain financial viability.

### **2.4.5.1 Funding Options**

Results, summarized in Table 4.8, show the following according to alternative and funding source:

- Percentage of the annual MHI that the average annual residential water bill represents.
- The first year in which a water rate increase would be required.
- The total increase in water rates required, compared to current rates.

Water rates resulting from the incremental capital costs of the alternative solutions were examined under a number of funding options. The first alternative examined was always funded from existing reserves plus future rate increases. Several funding options were analyzed to frame a range of possible outcomes.

- Grant funds for 100 percent of required capital. In this case, the PWS was only responsible for the associated O&M costs.
- Grant funds for 75 percent of required capital, with the balance treated as if revenue bond funded.
- Grant funds for 50 percent of required capital, with the balance treated as if revenue bond funded.
- State revolving fund loan at the most favorable available rates and terms applicable to the communities.
- If local MHI > 75 percent of state MHI, standard terms, currently at 3.8 percent interest for non-rated entities. Additionally:
  - If local MHI = 70-75 percent of state MHI, 1 percent interest rate on loan.
  - If local MHI = 60-70 percent of state MHI, 0 percent interest rate on loan.

- If local MHI = 50-60 percent of state MHI, 0 percent interest and 15 percent forgiveness of principal.
- If local MHI less than 50 percent of state MHI, 0 percent interest and 35 percent forgiveness of principal.
- Terms of revenue bonds assumed to be 25-year term at 6.0 percent interest rate.

#### **2.4.5.2 General Assumptions Embodied in Financial Plan Results**

The basis used to project future financial performance for the financial plan model included:

- No account growth (either positive or negative).
- No change in estimate of uncollectible revenues over time.
- Average consumption per account unchanged over time.
- No change in unaccounted for water as percentage of total (more efficient water use would lower total water requirements and costs).
- No inflation included in the analyses (although the model had provisions to add escalation of O&M costs, doing so would mix water rate impacts from inflation with the impacts from the alternatives being examined).
- Minimum working capital fund established for each district, based on specified months of O&M expenditures.
- O&M for alternatives begins 1 year after capital implementation.
- Balance of capital expenditures not funded from primary grant program is funded through debt (bond equivalent).
- Cash balance drives rate increases, unless provision chosen to override where current net cash flow is positive.

#### **2.4.5.3 Interpretation of Financial Plan Results**

Results of the financial plan model, as presented in Section 4 (Table 4.8), show the percentage of MHI represented by the annual water bill that resulted from any rate increases necessary to maintain financial viability over time. In some cases, this may require rate increases even without implementing a compliance alternative (the no action alternative). The table shows any increases such as these separately. The results table shows the total increase in rates necessary, including both the no action alternative increase and any increase required for the alternative. For example, if the no action alternative required a 10 percent increase in rates and the results table shows a rate increase of 25 percent, then the impact from the alternative was an increase in water rates of 15 percent. Likewise, the percentage of household income in the table reflects the total impact from all rate increases.

#### **2.4.5.4 Potential Funding Sources**

A number of potential funding sources exist for small public water systems. Both state and federal agencies offer grant and loan programs to assist rural communities in meeting their infrastructure needs.

Within Texas, the following state agencies offer financial assistance if needed:

- Texas Water Development Board,
- Office of Rural Community Affairs, and
- Texas Department of Health (Texas Small Towns Environment Program).

Small rural communities can also get assistance from the federal government. The primary agencies providing aid are:


- United States Department of Agriculture, Rural Utilities Service, and
- United States Housing and Urban Development.

## SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS

### 3.1 ARSENIC IN THE GULF COAST AQUIFER

The Gulf Coast aquifer parallels the Texas Gulf Coast and extends from the Texas-Louisiana border to the Rio Grande. Subunits of the Gulf Coast aquifer are, from oldest to youngest, the Jasper, Evangeline, and Chicot aquifers. The aquifer is a leaky artesian system composed of middle to upper Tertiary and younger interbedded and hydrologically connected layers of clay, silt, sand, and gravel (Ashworth and Hopkins 1992). The PWS wells of concern in Brazoria County are completed in the Chicot aquifer. Figure 3.1 shows detectable arsenic concentrations in the Gulf Coast aquifer from the TWDB database, and Figure 3.2 shows arsenic concentrations from the National Geochemical Database, also known as the National Uranium Resource Evaluation (NURE) database (<http://pubs.usgs.gov/of/1997/ofr-97-0492/index.html>).


**Figure 3.1 Detectable Arsenic Concentrations in Groundwater  
(TWDB Database)**



Source: (TWDB database, analyses from 1987 through 2004)

The most recent value is shown for each well (number of samples shown is 503).

**Figure 3.2 Detectable Arsenic Concentrations in Groundwater  
(NURE Database)**



Source: NURE database, analyses from 1976 through 1980

In the NURE database there is one sample per well (number of samples shown is 3,920).

### 3.2 GEOLOGY OF BRAZORIA COUNTY

Geologic units included in the Chicot aquifer are the Pleistocene formations, Willis, Lissie, and Beaumont (Doering 1935; Baker 1979). Since Pleistocene time, packages of fluvial sediments representing successively younger progradational cycles have been deposited along the Texas Gulf Coast (Blum 1992). The fluvial sediments, ranging in texture from gravel to clay, contain very little intergranular cement. The older parts of this depositional sequence are more coarse grained and dip 10 to 25 feet per mile (Willis Formation), whereas the younger units are more fine grained and dip only approximately 1 foot per mile (Beaumont Formation) (Doering 1935).

The Willis Formation was first described as a formal stratigraphic unit by Doering (1935). It is red sand with minor amounts of coarse sand and gravel that unconformably overlie Pliocene-age clay layers of the Fleming Formation in the vicinity of Brazoria County. In this area, the Willis Formation has a 30- to 40-foot thick gravel layer at the base that can provide an ample supply of usable quality water. The Lissie Formation is finer grained than the underlying Willis Formation; it contains interbedded layers of light-colored, fine-grained sand, clayey sand, and sandy clay (Doering 1935). Although

the Beaumont Formation as a whole is much more fine grained than directly underlying formations, it contains localized distributary channel deposits. The inclusive list of lithologies contained in the Beaumont Formation is clay, limey clay, sandy clay, clayey sand, and fine-grained sand (Doering 1935). Water wells completed in the Beaumont Formation section of the Chicot aquifer are usually no deeper than 75 to 100 feet and probably do not provide large quantities of water.

The lithology of geologic units within the Chicot aquifer is similar to that of the underlying Evangeline aquifer, which makes it difficult for drillers to determine in which aquifer they are completing water wells along the Texas Gulf Coast. The combined thickness of geologic units in the Chicot aquifer in the vicinity of Brazoria County varies among different researchers between 400 and 1,200 feet. According to Baker (1979), the maximum thickness of the entire Gulf Coast aquifer along the northern Gulf Coast is approximately 1,300 feet.

The 11 PWS wells of concern in Brazoria County are identified as being in the Chicot aquifer; completion depths are grouped around 300, 400, and 600 feet. It is possible the deeper wells are completed in the Evangeline aquifer or that screened intervals in these wells span both Chicot and Evangeline aquifers. A recognized geologic source of arsenic in groundwater is volcanic ash. Arsenic is often associated with other chemical elements such as fluoride, vanadium, molybdenum, selenium, and uranium. The association is generally seen at the subregional level, although not necessarily at the well level because of different geochemical behavior of individual elements. There are no reports of volcanic material in the geologic units that compose the Chicot aquifer. However, layers of bentonite (altered volcanic ash beds) and devitrified ash have been recognized in some parts of the Evangeline aquifer especially in South Texas. The major geologic unit of the Evangeline aquifer in South Texas is the Goliad Formation, but it is not present in outcrops north of the Colorado River (Hoel 1982). General hydrologic patterns with upward cross-formational flow along the coast support this hypothesis. However, other sources of arsenic are also possible. Arsenic hot spots exist in older formations (Catahoula and Goliad); some of those have eroded and are now part of the Chicot aquifer sediment. Additional potential sources include upwelling of highly mineralized water from salt domes. However, the spatial mismatch between salt dome distribution and areas with high arsenic concentration, as well as the lack of correlation between chloride and arsenic concentrations, precludes such an association, as discussed later.


Using uranium and radioactivity as proxies for arsenic sources, geophysical logs in Brazoria County near the PWS wells were analyzed to assess potential linkages between geologic units and elevated arsenic concentrations. Given the common association between uranium deposits and occurrences of arsenic, it was reasonable to inspect local oilfield geophysical logs for evidence of radioactive fluids in sandstone strata at depths sufficiently shallow to potentially contact fresh groundwater. A total of 40 hydrocarbon wells were identified with geophysical well logs that had (1) recorded geophysical responses within the upper 500 feet of the subsurface; and (2) latitude/longitude coordinates. Of these wells, 17 were selected on the basis of proximity to the

aforementioned PWS wells. Among these 17 hydrocarbon wells, only one provided the gamma ray and resistivity logs necessary for analysis. Wells range in depth between 295 and 625 feet and are completed in the Chicot aquifer. Only one well log for the area recorded sufficiently shallow data and also showed gamma ray and resistivity responses necessary to detect radioactively elevated pore fluids in the geologic section. The well is the Kilmarovo Jamison located at west longitude 95.3483° and north latitude 29.2586°. The nearest PWS wells are operated by the City of Danbury a few miles to the south of the logged well. Elevated gamma ray values greater than 150 American Petroleum Institute units occurred in sandstone beds with resistivities greater than 10 ohms at 1,520- to 1,550-foot depths in the Jamison well. An additional bed containing fluids with elevated radioactivity occurred at the depth of approximately 177 feet. Both of these stratigraphic intervals dip toward the south and are, therefore, at greater depths in more southerly locations. The City of Danbury PWS wells are completed at depths of 295 to 304 feet. Unless groundwater flow is upward between excessively radioactive strata contacted by the Jamison well and the Danbury PWS wells, it appears unlikely that radioactive fluids and associated ionic constituents, including possible arsenic, would contact the Chicot aquifer in the Danbury area.

### 3.3 GENERAL TRENDS IN ARSENIC CONCENTRATIONS


The geochemistry of arsenic is described in Appendix E. A general analysis of arsenic trends in the vicinity of Brazoria County was conducted to assess spatial trends, as well as correlations with other water quality parameters. Arsenic measurements from the TWDB database, the TCEQ database, and from a subset of the National Geochemical Database, also known as NURE (National Uranium Resource Evaluation) database, were used to assess arsenic trends. Figures 3.3 and 3.4 show spatial distribution of arsenic concentrations from TWDB (Figure 3.3) and NURE (Figure 3.4) databases.

**Figure 3.3 Spatial Distribution of Arsenic Concentrations (TWDB Database)**



Source: TWDB database

**Figure 3.4 Spatial Distribution of Arsenic Concentrations (NURE Database)**




Source: NURE database

The databases were queried in an area delineated by the following coordinates: bottom left, -97.45, 28.18; top right, -94.30, 30.64. Seven hundred thirty measurements were extracted from the TWDB database. Measurements representing the most recent arsenic measurement taken at a specific well, and wells not in the Gulf Coast aquifer were excluded. The NURE database contained 2,118 groundwater (sample type 03) arsenic measurements within the defined boundary. Because the wells have no aquifer identifier, no measurements were excluded.

Relationships between arsenic and well depth, pH,  $\text{SO}_4$ , fluoride, chloride, TDS, dissolved oxygen, phosphorus, iron, selenium, boron, vanadium, uranium, and molybdenum, were evaluated using data separately from the NURE and TWDB databases. Correlations between arsenic concentrations and most parameters were weak ( $r$  square values < 0.1); the highest correlation was found between arsenic and molybdenum. The relationship between the probability of arsenic > 10 micrograms per liter ( $\mu\text{g/L}$ ) and molybdenum concentration levels is shown for the NURE (Figure 3.5) and TWDB (Figure 3.6) databases.




**Figure 3.5 Relationship Between Arsenic and Molybdenum (NURE Database)**



Source: NURE database

**Figure 3.6 Relationship Between Arsenic and Molybdenum (TWDB Database)**




Source: TWDB database

N represents the number of measurements used from each database. Numbers on top of the graph columns show the number of arsenic measurements exceeding 10 µg/L and total number of measurements in each bin. For example, “7/76” in the bin of molybdenum > 20 means that seven of 76 arsenic measurements were greater than 10 µg/L.

Elevated arsenic concentrations and pH are also related (Figure 3.7). The absence of high arsenic concentrations (>10 µg/L) at pH less than 6.5 is notable.

**Figure 3.7 Relationship Between High Arsenic Concentrations and pH**




Correlations between arsenic, molybdenum, and pH suggest natural sources of elevated arsenic in Brazoria County; however, data are insufficient to make this conclusion definitively.

### 3.4 ARSENIC AND POINT SOURCES OF CONTAMINATION


Information regarding the location of potential source of contamination (PSOC) is collected as part of the TCEQ Source Water Assessment Program. Arsenic concentrations from TWDB (Figure 3.8) and NURE (Figure 3.9) databases were compared with PSOC coverage. A density map of PSOCs was generated (number of PSOCs per square kilometer), and PSOC density values were compared with arsenic concentrations from the NURE database.

**Figure 3.8 Potential Sources of Arsenic Contamination and Arsenic Concentrations (TWDB Database)**



Source: TWDB database

**Figure 3.9 Potential Sources of Arsenic Contamination and Arsenic Concentrations (NURE Database)**




Source: NURE database

No correlation was found between high arsenic concentrations and density of potential sources of contamination, strengthening the conclusion that sources of arsenic in this area are natural.

### 3.5 SALT DOMES

Elevated arsenic concentrations were not correlated with salt dome locations (Figure 3.10).

**Figure 3.10 Salt Dome Locations and Arsenic Concentrations**




Source: TWDB and NURE databases

### 3.6 CORRELATION WITH DEPTH

Arsenic concentrations were compared with well depth in an attempt to assess relationships between elevated arsenic concentrations and specific stratigraphic units (Figure 3.11). Data do not show a definite correlation between arsenic levels and well depth. Lack of geologic descriptions and geophysical logs makes it difficult to further evaluate relationships between arsenic concentrations and depth distributions of geologic units.

**Figure 3.11 Relationship Between Arsenic Concentrations and Well Depth**




The most recent sample was used for each well. N represents total number of wells in the analysis (719), and numbers above each column represent number of arsenic measurements > 10 µg/L and total number of analyses in the bin. For example, 5/181 represents five samples > 10 µg/L out of 181 analyses at a well depth between 0 and 200 feet.

### 3.7 DETAILED ASSESSMENT

There are eight wells with arsenic samples > 10 µg/L near the assessed PWS wells, seven from the TCEQ database, and one from the TWDB database (Figure 3.12). Samples from the TCEQ PWS database include only those that could be related to a specific well.

**Figure 3.12 Arsenic Concentrations in the Vicinity of PWS Wells**



Arsenic samples are from TWDB and TCEQ databases. The maximum arsenic concentration is shown for each well. PWS wells from the TCEQ database include two types of samples: raw (related to a single well), and entry point (taken from a single entry point related to a single well). Table 3.1 details well and screen depths of PWS wells with high arsenic concentrations ( $> 10 \mu\text{g/L}$ ).

**Table 3.1 Maximum and Minimum Arsenic Concentrations**

| Water Source | Max. – Min. – Number As samples (µg/L) | Well Depth (feet) | Screen Depth (feet) | Geology | Source |
|--------------|--|-------------------|---------------------|---------|--------|
| G0200494A    | 16.7 – 14.2 – 2                        | 419               | 399 – 419           | NA      | TCEQ   |
| G0200011B    | 11.3 – 6.0 – 2                         | 235               | 160 – 230           | NA      | TCEQ   |
| G0200036A    | 14.8 – 9.2 – 3                         | 324               | 307 – 323           | NA      | TCEQ   |
| G0200566A    | 10.3 – 9.4 – 4                         | 310               | NA                  | NA      | TCEQ   |
| G0200389A    | 11.7 – 8.3 – 2                         | 374               | NA                  | NA      | TCEQ   |
| G0200408A    | 10.6 – 10.6 – 1                        | 400               | NA                  | NA      | TCEQ   |
| G0200570A    | 55.2 – 8 – 3                           | 740               | 710 – 740           | NA      | TCEQ   |
| 6537904      | 16 – 16 – 1                            | 400               | NA                  | NA      | TWDB   |

Well depths range from 235 to 740 feet, and wells are screened between 160 and 740 feet. These large ranges in depth make it difficult to make a definitive statement regarding local correlation of arsenic with well or screen depth. Lack of geologic descriptions of these wells also prohibits a more comprehensive evaluation of relationships between arsenic concentrations and geology.

### 3.7.1 Grasslands (PWS 0200360)


Two wells are in the Grasslands water supply system, wells G0200360A and G0200360B. The depth of Well A, 426 feet, is screened between 406 and 426 feet. Well B has a depth of 425 feet and is screened between 395 and 425 feet. Both wells are related to the same entry point of the water supply which makes it difficult to separate the source of elevated arsenic concentrations shown in Table 3.2.

Groundwater arsenic concentrations can have a high degree of spatial variability. Because of this variability, an investigation of the existing wells should be conducted to determine whether both or only one produces non-compliant water. If one well is found to produce compliant water, as much production as possible should be shifted to the compliant well. Also, if one well is found to produce compliant water, the wells should be compared in terms of depths and well logs to identify differences that could be responsible for the elevated concentration of arsenic in the other well. Then if blending of water from the existing wells does not produce a sufficient quantity of compliant water, it may be possible to install a new well similar to the existing compliant well that would also provide compliant water.

**Table 3.2 Arsenic Concentrations in the Grasslands PWS**


| Date      | As (µg/L) | Source |
|-----------|-----------|--------|
| 5/16/2001 | 12.3      | TCEQ   |
| 9/15/2003 | 12.0      | TCEQ   |
| 2/17/2005 | 12.1      | TCEQ   |

**Figure 3.13 Arsenic Concentrations in 5- and 10-km Buffers of Grasslands PWS Wells (TWDB and NURE Databases)**



arsenic levels (16 µg/L), as did one well from the NURE database (19 µg/L). In addition to TWDB and NURE databases, samples from the TCEQ PWS database were analyzed (Figure 3.14).

**Figure 3.14 Arsenic Concentrations in 5- and 10-km Buffers of Grasslands PWS Wells (TCEQ Database)**



Two types of samples were used in the analysis: raw samples that can be related to a single well and entry-point samples taken from a single entry point, which can be related to a single well. Table 3.3 details arsenic concentrations, well depth, and screen depths of wells in 5- and 10-km buffers of the PWS wells.

**Table 3.3 Maximum and Minimum Arsenic Concentrations in the 5- and 10-km Buffers of Grasslands PWS**

| Water Source | Max. – Min. – No. As samples (µg/L) | Well Depth (feet) | Screen Depth (feet) |
|--------------|-------------------------------------|-------------------|---------------------|
| G0200360A    | 12.3 – 12.0 – 3                     | 426               | 406-426             |
| G0200360B    |                                     | 425               | 395-425             |
| G0200566A    | 10.3 – 9.4 – 4                      | 310               | NA                  |
| G0200036A    | 14.8 – 9.2 – 3                      | 324               | 307-323             |
| G0200527B    | 6.5 – 6.5 – 1                       | 159               | NA                  |
| G0200389A    | 11.7 – 8.3 – 2                      | 374               | NA                  |
| G0200410A    | 2.0 – 2 – 2                         | 210               | NA                  |

In addition to the assessed PWS wells (G0200360A and G0200360B), three wells (G0200566A, G0200036A, and G0200389A) have concentrations >10 µg/L, and one well (G0200527B) has concentrations >5 µg/L. Wells with higher concentrations have



depths between 310 and 426 feet. It is unclear whether arsenic is locally correlated with depth, and lack of geologic descriptions makes it difficult to correlate elevated arsenic concentrations to specific geologic units.

## **SECTION 4 ANALYSIS OF THE GRASSLANDS PWS**

### **4.1 DESCRIPTION OF EXISTING SYSTEM**

#### **4.1.1 Existing System**

The Grasslands PWS is shown on Figure 4.1. The system consists of two wells: G0200360A and G0200360B, also referred to as Well A and Well B, respectively. The wells are completed in the Chicot aquifer (Code 112CHCT). Well depths are 426 and 425 feet, respectively. The water system includes two submersible pumps (75 gpm at Well A and 65 gpm at Well B), one ground storage tank (44,000 gallons), two service pumps (150 gpm each), and one pressure tank (10,000 gallons). The system has a peak production capacity of 0.097 million gallons per day (mgd).


Arsenic has been detected in the Grasslands water supply at concentrations above the impending MCL of 0.01 mg/L, effective January 23, 2006. Although the current MCL for arsenic (0.05 mg/L) has not been exceeded at this system, all PWSs should take actions to reach the new regulatory health standard by the January 2006 date. Arsenic concentrations at Grasslands ranged between 0.012 and 0.0123 mg/L for samples collected between May 16, 2001 and February 17, 2005.

Groundwater from the wells is treated by gas chlorination and hypochlorination injections prior to flowing into the ground storage tank. The system was not designed to remove arsenic; therefore, system optimization will not result in a reduction of arsenic concentrations.

There is, however, a potential opportunity for system optimization to reduce arsenic concentrations. The system has two wells, and since arsenic concentrations can vary significantly between wells, arsenic concentrations should be determined for each well. If one of the wells happens to produce water with acceptable arsenic levels, as much production as possible should be shifted to that well. It may also be possible to identify arsenic-producing strata through comparison of well logs or through sampling of water produced by various strata within the well screen interval.


Basic system information is as follows:

- Population served: 450
- Connections: 150
- Average daily usage: 0.039 mgd
- Maximum daily usage: 0.090 mgd



**Figure 4.1**

## Grasslands Pipeline Alternatives



- Study Systems
- PWS's
- ▲ Cities
- 15 Mile Buffer
- City Limits
- Counties
- GL-1 Alvin
- GL-2 Angleton (BWA)
- GL-3 Bateman Water Works
- GL-4 Briar Meadows
- GL-5 Mammoet LLC
- GL-6 Oak Bend
- GL-7 Sienna Plantation
- GL-8 TDCJ Darrington
- GL-9 TDCJ Ramsey
- Major Roads

#### **4.1.2 Capacity Assessment for the Orbit Systems, Inc.**

Grasslands is owned and operated by Orbit Systems Inc. (Orbit). The following personnel associated with Orbit were interviewed:

- Peggy Paul, Environmental Engineer.
- Jeff Walker, Operations Supervisor.

All interviews were conducted in person.

##### **4.1.2.1 General Structure**

Orbit is an investor-owned utility. Management includes a President, an Operations Supervisor, and an Engineer who handle all of the management, engineering, and financial issues for the system. These individuals also establish policies and supervise the three water operators. There is also an office worker who handles paperwork, phone calls, and other related issues.

Orbit manages 33 small rural water systems. None of these systems are interconnected by pipeline. The population ranges from 170 for the smallest system to 450 for the largest system. The Orbit systems included in this study – Sandy Meadow, Rosharon Township, Rosharon Road Estates, Grasslands, and Mark V Estates – had approximately 56, 85, 76, 150, and 94 connections, respectively, and populations of 170, 255, 230, 450, and 285, respectively. All of the systems are groundwater systems and all are metered.

The managerial structure of all the water systems is the same, so only one capacity assessment was completed that covers all of the Orbit PWSs.

##### **4.1.2.2 General Assessment of Capacity**

Overall, the system had an adequate level of capacity. The system has some areas of needed improvement to be able to address its future compliance issues. However, the system has many positive aspects.

##### **4.1.2.3 Positive Aspects of Capacity**

In assessing a system's overall capacity, it is important to look at all aspects – positive and negative. It is important for systems to understand those characteristics that are working well so that those activities can be continued or strengthened. In addition, these positive aspects can assist the system in addressing the capacity deficiencies or concerns. As an example, this particular system has been able to manage 33 regional small water systems so that greater efficiencies are achieved through economy of scale. The factors particularly important for Orbit are listed below.

- Staff Longevity – The system is owned and the main managerial positions are staffed by one family. As such, the system has been able to maintain the same President, Engineer, and Operator/Operations Supervisor for

over 20 years. This longevity in staff creates a long-term memory of the system components and system characteristics. The staff is very dedicated to the system. Other than the general operators, the system has experienced little turnover.

- **Communication** – There is excellent communication among the staff. There is also good communication between the system and the customers. Communication occurs through Consumer Confidence Reports, personal visits with customers who have a complaint, and monthly billing statements.
- **In-House Expertise** – The system has an engineer on staff who is able to meet the systems engineering needs. Also, the system installs many of its own lines (less than 6-inches diameter). Part of the reason for doing so is to ensure that the lines are installed properly. In the past, the system has had problems with poorly constructed lines that were put in by private developers.
- **Planning for System Growth** – The systems are installed with consideration given to potential future connections. All future connections are installed initially and the lines are sized accordingly to ensure that build-out of the developments can be accommodated easily.
- **Regional Nature of the System** – Orbit operates 33 regional water systems. There is a single rate structure to cover all of the systems. This combined rate allows the overall system to create an economy of scale and an efficiency that helps all of the systems. As new rules are introduced that will require more complex treatment, the ability to take advantage of this regional approach will be critical. Orbit is willing to explore regionalization opportunities with neighboring systems who wish to work with them.
- The system maintains a good set of maps and uses them regularly. The maps are updated as the system is changed. Some private systems that were purchased did not have good mapping of the system components. Orbit is working on improving these maps over time.

#### **4.1.2.4 Capacity Deficiencies**

The following capacity deficiencies were noted in conducting the assessment.

- **Training** – The managerial staff does not regularly attend training. This lack of training may become a greater issue as new and more complex rules come into place. None of the staff, other than the President, are members of any water-related organization. Attendance at organization meetings could help keep the staff current on operational procedures and regulatory changes.
- **Safety** – The systems rely on gas chlorination. Gas chlorination has inherent dangers. The chlorination buildings do not have mechanical

ventilation, no alarm systems, and no self-contained breathing apparatus (SCBA). There are no written procedures for handling chlorine gas and a buddy system is not used.

- Budget – Orbit does not have an official budget. Also, there are no budgets for each of the individual systems to track what is needed by each system. There is no process of preparing and approving budgets.
- Capital Improvements Planning – There is no long-term capital improvements planning done for the overall system or the individual systems. Issues are addressed as they arise, rather than planned for in advance. Needs are considered but they are not written down or included in a plan.
- Emergency Planning – The system does not have a written emergency plan, nor does it have emergency equipment such as generators or SCBAs. The lack of a generator caused a problem when an electrical storm knocked out power for 3 days and the system was not able to deliver water.
- Audited Financial Report – There is no independently audited financial report. An annual financial statement is generated in house for the facilities. However, because there is no budget, there is nothing to evaluate the annual financial statements against.

#### **4.1.2.5 Potential Capacity Concerns**

The following items were concerns regarding capacity but there are no particular operational, managerial, or financial problems that can be attributed to these items. The system should focus on the deficiencies noted above in the capacity deficiency section. Addressing the items listed below will help in further improving technical, managerial, and financial capabilities.

- Source Water Protection – The system has not implemented any type of source water protection program.
- Written Operational Procedures – There are no written operational procedures for the staff. Currently, due to the family nature of the business and the longevity of the staff, no problems are created by a lack of these procedures. However, if there is a turn-over in staff, the lack of written procedures could be a major problem for the system. In addition, written procedures would help the general operators.
- Emergency Funding – Orbit should have a fund to cover emergencies. Currently, emergencies or other conditions that cause a short fall in funding are covered by private investment by the President. This practice has been able to sustain the system in the past, but it may not be a sustainable practice in the future. Orbit should consider some other means of covering these emergencies, such as reserve accounts.

## 4.2 ALTERNATIVE WATER SOURCE DEVELOPMENT

### 4.2.1 Identification of Alternative Existing Public Water Supply Sources

Table 4.1 is a list of the existing groundwater-supplied public water systems within approximately 15 miles of the Grasslands PWS. From this list of water systems, eight were selected for further evaluation based on factors such as water quality, distance from the Grasslands PWS, sufficient total production capacity for selling or sharing water, and willingness of the system to sell or share water or drill a new well. The wells selected for further evaluation are shown on Table 4.2.

**Table 4.1 Existing Public Water Systems within 15 miles of Grasslands**

| System Name                          | Dist. From Grasslands | Comments / Other Issues   |
|--------------------------------------|-----------------------|---|
| Oak Meadows Estates Subdivision      | 0.9                   | Small system with WQ issues: As, Fe   |
| Rosharon Township                    | 1.2                   | Small system with WQ issues: As, Mn   |
| Schlumberger Reservoir Comp          | 1.3                   | Large system (> 1 mgd) with WQ issues: As, Mn                                 |
| Mammoet USA, Inc.                    | 2.7                   | Small system with marginal Mn exceedances. <b>Evaluate further.</b>           |
| Sandy Meadow Estates Subdivision     | 3.0                   | Small system with WQ issues: As, Mn   |
| Rosharon Road Estates Subdivision    | 4.2                   | Small system with WQ issues: As, Mn   |
| TDCJ Darrington Unit                 | 4.4                   | Large system (> 1 mgd) without identified WQ issues. <b>Evaluate further.</b> |
| Briar Meadows                        | 5.3                   | Small system with marginal Fe exceedances. <b>Evaluate further.</b>           |
| TDCJ Ramsey Area                     | 6.4                   | Large system (> 1 mgd) with Fe exceedances. <b>Evaluate further.</b>          |
| Bateman Water Works                  | 7.3                   | Small system with Mn exceedances. <b>Evaluate further.</b>                    |
| Brazoria County Detention Center 2   | 7.6                   | Large system (> 1 mgd) with WQ issues: As, Fe (marginal)                      |
| JMP Utilities Inc.                   | 8.0                   | Small system with Mn exceedances.   |
| Riverside Estates                    | 8.2                   | Small system with Mn exceedances  |
| Bayou Shadows Water System           | 8.4                   | Small system with WQ issues: As, Mn   |
| Wolf Glen Water System               | 8.5                   | Small system with WQ issues: As (marginal), Fe, Mn                            |
| Oak Bend Estates                     | 8.7                   | Small system with Mn exceedances. <b>Evaluate further.</b>                    |
| Oak Manor MUD                        | 9.0                   | Small system with WQ issues: As, Mn   |
| Brandi Estates                       | 9.0                   | Small system with Mn exceedances  |
| Angelcrest Subdivision               | 9.2                   | Small system with Mn exceedances  |
| Beechwood Subdivision                | 9.3                   | Small system with Fe, Mn exceedances  |
| Alameda Water Well Service           | 9.5                   | Small system with Fe, Mn exceedances  |
| Southwood Estates Inc.               | 9.9                   | Small system with Fe, Mn exceedances  |
| Mark V Estates                       | 9.9                   | Small system with WQ issues: As   |
| Colony Cove Subdivision Water System | 9.9                   | Small system with Mn exceedances  |
| City of Manvel                       | 10.0                  | Small system with Mn exceedances  |
| City of Danbury                      | 10.3                  | Small system with WQ issues: As, Fe, Mn, nitrate                              |
| Lee Ridge Subdivision                | 10.5                  | Small system with Mn exceedances  |

| System Name                                 | Dist. From Grasslands | Comments / Other Issues   |
|---|-----------------------|---|
| City of Holiday Lake                        | 10.7                  | Small system with Fe, Mn (marginal) exceedances                               |
| Country Meadows                             | 10.7                  | Small system with Mn exceedances  |
| City of Liverpool                           | 10.8                  | Small system with WQ issues: As   |
| Sienna Plantation MUD 1                     | 10.9                  | Large system (> 1 mgd) with marginal Fe exceedances. <b>Evaluate further.</b> |
| Country Acres Estates                       | 10.9                  | Small system with Mn exceedances  |
| Weybridge Subdivision Water System          | 11.3                  | Small system with Mn exceedances  |
| Anchor Road Mobile Home Park                | 11.3                  | Small system with Fe, Mn exceedances  |
| Willow Wood Duplex                          | 11.5                  | Small system with Mn exceedances  |
| Televue Terrace Subdivision                 | 11.6                  | Small system with Fe, Mn exceedances  |
| City of Angleton/Brazosport Water Authority | 11.7                  | Large system (> 1 mgd) without identified WQ issues. <b>Evaluate further.</b> |
| Halliburton Services Fresno                 | 12.3                  | Small system with Fe (marginal), Mn exceedances                               |
| Fort Bend County MUD 23                     | 12.3                  | Large system (> 1 mgd) with Fe exceedances.                                   |
| Calico Farms Subdivision                    | 12.4                  | Small system with Mn exceedances  |
| Niagra Public Water Supply                  | 12.5                  | Small system with Fe, Mn exceedances  |
| Ashley Oaks Mobile Home Park                | 12.6                  | Small system with Mn exceedances  |
| City of Liverpool                           | 12.7                  | Small system with marginal Fe and Mn exceedances                              |
| Fresno Mobile Home Park                     | 12.8                  | Small system with Mn exceedances  |
| City of Alvin                               | 12.8                  | Large system (> 1 mgd) with marginal Mn exceedances. <b>Evaluate further.</b> |
| Sandy Ridge Subdivision                     | 13.0                  | Small system with Mn exceedances  |
| Pleasant Meadows Subdivision                | 13.1                  | Small system with Mn exceedances  |
| Turner Water Service                        | 13.2                  | Small system with Mn exceedances  |
| Meadowland Subdivision                      | 13.3                  | Small system with Mn exceedances  |
| Country Creek Estates Water Service         | 13.4                  | Small system with Mn exceedances  |
| Westwood Subdivision                        | 13.4                  | Small system with Mn exceedances  |
| Johnsons Water Service                      | 13.5                  | Small system with Mn exceedances  |
| Angle Acres Water System                    | 13.5                  | Small system with Fe, Mn exceedances  |
| Heights Country Subdivision                 | 13.6                  | Small system with Mn exceedances  |
| Windsong Subdivision                        | 13.7                  | Small system with Mn exceedances  |
| City of Hillcrest Village                   | 13.7                  | Small system with marginal Fe and Mn exceedances                              |
| Pine Colony Mobile Home Park                | 14.0                  | Small system with Mn exceedances  |
| Meadowview Subdivision                      | 14.0                  | Small system with Mn exceedances  |
| Moreland Subdivision Block 3&4              | 14.2                  | Small system with Mn exceedances  |
| Frontier Water Co.                          | 14.2                  | Small system with Fe, Mn exceedances  |
| Palmetto Subdivision                        | 14.2                  | Small system with Mn exceedances  |
| Village Trace Water System                  | 14.3                  | Small system with marginal Mn exceedances                                     |
| Coronado County                             | 14.3                  | Small system with Mn exceedances  |
| Mooreland Subdivision Water System          | 14.4                  | Small system with Mn exceedances  |
| Ryan Long Subdivision 2 Water System        | 14.4                  | Small system with Mn exceedances  |
| Moreland Subdivision Block 1&2              | 14.5                  | Small system with Fe exceedances  |
| West Lea Water System                       | 14.5                  | Small system with Mn exceedances  |



| System Name                     | Dist. From Grasslands | Comments / Other Issues                               |
|---------------------------------|-----------------------|---|
| Fort Bend County MUD 60         | 14.7                  | Large system (> 1 mgd) without identified WQ issues   |
| H L & P Parish Gas Plant        | 14.7                  | Large industrial system (> 1 mgd) with Fe exceedances |
| Quail Meadows Subdivision       | 14.7                  | Small system with Mn exceedances                      |
| Meadowlark Subdivision          | 14.8                  | Small system with Mn exceedances                      |
| Sharondale Subdivision          | 14.8                  | Small system with Mn exceedances                      |
| Blue Sage Gardens Subdivision   | 14.8                  | Small system with Mn exceedances                      |
| Manvel Road Terrace Subdivision | 14.9                  | Small system with Mn exceedances                      |

**Table 4.2 Existing Public Water Systems within 15 miles of Grasslands  
Selected for Further Evaluation**

| System Name                                       | Pop    | Conn  | Total Production (mgd) | Avg Daily Demand (mgd) | Approx. Dist. From Sandy Meadow Estates (mile) | Comments/ Other Issues   |
|---|--------|-------|------------------------|------------------------|--|--|
| City of Alvin                                     | 17,916 | 5,817 | 8.739                  | 1.307                  | 12.8   | Excess capacity and willing to sell water.   |
| City of Angleton/Brazosport Water Authority (BWA) | 19,167 | 6,389 | 5.112                  | 1.910                  | 11.7   | The City purchases supplemental treated water from BWA. BWA has excess capacity and is willing to sell water. There is an 18-inch BWA main to north of city. |
| Bateman Water Works                               | 72     | 24    | 0.086                  | na                     | 7.3  | No excess capacity. However, based on WQ data and proximity to Grasslands, this PWS may provide a suitable location for a new well. (WQ: Elevated Mn)        |
| Briar Meadows                                     | 111    | 37    | 0.101                  | 0.015                  | 5.3  | No excess capacity. However, based on WQ data and proximity to Grasslands, this PWS may provide a suitable location for a new well. (WQ: Marginal Fe)        |
| Mammoet USA, Inc.                                 | 25     | 2     | 0.029                  | na                     | 2.7  | No excess capacity. However, based on WQ data and proximity to Grasslands, this PWS may provide a suitable location for a new well. (WQ: Marginal Mn)        |
| Oak Bend Estates                                  | 114    | 38    | 0.055                  | 0.015                  | 8.7  | No excess capacity. However, based on WQ data and proximity to Grasslands, this PWS may provide a suitable location for a new well. (WQ: Elevated Mn)        |
| Sienna Plantation MUD 1                           | 7455   | 2485  | 5.4                    | 1.251                  | 10.9   | Adequate production with excess capacity. (WQ: Mn is marginal)   |
| TCDJ ID Darrington Unit                           | 2,037  | 1,250 | 1.886                  | 0.51                   | 4.4  | Adequate production with excess capacity.  |
| TCDJ Ramsey Area                                  | 6,000  | 2,000 | 1.919                  | 1.263                  | 6.4  | Adequate production with excess capacity. (WQ: Elevated Fe)  |

n/a (not applicable); na (not available); WQ (water quality); Fe (iron); Mn (manganese).

#### **4.2.1.1 City of Alvin**

The City of Alvin is located 12.8 miles northeast of Grasslands. The PWS is supplied by four groundwater wells, three of which are completed in the Lower Chicot aquifer (Code 112CHCTL) and one of which is completed in the Evangeline aquifer (Code 121EVGL). The four wells are between 688 and 711 feet deep, and have a total production of 8.739 mgd. Well water is treated with polyphosphate and hypochlorite before being discharged to several ground and elevated storage tanks. The City serves a population of 17,916 and has 5,817 metered connections. The reported average daily demand is 1.307 mgd.

The City of Alvin currently provides finished water to several small PWSs within its extra-territorial jurisdiction (ETJ) and is building lines out towards Manvel, which is located to the west along Highway 6. The City plans to build lines past Manvel and a new plant and storage tank in that region sometime in the next couple of years. Currently, the City has up to 4 mgd of excess capacity, and is willing to negotiate to sell water to other PWSs outside its ETJ.

The Gulf Coast Water Authority also plans to build a 150 mgd water treatment plant (WTP) to treat Brazos River water. Grasslands may be able to connect to this regional WTP distribution system within the City of Alvin. The new WTP may be built on 80 acres of land currently owned by the Fort Bend County Water Control & Improvement District (WC&ID) No. 2 (<http://www.fortbendcountycid2.com/WaterSource.htm>). This would be a regional WTP that may serve west Harris County, City of Sugar Land, City of Missouri City, City of Arcola, City of Pearland, City of Alvin, City of Manvel, City of Friendswood, and the area within the boundaries of Fort Bend County WC&ID No. 2, which includes the City of Stafford.

#### **4.2.1.2 City of Angleton/Brazosport Water Authority**

The City of Angleton is located 11.7 miles south of Grasslands. The PWS is supplied by six local groundwater wells, which are supplemented by treated surface water purchased from the Brazosport Water Authority (BWA). The BWA is a wholesale water provider that operates a WTP located in the City of Lake Jackson and supplies many communities in Brazoria County with treated water. Its primary water source is the Brazos River.

The City of Angleton's six wells draw water from the Chicot Aquifer (Code 112CHCT), are between 650 and 960 feet deep, and have a total production of 5.112 mgd. Well water is aerated and treated with polyphosphate and chlorine before being discharged to two storage tanks. The City uses the purchased water from BWA to mix with water from the wells. The City of Angleton serves a population of 19,200 and has approximately 6,400 metered connections. It is currently not in a position to sell water to third parties.

The BWA has up to 5 mgd of excess treated water capacity it is willing to sell, assuming that suitable arrangements can be negotiated. The BWA has an 18-inch supply line that terminates on the north side of the City of Angleton, near the corner of Vasquez and Henderson. The BWA requires that all its customers provide for a minimum of 8 hours storage capacity to sustain supply in the event of BWA's maintenance activities. Based on recent experience with Dow Chemical, the negotiation and approval process could take up to 2 years; however, it is expected the process would be less difficult for another PWS.

#### **4.2.1.3 Bateman Water Works**

Bateman Water Works is located 7.3 miles north of Grasslands. The water source is one 320-foot deep well that has a total production of 0.086 mgd. The system has 24 connections and serves approximately 75 people. The system has experienced some problems with the presence of manganese at levels in excess of the SMCL. Treatment consists of sequestration and hypochlorination.

There is not sufficient excess capacity at Bateman Water Works to supplement the Grasslands existing supply. Manganese is sometimes above the SMCL, which requires sequestering; however, based on the overall water quality data and the proximity to Grasslands, the location may be a suitable point for a new groundwater well.

#### **4.2.1.4 Briar Meadows**

Briar Meadows is located on FM 1462, 5.3 miles to the east-northeast of Grasslands. The PWS is owned by Orbit Systems, Inc., and is supplied by a single groundwater well. The well, completed in the Chicot aquifer, is 210 feet deep and rated for 0.086 mgd. The system has 5,000 gallons of storage capacity. Briar Meadows serves a population of 111 with 37 metered connections. The water delivery system has a total peak production of 0.101 mgd and water is hypochlorinated and treated with polyphosphate before distribution.

The estimated average and maximum daily demand is 0.015 mgd and 0.059 mgd, respectively. The well does not have enough capacity to meet the peak demand flow rate of Grasslands. However, based on Briar Meadows water quality data and its proximity to Grasslands, Briar Meadows may provide a suitable location for a new well.

#### **4.2.1.5 Mammoet USA, Inc.**

Mammoet USA, Inc. is located off of State Highway 288B in Bonney, Texas, approximately 2.7 miles south of Grasslands. The PWS is operated by Mammoet USA, Inc. and serves a population of 25 with two connections. The well is 270 feet deep with a rated capacity of 0.029 mgd. The water is used primarily for industrial and agricultural purposes. The water is hypochlorinated for disinfection before distribution. The system has one 310 gallon pressure tank. There is no information on the capacity of the booster pumps. Water consumption cannot be estimated because the water is used for industrial

and agricultural purposes. The quality of the water is good with an average arsenic concentration of 0.002 mg/L based on two sample results.

There is not sufficient excess capacity at Mammoet USA to supplement the Grasslands existing supply; however, based on the available water quality data, the location may be a suitable point for a new groundwater well.

#### **4.2.1.6 Oak Bend Estates**

Oak Bend Estates is located on County Road 864A off County Road 172, approximately 8.7 miles east of Grasslands. The PWS is operated by Southwest Utilities, Inc., in El Campo, Texas. Oak Bend Estates serves a population of 114 with 38 connections. The well is 145 feet deep with a rated capacity of 0.05 mgd. The system has a 21,000-gallon ground storage tank, two 125 gpm service pumps, and one 2,500-gallon pressure tank. The water delivery system has a total peak production of 0.055 mgd. The estimated average and maximum daily demand is 0.015 mgd and 0.06 mgd, respectively. Manganese is above the SMCL and the water is treated before distribution. The well has no excess capacity.

There is not sufficient excess capacity at Oak Bend Estates to supplement the Grasslands existing supply. However, based on overall water quality data, the location may be a suitable point for a new groundwater well.

#### **4.2.1.7 Sienna Plantation MUD 1**

Sienna Plantation Municipal Utility District (MUD) 1 is located just west of the town of Arcola, Texas, 10.9 miles to the north-northwest of Grasslands. Sienna Plantation MUD 1 serves a population of 7,455 with 2,485 metered connections. The MUD is supplied by four groundwater wells.

Average daily consumption for the system is 1.251 mgd, total production is 5.4 mgd, maximum purchased capacity is 4.932 mgd, and service pump capacity is 14.940 mgd. The total storage capacity of the system is 920,000 gallons and the pressure tank capacity is 50,000 gallons. Water quality is good with an average arsenic concentration of 0.0028 mg/L based on three sample results.

There is excess capacity at Sienna Plantation MUD 1 to supplement the Grasslands existing supply.

#### **4.2.1.8 TDCJ Darrington Unit**

The Texas Department of Criminal Justice (TDCJ) operates the Darrington Unit prison located 4.4 miles northwest of Grasslands. The TDCJ Darrington Unit serves a population of 2,037 with 1,250 connections. The PWS is supplied by three local groundwater wells, two of which are completed in the Lower Chicot aquifer and one of which is completed in the Evangeline aquifer. The wells G0200204A, G0200204B, and G0200204C were drilled to depths of 595 feet, 537 feet and 1,140 feet, respectively. The

tested flow rates of each well are 360, 350 and 600 gpm for a total system production capacity of 1.886 mgd. The treatment process consists of sequestration and chlorination. The average daily demand is 0.51 mgd which means that the TDCJ Darrington system is utilizing approximately 27 percent of the total system capacity.

This water supply system has excess capacity to supplement the Grasslands Water System. No water quality issues are reported for the TDCJ Darrington system in the TCEQ database.

#### **4.2.1.9 TDCJ Ramsey Area**

The TDCJ also operates the Ramsey Area prison located 6.4 miles to the southwest of Grasslands. The TDCJ Ramsey Area PWS serves a population of 6,000 with 2,000 metered connections. The PWS is supplied by five groundwater wells.

The average consumption for the system is 1.263 mgd, the maximum capacity is 2.203 mgd, and the service pump capacity is 5.4 mgd. The total storage capacity is 1,350,000 gallons with elevated storage of 200,000 gallons. The quality of the water is good with an average arsenic concentration of 0.002 mg/L based on four samples collected between March 1999 and November 2003. However, iron concentrations have exceeded the SMCL of 0.3 mg/L based on two samples collected between March 1999 and April 2002.

There is sufficient excess capacity at the TDCJ Ramsey Area PWS to supplement the Grasslands existing supply.

### **4.2.2 Potential for New Groundwater Sources**

#### **4.2.2.1 Installing New Compliant Wells**

Developing new wells or well fields is recommended, provided good quality groundwater available in sufficient quantity can be identified. Since a number of water systems in the area also have problems with arsenic, it should be possible to share in the cost and effort of identifying compliant groundwater and constructing well fields.

Since the PWS is already familiar with well operation, installation of a new well in the vicinity of the system intake point is likely to be an attractive option, provided compliant groundwater can be found. As a result, existing wells with good water quality should be investigated. Re-sampling and test pumping would be required to verify and determine the quality and quantity of water at those wells.

The use of existing wells should probably be limited to use as indicators of groundwater quality and availability. If a new groundwater source is to be developed, it is recommended that a new well or wells be installed instead of using existing wells. This will ensure the well characteristics are known and the well construction meets standards for drinking water wells.

Some of the alternatives suggest new wells be drilled in areas where existing wells are compliant with the new arsenic MCL of 0.01 mg/L. In developing the cost estimates, it is assumed that the aquifer in these areas would produce the required amount of water with only one well. Site investigations and geological research, which is beyond the scope of this study, may indicate that the aquifer at a particular site and depth may not provide the amount of water needed or more than one well would need to be drilled in separate areas.

#### **4.2.2.2 Results of Groundwater Availability Modeling**

Regional groundwater withdrawal in the area is extensive and is likely to steadily increase over the next decades. In Brazoria County, the Chicot aquifer constitutes the primary groundwater source for public supplies. This aquifer is the upper unit of the Gulf Coast aquifer system that extends along the entire Texas coastal region. Throughout the northern part of the Gulf Coast aquifer system, large groundwater withdrawals since the 1900s have resulted in declines in the aquifer's potentiometric surface from tens to hundreds of feet. The largest declines have occurred in the Harris-Galveston Coastal Subsidence District (HGCSA), around the Houston metropolitan area, where the area of influence encompasses most of Brazoria County, including the Grasslands system.

A groundwater availability model (GAM) for the northern part of the Gulf Coast aquifer was recently developed by the TWDB. Modeling was performed by the U.S. Geological Survey to simulate historical conditions (Kasmerek and Robinson, 2004), and to develop long-term groundwater projections (Kasmerek, Reece and Houston, 2005). Two projections were evaluated, a TWDB scenario based on 50-year regional projections by regional user groups, and a HGCSA scenario that incorporates 30-year projections by the HGCSA for the Houston Metropolitan area. Modeling of both projections anticipates extensive groundwater use and drop in aquifer levels, with far more critical groundwater availability conditions anticipated under the 30-year HGCSA scenario.

Under the HGCSA scenario, withdrawals from the Chicot aquifer and underlying Evangeline aquifer would increase by 2030 to an estimated 1,520 mgd, a 74 percent increase relative to 1995 conditions. Modeling of these projections indicate a significant increase in the aquifer's cone of depression by 2030, with depth increases of over 200 feet relative to current conditions (Kasmerek, Reece and Houston, 2005). The percent of withdrawals supplied by net aquifer recharges would also steadily decrease, from an estimated 72 percent in 1995 to 43 percent projected in 2030 (Kasmerek, Reece and Houston, 2005).

Under the TWDB scenario, long-term withdrawals from the Chicot aquifer and underlying Evangeline aquifer would moderately increase or remain level over the 50-year simulation period; the largest increase in withdrawal would occur between 2000 and 2010, with an 8 percent increase from 850 to 920 mgd (Kasmerek, Reece and Houston, 2005). Modeling of the TWDB scenario showed relatively little change in elevation of the Chicot aquifer's potentiometric surface. In Matagorda County, however, a drop of elevation from 50 to 100 feet would occur under 2010 withdrawal conditions.

The simulated net recharge of the aquifer, in contrast with the HGCSO scenario, would moderately increase under the TWDB scenario (Kasmerek, Reece and Houston, 2005).

The GAM of the northern part of the Gulf Coast aquifer was not run for the Grasslands system as groundwater availability would reflect regional HGCSO conditions. Water use by the system would represent a minor addition to the regional HGCSO groundwater withdrawal, making potential changes in aquifer levels well beyond the spatial resolution of the regional GAM model.

#### **4.2.3 Potential for New Surface Water Sources**

There is a low potential for development of new surface water sources for the Grasslands system as indicated by limited water availability within the site vicinity. The system is located within the San Jacinto-Brazos Basin where current surface water availability is expected to remain at current levels over the next 50 years according to the Texas Water Development Board's 2002 Water Plan (47,692 acre-feet per year during drought conditions). Approximately 7 miles west of the site, the San Jacinto-Brazos Basin transitions into the Brazos River Basin where water availability is expected to decrease up to 17 percent over the next 50 years.

The vicinity of the Grasslands system has a minimum availability of surface water for new uses. The TCEQ availability map for the San Jacinto-Brazos Basin and Brazos Basin indicates that, over a 20-mile radius of the site, unappropriated flows for new uses are typically available less than 75 percent of the time. This supply is inadequate as the TCEQ requires 100 percent supply availability for a municipal water supply.

#### **4.2.4 Options for Detailed Consideration**

The initial review of existing PWS sources results in the following options for more detailed consideration:

1. Purchase treated groundwater from the City of Alvin; install a storage tank, pump station, two transfer pumps, and pipeline (Alternative GL-1).
2. Purchase treated surface water from the BWA; install a storage tank, pump station, two transfer pumps, and pipeline to tie into the existing BWA main north of the City of Angleton (Alternative GL-2).
3. Drill a new well near Bateman Water Works; install a storage tank, pump station, two transfer pumps, and pipeline (GL-3).
4. Drill a new well near Briar Meadows; install a storage tank, pump station, two transfer pumps, and pipeline (Alternative GL-4).
5. Drill a new well near Mammoet USA; install a storage tank, pump station, two transfer pumps, and pipeline (Alternative GL-5).

6. Drill a new well near Oak Bend Estates; install a storage tank, pump station, two transfer pumps, and pipeline (Alternative GL-6).
7. Drill a new well near Sienna Plantation MUD 1; install a storage tank, pump station, two transfer pumps, and pipeline (GL-7).
8. Drill a new well near TDCJ Darrington Unit; install a storage tank, pump station, two transfer pumps, and pipeline (Alternative GL-8).
9. Drill a new well near TDCJ Ramsey Area; install a storage tank, pump station, two transfer pumps, and pipeline (Alternative GL-9).

In addition to the location-specific alternatives above, three hypothetical alternatives are considered in which new wells would be installed 10-, 5-, and 1-miles from the Grasslands PWS. Under each of these alternatives, it is assumed that a source of compliant water can be located and then a new well would be completed and a pipeline would be constructed to transfer the compliant water to Grasslands. These alternatives are GL-14, GL-15, and GL-16.

### **4.3 TREATMENT OPTIONS**

#### **4.3.1 Centralized Treatment Systems**

Centralized treatment of the water is identified as a potential option for the Grasslands system. Both iron-based adsorption and coagulation/filtration are potentially applicable technologies for arsenic removal from the groundwater. The central iron-based adsorption treatment alternative is Alternative GL-10, and the central coagulation/filtration alternative is Alternative GL-11.

#### **4.3.2 Point-of-Use Systems**

Point-of-use treatment using iron-based adsorption technology is valid for arsenic removal. The POU adsorption treatment alternative is GL-12.

#### **4.3.3 Point-of-Entry Systems**

Point-of-entry treatment using iron-based adsorption technology is valid for arsenic removal. The POE adsorption treatment alternative is GL-13.

### **4.4 BOTTLED WATER**

Providing bottled water is considered an interim measure to be used until a compliance alternative is implemented. Even though the community is small and people know each other, it would be reasonable to require quarterly communication advising customers of the need to take advantage of the bottled water program. An alternative to providing delivered bottled water is to provide a central, publicly accessible dispenser for



treated drinking water. Alternatives addressing bottled water are GL-17, GL-18, and GL-19.

## **4.5 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

A number of potential alternatives for compliance with the MCL for arsenic have been identified. Each of the potential alternatives is described in the following subsections. It should be noted that the cost information given is the capital cost and change in O&M costs associated with implementing the particular alternative. Appendix C contains cost estimates for the compliance alternatives. These compliance alternatives represent a range of possibilities, and a number of them are likely not feasible. However, all have been presented to provide a complete picture of the range of alternatives considered. It is anticipated that a PWS will be able to use the information contained herein to select the most attractive alternative(s) for more detailed evaluation and possible subsequent implementation. Cost analyses for shared solutions with other PWSs in the area are provided in Appendix G.

### **4.5.1 Alternative GL-1: Purchased Water from City of Alvin**

The GL-1 alternative consists of connecting directly to the City of Alvin PWS. The PWS is supplied by four local groundwater wells having a total capacity 8.739 mgd. The reported average daily demand is 1.307 mgd. The peak demand is estimated to be 5.228 mgd. Water is treated with polyphosphate and hypochlorite before being discharged to several ground and elevated storage tanks.

This alternative would require installation of two ground storage tanks, two pump stations with two transfer pumps at each station, and a pipeline to the Grasslands system. One of the two pumps in each pump station would be for backup in the event the other pump fails. The pipeline would be a maximum of 14.5 miles long, and would be a 4-inch polyvinyl chloride (PVC) line that discharges to the existing storage tank at Grasslands. It is possible that a closer connection point exists that would reduce the length of the transfer pipeline.

This alternative presents a regional solution, since other PWSs in the area also need compliant water. The City is already building lines to supply other small systems within its ETJ and is willing to negotiate to sell water to other PWSs outside its ETJ. Additionally, the regional surface water treatment plant proposed by the Gulf Coast Water Authority will replace some groundwater from wells in the Alvin area in the near future.

The estimated capital cost for this alternative includes construction of the pump stations and transfer pumps and a pipeline to the Grasslands system. The estimated O&M cost for this alternative includes the purchase price for treated water plus maintenance cost for the pipeline, and power and O&M labor and materials for the pump stations minus the cost Grasslands currently pays to operate its well field. The estimated capital cost for this alternative is \$3,751,000, and the estimated annual O&M cost is \$51,700.

The reliability of adequate amounts of compliant water under this alternative should be good. From the perspective of Orbit, this alternative is characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations are well understood, and Orbit currently operates pipelines and a pump station.

#### **4.5.2 Alternative GL-2: Purchased Water from Brazosport Water Authority**

The GL-2 alternative involves the purchase of treated surface water from the BWA. BWA currently has sufficient excess capacity for this alternative to be feasible and is willing to negotiate an agreement to supply water to PWSs in the area.

This alternative would require installing a ground storage tank and constructing a pipeline from the BWA 18-inch water main, located adjacent to State Highway 227 north of the City of Angleton, to the existing intake point at Grasslands. A pump station would also be required to overcome pipe friction and elevation differences between Angleton and Grasslands. The pipeline would be 11.4 miles long and constructed of 4-inch PVC pipe.

The pump station would be housed in a building and would include two pumps. One of the two pumps would be for backup. It is assumed the pumps and piping would be installed with capacity to meet all water demand for Grasslands, since the incremental cost would be relatively small and would provide operational flexibility.

The estimated capital cost for this alternative includes construction of a pump station with two transfer pumps and a pipeline to the Grasslands system. The estimated O&M cost for this alternative includes the purchase price for the treated water plus maintenance cost for the pipeline, and power and O&M labor and materials for the pump station minus the cost that Grasslands currently pays to operate its well field. The estimated capital cost for this alternative is \$2,769,500, and the estimated annual O&M cost is \$33,600.

The reliability of adequate amounts of compliant water under this alternative should be good. BWA provides treated surface water on a large scale, facilitating adequate O&M resources. From the perspective of Orbit, this alternative is characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations are well understood, and Orbit currently operates pipelines and a pump station.

The feasibility of this alternative is dependent on an agreement being reached with BWA to purchase treated drinking water.

#### **4.5.3 Alternative GL-3: New Well near Bateman Water Works**

The GL-3 alternative consists of drilling a new well near Bateman Water Works. Records indicate that water from the system is meeting the MCL for arsenic and the SMCL for iron, but exceeding the SMCL for manganese. Treatment includes sequestering for manganese.

This alternative would require drilling a new well and installing a ground storage tank, a pump station with two transfer pumps, and a pipeline to the Grasslands system. One of the two pumps in the pump station would be used for backup in the event the other pump fails. The pipeline would be a 4-inch PVC pipeline approximately 10.7 miles long.

This alternative presents a limited regional solution since other PWSs in the area also need compliant water. Some regionalization could be accomplished by sharing the cost of the pump station and pipeline with other non-compliant PWSs in the area.

The estimated capital cost for this alternative includes the costs for a new well and small ground storage tank, a pump station with two transfer pumps, and a pipeline to the Grasslands system. The estimated O&M cost for this alternative includes labor and material costs to operate the well field, to maintain the pipeline, and to operate the pump station. The estimated capital cost for this alternative is \$2,448,700 and the estimated annual O&M cost is \$17,400.

The reliability of adequate amounts of compliant water under this alternative should be good. From the perspective of Orbit, this alternative is characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations are well understood, and Orbit currently operates pipelines and a pump station.

The feasibility of this alternative is dependent on finding a suitable well site.

#### **4.5.4 Alternative GL-4: New Well near Briar Meadows**

The GL-4 alternative consists of drilling a new well in the Briar Meadows area to supplement the existing capacity at Grasslands. Records indicate that water from the Briar Meadows system is meeting the MCL for arsenic, and the SMCL for iron and manganese. It is expected that groundwater from a new well in the area will also be compliant with drinking water standards.

This alternative would require drilling a new well and installing a ground storage tank, a pump station with two transfer pumps, and a pipeline to the Grasslands system. One of the two pumps in the pump station would be for backup in the event the other pump fails. The pipeline would be constructed of 4-inch PVC pipe and would be 6.1 miles long and discharge to the existing storage tank at Grasslands.

The Grasslands and Briar Meadows water systems are owned and operated by Orbit. This alternative presents a good opportunity for a regional solution, since there are other PWSs in the area, including those owned and operated by Orbit, that need compliant water. Regionalization would allow the sharing of the cost of drilling the well(s) at the Briar Meadows well field.

The estimated capital cost for this alternative includes drilling a new well and installing a well pump, small ground storage tank, pump station with two transfer pumps, and a pipeline to the Grasslands system. The estimated O&M cost for this alternative

includes maintenance cost for the pipeline, and power and O&M labor and materials for the pump station minus the cost Grasslands currently pays to operate its well field. The estimated capital cost for this alternative is \$1,629,800, and the estimated annual O&M cost is \$13,400.

The reliability of adequate amounts of compliant water under this alternative should be good. From the perspective of Orbit, this alternative is characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations are well understood, and Orbit currently operates pipelines and a pump station. Additionally, both Grasslands PWS and Briar Meadows PWS are owned and operated by Orbit.

The feasibility of this alternative is dependent on finding a suitable well site.

#### **4.5.5 Alternative GL-5: New Well near Mammoet USA, Inc.**

The GL-5 alternative consists of drilling a new well near the Mammoet USA well in Bonney, Texas. Records indicate there is no detectable amount of arsenic in the Mammoet USA well water. Treatment may be required for manganese which is marginally high at times.

This alternative would require drilling a new well and installing a ground storage tank, a pump station with two transfer pumps, and a pipeline to the Grasslands system. One of the two pumps in the pump station would be used for backup in the event the other pump fails. The pipeline would be a 4-inch PVC pipeline 3.9 miles long.

This alternative presents a limited regional solution since other PWSs in the area also need compliant water. Some regionalization could be accomplished by sharing the cost of drilling the well with other non-compliant PWSs in the area.

The estimated capital cost for this alternative includes the costs for a new well and small ground storage tank, a pump station with two transfer pumps, and a pipeline to the Grasslands system. The estimated O&M cost for this alternative includes labor and material costs to operate the well field, to maintain the pipeline, and to operate the pump station. The estimated capital cost for this alternative is \$1,029,000 and the estimated annual O&M cost is \$11,200.

The reliability of adequate amounts of compliant water under this alternative should be good. From the perspective of Orbit, this alternative is characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations are well understood, and Orbit currently operates pipelines and a pump station.

The feasibility of this alternative is dependent on finding a suitable well site.

#### **4.5.6 Alternative GL-6: New Well near Oak Bend Estates**

Alternative GL-6 consists of drilling a new well in the Oak Bend Estates area. Records indicate that arsenic is not above the MCL in the Oak Bend Estates well water; however, manganese is above the SMCL.

This alternative would require drilling a new well and installing a ground storage tank, a pump station with two transfer pumps, and a pipeline to the Grasslands system. One of the two pumps in the pump station would be for backup in the event the other pump fails. The pipeline would be a 4-inch PVC line 11.3 miles long.

This alternative presents a limited regional solution, since other PWSs in the area also need compliant water. Some regionalization could be accomplished by sharing the cost of drilling the well with other non-compliant PWSs in the area.

The estimated capital cost for this alternative includes the cost to drill a new well and install a small ground storage tank, a pump station with two transfer pumps, and a pipeline to the Grasslands system. The estimated O&M cost for this alternative includes maintenance cost for the pipeline, and power and O&M labor and materials for the pump station minus the cost that the Grasslands currently pays to operate their well field. The estimated capital cost for this alternative is \$2,788,000 and the estimated annual O&M cost is \$17,400.

The reliability of adequate amounts of compliant water under this alternative should be good. From the perspective of Orbit, this alternative is characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations are well understood, and Orbit currently operates pipelines and a pump station.

The feasibility of this alternative is dependent on finding a suitable well site.

#### **4.5.7 Alternative GL-7: New Well near Sienna Plantation MUD 1**

This alternative consists of drilling a new well near Sienna Plantation MUD 1. Records indicate the average and maximum concentrations of arsenic in the Sienna Plantation well water are 0.0024 mg/L and 0.003 mg/L, respectively.

This alternative would require drilling a new well and installing two ground storage tanks, two pump stations with two transfer pumps at each station, and a pipeline to the Grasslands system. One of the pumps in each pump station would be for backup in the event the other pump fails. The pipeline would be 15.5 miles long and constructed of 4-inch PVC pipe.

This alternative presents a limited regional solution since other PWSs in the area also need compliant water. Some regionalization could be accomplished by sharing the cost of drilling the well with other non-compliant PWSs in the area.

The estimated capital cost for this alternative includes a new well and two small ground storage tanks, two pump stations with two transfer pumps each, and a pipeline to the Grasslands system. The estimated O&M cost for this alternative includes labor and material costs to operate the well field, to maintain the pipeline, and to operate the pump stations. The estimated capital cost for this alternative is \$3,692,300 and the estimated annual O&M cost for this alternative is \$36,500.

The reliability of adequate amounts of compliant water under this alternative should be good. From the perspective of Orbit, this alternative would be characterized as easy to operate and repair since Orbit currently operates pipelines and a pump station.

The feasibility of this alternative is dependent on finding a suitable well site.

#### **4.5.8 Alternative GL-8: New Well near TDCJ Darrington Unit**

The GL-8 alternative consists of drilling a new well near the TDCJ Darrington well field. Records indicate there is no detectable amount of arsenic in the TDCJ Darrington Unit well water.

This alternative would require drilling a new well and installing a well pump, small ground storage tank, a pump station with two transfer pumps, and a pipeline to the Grasslands system. One of the two pumps in the pump station would be for backup in the event the other pump fails. The pipeline would be a 4-inch PVC line 5.6 miles long.

This alternative presents a limited regional solution since other PWSs in the area also need compliant water. Some regionalization could be accomplished by sharing the cost of drilling the well with other non-compliant PWSs in the area.

The estimated capital cost for this alternative includes the costs for a new well and small ground storage tank, a pump station with two transfer pumps, and a pipeline to the Grasslands system. The estimated O&M cost for this alternative includes labor and material costs to operate the well field, to maintain the pipeline, and to operate the pump station. The estimated capital cost for this alternative is \$1,331,000 and the estimated annual O&M cost is \$13,600.

Reliability of supply of adequate amounts of compliant water under this alternative should be good. From the perspective of Orbit Systems, this alternative would be characterized as easy to operate and repair since Orbit Systems currently operates pipelines and a pump station.

The reliability of adequate amounts of compliant water under this alternative should be good. From the perspective of Orbit, this alternative is characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations is well understood, and Orbit currently operates pipelines and a pump station.

The feasibility of this alternative is dependent on finding a suitable well site.

#### **4.5.9 Alternative GL-9: New Well near TDCJ Ramsey Area**

The GL-9 alternative consists of drilling a new well near the TDCJ Ramsey Area well field. Records indicate there is no detectable amount of arsenic in the TDCJ Ramsey Area well water. However, iron exceeds the SMCL of 0.3 mg/L.

This alternative would require drilling a new well and installing a well pump, small ground storage tank, a pump station with two transfer pumps, and a pipeline to the Grasslands system. One of the two pumps would be for backup in the event the other pump fails. The pipeline would be a 4-inch PVC line approximately 10 miles long.

This alternative presents a limited regional solution since other PWSs in the area also need compliant water. Some regionalization could be accomplished by sharing the cost of drilling the well with other non-compliant PWSs in the area.

The estimated capital cost for this alternative includes the costs for a new well and small ground storage tank, a pump station with two transfer pumps, and a pipeline to the Grasslands system. The estimated O&M cost for this alternative includes labor and material costs to operate the well field, to maintain the pipeline, and to operate the pump station. The estimated capital cost for this alternative is \$2,468,800 and the estimated annual O&M cost is \$16,700.

The reliability of adequate amounts of compliant water under this alternative should be good. From the perspective of Orbit, this alternative is characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations is well understood, and Orbit currently operates pipelines and a pump station.

The feasibility of this alternative is dependent on finding a suitable well site.

#### **4.5.10 Alternative GL-10: Central Iron-Based Adsorption Treatment**

Orbit would treat groundwater from both Wells A and B using an iron-based adsorption system prior to distribution. This alternative consists of constructing the adsorption treatment plant at or near one of the two wells. The plant comprises a 400 square feet (ft<sup>2</sup>) building with a paved driveway, the pre-constructed adsorption system on a skid (*e.g.*, two Model APU-300 package units from Severn Trent), and a 5,000-gallon backwash wastewater equalization tank. The entire facility would be fenced. The water would be pre-chlorinated to oxidize As(III) to As(V) and post-chlorinated for disinfection prior to flowing to the distribution system. Backwash would be required monthly with raw well water supplied directly by the well pump. The backwash wastewater would be equalized in the 5,000-gallon tank and discharged to the sewer at a controlled rate. The adsorption media are expected to last approximately 2 years before replacement and disposal.

The estimated capital cost for this alternative is \$391,400, and the estimated annual O&M cost is \$40,900, which includes the annualized media replacement cost of \$14,000.

The reliability of adequate amounts of compliant water under this alternative is good as the adsorption technology has been demonstrated effective in full-scale and pilot-scale facilities. The technology is simple and requires minimal O&M effort.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other water supply entities.

#### **4.5.11 Alternative GL-11: Central Coagulation/Filtration Treatment**

Orbit would treat groundwater from both Wells A and B using a coagulation/filtration system prior to distribution. This alternative consists of constructing the coagulation/filtration plant at or near one of the two wells. The plant comprises a 400 ft<sup>2</sup> building with a paved driveway, the pre-constructed coagulation/filtration system on a skid (*e.g.*, three Macrolite filters from Kinetico), a ferric chloride feed and storage system, and a 5,000-gallon backwash wastewater equalization tank. The entire facility would be fenced. The water would be pre-chlorinated to oxidize As(III) to As(V) and post-chlorinated for disinfection prior to flowing to the distribution system. Ferric chloride solution would be fed to the well water after pre-chlorination and before entering the filters. The filters would be backwashed once every 1 to 2 days by well water directly from the well pump. The backwash wastewater would be equalized in the 5,000-gal tank and discharged to the sewer at a controlled rate. The Macrolite media does not need replacement.

The estimated capital cost for this alternative is \$313,300, and the estimated annual O&M cost is \$60,400. This alternative requires more O&M labor cost and sewer disposal charges than the adsorption alternative.

The reliability of adequate amounts of compliant water under this alternative is good as the coagulation/filtration is a well-established technology. The technology is simple but requires significant effort for chemical handling and backwash monitoring.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other water supply entities.

#### **4.5.12 Alternative GL-12: Point-of-Use Treatment**

This alternative consists of the continued operation of the wells at Grasslands, plus treatment of water to be used for drinking or food preparation at the POU to remove arsenic. The purchase, installation, and maintenance of POU treatment systems to be installed “under the sink” would be necessary for this alternative. The POU treatment system most applicable is the adsorption process using iron-based IX media. Blending is not an option in this case.

This alternative would require installation of the POU treatment units in houses and other buildings that provide water for drinking or cooking. Orbit would be responsible for purchase and maintenance of the treatment units, including media replacement, periodic sampling, and necessary repairs. In houses, the most convenient point for



installation of the treatment units is typically under the kitchen sink, with a separate tap installed for dispensing treated water. Installation of the treatment units in kitchens would require entry into the homes of customers by Orbit personnel or contract personnel. As a result, the cooperation of customers would be important for success in implementation of this alternative. The treatment units could be installed without house entry, but that would complicate the installation and increase costs.

POU arsenic treatment processes typically produce spent media that require disposal and possibly a small backwash waste stream. The backwash waste stream results in a slight increase in the overall volume of water used. POU systems have the advantage that only a minimum volume of water is treated (only that for human consumption). This minimizes the size of the treatment units, the increase in water required, and the waste for disposal. For this alternative, it is assumed that the increase in water consumption would be insignificant in terms of supply cost, and that the backwash waste stream can be discharged to the house septic or sewer system.

This alternative does not present options for a regional solution.

The estimated capital cost for this alternative includes purchasing and installing the POU treatment systems. The estimated O&M cost for this alternative includes the purchase and replacement of filters and media, as well as periodic sampling and record keeping. The estimated capital cost for this alternative is \$99,000, and the estimated annual O&M cost is \$93,800. For the cost estimate, it is assumed that one POU treatment unit would be required for each of the 150 existing connections to the Grasslands system. It should be noted that the POU treatment units would need to be more complex than units typically found in commercial retail outlets in order to meet regulatory requirements, making purchase and installation more expensive.

The reliability of adequate amounts of compliant water under this alternative is fair, since it relies on active cooperation of the customers for system installation, use, and maintenance, and only provides compliant water to a single tap within a house. Additionally, the O&M efforts required for the POU systems would be significant, and Orbit personnel are inexperienced in this type of work. From the perspective of Orbit, this alternative would be characterized as more difficult to operate due to the in-home requirements and the large number of individual units.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other PWS entities.

#### **4.5.13 Alternative GL-13: Point-of-Entry Treatment**

This alternative consists of the continued operation of the Grasslands well field, plus treatment of water to remove arsenic as it enters the residence. The purchase, installation, and maintenance of the treatment systems at the POE would be necessary for this alternative. Blending is not an option in this case.

This alternative would require installation of the POE treatment units at houses and other buildings that provide water for drinking or cooking. Orbit would be responsible for purchase and maintenance of the treatment units, including media and filter replacement, periodic sampling, and necessary repairs. It may also be desirable to modify piping so that water for non-consumptive uses can be withdrawn upstream of the treatment unit. The POE treatment units would be installed outside the residence, so entry would not be necessary for O&M. Some cooperation from customers would be necessary for installation and maintenance of the treatment systems.

POE arsenic treatment processes typically produce spent adsorption media as waste, and possibly backwash water that requires disposal. The backwash water stream results in a slight increase in the overall volume of water used. POE systems treat a greater volume of water than POU systems. For this alternative, it is assumed that the increase in water consumption would be insignificant in terms of supply cost, and that the backwash waste stream can be discharged to the house septic or sewer system.

This alternative does not present options for a regional solution.

The estimated capital cost for this alternative includes purchasing and installing the POE treatment systems. The estimated O&M cost for this alternative includes the purchase and replacement of filters and media, as well as periodic sampling and record keeping. The estimated capital cost for this alternative is \$1,732,500, and the estimated annual O&M cost is \$210,000. For the cost estimate, it is assumed that one POE treatment unit would be required for each of the 150 existing connections to the Grasslands system.

The reliability of adequate amounts of compliant water under this alternative is fair, but better than POU systems since it relies less on the active cooperation of customers for system installation, use, and maintenance, and compliant water is supplied to all taps within a house. Additionally, the O&M efforts required for the POE systems would be significant, and Orbit personnel are inexperienced in this type of work. From the perspective of Orbit, this alternative would be characterized as more difficult to operate due to the on-property requirements and the large number of individual units.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other PWS entities.

#### **4.5.14 Alternative GL-14: New Well at 10 Miles**

This alternative consists of installing one new well within 10 miles of the Grasslands which would produce compliant water in place of the water produced by the current well field. At this level of study, it is not possible to positively identify an existing well or the location where a new well could be installed. In order to address a range of solutions, three different well alternatives are developed, assuming the new well is located within 10 miles, 5 miles, and 1 mile from the existing intake point.

This alternative would require construction of one new 310-foot well, a new pump station with storage tank near the new well, and a pipeline from the new well/tank to the existing intake point for the Grasslands system. The pump station and storage tank would be necessary to overcome pipe friction and changes in land elevation. For this alternative, the pipeline is assumed to be approximately 10 miles long, and would be a 4-inch PVC line that discharges to the existing Grasslands storage tank. The pump station would include two pumps, including one standby, and would be housed in a building.

Depending on well location and capacity, this alternative could present some options for a more regional solution. It may be possible to share water and costs with another nearby system.

The estimated capital cost for this alternative includes installing the well, and constructing the pipeline and pump station. The estimated O&M cost for this alternative includes O&M for the pipeline and pump station, plus an amount for plugging and abandoning (in accordance with TCEQ requirements) the existing wells. The estimated capital cost for this alternative is \$2,437,800, and the estimated annual O&M cost is \$16,700.

The reliability of adequate amounts of compliant water under this alternative should be good, since water wells, pump stations and pipelines are commonly employed. From the perspective of Orbit, this alternative would be similar to operating the existing system. Orbit personnel are experienced with O&M of wells, pipelines, and pump stations.

The feasibility of this alternative is dependent on the ability to find an adequate existing well or success in installing a well that produces an adequate supply of compliant water. It is possible that an alternate groundwater source may not be found on Grasslands or Orbit-controlled land, so landowner cooperation would be required.

#### **4.5.15 Alternative GL-15: New Well at 5 Miles**

This alternative consists of installing one new well within 5 miles of Grasslands that would produce compliant water in place of the water produced by the current well field. At this level of study, it is not possible to positively identify an existing well or the location where a new well could be installed.

This alternative would require construction of one new 310-foot well, a new pump station with storage tank near the new well, and a pipeline from the new well/tank to the existing intake point for the Grasslands system. The pump station and storage tank would be necessary to overcome pipe friction and changes in land elevation. For this alternative, the pipeline is assumed to be approximately 5 miles long, and would be a 4-inch PVC line that discharges to the existing Grasslands storage tank. The pump station would include two pumps, including one standby, and would be housed in a building.

Depending on well location and capacity, this alternative could present some options for a more regional solution. It may be possible to share water and costs with another nearby PWS system.

The estimated capital cost for this alternative includes installing the well and constructing the pipeline and pump station. The estimated O&M cost for this alternative includes the cost for O&M for the pipeline and pump station, plus an amount for plugging and abandoning (in accordance with TCEQ requirements) the existing wells. The estimated capital cost for this alternative is \$1,308,000, and the estimated annual O&M cost is \$12,400.

The reliability of adequate amounts of compliant water under this alternative should be good, since water wells, pump stations, and pipelines are commonly employed. From the perspective of Orbit, this alternative would be similar to operating the existing system. Orbit personnel have experience with O&M of wells, pipelines, and pump stations.

The feasibility of this alternative is dependent on the ability to find an adequate existing well or success in installing a well that produces an adequate supply of compliant water. It is possible that an alternate groundwater source may not be found on Grasslands or Orbit-controlled land, so landowner cooperation would be required.

#### **4.5.16 Alternative GL-16: New Well at 1 Mile**

This alternative consists of installing one new well within 1 mile of Grasslands that would produce compliant water in place of the water produced by the current well field. At this level of study, it is not possible to positively identify an existing well or the location where a new well could be installed.

This alternative would require construction of one new 310-foot well and a pipeline from the new well to the existing intake point for the Grasslands system. . For this alternative, the pipeline is assumed to be approximately 1 mile long, and would be a 4-inch PVC line that discharges to the existing Grasslands storage tank.

Depending on well location and capacity, this alternative could present some options for a more regional solution. It may be possible to share water and costs with another nearby system.

The estimated capital cost for this alternative includes installing the well, and constructing the pipeline. The estimated O&M cost for this alternative includes O&M for the pipeline, plus an amount for plugging and abandoning (in accordance with TCEQ requirements) the existing wells. The estimated capital cost for this alternative is \$282,000, and the estimated annual O&M cost is \$6,400 less than current costs.

The reliability of adequate amounts of compliant water under this alternative should be good. From the perspective of Orbit, this alternative would be similar to operating the

existing system. Orbit personnel have experience with O&M of wells, pipelines, and pump stations.

The feasibility of this alternative is dependent on the ability to find an adequate existing well or success in installing a well that produces an adequate supply of compliant water. It is possible that an alternate groundwater source may not be found on Grasslands or Orbit-controlled land, so landowner cooperation would be required.

#### **4.5.17 Alternative GL-17: Public Dispenser for Treated Drinking Water**

This alternative consists of the continued operation of the Grasslands well field, plus dispensing treated water for drinking and cooking at a publicly accessible location. Implementing this alternative would require purchasing and installing a treatment unit where customers would be able to come to fill their own containers. This alternative also includes notifying customers of the importance of obtaining drinking water from the dispenser. In this way, only a relatively small volume of water requires treatment, but customers would be required to pick up and deliver their own water. Blending is not an option in this case. It should be noted that this alternative would be considered an interim measure until a compliance alternative is implemented.

Orbit would be responsible for maintenance of the treatment unit, including media replacement, periodic sampling, and necessary repairs. The spent media would require disposal. This alternative relies on a great deal of cooperation and action from customers in order to be effective.

This alternative does not present options for a regional solution.

The estimated capital cost for this alternative includes purchasing and installing the treatment system to be used for the drinking water dispenser. The estimated O&M cost for this alternative includes purchase and replacement of filters and media, as well as periodic sampling and record keeping. The estimated capital cost for this alternative is \$11,600, and the estimated annual O&M cost is \$16,700.

The reliability of adequate amounts of compliant water under this alternative is fair, because of the large amount of effort required from customers and the associated inconvenience. Orbit has not provided this type of service in the past. From the perspective of Orbit, this alternative would be characterized as relatively easy to operate, since these types of treatment units are highly automated, and there is only one unit.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other water supply entities.

#### **4.5.18 Alternative GL-18: 100 Percent Bottled Water Delivery**

This alternative consists of the continued operation of the Grasslands well field, but compliant drinking water would be delivered to customers in containers. This alternative involves setting up and operating a bottled water delivery program to serve all customers

in the system. It is expected that Orbit would find it convenient and economical to contract a bottled water service. The bottle delivery program would have to be flexible enough to allow for delivery of smaller containers should customers be incapable of lifting and manipulating 5-gallon bottles. Blending is not an option in this case. It should be noted that this alternative would be considered an interim measure until a compliance alternative is implemented.

This alternative does not involve capital cost for construction, but would require some initial costs for system setup, and then ongoing costs to have the bottled water furnished. It is assumed for this alternative that bottled water is provided to 100 percent of the Grasslands customers.

This alternative does not present options for a regional solution.

The estimated initial capital cost is for setting up the program. The estimated O&M cost for this alternative includes program administration and purchase of the bottled water. The estimated capital cost for this alternative is \$23,900, and the estimated annual O&M cost is \$286,500. For the cost estimate, it is assumed that each person requires 1 gallon of bottled water per day.

The reliability of adequate amounts of compliant water under this alternative is fair, since it relies on the active cooperation of customers to order and utilize the water. Management and administration of the bottled water delivery program would require attention from Orbit.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other PWS entities.

#### **4.5.19 Alternative GL-19: Public Dispenser for Trucked Drinking Water**

This alternative consists of continued operation of the Grasslands well field, plus dispensing compliant water for drinking and cooking at a publicly accessible location. The compliant water would be purchased from a nearby supplier, and delivered by truck to a tank at a central location where customers would be able to fill their own containers. This alternative also includes notifying customers of the importance of obtaining drinking water from the dispenser. In this way, only a relatively small volume of water requires trucking, but customers are required to pick up and deliver their own water. Blending is not an option in this case. It should be noted that this alternative would be considered an interim measure until a compliance alternative is implemented.

Orbit would purchase a truck suitable for hauling potable water and install a storage tank. It is assumed the storage tank would be filled once a week, and that the chlorine residual would be tested for each truckload. The truck would have to meet requirements for potable water, and each load would be treated with chlorine. This alternative relies on cooperation and action from customers for it to be effective.

This alternative presents limited options for a regional solution if two or more systems share the purchase and operation of the water truck.

The estimated capital cost for this alternative includes purchase of a water truck and construction of the storage tank to be used for the drinking water dispenser. The estimated O&M cost for this alternative includes O&M for the truck, maintenance for the tank, water quality testing, record keeping, and water purchase. The estimated capital cost for this alternative is \$103,000, and the estimated annual O&M cost is \$16,400.

The reliability of adequate amounts of compliant water under this alternative is fair because of the large amount of effort required from customers and the associated inconvenience. Orbit has not provided this type of service in the past. From the perspective of Orbit, this alternative would be characterized as relatively easy to operate, but the hauling and storage of water would need to be practiced with care to ensure sanitary conditions.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other PWS entities.

#### **4.5.20 Summary of Alternatives**

Table 4.3 provides a summary of the key features of each alternative for Grasslands.

**Table 4.3 Summary of Compliance Alternatives for Grasslands**

| Alt No. | Alternative Description                          | Major Components  | Capital Cost <sup>1</sup> | Annual O&M Cost | Total Annualized Cost <sup>2</sup> | Reliability | System Impact | Remarks  |
|---------|--|---|---------------------------|-----------------|------------------------------------|-------------|---------------|--|
| GL-1    | Purchased treated groundwater from City of Alvin | - Ground storage tanks<br>- Pump stations with two transfer pumps each<br>- 14.5-mile pipeline                        | \$3,751,000               | \$51,700        | \$378,700                          | Good        | N             | Alternative assumes City of Alvin will sell water.                                     |
| GL-2    | Purchase treated surface water from BWA          | - Ground storage tank<br>- Pump station with two transfer pumps<br>- 11.4-mile pipeline                               | \$2,769,500               | \$33,600        | \$275,000                          | Good        | N             | BWA expects to sell all excess capacity within the next 5 years.                       |
| GL-3    | Drill new well at Bateman Water Works            | - New well (310 ft)<br>- Ground storage tank<br>- Pump station with two transfer pumps<br>- 10.7 mile pipeline        | \$2,448,700               | \$17,400        | \$230,900                          | Good        | N             | Alternative assumes land and adequate quantity of compliant groundwater are available. |
| GL-4    | Drill new well near Briar Meadows                | - New well (215 ft)<br>- Ground storage tank<br>- Pump station with two transfer pumps<br>- 6.1-mile pipeline         | \$1,629,800               | \$13,400        | \$155,500                          | Good        | N             | Alternative assumes land and adequate quantity of compliant groundwater are available. |
| GL-5    | Drill new well near Mammoet USA, Inc.            | - New well (270 ft)<br>- Ground storage tank<br>- Pump station with two transfer pumps<br>- 3.9-mile pipeline         | \$1,029,000               | \$11,200        | \$100,900                          | Good        | N             | Alternative assumes land and adequate quantity of compliant groundwater are available. |
| GL-6    | Drill new well near Oak Bend Estates             | - New well (150 ft)<br>- Ground storage tank<br>- Pump station with two transfer pumps<br>- 11.3-mile pipeline        | \$2,788,000               | \$17,400        | \$260,500                          | Good        | N             | Alternative assumes land and adequate quantity of compliant groundwater are available. |
| GL-7    | Drill new well near Sienna Plantation MUD 1      | - New well (950 ft)<br>- Ground storage tanks<br>- Pump stations with two transfer pumps each<br>- 15.5-mile pipeline | \$3,629,300               | \$36,500        | \$353,000                          | Good        | N             | Alternative assumes land and adequate quantity of compliant groundwater are available. |
| GL-8    | Drill new well near TDCJ Darrington Unit         | - New well (600 ft)<br>- Ground storage tank<br>- Pump station with two transfer pumps<br>- 5.6-mile pipeline         | \$1,331,000               | \$13,600        | \$129,600                          | Good        | N             | Alternative assumes land and adequate quantity of compliant groundwater are available. |
| GL-9    | Drill new well near TDCJ Ramsey Area             | - New well (270 ft)<br>- Ground storage tank<br>- Pump station with two transfer pumps<br>- 10.0-mile pipeline        | \$2,468,800               | \$16,700        | \$231,900                          | Good        | N             | Alternative assumes land and adequate quantity of compliant groundwater are available. |



| Alt No. | Alternative Description  | Major Components  | Capital Cost <sup>1</sup> | Annual O&M Cost | Total Annualized Cost <sup>2</sup> | Reliability            | System Impact | Remarks   |
|---------|--|---|---------------------------|-----------------|------------------------------------|------------------------|---------------|---|
| GL-10   | Continued use of existing wells with central iron-based adsorption treatment     | One central iron-based adsorption treatment unit.   | \$391,400                 | \$40,900        | \$75,100                           | Good                   | T             | There are nearby systems that could possibly share in treatment plant cost.   |
| GL-11   | Continued use of existing wells with central coagulation / filtration treatment  | One central coagulation/filtration treatment unit   | \$313,300                 | \$60,400        | \$87,700                           | Good                   | T             | There are nearby systems that could possibly share in treatment plant cost.   |
| GL-12   | Continued use of existing wells with POU treatment                               | Small adsorption treatment unit for each customer   | \$99,000                  | \$93,800        | \$102,400                          | Fair                   | T, M          | Alternative assumes cooperation from all customers for entry into houses and businesses for installation and maintenance of treatment systems. Does not provide compliant water to all taps.                          |
| GL-13   | Continued use of existing wells with POE treatment                               | Small adsorption treatment unit for each customer   | \$1,732,500               | \$210,000       | \$361,000                          | Good                   | T, M          | Alternative assumes cooperation from all customers for installation and maintenance of treatment systems. Provides compliant water to all taps.   |
| GL-14   | Install new compliant well within 10 miles                                       | - New well<br>- Ground storage tank<br>- Pump station with two transfer pumps<br>- 10-mile pipeline | \$2,437,800               | \$16,700        | \$229,200                          | Good                   | N             | Alternative assumes land and adequate quantity of compliant groundwater are available.  |
| GL-15   | Install new compliant well within 5 miles  | - New well<br>- Ground storage tank<br>- Pump station with two transfer pumps<br>- 5-mile pipeline  | \$1,308,000               | \$12,400        | \$126,400                          | Good                   | N             | Alternative assumes land and adequate quantity of compliant groundwater are available.  |
| GL-16   | Install new compliant well within 1 mile   | - New well<br>- 1-mile pipeline   | \$282,000                 | \$(6,400)       | \$18,200                           | Good                   | N             | Alternative assumes land and adequate quantity of compliant groundwater are available.  |
| GL-17   | Continued use of existing wells with public dispenser for treated drinking water | Install medium size iron-based adsorption treatment system, storage tank, and public dispenser      | \$11,600                  | \$16,700        | \$17,700                           | Fair / interim measure | T             | INTERIM SOLUTION: Does not provide compliant water to home or building taps; requires considerable effort by customers.   |
| GL-18   | Continued use of existing wells with bottled water delivery for all customers    | Set up bottled water delivery system  | \$23,900                  | \$286,500       | \$288,600                          | Fair / interim measure | M             | INTERIM SOLUTION: Does not provide compliant water to home or building taps; requires considerable effort by customers to order and use delivered water. Management and administration of program may be significant. |

| o.    | Alternative Description  | Major Components  | Capital Cost <sup>1</sup> | Annual O&M Cost | Total Annualized Cost <sup>2</sup> | Reliability            | System Impact | Remarks   |
|-------|--|---|---------------------------|-----------------|------------------------------------|------------------------|---------------|---|
| GL-19 | Continued use of existing wells with public dispenser for trucked drinking water | Install storage tank and public dispenser. Buy delivery truck | \$103,000                 | \$16,400        | \$25,300                           | Fair / interim measure | M             | INTERIM SOLUTION: Does not provide compliant water to building taps; requires considerable effort by customers. |

Notes:

- N* – No significant increase required in technical or management capability
- T* – Implementation of alternative will require increase in technical capability
- M* – Implementation of alternative will require increase in management capability
- 1* – See cost breakdown in Appendix C
- 2* – 20-year return period and 6 percent interest

## 4.6 COST OF SERVICE AND FUNDING ANALYSIS

To evaluate the financial impact of implementing compliance alternatives, a 30-year financial planning model was developed. This model can be found in Appendix D. The financial model is based on estimated cash flows, with and without implementation of the compliance alternatives. Data for such models are typically derived from established budgets, audited financial reports, published water tariffs, and consumption data. Orbit manages 33 small rural PWSs and three wastewater treatment plants. The only financial data available were a consolidated Profit and Loss Statement and a Water and Wastewater Utilities Annual Report for 2004. The Water Utility Tariff and water usage records for all 33 Orbit PWSs were also available.

This analysis will need to be performed in a more detailed fashion and applied to alternatives that are deemed attractive and worthy of more detailed evaluation. A more detailed analysis should include additional factors such as:

- Cost escalation,
- Price elasticity effects where increased rates may result in lower water consumption,
- Costs for other system upgrades and rehabilitation needed to maintain compliant operation.

### 4.6.1 Financial Plan Development

#### 4.6.1.1 Grasslands Financial Data

Since Orbit does not keep separate financial records for each of the 33 PWSs it manages, revenues and expenses had to be estimated for Grasslands. Annual revenue was estimated using a base rate of \$21 per month per connection plus actual usage at a rate of \$1.90 per 1,000 gallons assuming a water loss of 11.4 percent. These values were plugged into the financial model resulting in 2004 revenue of \$67,595 (operating revenue plus required reserve) for Grasslands compared to \$7,780,508 total 2004 revenue for Orbit as summarized in Table 4.4.

**Table 4.4 Summary of Orbit Systems 2004 Water Revenues**

| PWS Name               | 2004 Water Usage<br>(gallons) | No. Connections | 2004 Water<br>Revenue |
|------------------------|-------------------------------|-----------------|-----------------------|
| Rosharon Township      | 8,055,400                     | 85              | \$40,038              |
| Rosharon Roads Estates | 5,455,900                     | 76              | \$29,870              |
| Sandy Meadow Estates   | 3,735,400                     | 56              | \$24,456              |
| Mark V Estates         | 7,178,900                     | 94              | \$37,858              |
| Grasslands             | 12,465,400                    | 150             | \$67,595              |
| Other Systems - Water  | 88,671,400                    | 1,236           | \$503,096             |
| Other Systems - Sewer  | 125,562,400                   | ---             | \$77,595              |
| Total                  |                               | 1,697           | \$780,508             |

Annual expenses for Grasslands were estimated based on its percentage water usage of 10.3 percent as shown by Appendix F. This resulted in 2004 expenses of \$79,317 (including depreciation) compared to \$770,256 total expenses for Orbit as summarized in Table 4.5.

**Table 4.5 Summary of Orbit Systems 2004 Expenses**

| PWS Name               | 2004 Water Usage<br>(gallons) | % Water Usage | 2004 Water<br>Expenses |
|------------------------|-------------------------------|---------------|------------------------|
| Rosharon Township      | 8,055,400                     | 6.4           | \$48,917               |
| Rosharon Roads Estates | 5,455,900                     | 4.3           | \$32,866               |
| Sandy Meadow Estates   | 3,735,400                     | 3.0           | \$22,930               |
| Mark V Estates         | 7,178,900                     | 5.7           | \$43,566               |
| Grasslands             | 12,465,400                    | 10.3          | \$79,317               |
| Other Systems          | 88,671,400                    | 70.3          | \$542,660              |
| <b>Total</b>           | <b>125,562,400</b>            | <b>100.0</b>  | <b>\$770,256</b>       |

#### 4.6.1.2 Current Financial Condition

##### 4.6.1.2.1 Cash Flow Needs

Table 4.6 shows the 2004 revenues and expenses for Grasslands compared to other Orbit PWSs included in this study. The shortfall for Grasslands of \$11,722 is based on current operations without any capital expenditures to address the arsenic problem. This means that Orbit is not currently charging its Grasslands customers enough for water usage to sustain this portion of the operation.

**Table 4.6 Summary of Orbit Systems 2004 Operations**

| PWS Name               | 2004 Water Expenses | 2004 Water Revenue | Over / (Under) |
|------------------------|---------------------|--------------------|----------------|
| Rosharon Township      | \$ 48,917           | \$ 40,038          | (\$ 8,879)     |
| Rosharon Roads Estates | \$ 32,866           | \$ 29,870          | (\$ 2,996)     |
| Sandy Meadow Estates   | \$ 22,930           | \$ 24,456          | \$ 1,526       |
| Mark V Estates         | \$ 43,566           | \$ 37,858          | (\$ 5,708)     |
| Grasslands             | \$ 79,317           | \$ 67,595          | (\$11,722)     |

Analysis of the long-term financial plan indicates that Grasslands will need to increase rates over the next few years to maintain financial viability even without considering any possible solution for the arsenic problem. The average annual bill for Grasslands customers must be increased by 17.3 percent just to meet operating expenses for this system based on the assumptions used in this analysis.

Table 4.7 shows how an 8.8 percent increase would impact the average annual bill for Grasslands customers as a percent of the MHI for Brazoria County compared to other Orbit PWSs included in this study. The average annual bill in Grasslands would increase from \$375 to \$408 based on the no action alternative.

**Table 4.7 Summary of Orbit Systems Required Revenue Increases**

| <b>PWS Name</b>        | <b>Current Average Annual Bill</b> | <b>Current % MHI</b> | <b>% Increase Needed</b> | <b>New Average Annual Bill</b> | <b>New % MHI</b> |
|------------------------|------------------------------------|----------------------|--------------------------|--------------------------------|------------------|
| Rosharon Township      | \$ 252                             | 0.52 %               | 71.4 %                   | \$ 432                         | 0.89 %           |
| Rosharon Roads Estates | \$ 373                             | 0.77 %               | 1.3 %                    | \$ 378                         | 0.81 %           |
| Sandy Meadow Estates   | \$ 344                             | 0.86 %               | None                     | \$ 295                         | 0.74 %           |
| Mark V Estates         | \$ 381                             | 0.78 %               | 6.3 %                    | \$ 405                         | 0.90 %           |
| Grasslands             | \$ 375                             | 0.77 %               | 8.8 %                    | \$ 408                         | 0.87 %           |

#### **4.6.1.2.2 Ratio Analysis**

There is not enough financial information available for Orbit or Grasslands to calculate the Current Ratio or the Debt to Net Worth Ratio. However, an Operating Ratio of 0.85 was calculated from available financial information. An Operating Ratio of 1.0 means that a utility is collecting just enough money to meet expenses; thus, an Operating Ratio of 0.85 is just another indication that Orbit must raise its water rates for its Grasslands customers in the future.

#### **4.6.1.3 Financial Plan Results**

Each compliance alternative for Grasslands was evaluated using the financial model to determine the overall increase in water rates that would be necessary to pay for improvements. Each alternative was examined under the various funding options described in Section 2.4.

The financial model results for all alternatives are summarized in Table 4.8 and Figure 4.2. Figure 4.3 shows the current average annual bill for Grasslands of \$375 and the average annual bill of \$408 needed to fully fund existing operations. There are two bars shown for each of the alternatives. The lowest bar is based on 100 percent grant funding of capital improvements for the compliance alternative. Thus, the higher average annual water bill reflects only higher O&M costs associated with the compliance alternative. The highest bar is based on entirely funding capital requirements with either loans or bonds, which represents the highest cost scenario. Therefore, the higher average annual water bill in this case reflects both higher O&M costs and the principal and interests costs to service debt associated with the compliance alternative. Figure 4.2 also shows the annual residential water bill as a percent of MHI for Brazoria County.

**Table 4.8 Financial Impact on Households for Grasslands Alternatives**


|      |                            | Funding Source #                             | 0           | 1          | 2         | 3         | 4        | 5         |
|------|----------------------------|--|-------------|------------|-----------|-----------|----------|-----------|
| #    | ALTERNATIVES               |  | All Revenue | 100% Grant | 75% Grant | 50% Grant | SRF      | Loan/Bond |
| GL-1 | Alvin                      | Average Annual Water Bill                    | \$ 21,782   | \$ 1,060   | \$ 1,865  | \$ 2,670  | \$ 3,891 | \$ 4,280  |
|      |                            | Maximum % of HH Income                       | 48%         | 2%         | 4%        | 6%        | 9%       | 10%       |
|      |                            | Percentage Rate Increase Compared to Current | 6110%       | 204%       | 437%      | 671%      | 1025%    | 1138%     |
|      |                            | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-2 | Brazosport Water Authority | Average Annual Water Bill                    | \$ 16,205   | \$ 869     | \$ 1,463  | \$ 2,057  | \$ 2,959 | \$ 3,246  |
|      |                            | Maximum % of HH Income                       | 36%         | 2%         | 3%        | 5%        | 7%       | 7%        |
|      |                            | Percentage Rate Increase Compared to Current | 4519%       | 146%       | 319%      | 491%      | 753%     | 836%      |
|      |                            | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-3 | Bateman Water Works        | Average Annual Water Bill                    | \$14,328    | \$ 698     | \$ 1,223  | \$ 1,749  | \$ 2,546 | \$ 2799   |
|      |                            | Maximum % of HH Income                       | 31%         | 1%         | 3%        | 4%        | 6%       | 6%        |
|      |                            | Percentage Rate Increase Compared to Current | 3982%       | 95%        | 247%      | 400%      | 631%     | 705%      |
|      |                            | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-4 | Briar Meadows              | Average Annual Water Bill                    | \$ 9,735    | \$ 655     | \$ 1,005  | \$ 1,355  | \$ 1,885 | \$ 2,054  |
|      |                            | Maximum % of HH Income                       | 21%         | 1%         | 2%        | 3%        | 4%       | 5%        |
|      |                            | Percentage Rate Increase Compared to Current | 2672%       | 82%        | 183%      | 285%      | 439%     | 488%      |
|      |                            | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-5 | Mammoet USA, Inc.          | Average Annual Water Bill                    | \$ 6,369    | \$ 632     | \$ 853    | \$ 1,073  | \$ 1,408 | \$ 1,15   |
|      |                            | Maximum % of HH Income                       | 14%         | 1%         | 2%        | 2%        | 3%       | 3%        |
|      |                            | Percentage Rate Increase Compared to Current | 1711%       | 75%        | 139%      | 203%      | 300%     | 331%      |
|      |                            | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-6 | Oak Bend                   | Average Annual Water Bill                    | \$ 16,222   | \$ 698     | \$ 1,296  | \$ 1,894  | \$ 2,802 | \$ 3,091  |
|      |                            | Maximum % of HH Income                       | 36%         | 1%         | 3%        | 4%        | 6%       | 7%        |
|      |                            | Percentage Rate Increase Compared to Current | 4522%       | 95%        | 268%      | 442%      | 705%     | 789%      |
|      |                            | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-7 | Sienna Plantation          | Average Annual Water Bill                    | \$ 21,021   | \$ 900     | \$ 1,679  | \$ 2,458  | \$ 3,639 | \$ 4,015  |
|      |                            | Maximum % of HH Income                       | 46%         | 2%         | 4%        | 5%        | 8%       | 9%        |
|      |                            | Percentage Rate Increase Compared to Current | 5893%       | 156%       | 382%      | 608%      | 951%     | 1060%     |
|      |                            | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |

|       |                     | Funding Source #                             | 0           | 1          | 2         | 3         | 4        | 5         |
|-------|---------------------|--|-------------|------------|-----------|-----------|----------|-----------|
| #     | ALTERNATIVES        |  | All Revenue | 100% Grant | 75% Grant | 50% Grant | SRF      | Loan/Bond |
| GL-8  | TDCJ Darrington     | Average Annual Water Bill                    | \$ 8,067    | \$ 657     | \$ 943    | \$ 1,228  | \$ 1,661 | \$ 1,799  |
|       |                     | Maximum % of HH Income                       | 18%         | 1%         | 2%        | 3%        | 4%       | 4%        |
|       |                     | Percentage Rate Increase Compared to Current | 2196%       | 82%        | 165%      | 248%      | 374%     | 414%      |
|       |                     | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-9  | TDCJ Ramsey         | Average Annual Water Bill                    | \$ 14,436   | \$ 690     | \$ 1,220  | \$ 1,750  | \$ 2,553 | \$ 2,809  |
|       |                     | Maximum % of HH Income                       | 32%         | 1%         | 3%        | 4%        | 6%       | 6%        |
|       |                     | Percentage Rate Increase Compared to Current | 4013%       | 92%        | 246%      | 400%      | 633%     | 707%      |
|       |                     | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-10 | Central Adsorption  | Average Annual Water Bill                    | \$ 2,970    | \$ 947     | \$ 1,031  | \$ 1,115  | \$ 1,242 | \$ 1,283  |
|       |                     | Maximum % of HH Income                       | 6%          | 2%         | 2%        | 2%        | 3%       | 3%        |
|       |                     | Percentage Rate Increase Compared to Current | 743%        | 170%       | 194%      | 218%      | 255%     | 267%      |
|       |                     | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-11 | Central Coagulation | Average Annual Water Bill                    | \$ 2,639    | \$ 1,152   | \$ 1,220  | \$ 1,287  | \$ 1,389 | \$ 1,421  |
|       |                     | Maximum % of HH Income                       | 6%          | 3%         | 3%        | 3%        | 3%       | 3%        |
|       |                     | Percentage Rate Increase Compared to Current | 650%        | 231%       | 251%      | 270%      | 300%     | 309%      |
|       |                     | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-12 | POU-Adsorption      | Average Annual Water Bill                    | \$ 1,622    | \$ 1,506   | \$ 1,527  | \$ 1,548  | \$ 1,581 | \$ 1,591  |
|       |                     | Maximum % of HH Income                       | 4%          | 3%         | 3%        | 3%        | 4%       | 4%        |
|       |                     | Percentage Rate Increase Compared to Current | 362%        | 338%       | 344%      | 350%      | 359%     | 362%      |
|       |                     | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-13 | POE-Adsorption      | Average Annual Water Bill                    | \$ 11,368   | \$ 2,737   | \$ 3,108  | \$ 3,480  | \$ 4,044 | \$ 4,224  |
|       |                     | Maximum % of HH Income                       | 25%         | 6%         | 7%        | 8%        | 9%       | 10%       |
|       |                     | Percentage Rate Increase Compared to Current | 3148%       | 708%       | 816%      | 924%      | 1088%    | 1140%     |
|       |                     | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-14 | New well 10 mi      | Average Annual Water Bill                    | \$ 14,262   | \$ 690     | \$ 1,213  | \$ 1,736  | \$ 2,559 | \$ 2,782  |
|       |                     | Maximum % of HH Income                       | 31%         | 1%         | 3%        | 4%        | 6%       | 6%        |
|       |                     | Percentage Rate Increase Compared to Current | 3963%       | 92%        | 244%      | 396%      | 626%     | 700%      |
|       |                     | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |

|       |                 | Funding Source #                             | 0           | 1          | 2         | 3         | 4        | 5         |
|-------|-----------------|--|-------------|------------|-----------|-----------|----------|-----------|
| #     | ALTERNATIVES    |  | All Revenue | 100% Grant | 75% Grant | 50% Grant | SRF      | Loan/Bond |
| GL-15 | New well 5 mi   | Average Annual Water Bill                    | \$ 7,933    | \$ 645     | \$ 925    | \$ 1,206  | \$ 1,632 | \$ 1,767  |
|       |                 | Maximum % of HH Income                       | 17%         | 1%         | 2%        | 3%        | 4%       | 4%        |
|       |                 | Percentage Rate Increase Compared to Current | 2158%       | 79%        | 160%      | 242%      | 365%     | 405%      |
|       |                 | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-16 | New well 1 mi   | Average Annual Water Bill                    | \$ 2,104    | \$ 530     | \$ 590    | \$ 651    | \$ 742   | \$ 772    |
|       |                 | Maximum % of HH Income                       | 5%          | 1%         | 1%        | 1%        | 2%       | 2%        |
|       |                 | Percentage Rate Increase Compared to Current | 494%        | 45%        | 62%       | 80%       | 106%     | 115%      |
|       |                 | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-17 | Dispenser       | Average Annual Water Bill                    | \$ 719      | \$ 690     | \$ 692    | \$ 695    | \$ 698   | \$ 700    |
|       |                 | Maximum % of HH Income                       | 2%          | 1%         | 1%        | 1%        | 2%       | 2%        |
|       |                 | Percentage Rate Increase Compared to Current | 100%        | 92%        | 93%       | 94%       | 95%      | 95%       |
|       |                 | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-18 | 100% Bottled    | Average Annual Water Bill                    | \$ 3,556    | \$ 3,546   | \$ 3,551  | \$ 3,55   | \$ 3,564 | \$ 3,567  |
|       |                 | Maximum % of HH Income                       | 8%          | 8%         | 8%        | 8%        | 8%       | 8%        |
|       |                 | Percentage Rate Increase Compared to Current | 952%        | 952%       | 953%      | 955%      | 957%     | 958%      |
|       |                 | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |
| GL-19 | Central Trucked | Average Annual Water Bill                    | \$ 1,227    | \$ 687     | \$ 709    | \$ 731    | \$ 764   | \$ 775    |
|       |                 | Maximum % of HH Income                       | 3%          | 2%         | 2%        | 2%        | 2%       | 2%        |
|       |                 | Percentage Rate Increase Compared to Current | 245%        | 91%        | 98%       | 104%      | 114%     | 117%      |
|       |                 | Year First Rate Increase Needed              | 2005        | 2005       | 2005      | 2005      | 2005     | 2005      |



**Figure 4-2 Alternative Cost Summary**



Current Rates:  
 Monthly: \$31.25  
 Median Household Income \$48,632  
 Average Monthly Residential Usage 5,382 gallons

---

## **SECTION 5 REFERENCES**

- Ashworth J. B., and Hopkins, J. 1992. Aquifers of Texas: Texas Water Development Board Report 345, 68 p.
- Kasmerek, M.C. and J.L. Robinson. 2004. Hydrogeology and simulation of ground-water flow and land-surface subsidence in the northern part of the Gulf Coast Aquifer system, Texas: U.S. Geological Survey Scientific Investigations Report 2004-5102, 111 p.
- Kasmerek, M.C., B.D. Reece, B.D., and N.A. Houston. 2005. Evaluation of ground-water flow and land-surface subsidence caused by hypothetical withdrawals in the northern part of the Gulf Coast aquifer system, Texas: U.S. Geological Survey Scientific Investigations Report 2005-5024, 70 p.
- Raucher, *et al.* 2004. Conventional and Unconventional Approaches to Water Service Provision [Project #2761]. Robert Raucher, Marca L. Hagenstad, Joseph Cotruvo, Ramesh Narasimhan, Kate Martin, Harish Arora, R. Nathan, Joseph Drago, and Fred Pontius. AWWA Research Foundation and American Water Works Association.
- TCEQ. 2004. Drinking Water Quality and Reporting Requirements for PWSs: 30 TAC 290 Subchapter F (290.104. Summary of Maximum Contaminant Levels, Maximum Residual Disinfectant Levels, Treatment Techniques, and Action Levels). Revised February 2004.
- USEPA. 2001. National Primary Drinking Water Regulations; Arsenic Contaminants Monitoring. Final Rule. *Federal Register*: January 22, 2001 (Volume 66, Number 14, p. 6975-7066).
- USEPA. 2004. Capital Costs of Arsenic Removal Technologies, U.S. EPA Arsenic Removal Technology Demonstration Program Round 1. EPA 600/R-04/201.
- USEPA. 2005a. List of Drinking Water Contaminants & MCLs. Online. Last updated February 23, 2005. [www.epa.gov/safewater/mcl.html](http://www.epa.gov/safewater/mcl.html).
- USEPA. 2005b. Technical Fact Sheet: Final Rule for Arsenic in Drinking Water. EPA 815-F-00-016. Online. Last updated February 14, 2005. [www.epa.gov/safewater/ars/ars\\_rule\\_techfactsheet.html](http://www.epa.gov/safewater/ars/ars_rule_techfactsheet.html).

1  
2

**APPENDIX A  
PWS INTERVIEW FORM**

# CAPACITY DEVELOPMENT ASSESSMENT FORM

Prepared By \_\_\_\_\_

Date \_\_\_\_\_

## **Section 1. Public Water System Information**

1. PWS ID #  2. Water System Name 3. County 4. Owner Address Tele. E-mail Fax Message 5. Admin Address Tele. E-mail Fax Message 6. Operator Address Tele. E-mail Fax Message 7. Population Served 8. No. of Service Connections 9. Ownership Type 10. Metered (Yes or No) 11. Source Type 12. Total PWS Annual Water Used 

13. Number of Water Quality Violations (Prior 36 months)

Total Coliform Chemical/Radiological Monitoring (CCR, Public Notification, etc.) Treatment Technique, D/DBP

## **A. Basic Information**

1. Name of Water System:
2. Name of Person Interviewed:
3. Position:
4. Number of years at job:
5. Number of years experience with drinking water systems:
6. Percent of time (day or week) on drinking water system activities, with current position (how much time is dedicated exclusively to the water system, not wastewater, solid waste or other activities):
7. Certified Water Operator (Yes or No):  
  
    If Yes,  
    7a. Certification Level (water):  
  
    7b. How long have you been certified?
8. Describe your water system related duties on a typical day.

## **B. Organization and Structure**

1. Describe the organizational structure of the Utility. Please provide an organizational chart. (Looking to find out the governance structure (who reports to whom), whether or not there is a utility board, if the water system answers to public works or city council, etc.)

2. If not already covered in Question 1, to whom do you report?
3. Do all of the positions have a written job description?
  - 3a. If yes, is it available to employees?
  - 3b. May we see a copy?

|                     |
|---------------------|
| <b>C. Personnel</b> |
|---------------------|

1. What is the current staffing level (include all personnel who spend more than 10% of their time working on the water system)?
2. Are there any vacant positions? How long have the positions been vacant?
3. In your opinion, is the current staffing level adequate? If not adequate, what are the issues or staffing needs (how many and what positions)?
4. What is the rate of employee turnover for management and operators? What are the major issues involved in the turnover (e.g., operator pay, working conditions, hours)?
5. Is the system staffed 24 hours a day? How is this handled (on-site or on-call)? Is there an alarm system to call an operator if an emergency occurs after hours?

|                         |
|-------------------------|
| <b>D. Communication</b> |
|-------------------------|

1. Does the utility have a mission statement? If yes, what is it?
2. Does the utility have water quality goals? What are they?
3. How are your work priorities set?
4. How are work tasks delegated to staff?
5. Does the utility have regular staff meetings? How often? Who attends?
6. Are there separate management meetings? If so, describe.
7. Do management personnel ever visit the treatment facility? If yes, how often?
8. Is there effective communication between utility management and state regulators (e.g., NMED)?
9. Describe communication between utility and customers.

|                                |
|--------------------------------|
| <b>E. Planning and Funding</b> |
|--------------------------------|

1. Describe the rate structure for the utility.
2. Is there a written rate structure, such as a rate ordinance? May we see it?
  - 2a. What is the average rate for 6,000 gallons of water?
3. How often are the rates reviewed?
4. What process is used to set or revise the rates?
5. In general, how often are the new rates set?
6. Is there an operating budget for the water utility? Is it separate from other activities, such as wastewater, other utilities, or general city funds?
7. Who develops the budget, how is it developed and how often is a new budget created or the old budget updated?
8. How is the budget approved or adopted?



9. In the last 5 years, how many budget shortfalls have there been (i.e., didn't collect enough money to cover expenses)? What caused the shortfall (e.g., unpaid bills, an emergency repair, weather conditions)?  
  
9a. How are budget shortfalls handled?
10. In the last 5 years how many years have there been budget surpluses (i.e., collected revenues exceeded expenses)?  
  
10a. How are budget surpluses handled (i.e., what is done with the money)?
11. Does the utility have a line-item in the budget for emergencies or some kind of emergency reserve account?
12. How do you plan and pay for short-term system needs?
13. How do you plan and pay for long- term system needs?
14. How are major water system capital improvements funded? Does the utility have a written capital improvements plan?
15. How is the facility planning for future growth (either new hook-ups or expansion into new areas)?
16. Does the utility have and maintain an annual financial report? Is it presented to policy makers?

17. Has an independent financial audit been conducted of the utility finances? If so, how often? When was the last one?
18. Will the system consider any type of regionalization with any other PWS, such as system interconnection, purchasing water, sharing operator, emergency water connection, sharing bookkeeper/billing or other?

|  |
|--|
| <b>F. Policies, Procedures, and Programs</b> |
|--|

1. Are there written operational procedures? Do the employees use them?
2. Who in the utility department has spending authorization? What is the process for obtaining needed equipment or supplies, including who approves expenditures?
3. Does the utility have a source water protection program? What are the major components of the program?
4. Are managers and operators familiar with current SDWA regulations?
5. How do the managers and operators hear about new or proposed regulations, such as arsenic, DBP, Groundwater Rule? Are there any new regulations that will be of particular concern to the utility?
6. What are the typical customer complaints that the utility receives?
7. Approximately how many complaints are there per month?

8. How are customer complaints handled? Are they recorded?
9. (If not specifically addressed in Question 7) If the complaint is of a water quality nature, how are these types of complaints handled?
10. Does the utility maintain an updated list of critical customers?
11. Is there a cross-connection control plan for the utility? Is it written? Who enforces the plan's requirements?
12. Does the utility have a written water conservation plan?
13. Has there been a water audit of the system? If yes, what were the results?
14. (If not specifically answered in 11 above) What is the estimated percentage for loss to leakage for the system?
15. Are you, or is the utility itself, a member of any trade organizations, such as AWWA or Rural Water Association? Are you an active member (i.e., attend regular meetings or participate in a leadership role)? Do you find this membership helpful? If yes, in what ways does it help you?

|                                      |
|--------------------------------------|
| <b>G. Operations and Maintenance</b> |
|--------------------------------------|

1. How is decision-making authority split between operations and management for the following items:
  - a. Process Control
  - b. Purchases of supplies or small equipment
  - c. Compliance sampling/reporting
  - d. Staff scheduling
2. Describe your utility's preventative maintenance program.
3. Do the operators have the ability to make changes or modify the preventative maintenance program?
4. How does management prioritize the repair or replacement of utility assets? Do the operators play a role in this prioritization process?
5. Does the utility keep an inventory of spare parts?
6. Where does staff have to go to buy supplies/minor equipment? How often?
  - 6a. How do you handle supplies that are critical, but not in close proximity (for example if chlorine is not available in the immediate area or if the components for a critical pump are not in the area)

7. Describe the system's disinfection process. Have you had any problems in the last few years with the disinfection system?

7a. Who has the ability to adjust the disinfection process?

8. How often is the disinfectant residual checked and where is it checked?

8a. Is there an official policy on checking residuals or is it up to the operators?

9. Does the utility have an O & M manual? Does the staff use it?

10. Are the operators trained on safety issues? How are they trained and how often?

11. Describe how on-going training is handled for operators and other staff. How do you hear about appropriate trainings? Who suggests the trainings – the managers or the operators? How often do operators, managers, or other staff go to training? Who are the typical trainers used and where are the trainings usually held?

12. In your opinion is the level of your on-going training adequate?

13. In your opinion is the level of on-going training for other staff members, particularly the operators, adequate?

14. Does the facility have mapping of the water utility components? Is it used on any routine basis by the operators or management? If so, how is it used? If not, what is the process used for locating utility components?
15. In the last sanitary survey, were any deficiencies noted? If yes, were they corrected?
16. How often are storage tanks inspected? Who does the inspection?
  - 16a. Have you experienced any problems with the storage tanks?

|                           |
|---------------------------|
| <b>H. SDWA Compliance</b> |
|---------------------------|

1. Has the system had any violations (monitoring or MCL) in the past 3 years? If so, describe.
2. How were the violations handled?
3. Does the system properly publish public notifications when notified of a violation?
4. Is the system currently in violation of any SDWA or state regulatory requirements, including failure to pay fees, fines, or other administrative type requirements?
5. Does the utility prepare and distribute a Consumer Confidence Report (CCR)? Is it done every year? What type of response does the utility get to the CCR from customers?

|                              |
|------------------------------|
| <b>I. Emergency Planning</b> |
|------------------------------|

1. Does the system have a written emergency plan to handle emergencies such as water outages, weather issues, loss of power, loss of major equipment, etc?
2. When was the last time the plan was updated?
3. Do all employees know where the plan is? Do they follow it?
4. Describe the last emergency the facility faced and how it was handled.

## Attachment A

**A. Technical Capacity Assessment Questions**

1. Based on available information of water rights on record and water pumped has the system exceeded its water rights in the past year? YES ☐ NO ☐

In any of the past 5 years? YES ☐ NO ☐ How many times? \_\_\_\_\_

2. Does the system have the proper level of certified operator? *(Use questions a – c to answer.)*  
YES ☐ NO ☐

a. What is the Classification Level of the system by NMED? \_\_\_\_\_

- b. Does the system have one or more certified operator(s)? [20 NMAC 7.4.20]

YES ☐ NO ☐

- c. If YES, provide the number of operators at each New Mexico Certification Level. [20 NMAC 7.4.12]

\_\_\_\_\_ NM Small System \_\_\_\_\_ Class 2

\_\_\_\_\_ NM Small System Advanced \_\_\_\_\_ Class 3

\_\_\_\_\_ Class 1 \_\_\_\_\_ Class 4

3. Did the system correct any sanitary deficiency noted on the most recent sanitary survey within 6 months of receiving that information? [20 NMAC 7.20.504]

YES ☐ NO ☐ No Deficiencies ☐

What was the type of deficiency? *(Check all that are applicable.)*

Source ☐ Storage ☐

Treatment ☐ Distribution ☐

Other \_\_\_\_\_

From the system's perspective, were there any other deficiencies that were not noted on the sanitary survey?  
Please describe.

4. Will the system's current treatment process meet known future regulations?

Radionuclides YES ☐ NO ☐ Doesn't Apply ☐

Arsenic YES ☐ NO ☐ Doesn't Apply ☐

Stage 1 Disinfectants and Disinfection By-Product (DBP)

YES ☐ NO ☐ Doesn't Apply ☐

Surface Water Treatment Rule YES ☐ NO ☐ Doesn't Apply ☐

5. Does the system have a current site plan/map? [20 NMAC 7.10.302 A.1.]

YES ☐ NO ☐



6. Has the system had a water supply outage in the prior 24 months?

YES ☐ NO ☐

What were the causes of the outage(s)? *(Include number of outages for each cause.)*

Drought \_\_\_\_\_ Limited Supply \_\_\_\_\_

System Failure \_\_\_\_\_ Other \_\_\_\_\_

7. Has the system ever had a water audit or a leak evaluation?

YES ☐ NO ☐ Don't Know ☐

If YES, please complete the following table.

| Type of Investigation | Date Done | Water Loss (%) | What approach or technology was used to complete the investigation? | Was any follow-up done? If so, describe |
|-----------------------|-----------|----------------|---|---|
|                       |           |                |   |   |
|                       |           |                |   |   |
|                       |           |                |   |   |
|                       |           |                |   |   |

8. Have all drinking water projects received NMED review and approval? [20 NMAC 7.10.201]

YES ☐ NO ☐

If NO, what types of projects have not received NMED review and approval.

Source ☐ Storage ☐

Treatment ☐ Distribution ☐

Other ☐ \_\_\_\_\_

9. What are the typical customer complaints that the utility receives?

10. Approximately how many complaints are there per month? \_\_\_\_\_

11. How are customer complaints handled? Are they recorded?

12. What is the age and composition of the distribution system? *(Collect this information from the Sanitary Survey)*

| Pipe Material | Approximate Age | Percentage of the system | Comments   |
|---------------|-----------------|--------------------------|--|
|               |                 |                          | Sanitary Survey Distribution System Records Attached |
|               |                 |                          |  |
|               |                 |                          |  |
|               |                 |                          |  |
|               |                 |                          |  |

13. Are there any dead end lines in the system?  
 YES ☐ NO ☐

14. Does the system have a flushing program?  
 YES ☐ NO ☐

If YES, please describe.

15. Are there any pressure problems within the system?  
 YES ☐ NO ☐

If YES, please describe.

16. Does the system disinfect the finished water?  
 YES ☐ NO ☐

If yes, which disinfectant product is used? \_\_\_\_\_

Interviewer Comments on Technical Capacity:

## **B. Managerial Capacity Assessment Questions**

17. Has the system completed a 5-year Infrastructure Capital Improvement Plan (ICIP) plan?

YES ☐ NO ☐

If YES, has the plan been submitted to Local Government Division?

YES ☐ NO ☐

18. Does the system have written operating procedures?

YES ☐ NO ☐

19. Does the system have written job descriptions for all staff?

YES ☐ NO ☐

20. Does the system have:
- |                                     |                          |     |                          |
|-------------------------------------|--------------------------|-----|--------------------------|
| A preventative maintenance plan?    |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
| A source water protection plan?     |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
|                                     |                          | N/A | <input type="checkbox"/> |
| An emergency plan?                  |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
| A cross-connection control program? |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
| An emergency source?                |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
| System security measures?           |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
21. Does the system report and maintain records in accordance with the drinking water regulations concerning:
- |                          |                          |    |                          |
|--------------------------|--------------------------|----|--------------------------|
| Water quality violations |                          |    |                          |
| YES                      | <input type="checkbox"/> | NO | <input type="checkbox"/> |
| Public notification      |                          |    |                          |
| YES                      | <input type="checkbox"/> | NO | <input type="checkbox"/> |
| Sampling exemptions      |                          |    |                          |
| YES                      | <input type="checkbox"/> | NO | <input type="checkbox"/> |
22. Please describe how the above records are maintained:
23. Describe the management structure for the water system, including board and operations staff. Please include examples of duties, if possible.
24. Please describe type and quantity of training or continuing education for staff identified above.
25. Describe last major project undertaken by the water system, including the following: project in detail, positive aspects, negative aspects, the way in which the project was funded, any necessary rate increases, the public response to the project, whether the project is complete or not, and any other pertinent information.

26. Does the system have any debt? YES ☐ NO ☐

If yes, is the system current with all debt payments?

YES ☐ NO ☐

If no, describe the applicable funding agency and the default.

27. Is the system currently contemplating or actively seeking funding for any project?

YES ☐ NO ☐

If yes, from which agency and how much?

Describe the project?

Is the system receiving assistance from any agency or organization in its efforts?

28. Will the system consider any type of regionalization with other PWS? *(Check YES if the system has already regionalized.)*

YES ☐ NO ☐

If YES, what type of regionalization has been implemented/considered/discussed? *(Check all that apply.)*

System interconnection ☐

Sharing operator ☐

Sharing bookkeeper ☐

Purchasing water ☐

Emergency water connection ☐

Other: \_\_\_\_\_

29. Does the system have any of the following? *(Check all that apply.)*

Water Conservation Policy/Ordinance ☐ Current Drought Plan ☐

Water Use Restrictions ☐ Water Supply Emergency Plan ☐

Interviewer Comments on Managerial Capacity:

**C. Financial Capacity Assessment**

30. Does the system have a budget?

YES ☐ NO ☐

If YES, what type of budget?

Operating Budget ☐Capital Budget ☐

31. Have the system revenues covered expenses and debt service for the past 5 years?

YES ☐ NO ☐

If NO, how many years has the system had a shortfall? \_\_\_\_\_

32. Does the system have a written/adopted rate structure?

YES ☐ NO ☐

33. What was the date of the last rate increase? \_\_\_\_\_

34. Are rates reviewed annually?

YES ☐ NO ☐

If YES, what was the date of the last review? \_\_\_\_\_

35. Did the rate review show that the rates covered the following expenses? (*Check all that apply.*)Operation & Maintenance ☐Infrastructure Repair & replacement ☐Staffing ☐Emergency/Reserve fund ☐Debt payment ☐

36. Is the rate collection above 90% of the customers?

YES ☐ NO ☐

37. Is there a cut-off policy for customers who are in arrears with their bill or for illegal connections?

YES ☐ NO ☐

If yes, is this policy implemented?

38. What is the residential water rate for 6,000 gallons of usage in one month. \_\_\_\_\_

39. In the past 12 months, how many customers have had accounts frozen or dropped for non-payment? \_\_\_\_\_

[Convert to % of active connections]

Less than 1% ☐ 1% - 3% ☐ 4% - 5% ☐ 6% - 10% ☐11% - 20% ☐ 21% - 50% ☐ Greater than 50% ☐ ]

40. The following questions refer to the process of obtaining needed equipment and supplies.

a. Can the water system operator buy or obtain supplies or equipment when they are needed?

YES ☐ NO ☐

b. Is the process simple or burdensome to the employees?

c. Can supplies or equipment be obtained quickly during an emergency?

YES ☐ NO ☐

d. Has the water system operator ever experienced a situation in which he/she couldn't purchase the needed supplies?

YES ☐ NO ☐

e. Does the system maintain some type of spare parts inventory?

YES ☐ NO ☐

If yes, please describe.

41. Has the system ever had a financial audit?

YES ☐ NO ☐

If YES, what is the date of the most recent audit? \_\_\_\_\_

42. Has the system ever had its electricity or phone turned off due to non-payment? Please describe.

Interviewer Comments on Financial Assessment:

43. What do you think the system capabilities are now and what are the issues you feel your system will be facing in the future? In addition, are there any specific needs, such as types of training that you would like to see addressed by NMED or its contractors?

## APPENDIX B COST BASIS

This section presents the basis for unit costs used to develop the conceptual cost estimates for the compliance alternatives. Cost estimates are conceptual in nature (+50%/-30%), and are intended to make comparisons between compliance options and to provide a preliminary indication of possible rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. Capital cost includes an allowance for engineering and construction management. It is assumed that adequate electrical power is available near the site. The cost estimates specifically do not include costs for the following:

- Obtaining land or easements.
- Surveying.
- Mobilization/demobilization for construction.
- Insurance and bonds.

In general, unit costs are based on recent construction bids for similar work in the area; when possible, consultations with vendors or other suppliers; published construction and O&M cost data; and USEPA cost guidance. Unit costs used for the cost estimates are summarized in Table B.1.

Unit costs for pipeline components are based on recent bids on Texas Department of Highways projects. The amounts of boring and encasement and open cut and encasement were estimated by counting the road, highway, railroad, stream, and river crossings for a conceptual routing of the pipeline. The number of air release valves is estimated by examining the land surface profile along the conceptual pipeline route. It is assumed gate valves and flush valves would be installed on average every 5,000 feet along the pipeline. Pipeline cost estimates are based on use of C-900 PVC pipe. Other pipe materials could be considered for more detailed development of attractive alternatives.

Pump station unit costs are based on experience with similar installations. The cost estimate for the pump stations include two pumps, station piping and valves, station electrical and instrumentation, minor site improvement, installation of a concrete pad and building, and tools. Construction cost of a storage tank is based on similar recent installations.

Electrical power cost is estimated to be \$0.136 per kWh, as supplied by Reliant Energy, Houston, Texas. The annual cost for power to a pump station is calculated based on the pumping head and volume, and includes 11,800 kWh for pump building heating, cooling, and lighting, as recommended in USEPA publication, *Standardized Costs for Water Supply Distribution Systems* (1992).

In addition to the cost of electricity, pump stations have other maintenance costs. These costs cover: materials for minor repairs to keep the pumps operating; purchase of



a maintenance vehicle, fuel costs, and vehicle maintenance costs; utilities; office supplies, small tools and equipment; and miscellaneous materials such as safety, clothing, chemicals, and paint. The non-power O&M costs are estimated based on the USEPA publication, *Standardized Costs for Water Supply Distribution Systems* (1992), which provides cost curves for O&M components. Costs from the 1992 report are adjusted to 2005 dollars based on the ENR construction cost index.

Pipeline maintenance costs include routine cleaning and flushing, as well as minor repairs to lines. The unit rate for pipeline maintenance is calculated based on the USEPA technical report, *Innovative and Alternate Technology Assessment Manual MCD 53* (1978). Costs from the 1978 report are adjusted to 2005 dollars based on the ENR construction cost index.

Storage tank maintenance costs include cleaning and renewal of interior lining and exterior coating. Unit costs for storage tank O&M are based on USEPA publication *Standardized Costs for Water Supply Distribution Systems* (1992). Costs from the 1992 report are adjusted to 2005 dollars based on the ENR construction cost index.

The purchase price for point-of-use (POU) water treatment units is based on vendor price lists for treatment units, plus installation. O&M costs for POU treatment units are also based on vendor price lists. It is assumed that a yearly water sample would be analyzed for the contaminant of concern.

The purchase price for point-of-entry (POE) water treatment units is based on vendor price lists for treatment units, plus an allowance for installation, including a concrete pad and shed, piping modifications, and electrical connection. O&M costs for POE treatment units are also based on vendor price lists. It is assumed that a yearly water sample would be analyzed for the contaminant of concern.

Central treatment plant costs, for both adsorption and coagulation/filtration, include pricing for buildings, utilities, and site work. Costs are based on pricing given in the various R.S. Means Construction Cost Data References, as well as prices obtained from similar work on other projects. Pricing for treatment equipment is from a USEPA arsenic removal demonstration project (USEPA 2004).

Well installation costs are based on quotations from drillers for installation of similar depth wells in the area. Well installation costs include drilling, a well pump, electrical and instrumentation installation, well finishing, piping, and water quality testing. O&M costs for water wells include power, materials, and labor. It is assumed that new wells located more than 1 mile from the intake point of an existing system would require a storage tank and pump station.

Purchase price for the treatment unit dispenser is based on vendor price lists, plus an allowance for installation at a centralized public location. The O&M costs are also based on vendor price lists. It is assumed that weekly water samples would be analyzed for the contaminant of concern.

Costs for bottled water delivery alternatives are based on consultation with vendors that deliver residential bottled water. The cost estimate includes an initial allowance for set-up of the program, and a yearly allowance for program administration.

The cost estimate for a public dispenser for trucked water includes the purchase price for a water truck and construction of a storage tank. Annual costs include labor for purchasing the water, picking up and delivering the water, truck maintenance, and water sampling and testing. It is assumed the water truck would be required to make one trip each week, and that chlorine residual would be determined for each truck load.

**Table B.1**  
**Summary of General Data**  
**Grasslands**  
**PWS #0200360**

**Service Population** 450  
**Total PWS Daily Water Usage** 0.039 (mgd)

**Number of Connections** 150  
**Source** 2005 Report

**Unit Cost Data**  
**West Texas**

| <b>General Items</b>                      | <b>Unit</b>            | <b>Unit Cost</b> | <b>Central Treatment Unit Costs</b> | <b>Unit</b> | <b>Unit Cost</b> |
|---|------------------------|------------------|-------------------------------------|-------------|------------------|
| Treated water purchase cost               | <i>See alternative</i> |                  | Site preparation                    | acre        | \$ 4,000         |
| Water purchase cost (trucked)             | \$/1,000 gals          | \$ 1.80          | Slab                                | CY          | \$ 1,000         |
|   |                        |                  | Building                            | SF          | \$ 60            |
| Contingency                               | 20%                    | n/a              | Building electrical                 | SF          | \$ 8             |
| Engineering & Constr. Management          | 25%                    | n/a              | Building plumbing                   | SF          | \$ 8             |
| Procurement/admin (POU/POE)               | 20%                    | n/a              | Heating and ventilation             | SF          | \$ 7             |
|   |                        |                  | Fence                               | LF          | \$ 15            |
| <b>Pipeline Unit Costs</b>                | <b>Unit</b>            | <b>Unit Cost</b> | Paving                              | SF          | \$ 2             |
| PVC water line, Class 200, 04"            | LF                     | \$ 26            | Electrical, Adsorption              | JOB         | \$ 50,000        |
| Bore and encasement, 10"                  | LF                     | \$ 60            | Electrical, Coagulation             | JOB         | \$ 30,000        |
| Open cut and encasement, 10"              | LF                     | \$ 30            | Piping, Adsorption                  | JOB         | \$ 20,000        |
| Gate valve and box, 04"                   | EA                     | \$ 340           | Piping, Coagulation                 | JOB         | \$ 10,000        |
| Air valve                                 | EA                     | \$ 1,000         | Adsorption package                  | UNIT        | \$ 115,000       |
| Flush valve                               | EA                     | \$ 750           | Coagulation package                 | UNIT        | \$ 89,700        |
| Metal detectable tape                     | LF                     | \$ 0.15          | Sewer connection fee                | EA          | \$ 15,000        |
|   |                        |                  | Chlorination point                  | EA          | \$ 2,000         |
| Bore and encasement, length               | Feet                   | 200              | Coagulant tank                      | GAL         | \$ 3.00          |
| Open cut and encasement, length           | Feet                   | 50               | Backwash tank                       | GAL         | \$ 2.00          |
|   |                        |                  | Tank, 20,000 GAL                    | GAL         | \$ 1.00          |
| <b>Pump Station Unit Costs</b>            | <b>Unit</b>            | <b>Unit Cost</b> | Tank, 10,000 GAL                    | GAL         | \$ 1.50          |
| Pump                                      | EA                     | \$ 7,500         | Excavation                          | CYD         | \$ 3.00          |
| Pump Station Piping, 04"                  | EA                     | \$ 4,000         | Compacted fill                      | CYD         | \$ 7.00          |
| Gate valve, 04"                           | EA                     | \$ 370           | Lining                              | SF          | \$ 0.50          |
| Check valve, 04"                          | EA                     | \$ 430           | Vegetation                          | SY          | \$ 1.00          |
| Electrical/Instrumentation                | EA                     | \$ 10,000        | Access road                         | LF          | \$ 30            |
| Site work                                 | EA                     | \$ 2,000         |                                     |             |                  |
| Building pad                              | EA                     | \$ 4,000         | Building Power                      | kwh/yr      | \$ 0.136         |
| Pump Building                             | EA                     | \$ 10,000        | Equipment power                     | kwh/yr      | \$ 0.136         |
| Fence                                     | EA                     | \$ 5,870         | Labor                               | hr          | \$ 40            |
| Tools                                     | EA                     | \$ 1,000         | Adsorption Materials                | year        | \$ 14,000        |
|   |                        |                  | Coagulation/Filtration Materials    | year        | \$ 2,000         |
| <b>Well Installation Unit Costs</b>       | <b>Unit</b>            | <b>Unit Cost</b> | Backwash discharge to sewer         | MG/year     | \$ 2,000         |
| Well installation                         | <i>See alternative</i> |                  | Chemicals, Coagulation              | year        | \$ 2,000         |
| Water quality testing                     | EA                     | \$ 1,500         | Analyses                            | test        | \$ 200           |
| Well pump                                 | EA                     | \$ 7,500         | Spent media disposal                | CY          | \$ 20            |
| Well electrical/instrumentation           | EA                     | \$ 5,000         |                                     |             |                  |
| Well cover and base                       | EA                     | \$ 3,000         |                                     |             |                  |
| Piping                                    | EA                     | \$ 2,500         |                                     |             |                  |
| Storage Tank - 5,000 gals                 | EA                     | \$ 7,025         |                                     |             |                  |
|   |                        |                  |                                     |             |                  |
| Electrical Power                          | \$/kWH                 | \$ 0.136         |                                     |             |                  |
| Building Power                            | kWH                    | 11,800           |                                     |             |                  |
| Labor                                     | \$/hr                  | \$ 30            |                                     |             |                  |
| Materials                                 | EA                     | \$ 1,200         |                                     |             |                  |
| Transmission main O&M                     | \$/mile                | \$ 200           |                                     |             |                  |
| Tank O&M                                  | EA                     | \$ 1,000         |                                     |             |                  |
|   |                        |                  |                                     |             |                  |
| <b>POU/POE Unit Costs</b>                 |                        |                  |                                     |             |                  |
| POU treatment unit purchase               | EA                     | \$ 250           |                                     |             |                  |
| POU treatment unit installation           | EA                     | \$ 150           |                                     |             |                  |
| POE treatment unit purchase               | EA                     | \$ 3,000         |                                     |             |                  |
| POE - pad and shed, per unit              | EA                     | \$ 2,000         |                                     |             |                  |
| POE - piping connection, per unit         | EA                     | \$ 1,000         |                                     |             |                  |
| POE - electrical hook-up, per unit        | EA                     | \$ 1,000         |                                     |             |                  |
|   |                        |                  |                                     |             |                  |
| POU treatment O&M, per unit               | \$/year                | \$ 225           |                                     |             |                  |
| POE treatment O&M, per unit               | \$/year                | \$ 1,000         |                                     |             |                  |
| Contaminant analysis                      | \$/year                | \$ 100           |                                     |             |                  |
| POU/POE labor support                     | \$/hr                  | \$ 30            |                                     |             |                  |
|   |                        |                  |                                     |             |                  |
| <b>Dispenser/Bottled Water Unit Costs</b> |                        |                  |                                     |             |                  |
| Treatment unit purchase                   | EA                     | \$ 3,000         |                                     |             |                  |
| Treatment unit installation               | EA                     | \$ 5,000         |                                     |             |                  |
| Treatment unit O&M                        | EA                     | \$ 500           |                                     |             |                  |
| Administrative labor                      | hr                     | \$ 40            |                                     |             |                  |
| Bottled water cost (inc. delivery)        | gallon                 | \$ 1.60          |                                     |             |                  |
| Water use, per capita per day             | gpcd                   | 1.0              |                                     |             |                  |
| Bottled water program materials           | EA                     | \$ 5,000         |                                     |             |                  |
| Storage Tank - 5,000 gals                 | EA                     | \$ 7,025         |                                     |             |                  |
| Site improvements                         | EA                     | \$ 4,000         |                                     |             |                  |
| Potable water truck                       | EA                     | \$ 60,000        |                                     |             |                  |
| Water analysis, per sample                | EA                     | \$ 100           |                                     |             |                  |
| Potable water truck O&M costs             | \$/mile                | \$ 1.00          |                                     |             |                  |

1  
2

## **APPENDIX C COMPLIANCE ALTERNATIVE CONCEPTUAL COST ESTIMATES**

3        This appendix presents the conceptual cost estimates developed for the compliance  
4 alternatives. The conceptual cost estimates are given in Tables C.1 through C.19. The  
5 cost estimates are conceptual in nature (+50%/-30%), and are intended for making  
6 comparisons between compliance options and to provide a preliminary indication of  
7 possible water rate impacts. Consequently, these costs are pre-planning level and should  
8 not be viewed as final estimated costs for alternative implementation.

**Table C.1**

|                           |  |
|---------------------------|--|
| <b>PWS Name</b>           | <b>Grasslands</b>                        |
| <b>Alternative Name</b>   | <b>Purchase Water from City of Alvin</b> |
| <b>Alternative Number</b> | <b>GL-1</b>                              |

|   |                        |
|---|------------------------|
| Distance from Alternative to PWS (along pipe) | 14.5 miles             |
| Total PWS annual water usage                  | 14.235 MG              |
| Treated water purchase cost                   | \$ 1.65 per 1,000 gals |
| Number of Pump Stations Needed                | 2                      |

**Capital Costs**

| Cost Item                      | Quantity | Unit | Unit Cost   | Total Cost          |
|--------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>   |          |      |             |                     |
| Number of Crossings, bore      | 37       | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut  | 6        | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04" | 76,320   | LF   | \$ 26.00    | \$ 1,984,320        |
| Bore and encasement, 10"       | 7,400    | LF   | \$ 60.00    | \$ 444,000          |
| Open cut and encasement, 10"   | 300      | LF   | \$ 30.00    | \$ 9,000            |
| Gate valve and box, 04"        | 15       | EA   | \$ 340.00   | \$ 5,190            |
| Air valve                      | 14       | EA   | \$ 1,000.00 | \$ 14,000           |
| Flush valve                    | 15       | EA   | \$ 750.00   | \$ 11,448           |
| Metal detectable tape          | 76,320   | LF   | \$ 0.15     | \$ 11,448           |
| <b>Subtotal</b>                |          |      |             | <b>\$ 2,479,406</b> |

*Pump Station(s) Installation*

|                            |   |    |           |                   |
|----------------------------|---|----|-----------|-------------------|
| Pump                       | 2 | EA | \$ 7,500  | \$ 15,000         |
| Pump Station Piping, 04"   | 2 | EA | \$ 4,000  | \$ 8,000          |
| Gate valve, 04"            | 8 | EA | \$ 370    | \$ 2,960          |
| Check valve, 04"           | 4 | EA | \$ 430    | \$ 1,720          |
| Electrical/Instrumentation | 2 | EA | \$ 10,000 | \$ 20,000         |
| Site work                  | 2 | EA | \$ 2,000  | \$ 4,000          |
| Building pad               | 2 | EA | \$ 4,000  | \$ 8,000          |
| Pump Building              | 2 | EA | \$ 10,000 | \$ 20,000         |
| Fence                      | 2 | EA | \$ 5,870  | \$ 11,740         |
| Tools                      | 2 | EA | \$ 1,000  | \$ 2,000          |
| Storage Tank - 5,000 gals  | 2 | EA | \$ 7,025  | \$ 14,050         |
| <b>Subtotal</b>            |   |    |           | <b>\$ 107,470</b> |

|                                    |                     |
|------------------------------------|---------------------|
| <b>Subtotal of Component Costs</b> | <b>\$ 2,586,876</b> |
|------------------------------------|---------------------|

|                            |     |            |
|----------------------------|-----|------------|
| Contingency                | 20% | \$ 517,375 |
| Design & Constr Management | 25% | \$ 646,719 |

|                            |                     |
|----------------------------|---------------------|
| <b>TOTAL CAPITAL COSTS</b> | <b>\$ 3,750,970</b> |
|----------------------------|---------------------|

**Annual Operations and Maintenance Costs**

| Cost Item                  | Quantity | Unit    | Unit Cost | Total Cost       |
|----------------------------|----------|---------|-----------|------------------|
| <i>Pipeline O&amp;M</i>    |          |         |           |                  |
| Pipeline O&M               | 14.5     | mile    | \$ 200    | \$ 2,891         |
| <b>Subtotal</b>            |          |         |           | <b>\$ 2,891</b>  |
| <i>Water Purchase Cost</i> |          |         |           |                  |
| From Source                | 14,235   | 1,000 g | \$ 1.65   | \$ 23,488        |
| <b>Subtotal</b>            |          |         |           | <b>\$ 23,488</b> |

*Pump Station(s) O&M*

|                 |        |     |          |                  |
|-----------------|--------|-----|----------|------------------|
| Building Power  | 23,600 | kWH | \$ 0.136 | \$ 3,210         |
| Pump Power      | 67,550 | kWH | \$ 0.136 | \$ 9,187         |
| Materials       | 2      | EA  | \$ 1,200 | \$ 2,400         |
| Labor           | 730    | Hrs | \$ 30    | \$ 21,900        |
| Tank O&M        | 2      | EA  | \$ 1,000 | \$ 2,000         |
| <b>Subtotal</b> |        |     |          | <b>\$ 38,696</b> |

*O&M Credit for Existing Well Closure*

|                 |       |     |          |                    |
|-----------------|-------|-----|----------|--------------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ (211)           |
| Well O&M matl   | 2     | EA  | \$ 1,200 | \$ (2,400)         |
| Well O&M labor  | 360   | Hrs | \$ 30    | \$ (10,800)        |
| <b>Subtotal</b> |       |     |          | <b>\$ (13,411)</b> |

|                                   |                  |
|-----------------------------------|------------------|
| <b>TOTAL ANNUAL O&amp;M COSTS</b> | <b>\$ 51,664</b> |
|-----------------------------------|------------------|

## Table C.2

**PWS Name** *Grasslands*  
**Alternative Name** *Purchase Water from City of Angleton*  
**Alternative Number** *GL-2*

**Distance from Alternative to PWS (along pipe)** 11.4 miles  
**Total PWS annual water usage** 14.235 MG  
**Treated water purchase cost** \$ 1.60 per 1,000 gals  
**Number of Pump Stations Needed** 1

### Capital Costs

| Cost Item                      | Quantity | Unit | Unit Cost   | Total Cost          |
|--------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>   |          |      |             |                     |
| Number of Crossings, bore      | 21       | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut  | 7        | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04" | 60,025   | LF   | \$ 26.00    | \$ 1,560,650        |
| Bore and encasement, 10"       | 4,200    | LF   | \$ 60.00    | \$ 252,000          |
| Open cut and encasement, 10"   | 350      | LF   | \$ 30.00    | \$ 10,500           |
| Gate valve and box, 04"        | 12       | EA   | \$ 340.00   | \$ 4,082            |
| Air valve                      | 11       | EA   | \$ 1,000.00 | \$ 11,000           |
| Flush valve                    | 12       | EA   | \$ 750.00   | \$ 9,004            |
| Metal detectable tape          | 60,025   | LF   | \$ 0.15     | \$ 9,004            |
| <b>Subtotal</b>                |          |      |             | <b>\$ 1,856,239</b> |

#### *Pump Station(s) Installation*

|                            |   |    |           |                  |
|----------------------------|---|----|-----------|------------------|
| Pump                       | 1 | EA | \$ 7,500  | \$ 7,500         |
| Pump Station Piping, 04"   | 1 | EA | \$ 4,000  | \$ 4,000         |
| Gate valve, 04"            | 4 | EA | \$ 370    | \$ 1,480         |
| Check valve, 04"           | 2 | EA | \$ 430    | \$ 860           |
| Electrical/Instrumentation | 1 | EA | \$ 10,000 | \$ 10,000        |
| Site work                  | 1 | EA | \$ 2,000  | \$ 2,000         |
| Building pad               | 1 | EA | \$ 4,000  | \$ 4,000         |
| Pump Building              | 1 | EA | \$ 10,000 | \$ 10,000        |
| Fence                      | 1 | EA | \$ 5,870  | \$ 5,870         |
| Tools                      | 1 | EA | \$ 1,000  | \$ 1,000         |
| Storage Tank - 5,000 gals  | 1 | EA | \$ 7,025  | \$ 7,025         |
| <b>Subtotal</b>            |   |    |           | <b>\$ 53,735</b> |

**Subtotal of Component Costs** **\$ 1,909,974**

Contingency 20% \$ 381,995  
 Design & Constr Management 25% \$ 477,494

**TOTAL CAPITAL COSTS** **\$ 2,769,463**

### Annual Operations and Maintenance Costs

| Cost Item                  | Quantity | Unit      | Unit Cost | Total Cost       |
|----------------------------|----------|-----------|-----------|------------------|
| <i>Pipeline O&amp;M</i>    |          |           |           |                  |
| Pipeline O&M               | 11.4     | mile      | \$ 200    | \$ 2,274         |
| <b>Subtotal</b>            |          |           |           | <b>\$ 2,274</b>  |
| <i>Water Purchase Cost</i> |          |           |           |                  |
| From Source                | 14,235   | 1,000 gal | \$ 1.60   | \$ 22,776        |
| <b>Subtotal</b>            |          |           |           | <b>\$ 22,776</b> |

#### *Pump Station(s) O&M*

|                 |        |     |          |                  |
|-----------------|--------|-----|----------|------------------|
| Building Power  | 11,800 | kWH | \$ 0.136 | \$ 1,605         |
| Pump Power      | 52,850 | kWH | \$ 0.136 | \$ 7,188         |
| Materials       | 1      | EA  | \$ 1,200 | \$ 1,200         |
| Labor           | 365    | Hrs | \$ 30    | \$ 10,950        |
| Tank O&M        | 1      | EA  | \$ 1,000 | \$ 1,000         |
| <b>Subtotal</b> |        |     |          | <b>\$ 21,942</b> |

#### *O&M Credit for Existing Well Closure*

|                 |       |     |          |                    |
|-----------------|-------|-----|----------|--------------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ (211)           |
| Well O&M matl   | 2     | EA  | \$ 1,200 | \$ (2,400)         |
| Well O&M labor  | 360   | Hrs | \$ 30    | \$ (10,800)        |
| <b>Subtotal</b> |       |     |          | <b>\$ (13,411)</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 33,581**

**Table C.3**

**PWS Name** *Grasslands*  
**Alternative Name** *New Well at Bateman Water Works*  
**Alternative Number** *GL-3*

**Distance from PWS to new well location** 10.66 miles  
**Estimated well depth** 310 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 1

**Capital Costs**

| Cost Item                      | Quantity | Unit | Unit Cost | Total Cost          |
|--------------------------------|----------|------|-----------|---------------------|
| <i>Pipeline Construction</i>   |          |      |           |                     |
| Number of Crossings, bore      | 8        | n/a  | n/a       | n/a                 |
| Number of Crossings, open cut  | 5        | n/a  | n/a       | n/a                 |
| PVC water line, Class 200, 04" | 56,291   | LF   | \$ 26     | \$ 1,463,566        |
| Bore and encasement, 10"       | 1,600    | LF   | \$ 60     | \$ 96,000           |
| Open cut and encasement, 10"   | 250      | LF   | \$ 30     | \$ 7,500            |
| Gate valve and box, 04"        | 11       | EA   | \$ 340    | \$ 3,828            |
| Air valve                      | 11       | EA   | \$ 1,000  | \$ 11,000           |
| Flush valve                    | 11       | EA   | \$ 750    | \$ 8,444            |
| Metal detectable tape          | 56,291   | LF   | \$ 0.15   | \$ 8,444            |
| <b>Subtotal</b>                |          |      |           | <b>\$ 1,598,781</b> |

*Pump Station(s) Installation*

|                            |   |    |           |                  |
|----------------------------|---|----|-----------|------------------|
| Pump                       | 2 | EA | \$ 7,500  | \$ 15,000        |
| Pump Station Piping, 04"   | 1 | EA | \$ 4,000  | \$ 4,000         |
| Gate valve, 04"            | 4 | EA | \$ 370    | \$ 1,480         |
| Check valve, 04"           | 2 | EA | \$ 430    | \$ 860           |
| Electrical/Instrumentation | 1 | EA | \$ 10,000 | \$ 10,000        |
| Site work                  | 1 | EA | \$ 2,000  | \$ 2,000         |
| Building pad               | 1 | EA | \$ 4,000  | \$ 4,000         |
| Pump Building              | 1 | EA | \$ 10,000 | \$ 10,000        |
| Fence                      | 1 | EA | \$ 5,870  | \$ 5,870         |
| Tools                      | 1 | EA | \$ 1,000  | \$ 1,000         |
| Storage Tank - 5,000 gals  | 1 | EA | \$ 7,025  | \$ 7,025         |
| <b>Subtotal</b>            |   |    |           | <b>\$ 61,235</b> |

*Well Installation*

|                                 |     |    |          |                  |
|---------------------------------|-----|----|----------|------------------|
| Well installation               | 310 | LF | \$ 25    | \$ 7,750         |
| Water quality testing           | 2   | EA | \$ 1,500 | \$ 3,000         |
| Well pump                       | 1   | EA | \$ 7,500 | \$ 7,500         |
| Well electrical/instrumentation | 1   | EA | \$ 5,000 | \$ 5,000         |
| Well cover and base             | 1   | EA | \$ 3,000 | \$ 3,000         |
| Piping                          | 1   | EA | \$ 2,500 | \$ 2,500         |
| <b>Subtotal</b>                 |     |    |          | <b>\$ 28,750</b> |

**Subtotal of Component Costs** **\$ 1,688,766**

Contingency 20% \$ 337,753  
 Design & Constr Management 25% \$ 422,192

**TOTAL CAPITAL COSTS** **\$ 2,448,711**

**Annual Operations and Maintenance Costs**

| Cost Item               | Quantity | Unit | Unit Cost | Total Cost      |
|-------------------------|----------|------|-----------|-----------------|
| <i>Pipeline O&amp;M</i> |          |      |           |                 |
| Pipeline O&M            | 10.7     | mile | \$ 200    | \$ 2,132        |
| <b>Subtotal</b>         |          |      |           | <b>\$ 2,132</b> |

*Pump Station(s) O&M*

|                 |        |     |          |                  |
|-----------------|--------|-----|----------|------------------|
| Building Power  | 11,800 | kWH | \$ 0.136 | \$ 1,605         |
| Pump Power      | 52,300 | kWH | \$ 0.136 | \$ 7,113         |
| Materials       | 1      | EA  | \$ 1,200 | \$ 1,200         |
| Labor           | 365    | Hrs | \$ 30    | \$ 10,950        |
| Tank O&M        | 1      | EA  | \$ 1,000 | \$ 1,000         |
| <b>Subtotal</b> |        |     |          | <b>\$ 21,868</b> |

*Well O&M*

|                 |       |     |          |                 |
|-----------------|-------|-----|----------|-----------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ 211          |
| Well O&M matl   | 1     | EA  | \$ 1,200 | \$ 1,200        |
| Well O&M labor  | 180   | Hrs | \$ 30    | \$ 5,400        |
| <b>Subtotal</b> |       |     |          | <b>\$ 6,811</b> |

*O&M Credit for Existing Well Closure*

|                 |       |     |          |                    |
|-----------------|-------|-----|----------|--------------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ (211)           |
| Well O&M matl   | 2     | EA  | \$ 1,200 | \$ (2,400)         |
| Well O&M labor  | 360   | Hrs | \$ 30    | \$ (10,800)        |
| <b>Subtotal</b> |       |     |          | <b>\$ (13,411)</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 17,400**

**Table C.4**

**PWS Name** *Grasslands*  
**Alternative Name** *New Well at Briar Meadows*  
**Alternative Number** *GL-4*

Distance from PWS to new well location 6.08 miles  
 Estimated well depth 215 feet  
 Number of wells required 1  
 Well installation cost (location specific) \$25 per foot  
 Number of pump stations needed 1

**Capital Costs**

| Cost Item                      | Quantity | Unit | Unit Cost | Total Cost          |
|--------------------------------|----------|------|-----------|---------------------|
| <i>Pipeline Construction</i>   |          |      |           |                     |
| Number of Crossings, bore      | 15       | n/a  | n/a       | n/a                 |
| Number of Crossings, open cut  | 3        | n/a  | n/a       | n/a                 |
| PVC water line, Class 200, 04" | 32,080   | LF   | \$ 26     | \$ 834,080          |
| Bore and encasement, 10"       | 3,000    | LF   | \$ 60     | \$ 180,000          |
| Open cut and encasement, 10"   | 150      | LF   | \$ 30     | \$ 4,500            |
| Gate valve and box, 04"        | 6        | EA   | \$ 340    | \$ 2,181            |
| Air valve                      | 6        | EA   | \$ 1,000  | \$ 6,000            |
| Flush valve                    | 6        | EA   | \$ 750    | \$ 4,812            |
| Metal detectable tape          | 32,080   | LF   | \$ 0.15   | \$ 4,812            |
| <b>Subtotal</b>                |          |      |           | <b>\$ 1,036,385</b> |

*Pump Station(s) Installation*

|                            |   |    |           |                  |
|----------------------------|---|----|-----------|------------------|
| Pump                       | 2 | EA | \$ 7,500  | \$ 15,000        |
| Pump Station Piping, 04"   | 1 | EA | \$ 4,000  | \$ 4,000         |
| Gate valve, 04"            | 4 | EA | \$ 370    | \$ 1,480         |
| Check valve, 04"           | 2 | EA | \$ 430    | \$ 860           |
| Electrical/Instrumentation | 1 | EA | \$ 10,000 | \$ 10,000        |
| Site work                  | 1 | EA | \$ 2,000  | \$ 2,000         |
| Building pad               | 1 | EA | \$ 4,000  | \$ 4,000         |
| Pump Building              | 1 | EA | \$ 10,000 | \$ 10,000        |
| Fence                      | 1 | EA | \$ 5,870  | \$ 5,870         |
| Tools                      | 1 | EA | \$ 1,000  | \$ 1,000         |
| Storage Tank - 5,000 gals  | 1 | EA | \$ 7,025  | \$ 7,025         |
| <b>Subtotal</b>            |   |    |           | <b>\$ 61,235</b> |

*Well Installation*

|                                 |     |    |          |                  |
|---------------------------------|-----|----|----------|------------------|
| Well installation               | 215 | LF | \$ 25    | \$ 5,375         |
| Water quality testing           | 2   | EA | \$ 1,500 | \$ 3,000         |
| Well pump                       | 1   | EA | \$ 7,500 | \$ 7,500         |
| Well electrical/instrumentation | 1   | EA | \$ 5,000 | \$ 5,000         |
| Well cover and base             | 1   | EA | \$ 3,000 | \$ 3,000         |
| Piping                          | 1   | EA | \$ 2,500 | \$ 2,500         |
| <b>Subtotal</b>                 |     |    |          | <b>\$ 26,375</b> |

**Subtotal of Component Costs** **\$ 1,123,995**

Contingency 20% \$ 224,799  
 Design & Constr Management 25% \$ 280,999

**TOTAL CAPITAL COSTS** **\$ 1,629,793**

**Annual Operations and Maintenance Costs**

| Cost Item               | Quantity | Unit | Unit Cost | Total Cost      |
|-------------------------|----------|------|-----------|-----------------|
| <i>Pipeline O&amp;M</i> |          |      |           |                 |
| Pipeline O&M            | 6.1      | mile | \$ 200    | \$ 1,215        |
| <b>Subtotal</b>         |          |      |           | <b>\$ 1,215</b> |

*Pump Station(s) O&M*

|                 |        |     |          |                  |
|-----------------|--------|-----|----------|------------------|
| Building Power  | 11,800 | kWH | \$ 0.136 | \$ 1,605         |
| Pump Power      | 30,200 | kWH | \$ 0.136 | \$ 4,107         |
| Materials       | 1      | EA  | \$ 1,200 | \$ 1,200         |
| Labor           | 365    | Hrs | \$ 30    | \$ 10,950        |
| Tank O&M        | 1      | EA  | \$ 1,000 | \$ 1,000         |
| <b>Subtotal</b> |        |     |          | <b>\$ 18,862</b> |

*Well O&M*

|                 |       |     |          |                 |
|-----------------|-------|-----|----------|-----------------|
| Pump power      | 1,075 | kWH | \$ 0.136 | \$ 146          |
| Well O&M matl   | 1     | EA  | \$ 1,200 | \$ 1,200        |
| Well O&M labor  | 180   | Hrs | \$ 30    | \$ 5,400        |
| <b>Subtotal</b> |       |     |          | <b>\$ 6,746</b> |

*O&M Credit for Existing Well Closure*

|                 |       |     |          |                    |
|-----------------|-------|-----|----------|--------------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ (211)           |
| Well O&M matl   | 2     | EA  | \$ 1,200 | \$ (2,400)         |
| Well O&M labor  | 360   | Hrs | \$ 30    | \$ (10,800)        |
| <b>Subtotal</b> |       |     |          | <b>\$ (13,411)</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 13,413**



**Table C.5**

**PWS Name** *Grasslands*  
**Alternative Name** *New Well at Mammoet LLC*  
**Alternative Number** *GL-5*

Distance from PWS to new well location 3.87 miles  
 Estimated well depth 270 feet  
 Number of wells required 1  
 Well installation cost (location specific) \$25 per foot  
 Number of pump stations needed 1

**Capital Costs**

| Cost Item                      | Quantity | Unit | Unit Cost | Total Cost        |
|--------------------------------|----------|------|-----------|-------------------|
| <i>Pipeline Construction</i>   |          |      |           |                   |
| Number of Crossings, bore      | 6        | n/a  | n/a       | n/a               |
| Number of Crossings, open cut  | 4        | n/a  | n/a       | n/a               |
| PVC water line, Class 200, 04" | 20,428   | LF   | \$ 26     | \$ 531,128        |
| Bore and encasement, 10"       | 1,200    | LF   | \$ 60     | \$ 72,000         |
| Open cut and encasement, 10"   | 200      | LF   | \$ 30     | \$ 6,000          |
| Gate valve and box, 04"        | 4        | EA   | \$ 340    | \$ 1,389          |
| Air valve                      | 4        | EA   | \$ 1,000  | \$ 4,000          |
| Flush valve                    | 4        | EA   | \$ 750    | \$ 3,064          |
| Metal detectable tape          | 20,428   | LF   | \$ 0.15   | \$ 3,064          |
| <b>Subtotal</b>                |          |      |           | <b>\$ 620,646</b> |

*Pump Station(s) Installation*

|                            |   |    |           |                  |
|----------------------------|---|----|-----------|------------------|
| Pump                       | 2 | EA | \$ 7,500  | \$ 15,000        |
| Pump Station Piping, 04"   | 1 | EA | \$ 4,000  | \$ 4,000         |
| Gate valve, 04"            | 4 | EA | \$ 370    | \$ 1,480         |
| Check valve, 04"           | 2 | EA | \$ 430    | \$ 860           |
| Electrical/Instrumentation | 1 | EA | \$ 10,000 | \$ 10,000        |
| Site work                  | 1 | EA | \$ 2,000  | \$ 2,000         |
| Building pad               | 1 | EA | \$ 4,000  | \$ 4,000         |
| Pump Building              | 1 | EA | \$ 10,000 | \$ 10,000        |
| Fence                      | 1 | EA | \$ 5,870  | \$ 5,870         |
| Tools                      | 1 | EA | \$ 1,000  | \$ 1,000         |
| Storage Tank - 5,000 gals  | 1 | EA | \$ 7,025  | \$ 7,025         |
| <b>Subtotal</b>            |   |    |           | <b>\$ 61,235</b> |

*Well Installation*

|                                 |     |    |          |                  |
|---------------------------------|-----|----|----------|------------------|
| Well installation               | 270 | LF | \$ 25    | \$ 6,750         |
| Water quality testing           | 2   | EA | \$ 1,500 | \$ 3,000         |
| Well pump                       | 1   | EA | \$ 7,500 | \$ 7,500         |
| Well electrical/instrumentation | 1   | EA | \$ 5,000 | \$ 5,000         |
| Well cover and base             | 1   | EA | \$ 3,000 | \$ 3,000         |
| Piping                          | 1   | EA | \$ 2,500 | \$ 2,500         |
| <b>Subtotal</b>                 |     |    |          | <b>\$ 27,750</b> |

**Subtotal of Component Costs** **\$ 709,631**

Contingency 20% \$ 141,926  
 Design & Constr Management 25% \$ 177,408

**TOTAL CAPITAL COSTS** **\$ 1,028,964**

**Annual Operations and Maintenance Costs**

| Cost Item               | Quantity | Unit | Unit Cost | Total Cost    |
|-------------------------|----------|------|-----------|---------------|
| <i>Pipeline O&amp;M</i> |          |      |           |               |
| Pipeline O&M            | 3.9      | mile | \$ 200    | \$ 774        |
| <b>Subtotal</b>         |          |      |           | <b>\$ 774</b> |

*Pump Station(s) O&M*

|                 |        |     |          |                  |
|-----------------|--------|-----|----------|------------------|
| Building Power  | 11,800 | kWH | \$ 0.136 | \$ 1,605         |
| Pump Power      | 16,750 | kWH | \$ 0.136 | \$ 2,278         |
| Materials       | 1      | EA  | \$ 1,200 | \$ 1,200         |
| Labor           | 365    | Hrs | \$ 30    | \$ 10,950        |
| Tank O&M        | 1      | EA  | \$ 1,000 | \$ 1,000         |
| <b>Subtotal</b> |        |     |          | <b>\$ 17,033</b> |

*Well O&M*

|                 |       |     |          |                 |
|-----------------|-------|-----|----------|-----------------|
| Pump power      | 1,350 | kWH | \$ 0.136 | \$ 184          |
| Well O&M matl   | 1     | EA  | \$ 1,200 | \$ 1,200        |
| Well O&M labor  | 180   | Hrs | \$ 30    | \$ 5,400        |
| <b>Subtotal</b> |       |     |          | <b>\$ 6,784</b> |

*O&M Credit for Existing Well Closure*

|                 |       |     |          |                    |
|-----------------|-------|-----|----------|--------------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ (211)           |
| Well O&M matl   | 2     | EA  | \$ 1,200 | \$ (2,400)         |
| Well O&M labor  | 360   | Hrs | \$ 30    | \$ (10,800)        |
| <b>Subtotal</b> |       |     |          | <b>\$ (13,411)</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 11,179**

**Table C.6**

**PWS Name** *Grasslands*  
**Alternative Name** *New Well at Oak Bend*  
**Alternative Number** *GL-6*

Distance from PWS to new well location 11.33 miles  
 Estimated well depth 150 feet  
 Number of wells required 1  
 Well installation cost (location specific) \$25 per foot  
 Number of pump stations needed 1

**Capital Costs**

| Cost Item                      | Quantity | Unit | Unit Cost | Total Cost          |
|--------------------------------|----------|------|-----------|---------------------|
| <i>Pipeline Construction</i>   |          |      |           |                     |
| Number of Crossings, bore      | 20       | n/a  | n/a       | n/a                 |
| Number of Crossings, open cut  | 6        | n/a  | n/a       | n/a                 |
| PVC water line, Class 200, 04" | 59,799   | LF   | \$ 26     | \$ 1,554,774        |
| Bore and encasement, 10"       | 4,000    | LF   | \$ 60     | \$ 240,000          |
| Open cut and encasement, 10"   | 300      | LF   | \$ 30     | \$ 9,000            |
| Gate valve and box, 04"        | 12       | EA   | \$ 340    | \$ 4,066            |
| Air valve                      | 11       | EA   | \$ 1,000  | \$ 11,000           |
| Flush valve                    | 12       | EA   | \$ 750    | \$ 8,970            |
| Metal detectable tape          | 59,799   | LF   | \$ 0.15   | \$ 8,970            |
| <b>Subtotal</b>                |          |      |           | <b>\$ 1,836,780</b> |

*Pump Station(s) Installation*

|                            |   |    |           |                  |
|----------------------------|---|----|-----------|------------------|
| Pump                       | 2 | EA | \$ 7,500  | \$ 15,000        |
| Pump Station Piping, 04"   | 1 | EA | \$ 4,000  | \$ 4,000         |
| Gate valve, 04"            | 4 | EA | \$ 370    | \$ 1,480         |
| Check valve, 04"           | 2 | EA | \$ 430    | \$ 860           |
| Electrical/Instrumentation | 1 | EA | \$ 10,000 | \$ 10,000        |
| Site work                  | 1 | EA | \$ 2,000  | \$ 2,000         |
| Building pad               | 1 | EA | \$ 4,000  | \$ 4,000         |
| Pump Building              | 1 | EA | \$ 10,000 | \$ 10,000        |
| Fence                      | 1 | EA | \$ 5,870  | \$ 5,870         |
| Tools                      | 1 | EA | \$ 1,000  | \$ 1,000         |
| Storage Tank - 5,000 gals  | 1 | EA | \$ 7,025  | \$ 7,025         |
| <b>Subtotal</b>            |   |    |           | <b>\$ 61,235</b> |

*Well Installation*

|                                 |     |    |          |                  |
|---------------------------------|-----|----|----------|------------------|
| Well installation               | 150 | LF | \$ 25    | \$ 3,750         |
| Water quality testing           | 2   | EA | \$ 1,500 | \$ 3,000         |
| Well pump                       | 1   | EA | \$ 7,500 | \$ 7,500         |
| Well electrical/instrumentation | 1   | EA | \$ 5,000 | \$ 5,000         |
| Well cover and base             | 1   | EA | \$ 3,000 | \$ 3,000         |
| Piping                          | 1   | EA | \$ 2,500 | \$ 2,500         |
| <b>Subtotal</b>                 |     |    |          | <b>\$ 24,750</b> |

**Subtotal of Component Costs** **\$ 1,922,765**

Contingency 20% \$ 384,553  
 Design & Constr Management 25% \$ 480,691

**TOTAL CAPITAL COSTS** **\$ 2,788,009**

**Annual Operations and Maintenance Costs**

| Cost Item               | Quantity | Unit | Unit Cost | Total Cost      |
|-------------------------|----------|------|-----------|-----------------|
| <i>Pipeline O&amp;M</i> |          |      |           |                 |
| Pipeline O&M            | 11.3     | mile | \$ 200    | \$ 2,265        |
| <b>Subtotal</b>         |          |      |           | <b>\$ 2,265</b> |

*Pump Station(s) O&M*

|                 |        |     |          |                  |
|-----------------|--------|-----|----------|------------------|
| Building Power  | 11,800 | kWH | \$ 0.136 | \$ 1,605         |
| Pump Power      | 52,250 | kWH | \$ 0.136 | \$ 7,106         |
| Materials       | 1      | EA  | \$ 1,200 | \$ 1,200         |
| Labor           | 365    | Hrs | \$ 30    | \$ 10,950        |
| Tank O&M        | 1      | EA  | \$ 1,000 | \$ 1,000         |
| <b>Subtotal</b> |        |     |          | <b>\$ 21,861</b> |

*Well O&M*

|                 |     |     |          |                 |
|-----------------|-----|-----|----------|-----------------|
| Pump power      | 750 | kWH | \$ 0.136 | \$ 102          |
| Well O&M matl   | 1   | EA  | \$ 1,200 | \$ 1,200        |
| Well O&M labor  | 180 | Hrs | \$ 30    | \$ 5,400        |
| <b>Subtotal</b> |     |     |          | <b>\$ 6,702</b> |

*O&M Credit for Existing Well Closure*

|                 |       |     |          |                    |
|-----------------|-------|-----|----------|--------------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ (211)           |
| Well O&M matl   | 2     | EA  | \$ 1,200 | \$ (2,400)         |
| Well O&M labor  | 360   | Hrs | \$ 30    | \$ (10,800)        |
| <b>Subtotal</b> |       |     |          | <b>\$ (13,411)</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 17,417**

**Table C.7**

**PWS Name** *Grasslands*  
**Alternative Name** *New Well at Sienna Plantation*  
**Alternative Number** *GL-7*

**Distance from PWS to new well location** 15.47 miles  
**Estimated well depth** 950 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 2

**Capital Costs**

| Cost Item                      | Quantity | Unit | Unit Cost | Total Cost          |
|--------------------------------|----------|------|-----------|---------------------|
| <i>Pipeline Construction</i>   |          |      |           |                     |
| Number of Crossings, bore      | 12       | n/a  | n/a       | n/a                 |
| Number of Crossings, open cut  | 15       | n/a  | n/a       | n/a                 |
| PVC water line, Class 200, 04" | 81,699   | LF   | \$ 26     | \$ 2,124,174        |
| Bore and encasement, 10"       | 2,400    | LF   | \$ 60     | \$ 144,000          |
| Open cut and encasement, 10"   | 750      | LF   | \$ 30     | \$ 22,500           |
| Gate valve and box, 04"        | 16       | EA   | \$ 340    | \$ 5,556            |
| Air valve                      | 15       | EA   | \$ 1,000  | \$ 15,000           |
| Flush valve                    | 16       | EA   | \$ 750    | \$ 12,255           |
| Metal detectable tape          | 81,699   | LF   | \$ 0.15   | \$ 12,255           |
| <b>Subtotal</b>                |          |      |           | <b>\$ 2,335,739</b> |

*Pump Station(s) Installation*

|                            |   |    |           |                   |
|----------------------------|---|----|-----------|-------------------|
| Pump                       | 4 | EA | \$ 7,500  | \$ 30,000         |
| Pump Station Piping, 04"   | 2 | EA | \$ 4,000  | \$ 8,000          |
| Gate valve, 04"            | 8 | EA | \$ 370    | \$ 2,960          |
| Check valve, 04"           | 4 | EA | \$ 430    | \$ 1,720          |
| Electrical/Instrumentation | 2 | EA | \$ 10,000 | \$ 20,000         |
| Site work                  | 2 | EA | \$ 2,000  | \$ 4,000          |
| Building pad               | 2 | EA | \$ 4,000  | \$ 8,000          |
| Pump Building              | 2 | EA | \$ 10,000 | \$ 20,000         |
| Fence                      | 2 | EA | \$ 5,870  | \$ 11,740         |
| Tools                      | 2 | EA | \$ 1,000  | \$ 2,000          |
| Storage Tank - 5,000 gals  | 2 | EA | \$ 7,025  | \$ 14,050         |
| <b>Subtotal</b>            |   |    |           | <b>\$ 122,470</b> |

*Well Installation*

|                                 |     |    |          |                  |
|---------------------------------|-----|----|----------|------------------|
| Well installation               | 950 | LF | \$ 25    | \$ 23,750        |
| Water quality testing           | 2   | EA | \$ 1,500 | \$ 3,000         |
| Well pump                       | 1   | EA | \$ 7,500 | \$ 7,500         |
| Well electrical/instrumentation | 1   | EA | \$ 5,000 | \$ 5,000         |
| Well cover and base             | 1   | EA | \$ 3,000 | \$ 3,000         |
| Piping                          | 1   | EA | \$ 2,500 | \$ 2,500         |
| <b>Subtotal</b>                 |     |    |          | <b>\$ 44,750</b> |

**Subtotal of Component Costs** **\$ 2,502,959**

Contingency 20% \$ 500,592  
Design & Constr Management 25% \$ 625,740

**TOTAL CAPITAL COSTS** **\$ 3,629,291**

**Annual Operations and Maintenance Costs**

| Cost Item               | Quantity | Unit | Unit Cost | Total Cost      |
|-------------------------|----------|------|-----------|-----------------|
| <i>Pipeline O&amp;M</i> |          |      |           |                 |
| Pipeline O&M            | 15.5     | mile | \$ 200    | \$ 3,095        |
| <b>Subtotal</b>         |          |      |           | <b>\$ 3,095</b> |

*Pump Station(s) O&M*

|                 |        |     |          |                  |
|-----------------|--------|-----|----------|------------------|
| Building Power  | 23,600 | kWH | \$ 0.136 | \$ 3,210         |
| Pump Power      | 74,300 | kWH | \$ 0.136 | \$ 10,105        |
| Materials       | 2      | EA  | \$ 1,200 | \$ 2,400         |
| Labor           | 730    | Hrs | \$ 30    | \$ 21,900        |
| Tank O&M        | 2      | EA  | \$ 1,000 | \$ 2,000         |
| <b>Subtotal</b> |        |     |          | <b>\$ 39,614</b> |

*Well O&M*

|                 |       |     |          |                 |
|-----------------|-------|-----|----------|-----------------|
| Pump power      | 4,748 | kWH | \$ 0.136 | \$ 646          |
| Well O&M matl   | 1     | EA  | \$ 1,200 | \$ 1,200        |
| Well O&M labor  | 180   | Hrs | \$ 30    | \$ 5,400        |
| <b>Subtotal</b> |       |     |          | <b>\$ 7,246</b> |

*O&M Credit for Existing Well Closure*

|                 |       |     |          |                    |
|-----------------|-------|-----|----------|--------------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ (211)           |
| Well O&M matl   | 2     | EA  | \$ 1,200 | \$ (2,400)         |
| Well O&M labor  | 360   | Hrs | \$ 30    | \$ (10,800)        |
| <b>Subtotal</b> |       |     |          | <b>\$ (13,411)</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 36,544**

**Table C.8**

**PWS Name** *Grasslands*  
**Alternative Name** *New Well at TCDJ Darrington*  
**Alternative Number** *GL-8*

Distance from PWS to new well location 5.56 miles  
 Estimated well depth 600 feet  
 Number of wells required 1  
 Well installation cost (location specific) \$25 per foot  
 Number of pump stations needed 1

**Capital Costs**

| Cost Item                      | Quantity | Unit | Unit Cost | Total Cost        |
|--------------------------------|----------|------|-----------|-------------------|
| <i>Pipeline Construction</i>   |          |      |           |                   |
| Number of Crossings, bore      | 3        | n/a  | n/a       | n/a               |
| Number of Crossings, open cut  | 3        | n/a  | n/a       | n/a               |
| PVC water line, Class 200, 04" | 29,361   | LF   | \$ 26     | \$ 763,386        |
| Bore and encasement, 10"       | 600      | LF   | \$ 60     | \$ 36,000         |
| Open cut and encasement, 10"   | 150      | LF   | \$ 30     | \$ 4,500          |
| Gate valve and box, 04"        | 6        | EA   | \$ 340    | \$ 1,997          |
| Air valve                      | 6        | EA   | \$ 1,000  | \$ 6,000          |
| Flush valve                    | 6        | EA   | \$ 750    | \$ 4,404          |
| Metal detectable tape          | 29,361   | LF   | \$ 0.15   | \$ 4,404          |
| <b>Subtotal</b>                |          |      |           | <b>\$ 820,691</b> |

*Pump Station(s) Installation*

|                            |   |    |           |                  |
|----------------------------|---|----|-----------|------------------|
| Pump                       | 2 | EA | \$ 7,500  | \$ 15,000        |
| Pump Station Piping, 04"   | 1 | EA | \$ 4,000  | \$ 4,000         |
| Gate valve, 04"            | 4 | EA | \$ 370    | \$ 1,480         |
| Check valve, 04"           | 2 | EA | \$ 430    | \$ 860           |
| Electrical/Instrumentation | 1 | EA | \$ 10,000 | \$ 10,000        |
| Site work                  | 1 | EA | \$ 2,000  | \$ 2,000         |
| Building pad               | 1 | EA | \$ 4,000  | \$ 4,000         |
| Pump Building              | 1 | EA | \$ 10,000 | \$ 10,000        |
| Fence                      | 1 | EA | \$ 5,870  | \$ 5,870         |
| Tools                      | 1 | EA | \$ 1,000  | \$ 1,000         |
| Storage Tank - 5,000 gals  | 1 | EA | \$ 7,025  | \$ 7,025         |
| <b>Subtotal</b>            |   |    |           | <b>\$ 61,235</b> |

*Well Installation*

|                                 |     |    |          |                  |
|---------------------------------|-----|----|----------|------------------|
| Well installation               | 600 | LF | \$ 25    | \$ 15,000        |
| Water quality testing           | 2   | EA | \$ 1,500 | \$ 3,000         |
| Well pump                       | 1   | EA | \$ 7,500 | \$ 7,500         |
| Well electrical/instrumentation | 1   | EA | \$ 5,000 | \$ 5,000         |
| Well cover and base             | 1   | EA | \$ 3,000 | \$ 3,000         |
| Piping                          | 1   | EA | \$ 2,500 | \$ 2,500         |
| <b>Subtotal</b>                 |     |    |          | <b>\$ 36,000</b> |

**Subtotal of Component Costs** **\$ 917,926**

Contingency 20% \$ 183,585  
 Design & Constr Management 25% \$ 229,481

**TOTAL CAPITAL COSTS** **\$ 1,330,992**

**Annual Operations and Maintenance Costs**

| Cost Item               | Quantity | Unit | Unit Cost | Total Cost      |
|-------------------------|----------|------|-----------|-----------------|
| <i>Pipeline O&amp;M</i> |          |      |           |                 |
| Pipeline O&M            | 5.6      | mile | \$ 200    | \$ 1,112        |
| <b>Subtotal</b>         |          |      |           | <b>\$ 1,112</b> |

*Pump Station(s) O&M*

|                 |        |     |          |                  |
|-----------------|--------|-----|----------|------------------|
| Building Power  | 11,800 | kWH | \$ 0.136 | \$ 1,605         |
| Pump Power      | 30,100 | kWH | \$ 0.136 | \$ 4,094         |
| Materials       | 1      | EA  | \$ 1,200 | \$ 1,200         |
| Labor           | 365    | Hrs | \$ 30    | \$ 10,950        |
| Tank O&M        | 1      | EA  | \$ 1,000 | \$ 1,000         |
| <b>Subtotal</b> |        |     |          | <b>\$ 18,848</b> |

*Well O&M*

|                 |       |     |          |                 |
|-----------------|-------|-----|----------|-----------------|
| Pump power      | 2,999 | kWH | \$ 0.136 | \$ 408          |
| Well O&M matl   | 1     | EA  | \$ 1,200 | \$ 1,200        |
| Well O&M labor  | 180   | Hrs | \$ 30    | \$ 5,400        |
| <b>Subtotal</b> |       |     |          | <b>\$ 7,008</b> |

*O&M Credit for Existing Well Closure*

|                 |       |     |          |                    |
|-----------------|-------|-----|----------|--------------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ (211)           |
| Well O&M matl   | 2     | EA  | \$ 1,200 | \$ (2,400)         |
| Well O&M labor  | 360   | Hrs | \$ 30    | \$ (10,800)        |
| <b>Subtotal</b> |       |     |          | <b>\$ (13,411)</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 13,558**

**Table C.9**

**PWS Name** *Grasslands*  
**Alternative Name** *New Well at TCDJ Ramsey*  
**Alternative Number** *GL-9*

Distance from PWS to new well location 10.04 miles  
 Estimated well depth 270 feet  
 Number of wells required 1  
 Well installation cost (location specific) \$25 per foot  
 Number of pump stations needed 1

**Capital Costs**

| Cost Item                      | Quantity | Unit | Unit Cost | Total Cost          |
|--------------------------------|----------|------|-----------|---------------------|
| <i>Pipeline Construction</i>   |          |      |           |                     |
| Number of Crossings, bore      | 16       | n/a  | n/a       | n/a                 |
| Number of Crossings, open cut  | 9        | n/a  | n/a       | n/a                 |
| PVC water line, Class 200, 04" | 53,025   | LF   | \$ 26     | \$ 1,378,650        |
| Bore and encasement, 10"       | 3,200    | LF   | \$ 60     | \$ 192,000          |
| Open cut and encasement, 10"   | 450      | LF   | \$ 30     | \$ 13,500           |
| Gate valve and box, 04"        | 11       | EA   | \$ 340    | \$ 3,606            |
| Air valve                      | 10       | EA   | \$ 1,000  | \$ 10,000           |
| Flush valve                    | 11       | EA   | \$ 750    | \$ 7,954            |
| Metal detectable tape          | 53,025   | LF   | \$ 0.15   | \$ 7,954            |
| <b>Subtotal</b>                |          |      |           | <b>\$ 1,613,663</b> |

*Pump Station(s) Installation*

|                            |   |    |           |                  |
|----------------------------|---|----|-----------|------------------|
| Pump                       | 2 | EA | \$ 7,500  | \$ 15,000        |
| Pump Station Piping, 04"   | 1 | EA | \$ 4,000  | \$ 4,000         |
| Gate valve, 04"            | 4 | EA | \$ 370    | \$ 1,480         |
| Check valve, 04"           | 2 | EA | \$ 430    | \$ 860           |
| Electrical/Instrumentation | 1 | EA | \$ 10,000 | \$ 10,000        |
| Site work                  | 1 | EA | \$ 2,000  | \$ 2,000         |
| Building pad               | 1 | EA | \$ 4,000  | \$ 4,000         |
| Pump Building              | 1 | EA | \$ 10,000 | \$ 10,000        |
| Fence                      | 1 | EA | \$ 5,870  | \$ 5,870         |
| Tools                      | 1 | EA | \$ 1,000  | \$ 1,000         |
| Storage Tank - 5,000 gals  | 1 | EA | \$ 7,025  | \$ 7,025         |
| <b>Subtotal</b>            |   |    |           | <b>\$ 61,235</b> |

*Well Installation*

|                                 |     |    |          |                  |
|---------------------------------|-----|----|----------|------------------|
| Well installation               | 270 | LF | \$ 25    | \$ 6,750         |
| Water quality testing           | 2   | EA | \$ 1,500 | \$ 3,000         |
| Well pump                       | 1   | EA | \$ 7,500 | \$ 7,500         |
| Well electrical/instrumentation | 1   | EA | \$ 5,000 | \$ 5,000         |
| Well cover and base             | 1   | EA | \$ 3,000 | \$ 3,000         |
| Piping                          | 1   | EA | \$ 2,500 | \$ 2,500         |
| <b>Subtotal</b>                 |     |    |          | <b>\$ 27,750</b> |

**Subtotal of Component Costs** **\$ 1,702,648**

Contingency 20% \$ 340,530  
 Design & Constr Management 25% \$ 425,662

**TOTAL CAPITAL COSTS** **\$ 2,468,840**

**Annual Operations and Maintenance Costs**

| Cost Item               | Quantity | Unit | Unit Cost | Total Cost      |
|-------------------------|----------|------|-----------|-----------------|
| <i>Pipeline O&amp;M</i> |          |      |           |                 |
| Pipeline O&M            | 10.0     | mile | \$ 200    | \$ 2,009        |
| <b>Subtotal</b>         |          |      |           | <b>\$ 2,009</b> |

*Pump Station(s) O&M*

|                 |        |     |          |                  |
|-----------------|--------|-----|----------|------------------|
| Building Power  | 11,800 | kWH | \$ 0.136 | \$ 1,605         |
| Pump Power      | 48,100 | kWH | \$ 0.136 | \$ 6,542         |
| Materials       | 1      | EA  | \$ 1,200 | \$ 1,200         |
| Labor           | 365    | Hrs | \$ 30    | \$ 10,950        |
| Tank O&M        | 1      | EA  | \$ 1,000 | \$ 1,000         |
| <b>Subtotal</b> |        |     |          | <b>\$ 21,296</b> |

*Well O&M*

|                 |       |     |          |                 |
|-----------------|-------|-----|----------|-----------------|
| Pump power      | 1,350 | kWH | \$ 0.136 | \$ 184          |
| Well O&M matl   | 1     | EA  | \$ 1,200 | \$ 1,200        |
| Well O&M labor  | 180   | Hrs | \$ 30    | \$ 5,400        |
| <b>Subtotal</b> |       |     |          | <b>\$ 6,784</b> |

*O&M Credit for Existing Well Closure*

|                 |       |     |          |                    |
|-----------------|-------|-----|----------|--------------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ (211)           |
| Well O&M matl   | 2     | EA  | \$ 1,200 | \$ (2,400)         |
| Well O&M labor  | 360   | Hrs | \$ 30    | \$ (10,800)        |
| <b>Subtotal</b> |       |     |          | <b>\$ (13,411)</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 16,678**

**Table C.10**

**PWS Name**  
**Alternative Name**  
**Alternative Number**

**Grasslands**  
**Central Treatment - Adsorption**  
**GL-10**

**Capital Costs**

| Cost Item                     | Quantity | Unit | Unit Cost  | Total Cost        |
|-------------------------------|----------|------|------------|-------------------|
| <b>Adsorption</b>             |          |      |            |                   |
| Site preparation              | 0.50     | acre | \$ 4,000   | \$ 2,000          |
| Slab                          | 15       | CY   | \$ 1,000   | \$ 15,000         |
| Building                      | 400      | SF   | \$ 60      | \$ 24,000         |
| Building electrical           | 400      | SF   | \$ 8       | \$ 3,200          |
| Building plumbing             | 400      | SF   | \$ 8       | \$ 3,200          |
| Heating and ventilation       | 400      | SF   | \$ 7       | \$ 2,800          |
| Fence                         | 300      | LF   | \$ 15      | \$ 4,500          |
| Paving                        | 1,600    | SF   | \$ 2       | \$ 3,200          |
| Electrical                    | 1        | JOB  | \$ 50,000  | \$ 50,000         |
| Piping                        | 1        | JOB  | \$ 20,000  | \$ 20,000         |
| Adsorption package including: |          |      |            |                   |
| 4 Adsorption vessels          |          |      |            |                   |
| E33 Iron oxide media          |          |      |            |                   |
| Controls & Instruments        | 1        | UNIT | \$ 115,000 | \$ 115,000        |
| Backwash Tank                 | 5,000    | GAL  | \$ 2.00    | \$ 10,000         |
| Sewer Connection Fee          | 1        | EA   | \$ 15,000  | \$ 15,000         |
| Chlorination Point            | 1        | EA   | \$ 2,000   | \$ 2,000          |
| <b>Subtotal</b>               |          |      |            | <b>\$ 269,900</b> |
| Contingency                   |          |      |            | 53,980            |
| Design & CM                   |          |      |            | 67,475            |
| <b>Total</b>                  |          |      |            | <b>\$ 391,355</b> |

**Annual Operations and Maintenance Costs**

| Cost Item                   | Quantity | Unit   | Unit Cost | Total Cost       |
|-----------------------------|----------|--------|-----------|------------------|
| <b>O&amp;M</b>              |          |        |           |                  |
| Building Power              | 6,000    | kwh/yr | \$ 0.136  | \$ 816           |
| Equipment power             | 1000     | kwh/yr | \$ 0.136  | \$ 136           |
| Labor                       | 500      | hrs/yr | \$ 40     | \$ 20,000        |
| Materials                   | 1        | year   | \$ 14,000 | \$ 14,000        |
| Analyses                    | 24       | test   | \$ 200    | \$ 4,800         |
| Backwash discharge to sewer | 0.53     | MG/yr  | \$ 2,000  | \$ 1,060         |
| Spent Media Disposal        | 6        | CY     | \$ 20     | \$ 120           |
| <b>Subtotal</b>             |          |        |           | <b>\$ 40,932</b> |
| <b>Total</b>                |          |        |           | <b>\$ 40,932</b> |

**Table C.11**

**PWS Name** *Grasslands*  
**Alternative Name** *Central Treatment - Coag-Filt*  
**Alternative Number** *GL-11*

**Capital Costs**

| Cost Item                             | Quantity | Unit | Unit Cost         | Total Cost |
|---------------------------------------|----------|------|-------------------|------------|
| <b>Central-Coagulation/Filtration</b> |          |      |                   |            |
| Site preparation                      | 0.50     | acre | \$ 4,000          | \$ 2,000   |
| Slab                                  | 15       | CY   | \$ 1,000          | \$ 15,000  |
| Building                              | 400      | SF   | \$ 60             | \$ 24,000  |
| Building electrical                   | 400      | SF   | \$ 8              | \$ 3,200   |
| Building plumbing                     | 400      | SF   | \$ 8              | \$ 3,200   |
| Heating and ventilation               | 400      | SF   | \$ 7              | \$ 2,800   |
| Fence                                 | 300      | LF   | \$ 15             | \$ 4,500   |
| Paving                                | 1,600    | SF   | \$ 2              | \$ 3,200   |
| Electrical                            | 1        | JOB  | \$ 30,000         | \$ 30,000  |
| Piping                                | 1        | JOB  | \$ 10,000         | \$ 10,000  |
| Coagulant/Filter package including:   |          |      |                   |            |
| Chemical feed system                  |          |      |                   |            |
| Pressure ceramic filters              |          |      |                   |            |
| Controls & Instruments                | 1        | UNIT | \$ 89,700         | \$ 89,700  |
| Backwash Tank                         | 5,000    | GAL  | \$ 2.00           | \$ 10,000  |
| Sewer Connection Fee                  | 1        | EA   | \$ 15,000         | \$ 15,000  |
| Chlorination Point                    | 1        | EA   | \$ 2,000          | \$ 2,000   |
| Coagulant Tank                        | 500      | GAL  | \$ 3              | \$ 1,500   |
| <b>Subtotal</b>                       |          |      | <b>\$ 216,100</b> |            |
| Contingency                           |          |      | 43,220            |            |
| Design & CM                           |          |      | 54,025            |            |
| <b>Total</b>                          |          |      | <b>\$ 313,345</b> |            |

**Annual Operations and Maintenance Costs**

| Cost Item                   | Quantity | Unit   | Unit Cost | Total Cost       |
|-----------------------------|----------|--------|-----------|------------------|
| <b>O&amp;M</b>              |          |        |           |                  |
| Building Power              | 6,000    | kwh/yr | \$ 0.136  | \$ 816           |
| Equipment power             | 1000     | kwh/yr | \$ 0.136  | \$ 136           |
| Labor                       | 1,000    | hrs/yr | \$ 40     | \$ 40,000        |
| Materials                   | 1        | year   | \$ 2,000  | \$ 2,000         |
| Chemicals                   | 1        | year   | \$ 2,000  | \$ 2,000         |
| Analyses                    | 24       | test   | \$ 200    | \$ 4,800         |
| Backwash discharge to sewer | 5.3      | MG/yr  | \$ 2,000  | \$ 10,600        |
| <b>Subtotal</b>             |          |        |           | <b>\$ 60,352</b> |
| <b>Total</b>                |          |        |           | <b>\$ 60,352</b> |

**Table C.12**

**PWS Name** *Grasslands*  
**Alternative Name** *Point-of-Use Treatment*  
**Alternative Number** *GL-12*

Number of Connections for POU Unit Installation 150

**Capital Costs**

| Cost Item                                    | Quantity | Unit | Unit Cost | Total Cost       |
|--|----------|------|-----------|------------------|
| <i>POU-Treatment - Purchase/Installation</i> |          |      |           |                  |
| POU treatment unit purchase                  | 150      | EA   | \$ 250    | \$ 37,500        |
| POU treatment unit installation              | 150      | EA   | \$ 150    | \$ 22,500        |
| <b>Subtotal</b>                              |          |      |           | <b>\$ 60,000</b> |
| <b>Subtotal of Component Costs</b>           |          |      |           | <b>\$ 60,000</b> |
| Contingency                                  | 20%      |      |           | \$ 12,000        |
| Design & Constr Management                   | 25%      |      |           | \$ 15,000        |
| Procurement & Administration                 | 20%      |      |           | \$ 12,000        |
| <b>TOTAL CAPITAL COSTS</b>                   |          |      |           | <b>\$ 99,000</b> |

**Annual Operations and Maintenance Costs**

| Cost Item                           | Quantity | Unit | Unit Cost | Total Cost       |
|-------------------------------------|----------|------|-----------|------------------|
| <i>O&amp;M</i>                      |          |      |           |                  |
| POU materials, per unit             | 150      | EA   | \$ 225    | \$ 33,750        |
| Contaminant analysis, 1/yr per unit | 150      | EA   | \$ 100    | \$ 15,000        |
| Program labor, 10 hrs/unit          | 1,500    | hrs  | \$ 30     | \$ 45,000        |
| <b>Subtotal</b>                     |          |      |           | <b>\$ 93,750</b> |
| <b>TOTAL ANNUAL O&amp;M COSTS</b>   |          |      |           | <b>\$ 93,750</b> |



**Table C.13**

**PWS Name** *Grasslands*  
**Alternative Name** *Point-of-Entry Treatment*  
**Alternative Number** *GL-13*

**Number of Connections for POE Unit Installation** 150

**Capital Costs**

| <b>Cost Item</b>                             | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b>   |
|--|-----------------|-------------|------------------|---------------------|
| <i>POE-Treatment - Purchase/Installation</i> |                 |             |                  |                     |
| POE treatment unit purchase                  | 150             | EA          | \$ 3,000         | \$ 450,000          |
| Pad and shed, per unit                       | 150             | EA          | \$ 2,000         | \$ 300,000          |
| Piping connection, per unit                  | 150             | EA          | \$ 1,000         | \$ 150,000          |
| Electrical hook-up, per unit                 | 150             | EA          | \$ 1,000         | \$ 150,000          |
| <b>Subtotal</b>                              |                 |             |                  | <b>\$ 1,050,000</b> |

**Subtotal of Component Costs** **\$ 1,050,000**

|                              |     |            |
|------------------------------|-----|------------|
| Contingency                  | 20% | \$ 210,000 |
| Design & Constr Management   | 25% | \$ 262,500 |
| Procurement & Administration | 20% | \$ 210,000 |

**TOTAL CAPITAL COSTS** **\$ 1,732,500**

**Annual Operations and Maintenance Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>O&amp;M</i>                      |                 |             |                  |                   |
| POE materials, per unit             | 150             | EA          | \$ 1,000         | \$ 150,000        |
| Contaminant analysis, 1/yr per unit | 150             | EA          | \$ 100           | \$ 15,000         |
| Program labor, 10 hrs/unit          | 1,500           | hrs         | \$ 30            | \$ 45,000         |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 210,000</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 210,000**

**Table C.14**

**PWS Name** *Grasslands*  
**Alternative Name** *New Well at 10 Miles*  
**Alternative Number** *GL-14*

**Distance from PWS to new well location** 10.0 miles  
**Estimated well depth** 310 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 1

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost | Total Cost          |
|-------------------------------------|----------|------|-----------|---------------------|
| <i>Pipeline Construction</i>        |          |      |           |                     |
| Number of Crossings, bore           | 15       | n/a  | n/a       | n/a                 |
| Number of Crossings, open cut       | 6        | n/a  | n/a       | n/a                 |
| PVC water line, Class 200, 04"      | 52,800   | LF   | \$ 26     | \$ 1,372,800        |
| Bore and encasement, 10"            | 3,000    | LF   | \$ 60     | \$ 180,000          |
| Open cut and encasement, 10"        | 300      | LF   | \$ 30     | \$ 9,000            |
| Gate valve and box, 04"             | 11       | EA   | \$ 340    | \$ 3,590            |
| Air valve                           | 10       | EA   | \$ 1,000  | \$ 10,000           |
| Flush valve                         | 11       | EA   | \$ 750    | \$ 7,920            |
| Metal detectable tape               | 52,800   | LF   | \$ 0.15   | \$ 7,920            |
| <b>Subtotal</b>                     |          |      |           | <b>\$ 1,591,230</b> |
| <i>Pump Station(s) Installation</i> |          |      |           |                     |
| Pump                                | 2        | EA   | \$ 7,500  | \$ 15,000           |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000  | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 370    | \$ 1,480            |
| Check valve, 04"                    | 2        | EA   | \$ 430    | \$ 860              |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000 | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000  | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000  | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000 | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870  | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000  | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025  | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |           | <b>\$ 61,235</b>    |
| <i>Well Installation</i>            |          |      |           |                     |
| Well installation                   | 310      | LF   | \$ 25     | \$ 7,750            |
| Water quality testing               | 2        | EA   | \$ 1,500  | \$ 3,000            |
| Well pump                           | 1        | EA   | \$ 7,500  | \$ 7,500            |
| Well electrical/instrumentation     | 1        | EA   | \$ 5,000  | \$ 5,000            |
| Well cover and base                 | 1        | EA   | \$ 3,000  | \$ 3,000            |
| Piping                              | 1        | EA   | \$ 2,500  | \$ 2,500            |
| <b>Subtotal</b>                     |          |      |           | <b>\$ 28,750</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |           | <b>\$ 1,681,215</b> |
| Contingency                         | 20%      |      |           | \$ 336,243          |
| Design & Constr Management          | 25%      |      |           | \$ 420,304          |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |           | <b>\$ 2,437,762</b> |

**Annual Operations and Maintenance Costs**

| Cost Item                                       | Quantity | Unit | Unit Cost | Total Cost         |
|---|----------|------|-----------|--------------------|
| <i>Pipeline O&amp;M</i>                         |          |      |           |                    |
| Pipeline O&M                                    | 10.0     | mile | \$ 200    | \$ 2,000           |
| <b>Subtotal</b>                                 |          |      |           | <b>\$ 2,000</b>    |
| <i>Pump Station(s) O&amp;M</i>                  |          |      |           |                    |
| Building Power                                  | 11,800   | kWH  | \$ 0.136  | \$ 1,605           |
| Pump Power                                      | 47,761   | kWH  | \$ 0.136  | \$ 6,495           |
| Materials                                       | 1        | EA   | \$ 1,200  | \$ 1,200           |
| Labor   | 365      | Hrs  | \$ 30     | \$ 10,950          |
| Tank O&M  | 1        | EA   | \$ 1,000  | \$ 1,000           |
| <b>Subtotal</b>                                 |          |      |           | <b>\$ 21,250</b>   |
| <i>Well O&amp;M</i>                             |          |      |           |                    |
| Pump power                                      | 1,550    | kWH  | \$ 0.136  | \$ 211             |
| Well O&M matl                                   | 1        | EA   | \$ 1,200  | \$ 1,200           |
| Well O&M labor                                  | 180      | Hrs  | \$ 30     | \$ 5,400           |
| <b>Subtotal</b>                                 |          |      |           | <b>\$ 6,811</b>    |
| <i>O&amp;M Credit for Existing Well Closure</i> |          |      |           |                    |
| Pump power                                      | 1,550    | kWH  | \$ 0.136  | \$ (211)           |
| Well O&M matl                                   | 2        | EA   | \$ 1,200  | \$ (2,400)         |
| Well O&M labor                                  | 360      | Hrs  | \$ 30     | \$ (10,800)        |
| <b>Subtotal</b>                                 |          |      |           | <b>\$ (13,411)</b> |

**TOTAL ANNUAL O&M COSTS****\$ 16,650**

**Table C.15**

**PWS Name** *Grasslands*  
**Alternative Name** *New Well at 5 Miles*  
**Alternative Number** *GL-15*

Distance from PWS to new well location 5.0 miles  
 Estimated well depth 310 feet  
 Number of wells required 1  
 Well installation cost (location specific) \$25 per foot  
 Number of pump stations needed 1

**Capital Costs**

| Cost Item                      | Quantity | Unit | Unit Cost | Total Cost        |
|--------------------------------|----------|------|-----------|-------------------|
| <i>Pipeline Construction</i>   |          |      |           |                   |
| Number of Crossings, bore      | 8        | n/a  | n/a       | n/a               |
| Number of Crossings, open cut  | 3        | n/a  | n/a       | n/a               |
| PVC water line, Class 200, 04" | 26,400   | LF   | \$ 26     | \$ 686,400        |
| Bore and encasement, 10"       | 1,800    | LF   | \$ 60     | \$ 108,000        |
| Open cut and encasement, 10"   | 100      | LF   | \$ 30     | \$ 3,000          |
| Gate valve and box, 04"        | 5        | EA   | \$ 340    | \$ 1,795          |
| Air valve                      | 5        | EA   | \$ 1,000  | \$ 5,000          |
| Flush valve                    | 5        | EA   | \$ 750    | \$ 3,960          |
| Metal detectable tape          | 26,400   | LF   | \$ 0.15   | \$ 3,960          |
| <b>Subtotal</b>                |          |      |           | <b>\$ 812,115</b> |

*Pump Station(s) Installation*

|                            |   |    |           |                  |
|----------------------------|---|----|-----------|------------------|
| Pump                       | 2 | EA | \$ 7,500  | \$ 15,000        |
| Pump Station Piping, 04"   | 1 | EA | \$ 4,000  | \$ 4,000         |
| Gate valve, 04"            | 4 | EA | \$ 370    | \$ 1,480         |
| Check valve, 04"           | 2 | EA | \$ 430    | \$ 860           |
| Electrical/Instrumentation | 1 | EA | \$ 10,000 | \$ 10,000        |
| Site work                  | 1 | EA | \$ 2,000  | \$ 2,000         |
| Building pad               | 1 | EA | \$ 4,000  | \$ 4,000         |
| Pump Building              | 1 | EA | \$ 10,000 | \$ 10,000        |
| Fence                      | 1 | EA | \$ 5,870  | \$ 5,870         |
| Tools                      | 1 | EA | \$ 1,000  | \$ 1,000         |
| Storage Tank - 5,000 gals  | 1 | EA | \$ 7,025  | \$ 7,025         |
| <b>Subtotal</b>            |   |    |           | <b>\$ 61,235</b> |

*Well Installation*

|                                 |     |    |          |                  |
|---------------------------------|-----|----|----------|------------------|
| Well installation               | 310 | LF | \$ 25    | \$ 7,750         |
| Water quality testing           | 2   | EA | \$ 1,500 | \$ 3,000         |
| Well pump                       | 1   | EA | \$ 7,500 | \$ 7,500         |
| Well electrical/instrumentation | 1   | EA | \$ 5,000 | \$ 5,000         |
| Well cover and base             | 1   | EA | \$ 3,000 | \$ 3,000         |
| Piping                          | 1   | EA | \$ 2,500 | \$ 2,500         |
| <b>Subtotal</b>                 |     |    |          | <b>\$ 28,750</b> |

**Subtotal of Component Costs** **\$ 902,100**

Contingency 20% \$ 180,420  
 Design & Constr Management 25% \$ 225,525

**TOTAL CAPITAL COSTS** **\$ 1,308,045**

**Annual Operations and Maintenance Costs**

| Cost Item               | Quantity | Unit | Unit Cost | Total Cost      |
|-------------------------|----------|------|-----------|-----------------|
| <i>Pipeline O&amp;M</i> |          |      |           |                 |
| Pipeline O&M            | 5.0      | mile | \$ 200    | \$ 1,000        |
| <b>Subtotal</b>         |          |      |           | <b>\$ 1,000</b> |

*Pump Station(s) O&M*

|                 |        |     |          |                  |
|-----------------|--------|-----|----------|------------------|
| Building Power  | 11,800 | kWH | \$ 0.136 | \$ 1,605         |
| Pump Power      | 23,880 | kWH | \$ 0.136 | \$ 3,248         |
| Materials       | 1      | EA  | \$ 1,200 | \$ 1,200         |
| Labor           | 365    | Hrs | \$ 30    | \$ 10,950        |
| Tank O&M        | 1      | EA  | \$ 1,000 | \$ 1,000         |
| <b>Subtotal</b> |        |     |          | <b>\$ 18,003</b> |

*Well O&M*

|                 |       |     |          |                 |
|-----------------|-------|-----|----------|-----------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ 211          |
| Well O&M matl   | 1     | EA  | \$ 1,200 | \$ 1,200        |
| Well O&M labor  | 180   | Hrs | \$ 30    | \$ 5,400        |
| <b>Subtotal</b> |       |     |          | <b>\$ 6,811</b> |

*O&M Credit for Existing Well Closure*

|                 |       |     |          |                    |
|-----------------|-------|-----|----------|--------------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ (211)           |
| Well O&M matl   | 2     | EA  | \$ 1,200 | \$ (2,400)         |
| Well O&M labor  | 360   | Hrs | \$ 30    | \$ (10,800)        |
| <b>Subtotal</b> |       |     |          | <b>\$ (13,411)</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 12,403**

**Table C.16**

**PWS Name** *Grasslands*  
**Alternative Name** *New Well at 1 Mile*  
**Alternative Number** *GL-16*

Distance from PWS to new well location 1.0 miles  
 Estimated well depth 310 feet  
 Number of wells required 1  
 Well installation cost (location specific) \$25 per foot  
 Number of pump stations needed 0

**Capital Costs**

| Cost Item                      | Quantity | Unit | Unit Cost | Total Cost        |
|--------------------------------|----------|------|-----------|-------------------|
| <i>Pipeline Construction</i>   |          |      |           |                   |
| Number of Crossings, bore      | 2        | n/a  | n/a       | n/a               |
| Number of Crossings, open cut  | 1        | n/a  | n/a       | n/a               |
| PVC water line, Class 200, 04" | 5,280    | LF   | \$ 26     | \$ 137,280        |
| Bore and encasement, 10"       | 400      | LF   | \$ 60     | \$ 24,000         |
| Open cut and encasement, 10"   | 50       | LF   | \$ 30     | \$ 1,500          |
| Gate valve and box, 04"        | 1        | EA   | \$ 340    | \$ 359            |
| Air valve                      | 1.00     | EA   | \$ 1,000  | \$ 1,000          |
| Flush valve                    | 1        | EA   | \$ 750    | \$ 792            |
| Metal detectable tape          | 5,280    | LF   | \$ 0.15   | \$ 792            |
| <b>Subtotal</b>                |          |      |           | <b>\$ 165,723</b> |

*Pump Station(s) Installation*

|                            |   |    |           |             |
|----------------------------|---|----|-----------|-------------|
| Pump                       | - | EA | \$ 7,500  | \$ -        |
| Pump Station Piping, 04"   | - | EA | \$ 4,000  | \$ -        |
| Gate valve, 04"            | - | EA | \$ 370    | \$ -        |
| Check valve, 04"           | - | EA | \$ 430    | \$ -        |
| Electrical/Instrumentation | - | EA | \$ 10,000 | \$ -        |
| Site work                  | - | EA | \$ 2,000  | \$ -        |
| Building pad               | - | EA | \$ 4,000  | \$ -        |
| Pump Building              | - | EA | \$ 10,000 | \$ -        |
| Fence                      | - | EA | \$ 5,870  | \$ -        |
| Tools                      | - | EA | \$ 1,000  | \$ -        |
| Storage Tank - 5,000 gals  | - | EA | \$ 7,025  | \$ -        |
| <b>Subtotal</b>            |   |    |           | <b>\$ -</b> |

*Well Installation*

|                                 |     |    |          |                  |
|---------------------------------|-----|----|----------|------------------|
| Well installation               | 310 | LF | \$ 25    | \$ 7,750         |
| Water quality testing           | 2   | EA | \$ 1,500 | \$ 3,000         |
| Well pump                       | 1   | EA | \$ 7,500 | \$ 7,500         |
| Well electrical/instrumentation | 1   | EA | \$ 5,000 | \$ 5,000         |
| Well cover and base             | 1   | EA | \$ 3,000 | \$ 3,000         |
| Piping                          | 1   | EA | \$ 2,500 | \$ 2,500         |
| <b>Subtotal</b>                 |     |    |          | <b>\$ 28,750</b> |

**Subtotal of Component Costs** **\$ 194,473**

Contingency 20% \$ 38,895  
 Design & Constr Management 25% \$ 48,618

**TOTAL CAPITAL COSTS** **\$ 281,986**

**Annual Operations and Maintenance Costs**

| Cost Item               | Quantity | Unit | Unit Cost | Total Cost    |
|-------------------------|----------|------|-----------|---------------|
| <i>Pipeline O&amp;M</i> |          |      |           |               |
| Pipeline O&M            | 1.0      | mile | \$ 200    | \$ 200        |
| <b>Subtotal</b>         |          |      |           | <b>\$ 200</b> |

*Pump Station(s) O&M*

|                 |   |     |          |             |
|-----------------|---|-----|----------|-------------|
| Building Power  | - | kWH | \$ 0.136 | \$ -        |
| Pump Power      | - | kWH | \$ 0.136 | \$ -        |
| Materials       | - | EA  | \$ 1,200 | \$ -        |
| Labor           | - | Hrs | \$ 30    | \$ -        |
| Tank O&M        | - | EA  | \$ 1,000 | \$ -        |
| <b>Subtotal</b> |   |     |          | <b>\$ -</b> |

*Well O&M*

|                 |       |     |          |                 |
|-----------------|-------|-----|----------|-----------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ 211          |
| Well O&M matl   | 1     | EA  | \$ 1,200 | \$ 1,200        |
| Well O&M labor  | 180   | Hrs | \$ 30    | \$ 5,400        |
| <b>Subtotal</b> |       |     |          | <b>\$ 6,811</b> |

*O&M Credit for Existing Well Closure*

|                 |       |     |          |                    |
|-----------------|-------|-----|----------|--------------------|
| Pump power      | 1,550 | kWH | \$ 0.136 | \$ (211)           |
| Well O&M matl   | 2     | EA  | \$ 1,200 | \$ (2,400)         |
| Well O&M labor  | 360   | Hrs | \$ 30    | \$ (10,800)        |
| <b>Subtotal</b> |       |     |          | <b>\$ (13,411)</b> |

**TOTAL ANNUAL O&M COSTS** **\$ (6,400)**

**Table C.17**

**PWS Name** *Grasslands*  
**Alternative Name** *Public Dispenser for Treated Drinking Water*  
**Alternative Number** *GL-14*

**Number of Treatment Units Recommended** 1

**Capital Costs**

| <b>Cost Item</b>                          | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|---|-----------------|-------------|------------------|-------------------|
| <i>Public Dispenser Unit Installation</i> |                 |             |                  |                   |
| POE-Treatment unit(s)                     | 1               | EA          | \$ 3,000         | \$ 3,000          |
| Unit installation costs                   | 1               | EA          | \$ 5,000         | \$ 5,000          |
| <b>Subtotal</b>                           |                 |             |                  | <b>\$ 8,000</b>   |
| <b>Subtotal of Component Costs</b>        |                 |             |                  | <b>\$ 8,000</b>   |
| Contingency                               | 20%             |             |                  | \$ 1,600          |
| Design & Constr Management                | 25%             |             |                  | \$ 2,000          |
| <b>TOTAL CAPITAL COSTS</b>                |                 |             |                  | <b>11,600</b>     |

**Annual Operations and Maintenance Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Program Operation</i>            |                 |             |                  |                   |
| Treatment unit O&M, 1 per unit      | 1               | EA          | \$ 500           | \$ 500            |
| Contaminant analysis, 1/wk per unit | 52              | EA          | \$ 100           | \$ 5,200          |
| Sampling/reporting, 1 hr/day        | 365             | HRS         | \$ 30            | \$ 10,950         |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 16,650</b>  |
| <b>TOTAL ANNUAL O&amp;M COSTS</b>   |                 |             |                  | <b>\$ 16,650</b>  |

**Table C.18**

**PWS Name** *Grasslands*  
**Alternative Name** *Supply Bottled Water to Population*  
**Alternative Number** *GL-15*

**Service Population** 450  
**Percentage of population requiring supply** 100%  
**Water consumption per person** 1.00 gpcd  
**Calculated annual potable water needs** 164,250 gallons

**Capital Costs**

| Cost Item                     | Quantity | Unit  | Unit Cost | Total Cost       |
|-------------------------------|----------|-------|-----------|------------------|
| <i>Program Implementation</i> |          |       |           |                  |
| Initial program set-up        | 500      | hours | \$ 40     | \$ 19,950        |
| <b>Subtotal</b>               |          |       |           | <b>\$ 19,950</b> |

**Subtotal of Component Costs** **\$ 19,950**

Contingency 20% \$ 3,990

**TOTAL CAPITAL COSTS** **\$ 23,940**

**Annual Operations and Maintenance Costs**

| Cost Item                | Quantity | Unit  | Unit Cost | Total Cost        |
|--------------------------|----------|-------|-----------|-------------------|
| <i>Program Operation</i> |          |       |           |                   |
| Water purchase costs     | 164,250  | gals  | \$ 1.60   | \$ 262,800        |
| Program admin, 9 hrs/wk  | 468      | hours | \$ 40     | \$ 18,673         |
| Program materials        | 1        | EA    | \$ 5,000  | \$ 5,000          |
| <b>Subtotal</b>          |          |       |           | <b>\$ 286,473</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 286,473**

**Table C.19**

**PWS Name** *Grasslands*  
**Alternative Name** *Central Trucked Drinking Water*  
**Alternative Number** *GL-16*

**Service Population** 450  
**Percentage of population requiring supply** 100%  
**Water consumption per person** 1.00 gpcd  
**Calculated annual potable water needs** 164,250 gallons  
**Travel distance to compliant water source (round trip)** 29 miles

**Capital Costs**

| Cost Item                        | Quantity | Unit | Unit Cost | Total Cost       |
|----------------------------------|----------|------|-----------|------------------|
| <i>Storage Tank Installation</i> |          |      |           |                  |
| Storage Tank - 5,000 gals        | 1        | EA   | \$ 7,025  | \$ 7,025         |
| Site improvements                | 1        | EA   | \$ 4,000  | \$ 4,000         |
| Potable water truck              | 1        | EA   | \$ 60,000 | \$ 60,000        |
| <b>Subtotal</b>                  |          |      |           | <b>\$ 71,025</b> |

**Subtotal of Component Costs** **\$ 71,025**

|                          |     |           |
|--------------------------|-----|-----------|
| Contingency              | 20% | \$ 14,205 |
| Design & Constr Manageme | 25% | \$ 17,756 |

**TOTAL CAPITAL COSTS** **\$ 102,986**

**Annual Operations and Maintenance Costs**

| Cost Item                        | Quantity | Unit       | Unit Cost | Total Cost       |
|----------------------------------|----------|------------|-----------|------------------|
| <i>Program Operation</i>         |          |            |           |                  |
| Water delivery labor, 4 hrs/wk   | 208      | hrs        | \$ 30     | \$ 6,240         |
| Truck operation, 1 round trip/wk | 1,508    | miles      | \$ 1.00   | \$ 1,508         |
| Water purchase                   | 164      | 1,000 gals | \$ 1.80   | \$ 296           |
| Water testing, 1 test/wk         | 52       | EA         | \$ 100    | \$ 5,200         |
| Sampling/reporting, 2 hrs/wk     | 104      | hrs        | \$ 30     | \$ 3,120         |
| <b>Subtotal</b>                  |          |            |           | <b>\$ 16,364</b> |

**TOTAL ANNUAL O&M COSTS** **\$ 16,364**

1  
2

**APPENDIX D  
EXAMPLE FINANCIAL MODEL**



Table D.1 Example Financial Model

Step 1

Water System:

Grasslands

Step 2

Click Here to Update Verification and Raw

|                                    |   |            |                     |    |         |
|------------------------------------|---|------------|---------------------|----|---------|
|                                    |   |            |                     |    |         |
| Water System                       | Grasslands  |            |                     |    |         |
| Alternative Description            | New Well at 1 Mile                                |            |                     |    |         |
| Sum of Amount                      |   | Year       | Funding Alternative |    |         |
|                                    |   |            | 2007                |    |         |
| Group                              | Type  | 100% Grant | Bond                |    |         |
| Capital Expenditures               | Capital Expenditures-Funded from Bonds            | \$         | 500                 | \$ | 282,486 |
|                                    | Capital Expenditures-Funded from Grants           | \$         | 281,986             | \$ | -       |
|                                    | Capital Expenditures-Funded from Revenue/Reserves | \$         | -                   | \$ | -       |
|                                    | Capital Expenditures-Funded from SRF Loans        | \$         | -                   | \$ | -       |
| Capital Expenditures Sum           |   | \$         | 282,486             | \$ | 282,486 |
| Debt Service                       | Revenue Bonds                                     | \$         | 39                  | \$ | 22,098  |
|                                    | State Revolving Funds                             | \$         | -                   | \$ | -       |
| Debt Service Sum                   |   | \$         | 39                  | \$ | 22,098  |
| Operating Expenditures             | Administrative Expenses                           | \$         | 6,771               | \$ | 6,771   |
|                                    | Chemicals, Treatment                              | \$         | 2,034               | \$ | 2,034   |
|                                    | Contract Labor                                    | \$         | 2,360               | \$ | 2,360   |
|                                    | Insurance   | \$         | 1,376               | \$ | 1,376   |
|                                    | Other Operating Expenditures 1                    | \$         | 1,582               | \$ | 1,582   |
|                                    | Other Operating Expenditures 2                    | \$         | 19,257              | \$ | 19,257  |
|                                    | Professional and Directors Fees                   | \$         | 297                 | \$ | 297     |
|                                    | Repairs   | \$         | 2,814               | \$ | 2,814   |
|                                    | Salaries & Benefits                               | \$         | 19,404              | \$ | 19,404  |
|                                    | Supplies  | \$         | 2,814               | \$ | 2,814   |
|                                    | Utilities   | \$         | 8,126               | \$ | 8,126   |
|                                    | Maintenance                                       | \$         | 2,814               | \$ | 2,814   |
|                                    | Accounting and Legal Fees                         | \$         | 115                 | \$ | 115     |
|                                    | Auto and Travel                                   | \$         | 25                  | \$ | 25      |
| Operating Expenditures Sum         |   | \$         | 69,788              | \$ | 69,788  |
| Residential Operating Revenue      | Residential Base Monthly Rate                     | \$         | 42,230              | \$ | 42,230  |
|                                    | Residential Tier 1 Monthly Rate                   | \$         | 20,565              | \$ | 20,565  |
|                                    | Residential Tier2 Monthly Rate                    | \$         | -                   | \$ | -       |
|                                    | Residential Tier3 Monthly Rate                    | \$         | -                   | \$ | -       |
|                                    | Residential Tier4 Monthly Rate                    | \$         | -                   | \$ | -       |
|                                    | Residential Unmetered Monthly Rate                | \$         | -                   | \$ | -       |
| Residential Operating Revenues Sum |   | \$         | 62,795              | \$ | 62,795  |


|               |                              |              |
|---------------|------------------------------|--------------|
| Location Name | Grasslands                   |              |
| Alt_Desc      | New Well at 1 Mile           |              |
|               |                              |              |
|               |                              | Current Year |
| Funding_Alt   | Data                         | 2007         |
| 100% Grant    | Sum of Beginning_Cash_Bal    | \$ (9,793)   |
|               | Sum of Total_Expenditures    | \$ 352,313   |
|               | Sum of Total_Receipts        | \$ 344,781   |
|               | Sum of Net_Cash_Flow         | \$ (7,532)   |
|               | Sum of Ending_Cash_Bal       | \$ (17,326)  |
|               | Sum of Working_Cap           | \$ -         |
|               | Sum of Repl_Resv             | \$ 4,765     |
|               | Sum of Total_Reqd_Resv       | \$ 4,765     |
|               | Sum of Net_Avail_Bal         | \$ (22,091)  |
|               | Sum of Add_Resv_Needed       | \$ (22,091)  |
|               | Sum of Rate_Inc_Needed       | 35%          |
|               | Sum of Percent_Rate_Increase | 0%           |
| Bond          | Sum of Beginning_Cash_Bal    | \$ (9,793)   |
|               | Sum of Total_Expenditures    | \$ 374,372   |
|               | Sum of Total_Receipts        | \$ 344,781   |
|               | Sum of Net_Cash_Flow         | \$ (29,591)  |
|               | Sum of Ending_Cash_Bal       | \$ (39,384)  |
|               | Sum of Working_Cap           | \$ -         |
|               | Sum of Repl_Resv             | \$ 4,765     |
|               | Sum of Total_Reqd_Resv       | \$ 4,765     |
|               | Sum of Net_Avail_Bal         | \$ (44,149)  |
|               | Sum of Add_Resv_Needed       | \$ (44,149)  |
|               | Sum of Rate_Inc_Needed       | 70%          |
|               | Sum of Percent_Rate_Increase | 0%           |

## APPENDIX E GENERAL ARSENIC GEOCHEMISTRY

Geochemistry of arsenic is complex because of (1) the possible coexistence of two or even three redox states, (2) the complex chemistry of organo-arsenicals, and (3) the strong interaction of most arsenic compounds with soil particles, particularly iron oxides (and to a lesser degree, aluminum and manganese oxides). Fully deprotonated arsenate  $\text{AsO}_4^{-3}$  is the expected form of arsenic in most soil under aerobic conditions only at high pH (Figure E.1). At more neutral and acid pH's,  $\text{HAsO}_4^{-2}$  and  $\text{H}_2\text{AsO}_4^{-1}$  forms, respectively, are dominant. General understanding of arsenic mobility in soil and aquifers is that it increases with increasing pH and phosphate concentration and with decreasing clay and iron oxide content. As pH increases, the negative charge of the arsenate ion increases, making it less likely to sorb on negatively charged soil particles. Phosphates have a chemical structure similar to that of arsenates and sorb to soil preferentially in some conditions. Nitrogen also belongs to the same group in the periodic table but does not show the same competing behavior as phosphate. Other structurally similar oxyanions, sulfate and selenate, are also weak sorbers. Under less oxidizing conditions, arsenite ion  $\text{H}_3\text{AsO}_3$  is most stable. Lack of charge renders the ion more mobile and less likely to sorb to soil particles. Its pH stability spread ranges from acid to alkaline. The first deprotonated form,  $\text{H}_2\text{AsO}_3^{-1}$ , exists at significant concentrations only above a pH of approximately 9. Redox processes seem to be mediated by microorganisms (Welch, *et al.* 2000) and to take place next to mineral surfaces.

Under even more reducing conditions, arsenide is the stable ionic form of arsenic. Arsenic has a complex geochemistry with sulfur, both in solution where several thioarsenic ions can form and in associated minerals. Arsenic metal –As(0)– rarely occurs. Methylated arsenic compounds are generally present at low aqueous concentrations (<1ppb), if at all, except perhaps when there is an abundance of organic matter (Welch, *et al.*, 2000).

As(V) and As(III) minerals are fairly soluble and do not control arsenic solubility in oxidizing or mildly reducing conditions, except, perhaps, if barium is present (Henry, *et al.* 1982). This situation is in contrast to that of other companion oxyanions which are not as mobile under reducing conditions, except vanadium. In reducing conditions, arsenic precipitates as arsenopyrite ( $\text{FeAsS}$ ), although more commonly in solid solution with pyrite. Realgar ( $\text{AsS}$ ) and orpiment ( $\text{As}_2\text{S}_3$ ) require high sulfur activity and are unlikely in the southern Gulf Coast.



**Figure E.1**  
**Eh-pH Diagram for Arsenic Aqueous Species in the As-O<sub>2</sub>-H<sub>2</sub>O System**  
**at 25°C and 1 bar (Smedley and Kinniburgh 2002)**

1  
2

**APPENDIX F  
ORBIT SYSTEMS WATER USAGE**

**Orbit Systems, Inc.  
2004 Water Usage**

| <b>No.</b> | <b>System Name</b>      | <b>2004 Water Usage (gal/yr)</b> | <b>% Water Usage %</b> | <b>No. Connections #</b> | <b>Usage Per Connection (gal/yr)</b> | <b>No. Customers #</b> | <b>Annual Usage Per Customer (gal/yr)</b> | <b>Daily Usage Per Customer (gpcd)</b> |
|------------|-------------------------|----------------------------------|------------------------|--------------------------|--------------------------------------|------------------------|---|--|
| 1          | Coronado Country        | 2,083,300                        | 1.7                    | 44                       | 47,348                               | 132                    | 15,783                                    | 43.2                                   |
| 2          | Country Acres           | 6,766,800                        | 5.4                    | 88                       | 76,895                               | 264                    | 25,632                                    | 70.2                                   |
| 3          | Colony Cove             | 4,239,800                        | 3.4                    | 48                       | 88,329                               | 144                    | 29,443                                    | 80.7                                   |
| 4          | Country Meadows         | 3,446,900                        | 2.7                    | 48                       | 71,810                               | 144                    | 23,937                                    | 65.6                                   |
| 5          | Blue Sage Gardens       | 2,976,800                        | 2.4                    | 43                       | 69,228                               | 129                    | 23,076                                    | 63.2                                   |
| 6          | Brandi Estates          | 3,524,700                        | 2.8                    | 43                       | 81,970                               | 129                    | 27,323                                    | 74.9                                   |
| 7          | Sandy Meadows           | 3,735,400                        | 3.0                    | 68                       | 54,932                               | 204                    | 18,311                                    | 50.2                                   |
| 8          | Rosharon Road Estates   | 5,455,900                        | 4.3                    | 76                       | 71,788                               | 228                    | 23,929                                    | 65.6                                   |
| 9          | Grasslands              | 12,465,400                       | 9.9                    | 171                      | 72,897                               | 513                    | 24,299                                    | 66.6                                   |
| 10         | Rosharon Township       | 8,055,400                        | 6.4                    | 99                       | 81,368                               | 297                    | 27,123                                    | 74.3                                   |
| 11         | Demi-John Island        | 3,973,000                        | 3.2                    | 99                       | 40,131                               | 297                    | 13,377                                    | 36.6                                   |
| 12         | San Bernard River       | 4,595,500                        | 3.7                    | 49                       | 93,786                               | 147                    | 31,262                                    | 85.6                                   |
| 13         | Angle Acres             | 3,330,500                        | 2.7                    | 44                       | 75,693                               | 132                    | 25,231                                    | 69.1                                   |
| 14         | Spanish Bait            | 672,000                          | 0.5                    | 8                        | 84,000                               | 24                     | 28,000                                    | 76.7                                   |
| 15         | Briar Meadow            | 5,231,700                        | 4.2                    | 41                       | 127,602                              | 123                    | 42,534                                    | 116.5                                  |
| 16         | Mooreland               | 4,605,600                        | 3.7                    | 48                       | 95,950                               | 144                    | 31,983                                    | 87.6                                   |
| 17         | Raynlong                | 2,736,600                        | 2.2                    | 32                       | 85,519                               | 96                     | 28,506                                    | 78.1                                   |
| 18         | Snug Harbor             | 2,030,600                        | 1.6                    | 33                       | 61,533                               | 99                     | 20,511                                    | 56.2                                   |
| 19         | Bernard Oaks            | 4,280,000                        | 3.4                    | 71                       | 60,282                               | 213                    | 20,094                                    | 55.1                                   |
| 20         | Demi-John Place         | 2,844,500                        | 2.3                    | 88                       | 32,324                               | 264                    | 10,775                                    | 29.5                                   |
| 21         | Teleview Terrace        | 5,997,600                        | 4.8                    | 47                       | 127,609                              | 141                    | 42,536                                    | 116.5                                  |
| 22         | Wolf Glen               | 2,809,900                        | 2.2                    | 35                       | 80,283                               | 105                    | 26,761                                    | 73.3                                   |
| 23         | Larkspur                | 420,000                          | 0.3                    | 5                        | 84,000                               | 15                     | 28,000                                    | 76.7                                   |
| 24         | Wilco Water             | 4,037,100                        | 3.2                    | 49                       | 82,390                               | 147                    | 27,463                                    | 75.2                                   |
| 25         | Beechwood               | 5,655,000                        | 4.5                    | 73                       | 77,466                               | 219                    | 25,822                                    | 70.7                                   |
| 26         | Oak Meadows             | 1,542,000                        | 1.2                    | 33                       | 46,727                               | 99                     | 15,576                                    | 42.7                                   |
| 27         | Mark V                  | 7,178,900                        | 5.7                    | 94                       | 76,371                               | 282                    | 25,457                                    | 69.7                                   |
| 28         | Riverside Estates       | 3,695,400                        | 2.9                    | 48                       | 76,988                               | 144                    | 25,663                                    | 70.3                                   |
| 29         | Lee Ridge               | 1,926,900                        | 1.5                    | 22                       | 87,586                               | 66                     | 29,195                                    | 80.0                                   |
| 30         | Quail Valley Ranches IV | 785,600                          | 0.6                    | 8                        | 98,200                               | 24                     | 32,733                                    | 89.7                                   |
| 31         | Paloma Acres            | 1,484,500                        | 1.2                    | 25                       | 59,380                               | 75                     | 19,793                                    | 54.2                                   |
| 32         | Colony Trails           | 2,254,100                        | 1.8                    | 45                       | 50,091                               | 135                    | 16,697                                    | 45.7                                   |
| 33         | Other                   | 725,000                          | 0.6                    | 19                       | 38,158                               | 57                     | 12,719                                    | 34.8                                   |
|            | <b>TOTAL</b>            | <b>125,562,400</b>               | <b>100</b>             | <b>1,744</b>             |                                      | <b>5,232</b>           |   |  |
|            | <b>AVERAGE</b>          |                                  |                        |                          | <b>74,504</b>                        |                        | <b>24,835</b>                             | <b>68.0</b>                            |

## **APPENDIX G ANALYSIS OF SHARED SOLUTIONS FOR OBTAINING WATER FROM BWA AND CITY OF ALVIN**

### **G.1 Overview of Method**

There are a number of small PWSs with water quality problems located in the vicinity of the Oak Meadows Estates PWS that could benefit from joining together and cooperating to share the cost for obtaining compliant drinking water. This cooperation could involve creating a formal organization of individual PWSs to address obtaining compliant drinking water, consolidating to form a single PWS, or having the individual PWSs be taken over or bought out by a larger regional entity.

The small PWSs with water quality problems near the Oak Meadows Estates PWS are summarized in Table G.1. Most of them are owned by Orbit. It is assumed for this analysis that all of the systems would participate in a shared solution.

This analysis focuses on compliance alternatives related to obtaining water from large water providers that are interested in providing water outside their current area, either by wholesaling to PWSs, or by expanding their service areas. This type of solution is most likely to have the best prospects for sustainability, and a reliable provision of compliant drinking water.

The purpose of this analysis is to approximate the level of capital cost savings that could be expected from pursuing a shared solution versus a solution where the study PWS obtains compliant drinking water on its own. Regardless of the form a group solution would take, one way or another the water consumers would have to pay for the infrastructure needed for obtaining compliant water. In order to keep this analysis as straightforward and realistic as possible, it is assumed the individual PWSs would remain independent, and would share the capital cost for the infrastructure required. Also, to maintain simplicity this analysis is limited to estimating capital cost savings. A shared solution could also produce savings in O&M expenses as a result of reduction in redundant facilities and the potential for shared O&M resources, and these savings would have to be evaluated if the PWSs are interested in implementing a shared solution.

There are many ways capital costs could be divided between participating PWSs and the final apportioning of costs would likely be based on negotiation between the participating entities. At this preliminary stage of analysis it is not possible to project results from negotiations regarding cost sharing. For this reason, two methods are used to allocate cost between PWSs in an effort to give an approximation of the range of savings that might be attainable for an individual PWS. This range is considered to be representative of possible savings that could result from an agreement that should be fair and equitable to all parties involved.

Method A is based on allocating capital cost of the shared solution proportionate to the amount of water used by the PWSs. In this case, the total capital cost for the pipeline and the necessary pump stations is estimated, and then capital cost for each component is

allocated based on the fraction of the total water used by each PWS. This method is a reasonable method for allocating cost when all of the PWSs are different in size but are relatively equidistant from the shared water source.

Method B is based on allocating capital cost of the shared solution proportionate to the cost each PWS would have to pay to obtain compliant water if it were to implement an individual solution. In this case, the total capital cost for the shared pipeline and the necessary pump stations is estimated as well as the capital cost each PWS would have for obtaining its own pipeline. The total capital cost for the shared solution is then allocated between the participating PWSs based on what each PWS would have to pay to construct its own pipeline. This method is a reasonable method for allocating cost when the PWS are not equidistant from the water source.

## **G.2 Shared Solution for Obtaining Water from City of Alvin**

This alternative would consist of constructing a main pipeline from the southwest part of the City of Alvin that would run southwest and west along FM 1462 to Rosharon Township. Each PWS would connect to this main with a spur line. Spur lines would convey the water from the main line to the storage tanks of each PWS. The main pipeline would start out as 6 inches in diameter, and reduce to 4 inches in diameter at the end. All of the spur pipelines would be 4 inches in diameter. It is assumed two pump stations would be required to transfer the water from the City of Alvin to the end of the pipeline. The pipeline routing is shown on Figure G.1.

The capital costs for each pipe segment and the total capital cost for the shared pipeline are summarized in Table G.2. Tables G.3, G.4 and G.5 show the capital costs allocated to each PWS using Methods A, B and C respectively while Table G.6 compares the found values from each method. More detailed cost estimates for the pipe segments are shown in Tables G.12 through G.22 and G.35 through G.40.

Based on these estimates, the range of capital cost savings to the Grasslands PWS could be between \$1.91 million and \$2.02 million, or 73 and 78 percent if it implemented a shared solution like this. These estimates are hypothetical and are only provided to approximate the magnitude of potential savings if this shared solution is implemented as described.


## **G.3 Group Solution for Obtaining Water from Brazosport Water Authority**

This alternative would consist of constructing a main pipeline that starts at the north part of the City of Angleton where the Brazosport Water Authority line currently terminates. The line would run north along Highway 288 to Rosharon Township and turn to run east along FM 1462 to Rosharon Road Estates. Spur lines would convey the water from the main line to the storage tanks. The main pipeline would start out as 6 inches in diameter, and reduce to 4 inches in diameter at the end. All of the spur pipelines would be 4 inches in diameter. It is assumed three pump stations would be required to transfer the water from the Brazosport Water Authority line to the end of the pipeline. The pipeline routing is shown on Figure G.2.

The capital costs for each pipe segment and the total capital cost for the shared pipeline are summarized in Table G.7. Table G.8, G.9 and G.10 show the capital costs allocated to each PWS using Methods A, B and C respectively while Table G.11 compares the found values from each method. More detailed cost estimates for the pipe segments are shown in Tables G.23 through G.17 and G.41 through G.46.


Based on these estimates, the range of capital cost savings to the Grasslands PWS could be between \$0.84 million and \$1.86 million, or 33 and 73 percent, if they were to implement a shared solution like this. These estimates are hypothetical and are only provided to approximate the magnitude of potential savings if this shared solution is implemented as described.






**Figure G.1**

**Regional Solution  
Water from City of Alvin**



**Figure G.2**

**Regional Solution  
Water from  
Brazosport Water Authority**



- Participating PWS
- Source Location
- Regional Pipeline
- Water Features
- Roads
- City Limits

Table G.1

| PWS                               | Average Water Demand (mgd) | Water Demand as Percent of Total |
|-----------------------------------|----------------------------|----------------------------------|
| Rosharon Road Estates Subdivision | 0.10443                    | 28%                              |
| Sandy Meadows Estates Subdivision | 0.08943                    | 24%                              |
| Stoneridge Lakes                  | 0.07343                    | 19%                              |
| Grasslands                        | 0.06485                    | 17%                              |
| Oak Meadows                       | 0.02585                    | 7%                               |
| Rosharon Township                 | 0.0191                     | 5%                               |
| 0                                 | 0                          | 0%                               |
| 0                                 | 0                          | 0%                               |
| 0                                 | 0                          | 0%                               |

Table G.2

Capital Cost for Shared Pipeline from the City of Alvin

| Pipe Segment | Capital Cost        |
|--------------|---------------------|
| Pipe 1       | \$ 1,867,972        |
| Pipe 2       | \$ 231,354          |
| Pipe 3       | \$ 771,954          |
| Pipe 4       | \$ 66,985           |
| Pipe 5       | \$ 110,723          |
| Pipe 6       | \$ -                |
| Pipe 7       | \$ -                |
| Pipe 8       | \$ -                |
| Pipe 9       | \$ -                |
| Pipe A       | \$ 83,183           |
| Pipe B       | \$ 56,081           |
| Pipe C       | \$ 28,781           |
| Pipe D       | \$ 20,947           |
| Pipe E       | \$ 121,746          |
| Pipe F       | \$ 81,115           |
| Pipe G       | \$ -                |
| Pipe H       | \$ -                |
| Pipe I       | \$ -                |
| <b>Total</b> | <b>\$ 3,440,840</b> |

Table G.3  
Cost Solution A

| <b>PWS</b>                        | <b>Percentage<br/>Based On Flow</b> | <b>Total Costs</b>  |
|-----------------------------------|-------------------------------------|---------------------|
| Rosharon Road Estates Subdivision | 28%                                 | \$ 952,894          |
| Sandy Meadows Estates Subdivision | 24%                                 | \$ 816,024          |
| Stoneridge Lakes                  | 19%                                 | \$ 670,028          |
| Grasslands                        | 17%                                 | \$ 591,738          |
| Oak Meadows                       | 7%                                  | \$ 235,874          |
| Rosharon Township                 | 5%                                  | \$ 174,282          |
| 0                                 | 0%                                  | \$ -                |
| 0                                 | 0%                                  | \$ -                |
| 0                                 | 0%                                  | \$ -                |
| <b>Total</b>                      | <b>100%</b>                         | <b>\$ 3,440,840</b> |

Table G.4  
Cost Solution B

| <b>PWS</b>                        | <b>Costs Incurred<br/>due to Shared<br/>Pipeline</b> | <b>Costs Incurred<br/>due to Personal<br/>Pipeline</b> | <b>Total Costs</b>  |
|-----------------------------------|--|--|---------------------|
| Rosharon Road Estates Subdivision | \$ 517,310   | \$ 83,183  | \$ 600,493          |
| Sandy Meadows Estates Subdivision | \$ 518,887   | \$ 56,081  | \$ 574,968          |
| Stoneridge Lakes                  | \$ 735,416   | \$ 28,781  | \$ 764,196          |
| Grasslands                        | \$ 689,048   | \$ 20,947  | \$ 709,995          |
| Oak Meadows                       | \$ 338,338   | \$ 121,746   | \$ 460,083          |
| Rosharon Township                 | \$ 249,990   | \$ 81,115  | \$ 331,105          |
| 0                                 | \$ -   | \$ -   | \$ -                |
| 0                                 | \$ -   | \$ -   | \$ -                |
| 0                                 | \$ -   | \$ -   | \$ -                |
| <b>Total</b>                      | <b>\$ 3,048,988</b>                                  | <b>\$ 391,852</b>                                      | <b>\$ 3,440,840</b> |

Table G.5  
Cost Solution C

| PWS                               | Percentage based on Individual Solutions | Total Costs         |
|-----------------------------------|--|---------------------|
| Rosharon Road Estates Subdivision | 12%                                      | \$ 397,613          |
| Sandy Meadows Estates Subdivision | 13%                                      | \$ 449,660          |
| Stoneridge Lakes                  | 18%                                      | \$ 614,387          |
| Grasslands                        | 18%                                      | \$ 623,111          |
| Oak Meadows                       | 20%                                      | \$ 673,214          |
| Rosharon Township                 | 20%                                      | \$ 682,855          |
| 0                                 | 0%                                       | \$ -                |
| 0                                 | 0%                                       | \$ -                |
| 0                                 | 0%                                       | \$ -                |
| <b>Total</b>                      | <b>100%</b>                              | <b>\$ 3,440,840</b> |

Table G.6  
Summation Table

| PWS                               | Individual Pipeline Cost | Capital Cost Option A | Capital Cost Option B | Capital Cost Option C | Percent Savings A | Percent Savings B | Percent Savings C |
|-----------------------------------|--------------------------|-----------------------|-----------------------|-----------------------|-------------------|-------------------|-------------------|
| Rosharon Road Estates Subdivision | \$ 1,660,177             | \$ 952,894            | \$ 600,493            | \$ 397,613            | 43%               | 64%               | 76%               |
| Sandy Meadows Estates Subdivision | \$ 1,877,491             | \$ 816,024            | \$ 574,968            | \$ 449,660            | 57%               | 69%               | 76%               |
| Stoneridge Lakes                  | \$ 2,565,286             | \$ 670,028            | \$ 764,196            | \$ 614,387            | 74%               | 70%               | 76%               |
| Grasslands                        | \$ 2,601,709             | \$ 591,738            | \$ 709,995            | \$ 623,111            | 77%               | 73%               | 76%               |
| Oak Meadows                       | \$ 2,810,908             | \$ 235,874            | \$ 460,083            | \$ 673,214            | 92%               | 84%               | 76%               |
| Rosharon Township                 | \$ 2,851,163             | \$ 174,282            | \$ 331,105            | \$ 682,855            | 94%               | 88%               | 76%               |
| 0                                 | \$ -                     | \$ -                  | \$ -                  | \$ -                  | false             | false             | false             |
| 0                                 | \$ -                     | \$ -                  | \$ -                  | \$ -                  | false             | false             | false             |
| 0                                 | \$ -                     | \$ -                  | \$ -                  | \$ -                  | false             | false             | false             |
| <b>Total</b>                      | <b>\$ 14,366,734</b>     | <b>\$ 3,440,840</b>   | <b>\$ 3,440,840</b>   | <b>\$ 3,440,840</b>   | <b>73%</b>        | <b>75%</b>        | <b>76%</b>        |

Table G.7  
Capital Cost for Shared Pipeline from BWA

| Pipe Segment | Capital Cost        |
|--------------|---------------------|
| Pipe 1       | \$ 2,988,751        |
| Pipe 2       | \$ 92,141           |
| Pipe 3       | \$ 110,723          |
| Pipe 4       | \$ 66,985           |
| Pipe 5       | \$ 786,817          |
| Pipe 6       | \$ 231,354          |
| Pipe 7       | \$ -                |
| Pipe 8       | \$ -                |
| Pipe 9       | \$ -                |
| Pipe A       | \$ 74,108           |
| Pipe B       | \$ 121,746          |
| Pipe C       | \$ 20,947           |
| Pipe D       | \$ 28,769           |
| Pipe E       | \$ 56,085           |
| Pipe F       | \$ 83,254           |
| Pipe G       | \$ -                |
| Pipe H       | \$ -                |
| Pipe I       | \$ -                |
| <b>Total</b> | <b>\$ 4,661,678</b> |

Table G.8  
Cost Solution A

| PWS                               | Percentage Based On Flow | Total Costs         |
|-----------------------------------|--------------------------|---------------------|
| Rosharon Township                 | 18%                      | \$ 852,611          |
| Oak Meadows                       | 6%                       | \$ 301,315          |
| Grasslands                        | 37%                      | \$ 1,740,934        |
| Stoneridge Lakes                  | 8%                       | \$ 383,005          |
| Sandy Meadows Estates Subdivision | 15%                      | \$ 714,222          |
| Rosharon Road Estates Subdivision | 14%                      | \$ 669,590          |
| 0                                 | 0%                       | \$ -                |
| 0                                 | 0%                       | \$ -                |
| 0                                 | 0%                       | \$ -                |
| <b>Total</b>                      | <b>100%</b>              | <b>\$ 4,661,678</b> |

Table G.9  
Cost Solution B

| <b>PWS</b>                        | <b>Costs Incurred<br/>due to Shared<br/>Pipeline</b> | <b>Costs Incurred<br/>due to Personal<br/>Pipeline</b> | <b>Total Costs</b>  |
|-----------------------------------|--|--|---------------------|
| Rosharon Township                 | \$ 546,636   | \$ 74,108  | \$ 620,744          |
| Oak Meadows                       | \$ 200,472   | \$ 121,746   | \$ 322,217          |
| Grasslands                        | \$ 1,213,235   | \$ 20,947  | \$ 1,234,181        |
| Stoneridge Lakes                  | \$ 281,432   | \$ 28,769  | \$ 310,202          |
| Sandy Meadows Estates Subdivision | \$ 930,908   | \$ 56,085  | \$ 986,992          |
| Rosharon Road Estates Subdivision | \$ 1,104,088   | \$ 83,254  | \$ 1,187,342        |
| 0                                 | \$ -   | \$ -   | \$ -                |
| 0                                 | \$ -   | \$ -   | \$ -                |
| 0                                 | \$ -   | \$ -   | \$ -                |
| <b>Total</b>                      | <b>\$ 4,276,771</b>                                  | <b>\$ 384,908</b>                                      | <b>\$ 4,661,678</b> |

Table G.10  
Cost Solution C

| <b>PWS</b>                        | <b>Percentage<br/>based on<br/>Individual<br/>Solutions</b> | <b>Total Costs</b>  |
|-----------------------------------|---|---------------------|
| Rosharon Township                 | 15%   | \$ 699,159          |
| Oak Meadows                       | 16%   | \$ 744,220          |
| Grasslands                        | 15%   | \$ 703,840          |
| Stoneridge Lakes                  | 15%   | \$ 698,313          |
| Sandy Meadows Estates Subdivision | 19%   | \$ 891,538          |
| Rosharon Road Estates Subdivision | 20%   | \$ 924,609          |
| 0                                 | 0%  | \$ -                |
| 0                                 | 0%  | \$ -                |
| 0                                 | 0%  | \$ -                |
| <b>Total</b>                      | <b>100%</b>   | <b>\$ 4,661,678</b> |

Table G.11  
Summation Table

| <b>PWS</b>                        | <b>Individual<br/>Pipeline Cost</b> | <b>Capital Cost<br/>Option A</b> | <b>Capital Cost<br/>Option B</b> | <b>Capital Cost<br/>Option C</b> | <b>Percent<br/>Savings A</b> | <b>Percent<br/>Savings B</b> | <b>Percent<br/>Savings C</b> |
|-----------------------------------|-------------------------------------|----------------------------------|----------------------------------|----------------------------------|------------------------------|------------------------------|------------------------------|
| Rosharon Township                 | \$ 2,540,184                        | \$ 852,611                       | \$ 620,744                       | \$ 699,159                       | 66%                          | 76%                          | 72%                          |
| Oak Meadows                       | \$ 2,703,899                        | \$ 301,315                       | \$ 322,217                       | \$ 744,220                       | 89%                          | 88%                          | 72%                          |
| Grasslands                        | \$ 2,557,190                        | \$ 1,740,934                     | \$ 1,234,181                     | \$ 703,840                       | 32%                          | 52%                          | 72%                          |
| Stoneridge Lakes                  | \$ 2,537,109                        | \$ 383,005                       | \$ 310,202                       | \$ 698,313                       | 85%                          | 88%                          | 72%                          |
| Sandy Meadows Estates Subdivision | \$ 3,239,135                        | \$ 714,222                       | \$ 986,992                       | \$ 891,538                       | 78%                          | 70%                          | 72%                          |
| Rosharon Road Estates Subdivision | \$ 3,359,289                        | \$ 669,590                       | \$ 1,187,342                     | \$ 924,609                       | 80%                          | 65%                          | 72%                          |
| 0                                 | \$ -                                | \$ -                             | \$ -                             | \$ -                             | false                        | false                        | false                        |
| 0                                 | \$ -                                | \$ -                             | \$ -                             | \$ -                             | false                        | false                        | false                        |
| 0                                 | \$ -                                | \$ -                             | \$ -                             | \$ -                             | false                        | false                        | false                        |
| <b>Total</b>                      | <b>\$ 16,936,806</b>                | <b>\$ 4,661,678</b>              | <b>\$ 4,661,678</b>              | <b>\$ 4,661,678</b>              | <b>72%</b>                   | <b>73%</b>                   | <b>72%</b>                   |



**Table G.12****Obtain Water From the City of Alvin****Main Link # 1****Total Pipe Length**

6.67 miles

**Number of Pump Stations Needed**

1

**Pipe Size**

06" inches

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b>   |
|-------------------------------------|-----------------|-------------|------------------|---------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                     |
| Number of Crossings, bore           | 4               | n/a         | n/a              | n/a                 |
| Number of Crossings, open cut       | 14              | n/a         | n/a              | n/a                 |
| PVC water line, Class 200, 06"      | 35,210          | LF          | \$ 32            | \$ 1,126,720        |
| Bore and encasement, 10"            | 800             | LF          | \$ 60            | \$ 48,000           |
| Open cut and encasement, 10"        | 700             | LF          | \$ 35            | \$ 24,500           |
| Gate valve and box, 06"             | 8               | EA          | \$ 465           | \$ 3,720            |
| Air valve                           | 7               | EA          | \$ 1,000         | \$ 7,000            |
| Flush valve                         | 8               | EA          | \$ 750           | \$ 6,000            |
| Metal detectable tape               | 35,210          | LF          | \$ 0.15          | \$ 5,282            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 1,221,222</b> |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                     |
| Pump                                | 2               | EA          | \$ 7,500         | \$ 15,000           |
| Pump Station Piping, 06"            | 2               | EA          | \$ 4,000         | \$ 8,000            |
| Gate valve, 06"                     | 4               | EA          | \$ 590           | \$ 2,360            |
| Check valve, 06"                    | 2               | EA          | \$ 890           | \$ 1,780            |
| Electrical/Instrumentation          | 1               | EA          | \$ 10,000        | \$ 10,000           |
| Site work                           | 1               | EA          | \$ 2,000         | \$ 2,000            |
| Building pad                        | 1               | EA          | \$ 4,000         | \$ 4,000            |
| Pump Building                       | 1               | EA          | \$ 10,000        | \$ 10,000           |
| Fence                               | 1               | EA          | \$ 5,870         | \$ 5,870            |
| Tools                               | 1               | EA          | \$ 1,000         | \$ 1,000            |
| Storage Tank - 5000 gals            | 1               | EA          | \$ 7,025         | \$ 7,025            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 67,035</b>    |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 1,288,257</b> |
| Contingency                         | 20%             |             |                  | \$ 257,651          |
| Design & Constr Management          | 25%             |             |                  | \$ 322,064          |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 1,867,972</b> |

**Table G.13****Obtain Water From the City of Alvin****Main Link # 2****Total Pipe Length**

0.99 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

| Cost Item | Quantity | Unit | Unit Cost | Total Cost |
|-----------|----------|------|-----------|------------|
|-----------|----------|------|-----------|------------|

*Pipeline Construction*

|                                |       |     |          |                   |
|--------------------------------|-------|-----|----------|-------------------|
| Number of Crossings, bore      | 1     | n/a | n/a      | n/a               |
| Number of Crossings, open cut  | 1     | n/a | n/a      | n/a               |
| PVC water line, Class 200, 04" | 5,251 | LF  | \$ 27    | \$ 141,777        |
| Bore and encasement, 10"       | 200   | LF  | \$ 60    | \$ 12,000         |
| Open cut and encasement, 10"   | 50    | LF  | \$ 35    | \$ 1,750          |
| Gate valve and box, 04"        | 2     | EA  | \$ 370   | \$ 740            |
| Air valve                      | 1     | EA  | \$ 1,000 | \$ 1,000          |
| Flush valve                    | 2     | EA  | \$ 750   | \$ 1,500          |
| Metal detectable tape          | 5,251 | LF  | \$ 0.15  | \$ 788            |
| <b>Subtotal</b>                |       |     |          | <b>\$ 159,555</b> |

*Pump Station(s) Installation*

|                            |   |    |           |             |
|----------------------------|---|----|-----------|-------------|
| Pump                       | - | EA | \$ 7,500  | \$ -        |
| Pump Station Piping, 04"   | - | EA | \$ 4,000  | \$ -        |
| Gate valve, 04"            | - | EA | \$ 405    | \$ -        |
| Check valve, 04"           | - | EA | \$ 595    | \$ -        |
| Electrical/Instrumentation | - | EA | \$ 10,000 | \$ -        |
| Site work                  | - | EA | \$ 2,000  | \$ -        |
| Building pad               | - | EA | \$ 4,000  | \$ -        |
| Pump Building              | - | EA | \$ 10,000 | \$ -        |
| Fence                      | - | EA | \$ 5,870  | \$ -        |
| Tools                      | - | EA | \$ 1,000  | \$ -        |
| Storage Tank - 5000 gals   | - | EA | \$ 7,025  | \$ -        |
| <b>Subtotal</b>            |   |    |           | <b>\$ -</b> |

|                                    |                   |
|------------------------------------|-------------------|
| <b>Subtotal of Component Costs</b> | <b>\$ 159,555</b> |
|------------------------------------|-------------------|

|                            |     |           |
|----------------------------|-----|-----------|
| Contingency                | 20% | \$ 31,911 |
| Design & Constr Management | 25% | \$ 39,889 |

|                            |                   |
|----------------------------|-------------------|
| <b>TOTAL CAPITAL COSTS</b> | <b>\$ 231,354</b> |
|----------------------------|-------------------|

**Table G.14****Obtain Water From the City of Alvin****Main Link # 3****Total Pipe Length**

2.92 miles

**Number of Pump Stations Needed**

1

**Pipe Size**

04" inches

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | 3               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 3               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 15,394          | LF          | \$ 27            | \$ 415,638        |
| Bore and encasement, 10"            | 600             | LF          | \$ 60            | \$ 36,000         |
| Open cut and encasement, 10"        | 150             | LF          | \$ 35            | \$ 5,250          |
| Gate valve and box, 04"             | 4               | EA          | \$ 370           | \$ 1,480          |
| Air valve                           | 3               | EA          | \$ 1,000         | \$ 3,000          |
| Flush valve                         | 4               | EA          | \$ 750           | \$ 3,000          |
| Metal detectable tape               | 15,394          | LF          | \$ 0.15          | \$ 2,309          |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 466,677</b> |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | 2               | EA          | \$ 7,500         | \$ 15,000         |
| Pump Station Piping, 04"            | 2               | EA          | \$ 4,000         | \$ 8,000          |
| Gate valve, 04"                     | 4               | EA          | \$ 405           | \$ 1,620          |
| Check valve, 04"                    | 2               | EA          | \$ 595           | \$ 1,190          |
| Electrical/Instrumentation          | 1               | EA          | \$ 10,000        | \$ 10,000         |
| Site work                           | 1               | EA          | \$ 2,000         | \$ 2,000          |
| Building pad                        | 1               | EA          | \$ 4,000         | \$ 4,000          |
| Pump Building                       | 1               | EA          | \$ 10,000        | \$ 10,000         |
| Fence                               | 1               | EA          | \$ 5,870         | \$ 5,870          |
| Tools                               | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Storage Tank - 5000 gals            | 1               | EA          | \$ 7,025         | \$ 7,025          |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 65,705</b>  |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 532,382</b> |
| Contingency                         | 20%             |             |                  | \$ 106,476        |
| Design & Constr Management          | 25%             |             |                  | \$ 133,096        |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 771,954</b> |

**Table G.15****Obtain Water From the City of Alvin****Main Link # 4****Total Pipe Length**

0.30 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

| Cost Item | Quantity | Unit | Unit Cost | Total Cost |
|-----------|----------|------|-----------|------------|
|-----------|----------|------|-----------|------------|

*Pipeline Construction*

|                                |       |     |          |                  |
|--------------------------------|-------|-----|----------|------------------|
| Number of Crossings, bore      | -     | n/a | n/a      | n/a              |
| Number of Crossings, open cut  | 1     | n/a | n/a      | n/a              |
| PVC water line, Class 200, 04" | 1,559 | LF  | \$ 27    | \$ 42,093        |
| Bore and encasement, 10"       | -     | LF  | \$ 60    | \$ -             |
| Open cut and encasement, 10"   | 50    | LF  | \$ 35    | \$ 1,750         |
| Gate valve and box, 04"        | 1     | EA  | \$ 370   | \$ 370           |
| Air valve                      | 1     | EA  | \$ 1,000 | \$ 1,000         |
| Flush valve                    | 1     | EA  | \$ 750   | \$ 750           |
| Metal detectable tape          | 1,559 | LF  | \$ 0.15  | \$ 234           |
| <b>Subtotal</b>                |       |     |          | <b>\$ 46,197</b> |

*Pump Station(s) Installation*

|                            |   |    |           |             |
|----------------------------|---|----|-----------|-------------|
| Pump                       | - | EA | \$ 7,500  | \$ -        |
| Pump Station Piping, 04"   | - | EA | \$ 4,000  | \$ -        |
| Gate valve, 04"            | - | EA | \$ 405    | \$ -        |
| Check valve, 04"           | - | EA | \$ 595    | \$ -        |
| Electrical/Instrumentation | - | EA | \$ 10,000 | \$ -        |
| Site work                  | - | EA | \$ 2,000  | \$ -        |
| Building pad               | - | EA | \$ 4,000  | \$ -        |
| Pump Building              | - | EA | \$ 10,000 | \$ -        |
| Fence                      | - | EA | \$ 5,870  | \$ -        |
| Tools                      | - | EA | \$ 1,000  | \$ -        |
| Storage Tank - 5000 gals   | - | EA | \$ 7,025  | \$ -        |
| <b>Subtotal</b>            |   |    |           | <b>\$ -</b> |

|                                    |                  |
|------------------------------------|------------------|
| <b>Subtotal of Component Costs</b> | <b>\$ 46,197</b> |
|------------------------------------|------------------|

|                            |     |           |
|----------------------------|-----|-----------|
| Contingency                | 20% | \$ 9,239  |
| Design & Constr Management | 25% | \$ 11,549 |

|                            |                  |
|----------------------------|------------------|
| <b>TOTAL CAPITAL COSTS</b> | <b>\$ 66,985</b> |
|----------------------------|------------------|

**Table G.16****Obtain Water From the City of Alvin****Main Link # 5****Total Pipe Length**

0.51 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

| Cost Item | Quantity | Unit | Unit Cost | Total Cost |
|-----------|----------|------|-----------|------------|
|-----------|----------|------|-----------|------------|

*Pipeline Construction*

|                                |       |     |          |                  |
|--------------------------------|-------|-----|----------|------------------|
| Number of Crossings, bore      | -     | n/a | n/a      | n/a              |
| Number of Crossings, open cut  | 1     | n/a | n/a      | n/a              |
| PVC water line, Class 200, 04" | 2,670 | LF  | \$ 27    | \$ 72,090        |
| Bore and encasement, 10"       | -     | LF  | \$ 60    | \$ -             |
| Open cut and encasement, 10"   | 50    | LF  | \$ 35    | \$ 1,750         |
| Gate valve and box, 04"        | 1     | EA  | \$ 370   | \$ 370           |
| Air valve                      | 1     | EA  | \$ 1,000 | \$ 1,000         |
| Flush valve                    | 1     | EA  | \$ 750   | \$ 750           |
| Metal detectable tape          | 2,670 | LF  | \$ 0.15  | \$ 401           |
| <b>Subtotal</b>                |       |     |          | <b>\$ 76,361</b> |

*Pump Station(s) Installation*

|                            |   |    |           |             |
|----------------------------|---|----|-----------|-------------|
| Pump                       | - | EA | \$ 7,500  | \$ -        |
| Pump Station Piping, 04"   | - | EA | \$ 4,000  | \$ -        |
| Gate valve, 04"            | - | EA | \$ 405    | \$ -        |
| Check valve, 04"           | - | EA | \$ 595    | \$ -        |
| Electrical/Instrumentation | - | EA | \$ 10,000 | \$ -        |
| Site work                  | - | EA | \$ 2,000  | \$ -        |
| Building pad               | - | EA | \$ 4,000  | \$ -        |
| Pump Building              | - | EA | \$ 10,000 | \$ -        |
| Fence                      | - | EA | \$ 5,870  | \$ -        |
| Tools                      | - | EA | \$ 1,000  | \$ -        |
| Storage Tank - 5000 gals   | - | EA | \$ 7,025  | \$ -        |
| <b>Subtotal</b>            |   |    |           | <b>\$ -</b> |

|                                    |                  |
|------------------------------------|------------------|
| <b>Subtotal of Component Costs</b> | <b>\$ 76,361</b> |
|------------------------------------|------------------|

|                            |     |           |
|----------------------------|-----|-----------|
| Contingency                | 20% | \$ 15,272 |
| Design & Constr Management | 25% | \$ 19,090 |

|                            |                   |
|----------------------------|-------------------|
| <b>TOTAL CAPITAL COSTS</b> | <b>\$ 110,723</b> |
|----------------------------|-------------------|

**Table G.17****Segment A****Obtain Water From the City of Alvin****Rosharon Road Estates Subdivision****Private Pipe Size**

04"

**Total Pipe Length**

0.28 miles

**Total PWS annual water usage**

38.1 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | 1               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 2               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 1,464           | LF          | \$ 27            | \$ 39,528         |
| Bore and encasement, 10"            | 200             | LF          | \$ 60            | \$ 12,000         |
| Open cut and encasement, 10"        | 100             | LF          | \$ 35            | \$ 3,500          |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 1,464           | LF          | \$ 0.15          | \$ 220            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 57,368</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 57,368</b>  |
| Contingency                         | 20%             |             |                  | \$ 11,474         |
| Design & Constr Management          | 25%             |             |                  | \$ 14,342         |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 83,183</b>  |

**Table G.18****Segment B****Obtain Water From the City of Alvin****Sandy Meadows Estates Subdivision****Private Pipe Size**

04"

**Total Pipe Length**

0.24 miles

**Total PWS annual water usage**

32.6 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 1               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 1,282           | LF          | \$ 27            | \$ 34,614         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | 50              | LF          | \$ 35            | \$ 1,750          |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 1,282           | LF          | \$ 0.15          | \$ 192            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 38,676</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 38,676</b>  |
| Contingency                         | 20%             |             |                  | \$ 7,735          |
| Design & Constr Management          | 25%             |             |                  | \$ 9,669          |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 56,081</b>  |

**Table G.19****Segment C****Obtain Water From the City of Alvin****Stoneridge Lakes****Private Pipe Size**

04"

**Total Pipe Length**

0.12 miles

**Total PWS annual water usage**

26.8 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | -               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 653             | LF          | \$ 27            | \$ 17,631         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | -               | LF          | \$ 35            | \$ -              |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 653             | LF          | \$ 0.15          | \$ 98             |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 19,849</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 19,849</b>  |
| Contingency                         | 20%             |             |                  | \$ 3,970          |
| Design & Constr Management          | 25%             |             |                  | \$ 4,962          |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 28,781</b>  |



**Table G.20****Segment D****Obtain Water From the City of Alvin****Grasslands****Private Pipe Size**

04"

**Total Pipe Length**

0.09 miles

**Total PWS annual water usage**

23.7 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | -               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 454             | LF          | \$ 27            | \$ 12,258         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | -               | LF          | \$ 35            | \$ -              |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 454             | LF          | \$ 0.15          | \$ 68             |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 14,446</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 14,446</b>  |
| Contingency                         | 20%             |             |                  | \$ 2,889          |
| Design & Constr Management          | 25%             |             |                  | \$ 3,612          |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 20,947</b>  |

**Table G.21****Segment E****Obtain Water From the City of Alvin****Oak Meadows****Private Pipe Size**

04"

**Total Pipe Length**

0.56 miles

**Total PWS annual water usage**

9.4 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 1               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 2,950           | LF          | \$ 27            | \$ 79,650         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | 50              | LF          | \$ 35            | \$ 1,750          |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 2,950           | LF          | \$ 0.15          | \$ 443            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 83,963</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 83,963</b>  |
| Contingency                         | 20%             |             |                  | \$ 16,793         |
| Design & Constr Management          | 25%             |             |                  | \$ 20,991         |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 121,746</b> |

**Table G.22****Segment F****Obtain Water From the City of Alvin****Rosharon Township****Private Pipe Size**

04"

**Total Pipe Length**

0.34 miles

**Total PWS annual water usage**

7.0 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 3               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 1,789           | LF          | \$ 27            | \$ 48,303         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | 150             | LF          | \$ 35            | \$ 5,250          |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 1,789           | LF          | \$ 0.15          | \$ 268            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 55,941</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 55,941</b>  |
| Contingency                         | 20%             |             |                  | \$ 11,188         |
| Design & Constr Management          | 25%             |             |                  | \$ 13,985         |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 81,115</b>  |

**Table G.23****Obtain Water From the City of Alvin****Main Link # 1****Total Pipe Length**

11.36 miles

**Number of Pump Stations Needed**

1

**Pipe Size**

06" inches

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b>   |
|-------------------------------------|-----------------|-------------|------------------|---------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                     |
| Number of Crossings, bore           | 2               | n/a         | n/a              | n/a                 |
| Number of Crossings, open cut       | 9               | n/a         | n/a              | n/a                 |
| PVC water line, Class 200, 06"      | 59,964          | LF          | \$ 32            | \$ 1,918,848        |
| Bore and encasement, 10"            | 400             | LF          | \$ 60            | \$ 24,000           |
| Open cut and encasement, 10"        | 450             | LF          | \$ 35            | \$ 15,750           |
| Gate valve and box, 06"             | 12              | EA          | \$ 465           | \$ 5,580            |
| Air valve                           | 12              | EA          | \$ 1,000         | \$ 12,000           |
| Flush valve                         | 12              | EA          | \$ 750           | \$ 9,000            |
| Metal detectable tape               | 59,964          | LF          | \$ 0.15          | \$ 8,995            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 1,994,173</b> |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                     |
| Pump                                | 2               | EA          | \$ 7,500         | \$ 15,000           |
| Pump Station Piping, 06"            | 2               | EA          | \$ 4,000         | \$ 8,000            |
| Gate valve, 06"                     | 4               | EA          | \$ 590           | \$ 2,360            |
| Check valve, 06"                    | 2               | EA          | \$ 890           | \$ 1,780            |
| Electrical/Instrumentation          | 1               | EA          | \$ 10,000        | \$ 10,000           |
| Site work                           | 1               | EA          | \$ 2,000         | \$ 2,000            |
| Building pad                        | 1               | EA          | \$ 4,000         | \$ 4,000            |
| Pump Building                       | 1               | EA          | \$ 10,000        | \$ 10,000           |
| Fence                               | 1               | EA          | \$ 5,870         | \$ 5,870            |
| Tools                               | 1               | EA          | \$ 1,000         | \$ 1,000            |
| Storage Tank - 5000 gals            | 1               | EA          | \$ 7,025         | \$ 7,025            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 67,035</b>    |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 2,061,208</b> |
| Contingency                         | 20%             |             |                  | \$ 412,242          |
| Design & Constr Management          | 25%             |             |                  | \$ 515,302          |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 2,988,751</b> |

**Table G.24****Obtain Water From the City of Alvin****Main Link # 2****Total Pipe Length**

0.33 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

| Cost Item | Quantity | Unit | Unit Cost | Total Cost |
|-----------|----------|------|-----------|------------|
|-----------|----------|------|-----------|------------|

*Pipeline Construction*

|                                |       |     |          |                  |
|--------------------------------|-------|-----|----------|------------------|
| Number of Crossings, bore      | 1     | n/a | n/a      | n/a              |
| Number of Crossings, open cut  | 1     | n/a | n/a      | n/a              |
| PVC water line, Class 200, 04" | 1,756 | LF  | \$ 27    | \$ 47,412        |
| Bore and encasement, 10"       | 200   | LF  | \$ 60    | \$ 12,000        |
| Open cut and encasement, 10"   | 50    | LF  | \$ 35    | \$ 1,750         |
| Gate valve and box, 04"        | 1     | EA  | \$ 370   | \$ 370           |
| Air valve                      | 1     | EA  | \$ 1,000 | \$ 1,000         |
| Flush valve                    | 1     | EA  | \$ 750   | \$ 750           |
| Metal detectable tape          | 1,756 | LF  | \$ 0.15  | \$ 263           |
| <b>Subtotal</b>                |       |     |          | <b>\$ 63,545</b> |

*Pump Station(s) Installation*

|                            |   |    |           |             |
|----------------------------|---|----|-----------|-------------|
| Pump                       | - | EA | \$ 7,500  | \$ -        |
| Pump Station Piping, 04"   | - | EA | \$ 4,000  | \$ -        |
| Gate valve, 04"            | - | EA | \$ 405    | \$ -        |
| Check valve, 04"           | - | EA | \$ 595    | \$ -        |
| Electrical/Instrumentation | - | EA | \$ 10,000 | \$ -        |
| Site work                  | - | EA | \$ 2,000  | \$ -        |
| Building pad               | - | EA | \$ 4,000  | \$ -        |
| Pump Building              | - | EA | \$ 10,000 | \$ -        |
| Fence                      | - | EA | \$ 5,870  | \$ -        |
| Tools                      | - | EA | \$ 1,000  | \$ -        |
| Storage Tank - 5000 gals   | - | EA | \$ 7,025  | \$ -        |
| <b>Subtotal</b>            |   |    |           | <b>\$ -</b> |

|                                    |                  |
|------------------------------------|------------------|
| <b>Subtotal of Component Costs</b> | <b>\$ 63,545</b> |
|------------------------------------|------------------|

|                            |     |           |
|----------------------------|-----|-----------|
| Contingency                | 20% | \$ 12,709 |
| Design & Constr Management | 25% | \$ 15,886 |

|                            |                  |
|----------------------------|------------------|
| <b>TOTAL CAPITAL COSTS</b> | <b>\$ 92,141</b> |
|----------------------------|------------------|

**Table G.25****Obtain Water From the City of Alvin****Main Link # 3****Total Pipe Length**

0.51 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 1               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 2,670           | LF          | \$ 27            | \$ 72,090         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | 50              | LF          | \$ 35            | \$ 1,750          |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 2,670           | LF          | \$ 0.15          | \$ 401            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 76,361</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5000 gals            | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 76,361</b>  |
| Contingency                         | 20%             |             |                  | \$ 15,272         |
| Design & Constr Management          | 25%             |             |                  | \$ 19,090         |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 110,723</b> |

**Table G.26****Obtain Water From the City of Alvin****Main Link # 4****Total Pipe Length**

0.30 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 1               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 1,559           | LF          | \$ 27            | \$ 42,093         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | 50              | LF          | \$ 35            | \$ 1,750          |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 1,559           | LF          | \$ 0.15          | \$ 234            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 46,197</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5000 gals            | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 46,197</b>  |
| Contingency                         | 20%             |             |                  | \$ 9,239          |
| Design & Constr Management          | 25%             |             |                  | \$ 11,549         |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 66,985</b>  |

**Table G.27****Obtain Water From the City of Alvin****Main Link # 5****Total Pipe Length**

2.92 miles

**Number of Pump Stations Needed**

1

**Pipe Size**

04" inches

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | 4               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 2               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 15,394          | LF          | \$ 27            | \$ 415,638        |
| Bore and encasement, 10"            | 800             | LF          | \$ 60            | \$ 48,000         |
| Open cut and encasement, 10"        | 100             | LF          | \$ 35            | \$ 3,500          |
| Gate valve and box, 04"             | 4               | EA          | \$ 370           | \$ 1,480          |
| Air valve                           | 3               | EA          | \$ 1,000         | \$ 3,000          |
| Flush valve                         | 4               | EA          | \$ 750           | \$ 3,000          |
| Metal detectable tape               | 15,394          | LF          | \$ 0.15          | \$ 2,309          |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 476,927</b> |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | 2               | EA          | \$ 7,500         | \$ 15,000         |
| Pump Station Piping, 04"            | 2               | EA          | \$ 4,000         | \$ 8,000          |
| Gate valve, 04"                     | 4               | EA          | \$ 405           | \$ 1,620          |
| Check valve, 04"                    | 2               | EA          | \$ 595           | \$ 1,190          |
| Electrical/Instrumentation          | 1               | EA          | \$ 10,000        | \$ 10,000         |
| Site work                           | 1               | EA          | \$ 2,000         | \$ 2,000          |
| Building pad                        | 1               | EA          | \$ 4,000         | \$ 4,000          |
| Pump Building                       | 1               | EA          | \$ 10,000        | \$ 10,000         |
| Fence                               | 1               | EA          | \$ 5,870         | \$ 5,870          |
| Tools                               | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Storage Tank - 5000 gals            | 1               | EA          | \$ 7,025         | \$ 7,025          |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 65,705</b>  |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 542,632</b> |
| Contingency                         | 20%             |             |                  | \$ 108,526        |
| Design & Constr Management          | 25%             |             |                  | \$ 135,658        |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 786,817</b> |



**Table G.28****Obtain Water From the City of Alvin****Main Link # 6****Total Pipe Length**

0.99 miles

**Number of Pump Stations Needed**

0

**Pipe Size**

04" inches

**Capital Costs**

| Cost Item | Quantity | Unit | Unit Cost | Total Cost |
|-----------|----------|------|-----------|------------|
|-----------|----------|------|-----------|------------|

*Pipeline Construction*

|                                |       |     |          |                   |
|--------------------------------|-------|-----|----------|-------------------|
| Number of Crossings, bore      | 1     | n/a | n/a      | n/a               |
| Number of Crossings, open cut  | 1     | n/a | n/a      | n/a               |
| PVC water line, Class 200, 04" | 5,251 | LF  | \$ 27    | \$ 141,777        |
| Bore and encasement, 10"       | 200   | LF  | \$ 60    | \$ 12,000         |
| Open cut and encasement, 10"   | 50    | LF  | \$ 35    | \$ 1,750          |
| Gate valve and box, 04"        | 2     | EA  | \$ 370   | \$ 740            |
| Air valve                      | 1     | EA  | \$ 1,000 | \$ 1,000          |
| Flush valve                    | 2     | EA  | \$ 750   | \$ 1,500          |
| Metal detectable tape          | 5,251 | LF  | \$ 0.15  | \$ 788            |
| <b>Subtotal</b>                |       |     |          | <b>\$ 159,555</b> |

*Pump Station(s) Installation*

|                            |   |    |           |             |
|----------------------------|---|----|-----------|-------------|
| Pump                       | - | EA | \$ 7,500  | \$ -        |
| Pump Station Piping, 04"   | - | EA | \$ 4,000  | \$ -        |
| Gate valve, 04"            | - | EA | \$ 405    | \$ -        |
| Check valve, 04"           | - | EA | \$ 595    | \$ -        |
| Electrical/Instrumentation | - | EA | \$ 10,000 | \$ -        |
| Site work                  | - | EA | \$ 2,000  | \$ -        |
| Building pad               | - | EA | \$ 4,000  | \$ -        |
| Pump Building              | - | EA | \$ 10,000 | \$ -        |
| Fence                      | - | EA | \$ 5,870  | \$ -        |
| Tools                      | - | EA | \$ 1,000  | \$ -        |
| Storage Tank - 5000 gals   | - | EA | \$ 7,025  | \$ -        |
| <b>Subtotal</b>            |   |    |           | <b>\$ -</b> |

|                                    |                   |
|------------------------------------|-------------------|
| <b>Subtotal of Component Costs</b> | <b>\$ 159,555</b> |
|------------------------------------|-------------------|

|                            |     |           |
|----------------------------|-----|-----------|
| Contingency                | 20% | \$ 31,911 |
| Design & Constr Management | 25% | \$ 39,889 |

|                            |                   |
|----------------------------|-------------------|
| <b>TOTAL CAPITAL COSTS</b> | <b>\$ 231,354</b> |
|----------------------------|-------------------|

**Table G.29****Segment A****Obtain Water From the City of Alvin****Rosharon Township****Private Pipe Size**

04"

**Total Pipe Length**

0.31 miles

**Total PWS annual water usage**

4,841.3 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 3               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 1,611           | LF          | \$ 27            | \$ 43,497         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | 150             | LF          | \$ 35            | \$ 5,250          |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 1,611           | LF          | \$ 0.15          | \$ 242            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 51,109</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 51,109</b>  |
| Contingency                         | 20%             |             |                  | \$ 10,222         |
| Design & Constr Management          | 25%             |             |                  | \$ 12,777         |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 74,108</b>  |

**Table G.30****Segment B****Obtain Water From the City of Alvin****Oak Meadows****Private Pipe Size**

04"

**Total Pipe Length**

0.56 miles

**Total PWS annual water usage**

1,710.9 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 1               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 2,950           | LF          | \$ 27            | \$ 79,650         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | 50              | LF          | \$ 35            | \$ 1,750          |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 2,950           | LF          | \$ 0.15          | \$ 443            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 83,963</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 83,963</b>  |
| Contingency                         | 20%             |             |                  | \$ 16,793         |
| Design & Constr Management          | 25%             |             |                  | \$ 20,991         |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 121,746</b> |

**Table G.31****Segment C****Obtain Water From the City of Alvin****Grasslands****Private Pipe Size**

04"

**Total Pipe Length**

0.09 miles

**Total PWS annual water usage**

9,885.4 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | -               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 454             | LF          | \$ 27            | \$ 12,258         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | -               | LF          | \$ 35            | \$ -              |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 454             | LF          | \$ 0.15          | \$ 68             |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 14,446</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 14,446</b>  |
| Contingency                         | 20%             |             |                  | \$ 2,889          |
| Design & Constr Management          | 25%             |             |                  | \$ 3,612          |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 20,947</b>  |

**Table G.32****Segment D****Obtain Water From the City of Alvin****Stoneridge Lakes****Private Pipe Size**

04"

**Total Pipe Length**

0.12 miles

**Total PWS annual water usage**

2,174.8 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | -               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 653             | LF          | \$ 27            | \$ 17,623         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | -               | LF          | \$ 35            | \$ -              |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 653             | LF          | \$ 0.15          | \$ 98             |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 19,841</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 19,841</b>  |
| Contingency                         | 20%             |             |                  | \$ 3,968          |
| Design & Constr Management          | 25%             |             |                  | \$ 4,960          |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 28,769</b>  |

**Table G.33****Segment E****Obtain Water From the City of Alvin****Sandy Meadows Estates Subdivision****Private Pipe Size**

04"

**Total Pipe Length**

0.24 miles

**Total PWS annual water usage**

4,055.5 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | -               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 1               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 1,282           | LF          | \$ 27            | \$ 34,617         |
| Bore and encasement, 10"            | -               | LF          | \$ 60            | \$ -              |
| Open cut and encasement, 10"        | 50              | LF          | \$ 35            | \$ 1,750          |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 1,282           | LF          | \$ 0.15          | \$ 192            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 38,679</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 38,679</b>  |
| Contingency                         | 20%             |             |                  | \$ 7,736          |
| Design & Constr Management          | 25%             |             |                  | \$ 9,670          |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 56,085</b>  |

**Table G.34****Segment F****Obtain Water From the City of Alvin****Rosharon Road Estates Subdivision****Private Pipe Size**

04"

**Total Pipe Length**

0.28 miles

**Total PWS annual water usage**

3,802.1 MG

**Treated water purchase cost**

\$ 1.25 per 1,000 gals

**Number of Pump Stations Needed**

0

**Capital Costs**

| <b>Cost Item</b>                    | <b>Quantity</b> | <b>Unit</b> | <b>Unit Cost</b> | <b>Total Cost</b> |
|-------------------------------------|-----------------|-------------|------------------|-------------------|
| <i>Pipeline Construction</i>        |                 |             |                  |                   |
| Number of Crossings, bore           | 1               | n/a         | n/a              | n/a               |
| Number of Crossings, open cut       | 2               | n/a         | n/a              | n/a               |
| PVC water line, Class 200, 04"      | 1,466           | LF          | \$ 27            | \$ 39,577         |
| Bore and encasement, 10"            | 200             | LF          | \$ 60            | \$ 12,000         |
| Open cut and encasement, 10"        | 100             | LF          | \$ 35            | \$ 3,500          |
| Gate valve and box, 04"             | 1               | EA          | \$ 370           | \$ 370            |
| Air valve                           | 1               | EA          | \$ 1,000         | \$ 1,000          |
| Flush valve                         | 1               | EA          | \$ 750           | \$ 750            |
| Metal detectable tape               | 1,466           | LF          | \$ 0.15          | \$ 220            |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ 57,416</b>  |
| <i>Pump Station(s) Installation</i> |                 |             |                  |                   |
| Pump                                | -               | EA          | \$ 7,500         | \$ -              |
| Pump Station Piping, 04"            | -               | EA          | \$ 4,000         | \$ -              |
| Gate valve, 04"                     | -               | EA          | \$ 405           | \$ -              |
| Check valve, 04"                    | -               | EA          | \$ 595           | \$ -              |
| Electrical/Instrumentation          | -               | EA          | \$ 10,000        | \$ -              |
| Site work                           | -               | EA          | \$ 2,000         | \$ -              |
| Building pad                        | -               | EA          | \$ 4,000         | \$ -              |
| Pump Building                       | -               | EA          | \$ 10,000        | \$ -              |
| Fence                               | -               | EA          | \$ 5,870         | \$ -              |
| Tools                               | -               | EA          | \$ 1,000         | \$ -              |
| Storage Tank - 5,000 gals           | -               | EA          | \$ 7,025         | \$ -              |
| <b>Subtotal</b>                     |                 |             |                  | <b>\$ -</b>       |
| <b>Subtotal of Component Costs</b>  |                 |             |                  | <b>\$ 57,416</b>  |
| Contingency                         | 20%             |             |                  | \$ 11,483         |
| Design & Constr Management          | 25%             |             |                  | \$ 14,354         |
| <b>TOTAL CAPITAL COSTS</b>          |                 |             |                  | <b>\$ 83,254</b>  |

**Table G.35**

**Alternative Name** *Alvin to each PWS*  
**Alternative Number** *Purchase Water from Alvin to Rosharon Road RR*

|   |         |                |
|---|---------|----------------|
| Distance from Alternative to PWS (along pipe) | 7.0     | miles          |
| Total PWS annual water usage                  | 5.475   | MG             |
| Treated water purchase cost                   | \$ 1.65 | per 1,000 gals |
| Number of Pump Stations Needed                | 1       |                |

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost   | Total Cost          |
|-------------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>        |          |      |             |                     |
| Number of Crossings, bore           | 4        | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut       | 17       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04"      | 36,750   | LF   | \$ 27.00    | \$ 992,250          |
| Bore and encasement, 10"            | 800      | LF   | \$ 60.00    | \$ 48,000           |
| Open cut and encasement, 10"        | 850      | LF   | \$ 35.00    | \$ 29,750           |
| Gate valve and box, 04"             | 7        | EA   | \$ 370.00   | \$ 2,720            |
| Air valve                           | 7        | EA   | \$ 1,000.00 | \$ 7,000            |
| Flush valve                         | 7        | EA   | \$ 750.00   | \$ 5,513            |
| Metal detectable tape               | 36,750   | LF   | \$ 0.15     | \$ 5,513            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 1,090,745</b> |
| <i>Pump Station(s) Installation</i> |          |      |             |                     |
| Pump                                | 1        | EA   | \$ 7,500    | \$ 7,500            |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 405      | \$ 1,620            |
| Check valve, 04"                    | 2        | EA   | \$ 595      | \$ 1,190            |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000    | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870    | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000    | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025    | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 54,205</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |             | <b>\$ 1,144,950</b> |
| Contingency                         | 20%      |      |             | \$ 228,990          |
| Design & Constr Management          | 25%      |      |             | \$ 286,237          |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |             | <b>\$ 1,660,177</b> |



**Table G.36**

**Alternative Name** *Alvin to each PWS*  
**Alternative Number** *Purchase Water from Alvin to Sandy Meadow SM*

**Distance from Alternative to PWS (along pipe)** 7.9 miles  
**Total PWS annual water usage** 5.840 MG  
**Treated water purchase cost** \$ 1.65 per 1,000 gals  
**Number of Pump Stations Needed** 1

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost   | Total Cost          |
|-------------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>        |          |      |             |                     |
| Number of Crossings, bore           | 5        | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut       | 16       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04"      | 41,814   | LF   | \$ 27.00    | \$ 1,128,978        |
| Bore and encasement, 10"            | 1,000    | LF   | \$ 60.00    | \$ 60,000           |
| Open cut and encasement, 10"        | 800      | LF   | \$ 35.00    | \$ 28,000           |
| Gate valve and box, 04"             | 8        | EA   | \$ 370.00   | \$ 3,094            |
| Air valve                           | 8        | EA   | \$ 1,000.00 | \$ 8,000            |
| Flush valve                         | 8        | EA   | \$ 750.00   | \$ 6,272            |
| Metal detectable tape               | 41,814   | LF   | \$ 0.15     | \$ 6,272            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 1,240,616</b> |
| <i>Pump Station(s) Installation</i> |          |      |             |                     |
| Pump                                | 1        | EA   | \$ 7,500    | \$ 7,500            |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 405      | \$ 1,620            |
| Check valve, 04"                    | 2        | EA   | \$ 595      | \$ 1,190            |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000    | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870    | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000    | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025    | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 54,205</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |             | <b>\$ 1,294,821</b> |
| Contingency                         | 20%      |      |             | \$ 258,964          |
| Design & Constr Management          | 25%      |      |             | \$ 323,705          |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |             | <b>\$ 1,877,491</b> |

**Table G.37**

**Alternative Name** *Alvin to each PWS*  
**Alternative Number** *Purchase Water from Alvin to Stoneridge SR*

**Distance from Alternative to PWS (along pipe)** 10.7 miles  
**Total PWS annual water usage** 3.132 MG  
**Treated water purchase cost** \$ 1.65 per 1,000 gals  
**Number of Pump Stations Needed** 1

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost   | Total Cost          |
|-------------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>        |          |      |             |                     |
| Number of Crossings, bore           | 10       | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut       | 20       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04"      | 56,585   | LF   | \$ 27.00    | \$ 1,527,795        |
| Bore and encasement, 10"            | 2,000    | LF   | \$ 60.00    | \$ 120,000          |
| Open cut and encasement, 10"        | 1,000    | LF   | \$ 35.00    | \$ 35,000           |
| Gate valve and box, 04"             | 11       | EA   | \$ 370.00   | \$ 4,187            |
| Air valve                           | 11       | EA   | \$ 1,000.00 | \$ 11,000           |
| Flush valve                         | 11       | EA   | \$ 750.00   | \$ 8,488            |
| Metal detectable tape               | 56,585   | LF   | \$ 0.15     | \$ 8,488            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 1,714,958</b> |
| <i>Pump Station(s) Installation</i> |          |      |             |                     |
| Pump                                | 1        | EA   | \$ 7,500    | \$ 7,500            |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 405      | \$ 1,620            |
| Check valve, 04"                    | 2        | EA   | \$ 595      | \$ 1,190            |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000    | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870    | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000    | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025    | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 54,205</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |             | <b>\$ 1,769,163</b> |
| Contingency                         | 20%      |      |             | \$ 353,833          |
| Design & Constr Management          | 25%      |      |             | \$ 442,291          |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |             | <b>\$ 2,565,286</b> |

**Table G.38**

**Alternative Name** *Alvin to each PWS*  
**Alternative Number** *Purchase Water from Alvin to Grasslands Grass*

**Distance from Alternative to PWS (along pipe)** 11.0 miles  
**Total PWS annual water usage** 14.235 MG  
**Treated water purchase cost** \$ 1.65 per 1,000 gals  
**Number of Pump Stations Needed** 1

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost   | Total Cost          |
|-------------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>        |          |      |             |                     |
| Number of Crossings, bore           | 9        | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut       | 20       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04"      | 57,941   | LF   | \$ 27.00    | \$ 1,564,407        |
| Bore and encasement, 10"            | 1,800    | LF   | \$ 60.00    | \$ 108,000          |
| Open cut and encasement, 10"        | 1,000    | LF   | \$ 35.00    | \$ 35,000           |
| Gate valve and box, 04"             | 12       | EA   | \$ 370.00   | \$ 4,288            |
| Air valve                           | 11       | EA   | \$ 1,000.00 | \$ 11,000           |
| Flush valve                         | 12       | EA   | \$ 750.00   | \$ 8,691            |
| Metal detectable tape               | 57,941   | LF   | \$ 0.15     | \$ 8,691            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 1,740,077</b> |
| <i>Pump Station(s) Installation</i> |          |      |             |                     |
| Pump                                | 1        | EA   | \$ 7,500    | \$ 7,500            |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 405      | \$ 1,620            |
| Check valve, 04"                    | 2        | EA   | \$ 595      | \$ 1,190            |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000    | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870    | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000    | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025    | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 54,205</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |             | <b>\$ 1,794,282</b> |
| Contingency                         | 20%      |      |             | \$ 358,856          |
| Design & Constr Management          | 25%      |      |             | \$ 448,570          |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |             | <b>\$ 2,601,709</b> |

**Table G.39**

**Alternative Name** *Alvin to each PWS*  
**Alternative Number** *Purchase Water from Alvin to Oak Meadows OM*

**Distance from Alternative to PWS (along pipe)** 12.0 miles  
**Total PWS annual water usage** 5.475 MG  
**Treated water purchase cost** \$ 1.65 per 1,000 gals  
**Number of Pump Stations Needed** 1

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost   | Total Cost          |
|-------------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>        |          |      |             |                     |
| Number of Crossings, bore           | 9        | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut       | 20       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04"      | 63,175   | LF   | \$ 27.00    | \$ 1,705,725        |
| Bore and encasement, 10"            | 1,800    | LF   | \$ 60.00    | \$ 108,000          |
| Open cut and encasement, 10"        | 1,000    | LF   | \$ 35.00    | \$ 35,000           |
| Gate valve and box, 04"             | 13       | EA   | \$ 370.00   | \$ 4,675            |
| Air valve                           | 12       | EA   | \$ 1,000.00 | \$ 12,000           |
| Flush valve                         | 13       | EA   | \$ 750.00   | \$ 9,476            |
| Metal detectable tape               | 63,175   | LF   | \$ 0.15     | \$ 9,476            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 1,884,352</b> |
| <i>Pump Station(s) Installation</i> |          |      |             |                     |
| Pump                                | 1        | EA   | \$ 7,500    | \$ 7,500            |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 405      | \$ 1,620            |
| Check valve, 04"                    | 2        | EA   | \$ 595      | \$ 1,190            |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000    | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870    | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000    | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025    | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 54,205</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |             | <b>\$ 1,938,557</b> |
| Contingency                         | 20%      |      |             | \$ 387,711          |
| Design & Constr Management          | 25%      |      |             | \$ 484,639          |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |             | <b>\$ 2,810,908</b> |

**Table G.40**

**Alternative Name** *Alvin to each PWS*  
**Alternative Number** *Purchase Water from Alvin to Rosharon Township RT*

|   |         |                |
|---|---------|----------------|
| Distance from Alternative to PWS (along pipe) | 12.0    | miles          |
| Total PWS annual water usage                  | 6.972   | MG             |
| Treated water purchase cost                   | \$ 1.65 | per 1,000 gals |
| Number of Pump Stations Needed                | 1       |                |

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost   | Total Cost          |
|-------------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>        |          |      |             |                     |
| Number of Crossings, bore           | 10       | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut       | 23       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04"      | 63,559   | LF   | \$ 27.00    | \$ 1,716,093        |
| Bore and encasement, 10"            | 2,000    | LF   | \$ 60.00    | \$ 120,000          |
| Open cut and encasement, 10"        | 1,150    | LF   | \$ 35.00    | \$ 40,250           |
| Gate valve and box, 04"             | 13       | EA   | \$ 370.00   | \$ 4,703            |
| Air valve                           | 12       | EA   | \$ 1,000.00 | \$ 12,000           |
| Flush valve                         | 13       | EA   | \$ 750.00   | \$ 9,534            |
| Metal detectable tape               | 63,559   | LF   | \$ 0.15     | \$ 9,534            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 1,912,114</b> |
| <i>Pump Station(s) Installation</i> |          |      |             |                     |
| Pump                                | 1        | EA   | \$ 7,500    | \$ 7,500            |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 405      | \$ 1,620            |
| Check valve, 04"                    | 2        | EA   | \$ 595      | \$ 1,190            |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000    | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870    | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000    | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025    | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 54,205</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |             | <b>\$ 1,966,319</b> |
| Contingency                         | 20%      |      |             | \$ 393,264          |
| Design & Constr Management          | 25%      |      |             | \$ 491,580          |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |             | <b>\$ 2,851,163</b> |

**Table G.41**

**Alternative Name** *Angleton to each PWS*  
**Alternative Number** *Purchase Water from Angleton to RoshTownship RT*

|   |         |                |
|---|---------|----------------|
| Distance from Alternative to PWS (along pipe) | 11.4    | miles          |
| Total PWS annual water usage                  | 6.972   | MG             |
| Treated water purchase cost                   | \$ 1.60 | per 1,000 gals |
| Number of Pump Stations Needed                | 1       |                |

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost   | Total Cost          |
|-------------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>        |          |      |             |                     |
| Number of Crossings, bore           | 2        | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut       | 12       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04"      | 59,971   | LF   | \$ 27.00    | \$ 1,619,217        |
| Bore and encasement, 10"            | 400      | LF   | \$ 60.00    | \$ 24,000           |
| Open cut and encasement, 10"        | 600      | LF   | \$ 35.00    | \$ 21,000           |
| Gate valve and box, 04"             | 12       | EA   | \$ 370.00   | \$ 4,438            |
| Air valve                           | 11       | EA   | \$ 1,000.00 | \$ 11,000           |
| Flush valve                         | 12       | EA   | \$ 750.00   | \$ 8,996            |
| Metal detectable tape               | 59,971   | LF   | \$ 0.15     | \$ 8,996            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 1,697,646</b> |
| <i>Pump Station(s) Installation</i> |          |      |             |                     |
| Pump                                | 1        | EA   | \$ 7,500    | \$ 7,500            |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 405      | \$ 1,620            |
| Check valve, 04"                    | 2        | EA   | \$ 595      | \$ 1,190            |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000    | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870    | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000    | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025    | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 54,205</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |             | <b>\$ 1,751,851</b> |
| Contingency                         | 20%      |      | \$          | 350,370             |
| Design & Constr Management          | 25%      |      | \$          | 437,963             |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |             | <b>\$ 2,540,184</b> |

**Table G.42**

**Alternative Name** *Angleton to each PWS*  
**Alternative Number** *Purchase Water from Angleton to Oak Meadow OM*

|   |         |                |
|---|---------|----------------|
| Distance from Alternative to PWS (along pipe) | 12.1    | miles          |
| Total PWS annual water usage                  | 2.464   | MG             |
| Treated water purchase cost                   | \$ 1.60 | per 1,000 gals |
| Number of Pump Stations Needed                | 1       |                |

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost   | Total Cost          |
|-------------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>        |          |      |             |                     |
| Number of Crossings, bore           | 2        | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut       | 11       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04"      | 64,123   | LF   | \$ 27.00    | \$ 1,731,321        |
| Bore and encasement, 10"            | 400      | LF   | \$ 60.00    | \$ 24,000           |
| Open cut and encasement, 10"        | 550      | LF   | \$ 35.00    | \$ 19,250           |
| Gate valve and box, 04"             | 13       | EA   | \$ 370.00   | \$ 4,745            |
| Air valve                           | 12       | EA   | \$ 1,000.00 | \$ 12,000           |
| Flush valve                         | 13       | EA   | \$ 750.00   | \$ 9,618            |
| Metal detectable tape               | 64,123   | LF   | \$ 0.15     | \$ 9,618            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 1,810,553</b> |
| <i>Pump Station(s) Installation</i> |          |      |             |                     |
| Pump                                | 1        | EA   | \$ 7,500    | \$ 7,500            |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 405      | \$ 1,620            |
| Check valve, 04"                    | 2        | EA   | \$ 595      | \$ 1,190            |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000    | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870    | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000    | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025    | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 54,205</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |             | <b>\$ 1,864,758</b> |
| Contingency                         | 20%      |      |             | \$ 372,952          |
| Design & Constr Management          | 25%      |      |             | \$ 466,190          |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |             | <b>\$ 2,703,899</b> |

**Table G.43**

**Alternative Name** *Angleton to each PWS*  
**Alternative Number** *Purchase Water from Angleton to Grasslands Grass*

**Distance from Alternative to PWS (along pipe)** 11.4 miles  
**Total PWS annual water usage** 14.235 MG  
**Treated water purchase cost** \$ 1.60 per 1,000 gals  
**Number of Pump Stations Needed** 1

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost   | Total Cost          |
|-------------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>        |          |      |             |                     |
| Number of Crossings, bore           | 3        | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut       | 11       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04"      | 60,025   | LF   | \$ 27.00    | \$ 1,620,675        |
| Bore and encasement, 10"            | 600      | LF   | \$ 60.00    | \$ 36,000           |
| Open cut and encasement, 10"        | 550      | LF   | \$ 35.00    | \$ 19,250           |
| Gate valve and box, 04"             | 12       | EA   | \$ 370.00   | \$ 4,442            |
| Air valve                           | 11       | EA   | \$ 1,000.00 | \$ 11,000           |
| Flush valve                         | 12       | EA   | \$ 750.00   | \$ 9,004            |
| Metal detectable tape               | 60,025   | LF   | \$ 0.15     | \$ 9,004            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 1,709,374</b> |
| <i>Pump Station(s) Installation</i> |          |      |             |                     |
| Pump                                | 1        | EA   | \$ 7,500    | \$ 7,500            |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 405      | \$ 1,620            |
| Check valve, 04"                    | 2        | EA   | \$ 595      | \$ 1,190            |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000    | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870    | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000    | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025    | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 54,205</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |             | <b>\$ 1,763,579</b> |
| Contingency                         | 20%      |      | \$          | 352,716             |
| Design & Constr Management          | 25%      |      | \$          | 440,895             |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |             | <b>\$ 2,557,190</b> |



**Table G.44**

**Angleton to each PWS**  
**Purchase Water from Angleton to Stoneridge**  
**SR**

|   |                        |
|---|------------------------|
| Distance from Alternative to PWS (along pipe) | 11.1 miles             |
| Total PWS annual water usage                  | 3.132 MG               |
| Treated water purchase cost                   | \$ 1.60 per 1,000 gals |
| Number of Pump Stations Needed                | 1                      |

**Capital Costs**

| Cost Item                      | Quantity | Unit | Unit Cost   | Total Cost          |
|--------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>   |          |      |             |                     |
| Number of Crossings, bore      | 4        | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut  | 15       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04" | 58,825   | LF   | \$ 27.00    | \$ 1,588,275        |
| Bore and encasement, 10"       | 800      | LF   | \$ 60.00    | \$ 48,000           |
| Open cut and encasement, 10"   | 750      | LF   | \$ 35.00    | \$ 26,250           |
| Gate valve and box, 04"        | 12       | EA   | \$ 370.00   | \$ 4,353            |
| Air valve                      | 11       | EA   | \$ 1,000.00 | \$ 11,000           |
| Flush valve                    | 12       | EA   | \$ 750.00   | \$ 8,824            |
| Metal detectable tape          | 58,825   | LF   | \$ 0.15     | \$ 8,824            |
| <b>Subtotal</b>                |          |      |             | <b>\$ 1,695,526</b> |

*Pump Station(s) Installation*

|                            |   |    |           |                  |
|----------------------------|---|----|-----------|------------------|
| Pump                       | 1 | EA | \$ 7,500  | \$ 7,500         |
| Pump Station Piping, 04"   | 1 | EA | \$ 4,000  | \$ 4,000         |
| Gate valve, 04"            | 4 | EA | \$ 405    | \$ 1,620         |
| Check valve, 04"           | 2 | EA | \$ 595    | \$ 1,190         |
| Electrical/Instrumentation | 1 | EA | \$ 10,000 | \$ 10,000        |
| Site work                  | 1 | EA | \$ 2,000  | \$ 2,000         |
| Building pad               | 1 | EA | \$ 4,000  | \$ 4,000         |
| Pump Building              | 1 | EA | \$ 10,000 | \$ 10,000        |
| Fence                      | 1 | EA | \$ 5,870  | \$ 5,870         |
| Tools                      | 1 | EA | \$ 1,000  | \$ 1,000         |
| Storage Tank - 5,000 gals  | 1 | EA | \$ 7,025  | \$ 7,025         |
| <b>Subtotal</b>            |   |    |           | <b>\$ 54,205</b> |

**Subtotal of Component Costs                      \$ 1,749,731**

|                            |     |            |
|----------------------------|-----|------------|
| Contingency                | 20% | \$ 349,946 |
| Design & Constr Management | 25% | \$ 437,433 |

**TOTAL CAPITAL COSTS                      \$ 2,537,109**

**Table G.45**

**Alternative Name** *Angleton to each PWS*  
**Alternative Number** *Purchase Water from Ang to Sandy Meadow SM*

**Distance from Alternative to PWS (along pipe)** 14.2 miles  
**Total PWS annual water usage** 5,840 MG  
**Treated water purchase cost** \$ 1.60 per 1,000 gals  
**Number of Pump Stations Needed** 1

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost   | Total Cost          |
|-------------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>        |          |      |             |                     |
| Number of Crossings, bore           | 7        | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut       | 15       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04"      | 75,087   | LF   | \$ 27.00    | \$ 2,027,349        |
| Bore and encasement, 10"            | 1,400    | LF   | \$ 60.00    | \$ 84,000           |
| Open cut and encasement, 10"        | 750      | LF   | \$ 35.00    | \$ 26,250           |
| Gate valve and box, 04"             | 15       | EA   | \$ 370.00   | \$ 5,556            |
| Air valve                           | 14       | EA   | \$ 1,000.00 | \$ 14,000           |
| Flush valve                         | 15       | EA   | \$ 750.00   | \$ 11,263           |
| Metal detectable tape               | 75,087   | LF   | \$ 0.15     | \$ 11,263           |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 2,179,682</b> |
| <i>Pump Station(s) Installation</i> |          |      |             |                     |
| Pump                                | 1        | EA   | \$ 7,500    | \$ 7,500            |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 405      | \$ 1,620            |
| Check valve, 04"                    | 2        | EA   | \$ 595      | \$ 1,190            |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000    | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870    | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000    | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025    | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 54,205</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |             | <b>\$ 2,233,887</b> |
| Contingency                         | 20%      |      | \$          | 446,777             |
| Design & Constr Management          | 25%      |      | \$          | 558,472             |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |             | <b>\$ 3,239,135</b> |

**Table G.46**

**Angleton to each PWS**  
**Alternative Name Purchase Water from Ang to Roasharon Road**  
**Alternative Number RR**

|   |                        |
|---|------------------------|
| Distance from Alternative to PWS (along pipe) | 14.6 miles             |
| Total PWS annual water usage                  | 5.475 MG               |
| Treated water purchase cost                   | \$ 1.60 per 1,000 gals |
| Number of Pump Stations Needed                | 1                      |

**Capital Costs**

| Cost Item                           | Quantity | Unit | Unit Cost   | Total Cost          |
|-------------------------------------|----------|------|-------------|---------------------|
| <i>Pipeline Construction</i>        |          |      |             |                     |
| Number of Crossings, bore           | 9        | n/a  | n/a         | n/a                 |
| Number of Crossings, open cut       | 17       | n/a  | n/a         | n/a                 |
| PVC water line, Class 200, 04"      | 77,073   | LF   | \$ 27.00    | \$ 2,080,971        |
| Bore and encasement, 10"            | 1,800    | LF   | \$ 60.00    | \$ 108,000          |
| Open cut and encasement, 10"        | 850      | LF   | \$ 35.00    | \$ 29,750           |
| Gate valve and box, 04"             | 15       | EA   | \$ 370.00   | \$ 5,703            |
| Air valve                           | 15       | EA   | \$ 1,000.00 | \$ 15,000           |
| Flush valve                         | 15       | EA   | \$ 750.00   | \$ 11,561           |
| Metal detectable tape               | 77,073   | LF   | \$ 0.15     | \$ 11,561           |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 2,262,546</b> |
| <i>Pump Station(s) Installation</i> |          |      |             |                     |
| Pump                                | 1        | EA   | \$ 7,500    | \$ 7,500            |
| Pump Station Piping, 04"            | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Gate valve, 04"                     | 4        | EA   | \$ 405      | \$ 1,620            |
| Check valve, 04"                    | 2        | EA   | \$ 595      | \$ 1,190            |
| Electrical/Instrumentation          | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Site work                           | 1        | EA   | \$ 2,000    | \$ 2,000            |
| Building pad                        | 1        | EA   | \$ 4,000    | \$ 4,000            |
| Pump Building                       | 1        | EA   | \$ 10,000   | \$ 10,000           |
| Fence                               | 1        | EA   | \$ 5,870    | \$ 5,870            |
| Tools                               | 1        | EA   | \$ 1,000    | \$ 1,000            |
| Storage Tank - 5,000 gals           | 1        | EA   | \$ 7,025    | \$ 7,025            |
| <b>Subtotal</b>                     |          |      |             | <b>\$ 54,205</b>    |
| <b>Subtotal of Component Costs</b>  |          |      |             | <b>\$ 2,316,751</b> |
| Contingency                         | 20%      |      | \$          | 463,350             |
| Design & Constr Management          | 25%      |      | \$          | 579,188             |
| <b>TOTAL CAPITAL COSTS</b>          |          |      |             | <b>\$ 3,359,289</b> |