

DRAFT FEASIBILITY REPORT FEASIBILITY ANALYSIS OF WATER SUPPLY FOR SMALL PUBLIC WATER SYSTEMS

ORBIT SYSTEMS, INC. - ROSHARON ROAD ESTATES
PWS ID# 0200346, CCN# 11982

Prepared for:

THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



Prepared by:

THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC GEOLOGY

AND

PARSONS

Preparation of this report was financed by the Texas Commission on Environmental Quality through the Drinking Water State Revolving Fund Small Systems Assistance Program

AUGUST 2005

Draft Feasibility Report

FEASIBILITY ANALYSIS OF WATER SUPPLY FOR SMALL PUBLIC WATER SYSTEMS

Orbit Systems, Inc - Rosharon Road Estates
PWS ID# 0200346, CCN# 11982

Prepared for:

THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Prepared by:

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC
GEOLOGY
AND**

PARSONS

***PREPARATION OF THIS REPORT WAS FINANCED BY THE TEXAS COMMISSION
ON ENVIRONMENTAL QUALITY THROUGH THE DRINKING WATER STATE
REVOLVING FUND SMALL SYSTEMS ASSISTANCE PROGRAM***

THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF INTERIM REVIEW UNDER
THE AUTHORITY OF ERIC J. DAWSON, P.E. 79564 ON AUGUST 31, 2005. IT IS NOT TO
BE USED FOR CONSTRUCTION, BIDDING, OR PERMIT PURPOSES.

August 2005

1

EXECUTIVE SUMMARY

2

INTRODUCTION

3

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Infrastructure and Technology Group Inc. (Parsons), were contracted by the Texas Commission on Environmental Quality (TCEQ) to conduct a study to assist with identifying and analyzing alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

8

The overall goal of this project was to promote compliance using sound engineering and financial methods and data for PWSs that had recently recorded sample results exceeding maximum contaminant levels (MCL). The primary objectives of this project were to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS for future implementation.

15

This feasibility report provides an evaluation of water supply alternatives for the Rosharon Road Estates (RRE) PWS, located in Brazoria County. Samples for arsenic were below the previous MCL for arsenic of 50 micrograms per liter ($\mu\text{g/L}$), which was the MCL for arsenic at the time of sample collection; however, the arsenic concentrations were above the 10 $\mu\text{g/L}$ MCL for arsenic effective beginning January 23, 2006 (USEPA 2005a; TCEQ 2004a). Therefore, it was likely that RRE PWS would face potential compliance issues under the new arsenic drinking water standard.

22

Basic system information for the RRE PWS is shown in Table ES.1.

23

Table ES.1

24

RRE PWS

25

Basic System Information

Population served	230
Connections	76
Average daily flow rate	0.015 million gallons per day (mgd)
Peak demand flow rate	41.7 gallons per minute
Water system peak capacity	0.172 mgd
Typical arsenic range	23 to 26 $\mu\text{g/L}$

1 **STUDY METHODS**

2 The methods used for this study were based on a pilot study performed in 2004 and
3 2005 by TCEQ, BEG, and Parsons. Methods for identifying and analyzing compliance
4 options were developed in the pilot study (a decision tree approach).

5 The process for developing the feasibility study used the following general steps:

- 6 1. Gather data from the TCEQ and Texas Water Development Board
7 databases, from TCEQ files, and from information maintained by the
8 PWS;
- 9 2. Conduct financial, managerial, and technical (FMT) evaluations of the
10 PWS;
- 11 3. Perform a geologic and hydrogeologic assessment of the study area;
- 12 4. Develop treatment and non-treatment compliance alternatives which, in
13 general, consist of the following possible options:
 - 14 a. Connecting to neighboring PWSs via new pipeline or by pumping
15 water from a newly installed well or an available surface water
16 supply within the jurisdiction of the neighboring PWS;
 - 17 b. Installing new wells within the vicinity of the PWS into other
18 aquifers with confirmed water quality standards meeting the
19 MCLs;
 - 20 c. Installing a new intake system within the vicinity of the PWS to
21 obtain water from a surface water supply with confirmed water
22 quality standards meeting the MCLs;
 - 23 d. Treating the existing non-compliant water supply by various
24 methods depending on the type of contaminant; and
 - 25 e. Delivering potable water by way of a bottled water program or a
26 treated water dispenser as an interim measure only.
- 27 5. Assess each of the potential alternatives with respect to economic and
28 non-economic criteria; and
- 29 6. Prepare a feasibility report and present the results to the PWS.


30 This basic approach is summarized in Figure ES-1.

31 **HYDROGEOLOGICAL ANALYSIS**

32 The RRE PWS obtains groundwater from the Chicot subunit of the Gulf Coast
33 aquifer. Arsenic is commonly found in area wells at concentrations greater than the
34 MCL. Volcanic ash incorporated into the aquifer material may be the source of arsenic.
35 Arsenic concentrations can vary significantly over relatively short distances; as a result,
36

1
2

Figure ES-1
Summary of Project Methods



1 there could be good quality groundwater nearby. However, the variability of arsenic
2 concentrations makes it difficult to determine where wells can be located to produce
3 acceptable water. Additionally, systems with more than one well should characterize the
4 water quality of each well. If one of the wells is found to produce compliant water, as
5 much production as possible should be shifted to that well as a method of achieving
6 compliance. It may also be possible to do down-hole testing on non-compliant wells to
7 determine the source of the contaminant. If the contaminant derives primarily from a
8 single part of the formation, that part could be excluded by modifying the existing well,
9 or avoided altogether by completing a new well.

10 **COMPLIANCE ALTERNATIVES**

11 The RRE PWS is managed by Orbit Systems, an investor-owned utility that manages
12 33 water systems in the region. Overall, the system had an adequate level of FMT
13 capacity. The system had some areas that needed improvement to be able to address
14 future compliance issues; however, the system does have many positive aspects,
15 including staff longevity, good communication, in-house expertise, effective planning for
16 system growth, the regional nature of the Orbit organization, and maintenance and use of
17 up-to-date system maps. Areas of concern for the system included lack of regular
18 training; lack of ventilation, alarms, and breathing apparatus for chlorine buildings; lack
19 of budgeting for individual systems; lack of capital improvement planning; lack of
20 emergency planning; and lack of independently audited financial reports.

21 There are numerous PWSs within 10 miles of RRE. Many of these nearby systems
22 also have problems with arsenic, but there are several with good quality water. In
23 general, feasibility alternatives were developed based on obtaining water from the nearest
24 PWSs, either by directly purchasing water, or by expanding the existing well field. There
25 is a minimum of surface water available in the area, and obtaining a new surface water
26 source is considered through an alternative where treated surface water is obtained from
27 the Brazosport Water Authority (BWA). In addition to the BWA, the City of Alvin is a
28 potential large regional water supplier, and there are plans for the Gulf Coast Water
29 Authority to build a surface water treatment plant in Fort Bend County that could
30 potentially supply water to RRE.

31 A number of centralized treatment alternatives for arsenic removal have been
32 developed and were considered for this report, for example, iron-based adsorption and
33 coagulation/filtration. Point-of-use (POU) and point-of-entry treatment alternatives were
34 also considered. Temporary solutions such as providing bottled water or providing a
35 centralized dispenser for treated or trucked-in water, were also considered as alternatives.

36 Developing a new well close to RRE is likely to be the best solution if compliant
37 groundwater can be found. Having a new well close to RRE is likely to be one of the
38 lower cost alternatives since the PWS already possesses the technical and managerial
39 expertise needed to implement this option. The cost of new well alternatives quickly
40 increases with pipeline length, making proximity of the alternate source a key concern.

1 A new compliant well or obtaining water from a neighboring compliant PWS has the
2 advantage of providing compliant water to all taps in the system.

3 Central treatment can be cost-competitive with the alternative of new nearby wells,
4 but would require significant institutional changes to manage and operate. Like
5 obtaining an alternate compliant water source, central treatment would provide compliant
6 water to all water taps.

7 POU treatment can be cost competitive, but does not supply compliant water to all
8 taps. Additionally, significant efforts would be required for maintenance and monitoring
9 of the POU treatment units.

10 Providing compliant water through a central dispenser is significantly less expensive
11 than providing bottled water to 100 percent of the population, but a significant effort is
12 required for clients to fill their containers at the central dispenser.

13 **FINANCIAL ANALYSIS**

14 Financial analysis of the RRE PWS indicated that current water rates are under
15 funding operations, and a rate increase of approximately 1.3 percent would be necessary
16 to meet operating expenses. This increase would raise the average annual water bill from
17 \$373 to \$378. The current average water bill represents approximately 0.9 percent of the
18 median household income (MHI), and would represent approximately the same amount
19 with the increase. Table ES.2 provides a summary of the financial impact of
20 implementing selected compliance alternatives, including the rate increase necessary to
21 meet current operating expenses. The alternatives were selected to highlight results for
22 the best alternatives from each different type or category.

23 Some of the compliance alternatives offer potential for shared or regional solutions.
24 A group of PWSs could work together to implement alternatives for developing a new
25 groundwater source or expanding an existing source, obtaining compliant water from a
26 large regional provider, or for central treatment. Sharing the cost for implementation of
27 these alternatives could reduce the cost on a per user basis. Additionally, merging PWSs
28 or management of several PWSs by a single entity offers the potential for reduction in
29 administrative costs.

1
2

Table ES.2
Selected Financial Analysis Results

Alternative	Funding Option	Average Annual Water Bill	Percent of MHI
Current	NA	\$373	0.8
To meet current expenses	NA	\$378	0.8
Nearby well within approximately 1 mile	100% Grant	\$448	1.0
	Loan/Bond	\$873	2.0
Central treatment	100% Grant	\$1,536	3.0
	Loan/Bond	\$2,200	5.0
Point-of-use	100% Grant	\$1,875	4.0
	Loan/Bond	\$1,960	4.0
Public dispenser	100% Grant	\$994	2.0
	Loan/Bond	\$1,014	2.0

TABLE OF CONTENTS

1		
2	EXECUTIVE SUMMARY	ES-1
3	Introduction.....	ES-1
4	Study Methods	ES-2
5	Hydrogeological Analysis.....	ES-2
6	Compliance Alternatives.....	ES-4
7	Financial Analysis.....	ES-5
8	TABLE OF CONTENTS	i
9	LIST OF TABLES	v
10	LIST OF FIGURES	v
11	ACRONYMS AND ABBREVIATIONS.....	vii
12	SECTION 1 INTRODUCTION.....	1-1
13	1.1 Public Health and Compliance with MCLs	1-2
14	1.2 Methodology	1-2
15	1.3 Regulatory Perspective	1-4
16	1.4 Abatement Options	1-4
17	1.4.1 Existing Public Water Supply Systems	1-5
18	1.4.1.1 Quantity	1-5
19	1.4.1.2 Quality	1-6
20	1.4.2 Potential for New Groundwater Sources	1-6
21	1.4.2.1 Existing Non-Public Supply Wells.....	1-6
22	1.4.2.2 Develop New Wells.....	1-7
23	1.4.3 Potential for Surface Water Sources.....	1-7
24	1.4.3.1 Existing Surface Water Sources	1-8
25	1.4.3.2 New Surface Water Sources	1-8
26	1.4.4 Identification of Treatment Technologies.....	1-9
27	1.4.4.1 Treatment Technologies for Arsenic	1-9
28	1.4.5 Description of Treatment Technologies	1-10
29	1.4.5.1 Ion Exchange	1-10
30	1.4.5.2 Reverse Osmosis.....	1-11
31	1.4.5.3 Adsorption	1-13
32	1.4.5.4 Coagulation/Filtration and Iron Removal Technologies	1-15
33	1.4.6 Point-of-Entry and Point-of-Use Treatment Systems.....	1-16
34	1.4.7 Water Delivery or Central Drinking Water Dispensers.....	1-17

1	SECTION 2 EVALUATION METHODOLOGY	2-1
2	2.1 Decision Tree	2-1
3	2.2 Data Sources and Data Collection	2-1
4	2.2.1 Data Search	2-1
5	2.2.1.1 Water Supply Systems	2-1
6	2.2.1.2 Existing Wells.....	2-6
7	2.2.1.3 Surface Water Sources.....	2-6
8	2.2.1.4 Groundwater Availability Model.....	2-6
9	2.2.1.5 Water Availability Model	2-6
10	2.2.1.6 Financial Data.....	2-7
11	2.2.1.7 Demographic Data	2-7
12	2.2.2 PWS Interviews	2-7
13	2.2.2.1 PWS Capacity Assessment Process.....	2-7
14	2.2.2.2 Interview Process.....	2-9
15	2.3 Alternative Development and Analysis	2-9
16	2.3.1 Existing Public Water Systems.....	2-10
17	2.3.2 New Groundwater Source.....	2-10
18	2.3.3 New Surface Water Source.....	2-11
19	2.3.4 Treatment	2-11
20	2.4 Cost of Service and Funding Analysis.....	2-12
21	2.4.1 Financial Feasibility.....	2-12
22	2.4.2 Median Household Income	2-12
23	2.4.3 Annual Average Water Bill	2-12
24	2.4.4 Financial Plan Development.....	2-13
25	2.4.5 Financial Plan Results.....	2-14
26	2.4.5.1 Funding Options	2-14
27	2.4.5.2 General Assumptions Embodied in Financial Plan Results	2-15
28	2.4.5.3 Interpretation of Financial Plan Results	2-15
29	2.4.5.4 Potential Funding Sources	2-15
30	SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS.....	3-1
31	3.1 Arsenic in the Gulf Coast Aquifer	3-1
32	3.2 Geology of Brazoria County.....	3-2
33	3.3 General Trends in Arsenic Concentrations.....	3-4
34	3.4 Arsenic and Point Sources of Contamination.....	3-7
35	3.5 Salt Domes	3-8
36	3.6 Correlation with Depth	3-9

1	3.7	Detailed Assessment	3-9
2	3.7.1	Rosharon Road Estates Subdivision (PWS 0200346)	3-11
3	SECTION 4 ANALYSIS OF THE ROSHARON ROAD ESTATES PWS		4-1
4	4.1	Description of Existing System	4-1
5	4.1.1	Existing System	4-1
6	4.1.2	Capacity Assessment for Orbit Systems, Inc.	4-3
7	4.1.2.1	General Structure	4-3
8	4.1.2.2	General Assessment of Capacity	4-3
9	4.1.2.3	Positive Aspects of Capacity	4-3
10	4.1.2.4	Capacity Deficiencies	4-4
11	4.1.2.5	Potential Capacity Concerns	4-5
12	4.2	Alternative Water Source Development	4-6
13	4.2.1	Identification of Alternative Existing Public Water Supply Sources	4-6
14	4.2.1.1	Briar Meadows	4-11
15	4.2.1.2	J M P Utilities	4-11
16	4.2.1.3	Oak Bend Estates	4-12
17	4.2.1.4	TDCJ Darrington Unit	4-12
18	4.2.1.5	Best Sea Pack	4-12
19	4.2.1.6	City of Alvin	4-13
20	4.2.1.7	City of Hillcrest Village	4-13
21	4.2.1.8	City of Angleton/Brazosport Water Authority	4-14
22	4.2.2	Potential for New Groundwater Sources	4-14
23	4.2.2.1	Existing Non-Public Supply Wells	4-14
24	4.2.2.2	Results of Groundwater Availability Modeling	4-15
25	4.2.3	Potential for New Surface Water Sources	4-16
26	4.2.4	Options for Detailed Consideration	4-16
27	4.3	Treatment Options	4-17
28	4.3.1	Centralized Treatment Systems	4-17
29	4.3.2	Point-of-Entry Systems	4-17
30	4.3.3	Point-of-Use Systems	4-17
31	4.4	Bottled Water	4-17
32	4.5	Alternative Development and Analysis	4-18
33	4.5.1	Alternative RR-1: Purchase Treated Water from J M P Utilities	4-18
34	4.5.2	Alternative RR-2: New Well at TDCJ Darrington	4-19
35	4.5.3	Alternative RR-3: Purchase Treated Water from the City of Alvin	4-19
36	4.5.4	Alternative RR-4: Purchase Treated Water from Hillcrest Village	4-20

1	4.5.5	Alternative RR-5: Purchase Treated Water from Brazos Water Authority ..	4-20
2	4.5.6	Alternative RR-6: New Well at Briar Meadows.....	4-21
3	4.5.7	Alternative RR-7: New Well at Oak Bend	4-22
4	4.5.8	Alternative RR-8: New Well at Best Sea Pack, Inc.....	4-23
5	4.5.9	Alternative RR-9: Central Iron-Based Adsorption Treatment.....	4-24
6	4.5.10	Alternative RR-10: Central Coagulation/Filtration Treatment.....	4-24
7	4.5.11	Alternative RR-11: Point-of-Use Treatment - Adsorption	4-25
8	4.5.12	Alternative RR-12: Point-of-Entry Treatment - Adsorption.....	4-26
9	4.5.13	Alternative RR-13: New Well at 10 Miles	4-27
10	4.5.14	Alternative RR-14: New Well at 5 Miles	4-27
11	4.5.15	Alternative RR-15: New Well at 1 Mile	4-28
12	4.5.16	Alternative RR-16: Public Dispenser for Treated Drinking Water	4-29
13	4.5.17	Alternative RR-17: 100 Percent Bottled Water Delivery	4-30
14	4.5.18	Alternative RR-18: Public Dispenser for Trucked Drinking Water	4-30
15	4.5.19	Summary of Alternatives	4-31
16	4.6	Cost of Service and Funding Analysis.....	4-34
17	4.6.1	Financial Plan Development.....	4-34
18	4.6.1.1	Rosharon Road Estates Financial Data.....	4-34
19	4.6.1.2	Current Financial Condition	4-35
20	4.6.1.3	Financial Plan Results.....	4-37
21	SECTION 5 REFERENCES.....		5-1

APPENDICES

22			
23	Appendix A	PWS Interview Form	
24	Appendix B	Cost Basis	
25	Appendix C	Compliance Alternative Conceptual Cost Estimates	
26	Appendix D	Example Financial Model	
27	Appendix E	General Arsenic Geochemistry	
28	Appendix F	Orbit Systems Water Usage	
29	Appendix G	Analysis of Shared Solutions for Obtaining Water from BWA and City of	
30		Alvin	

1

LIST OF TABLES

2	Table ES.1	RRE PWS Basic System Information.....	ES-1
3	Table ES.2	Selected Financial Analysis Results	ES-6
4	Table 3.1	Maximum and Minimum Arsenic Concentrations	3-10
5	Table 3.2	Arsenic Concentrations in Rosharon Road Estates Subdivision PWS	3-11
6	Table 3.3	Maximum and Minimum Arsenic Concentrations in the 5- and 10-km	
7		Buffers of Rosharon Road Estates Subdivision PWS.....	3-13
8	Table 4.1	Surrounding Public Water Systems within 15 miles of RRE	4-6
9	Table 4.2	Public Water Systems within 15 Miles of RRE Selected for Further	
10		Evaluation	4-10
11	Table 4.3	Summary of Compliance Alternatives for RRE	4-32
12	Table 4.4	Summary of Orbit Systems 2004 Water Revenues.....	4-35
13	Table 4.5	Summary of Orbit Systems 2004 Expenses.....	4-35
14	Table 4.6	Summary of Orbit Systems 2004 Operations	4-36
15	Table 4.7	Summary of Orbit Systems Required Revenue Increases	4-36
16	Table 4.8	Financial Impact on Households for RRE	4-38

17

18

LIST OF FIGURES

19	Figure ES-1	Summary of Project Methods	ES-3
20	Figure 1.1	Location Map.....	1-3
21	Figure 2.1	Decision Tree – Tree 1 Existing Facility Analysis.....	2-2
22	Figure 2.2	Decision Tree – Tree 2 Develop Treatment Alternatives	2-3
23	Figure 2.3	Decision Tree – Tree 3 Preliminary Analysis.....	2-4
24	Figure 2.4	Decision Tree – Tree 4 Financial.....	2-5
25	Figure 3.1	Detectable Arsenic Concentrations in Groundwater	3-1
26	Figure 3.2	Detectable Arsenic Concentrations in Groundwater	3-2
27	Figure 3.3	Spatial Distribution of Arsenic Concentrations	3-4
28	Figure 3.4	Spatial Distribution of Arsenic Concentrations	3-5
29	Figure 3.5	Relationship Between Arsenic and Molybdenum	3-6
30	Figure 3.6	Relationship Between Arsenic and Molybdenum	3-6
31	Figure 3.7	Relationship Between High Arsenic Concentrations and pH.....	3-7
32	Figure 3.8	Potential Sources of Arsenic Contamination and Arsenic Concentrations.....	3-7
33	Figure 3.9	Potential Sources of Arsenic Contamination and Arsenic Concentrations.....	3-8
34	Figure 3.10	Salt Dome Locations and Arsenic Concentrations	3-8
35	Figure 3.11	Relationship Between Arsenic Concentrations and Well Depth	3-9

1	Figure 3.12	Arsenic Concentrations in the Vicinity of PWS Wells.....	3-10
2	Figure 3.13	Arsenic Concentrations in 5- and 10-km Buffers of Rosharon Road Estates	
3		Subdivision PWS Wells (TWDB and NURE Databases).....	3-12
4	Figure 3.14	Arsenic Concentrations in 5- and 10-km Buffers of Rosharon Road Estates	
5		Subdivision PWS Wells (TCEQ Database)	3-13
6	Figure 4.1	Rosharon Road Estates Pipeline Alternatives.....	4-2
7	Figure 4.2	Alternative Costs Summary: Rosharon Road Estates.....	4-41

ACRONYMS AND ABBREVIATIONS

°F	Degrees Fahrenheit
µg/L	Micrograms per liter
AA	Activated alumina
BAT	Best available technology
BEG	Bureau of Economic Geology
BWA	Brazosport Water Authority
CA	Chemical analysis
CCN	Certificate of Convenience and Necessity
CFR	Code of Federal Regulations
CO	Correspondence
DWSRF	Drinking Water State Revolving Fund
EDR	Electrodialysis reversal
ETJ	Extra territorial jurisdiction
FMT	Financial, managerial, and technical
GAM	Groundwater Availability Model
gpd	Gallons per day
gpm	Gallons per minute
gpm/ft ²	Gallons per minute per square foot
HGCSD	Harris-Galveston Coastal Subsidence District
ISD	Independent School District
IX	Ion exchange
MCL	Maximum contaminant level
mg/L	Milligram per liter
mgd	Million gallons per day
MHI	Median household income
MOR	Monthly operating report
NMEFC	New Mexico Environmental Financial Center
NURE	National Uranium Resource Evaluation
O&M	Operation and Maintenance
Parsons	Parsons Infrastructure and Technology, Inc.
POE	Point-of-entry
POU	Point-of-use
PSOC	Potential source of contamination
PVC	Polyvinyl chloride
PWS	Public water system
RO	Reverse osmosis
RRE	Rosharon Road Estates
SCBA	Self-contained breathing apparatus
SDWA	Safe Drinking Water Act
SSCT	Small System Compliance Technology

TCEQ	Texas Commission on Environmental Quality
TDCJ	Texas Department of Criminal Justice
TDS	Total dissolved solids
TSS	Total suspended solids
TWDB	Texas Water Development Board
USEPA	U.S. Environmental Protection Agency
WAM	Water Availability Model
WTP	Water treatment plant

SECTION 1
INTRODUCTION

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Infrastructure and Technology Group Inc. (Parsons), have been contracted by the Texas Commission on Environmental Quality (TCEQ) to assist with identifying and analyzing compliance alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards. A total of 15 PWSs were evaluated in this project and each is addressed in a separate report. The 15 systems evaluated for this project are listed below:

Public Water System	Texas County
City of Danbury	Brazoria
Rosharon Road Estates	Brazoria
Mark V Estates	Brazoria
Rosharon Township	Brazoria
Sandy Meadows Estates Subdivision	Brazoria
Grasslands	Brazoria
City of Eden	Concho
City of Mason	Mason
Falling Water	Kerr
Greenwood Independent School District	Midland
County Village Mobile Home Estates	Midland
South Midland County Water Systems	Midland
Warren Road Subdivision Water Supply	Midland
Huber Garden Estates	Ector
Devilla Mobile Home Park	Ector

The overall goal of this project is to promote compliance using sound engineering and financial methods and data for PWSs that have recently had sample results that exceed maximum contaminant levels (MCL). The primary objectives of this project are to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS with regard to future implementation. The feasibility studies identify a range of potential compliance alternatives, and present basic data that can be used for evaluating feasibility. The compliance alternatives addressed include a description of what would be required for implementation, conceptual cost estimates for implementation, and non-cost factors that could be used to differentiate between alternatives. The cost estimates are intended for

1 comparing compliance alternatives, and to give a preliminary indication of potential
2 impacts on water rates resulting from implementation.

3 It is anticipated that the PWS will review the compliance alternatives in this report to
4 determine if there are promising alternatives, and then select the most attractive
5 alternative(s) for more detailed evaluation and possible subsequent implementation. This
6 report contains a decision tree approach that guided the efforts for this study, and also
7 contains steps to guide a PWS through the subsequent evaluation, selection, and
8 implementation of a compliance alternative.

9 This feasibility report provides an evaluation of water supply compliance options for
10 the Rosharon Road Estates (RRE) Water System, PWS ID# 0200346, Certificate of
11 Convenience and Necessity (CCN) # 11982, located in Brazoria County. Recent sample
12 results from the RRE Water System exceeded the MCL for arsenic of 0.01 milligrams per
13 liter (mg/L) that will go into effect January 23, 2006 (USEPA 2005a; TCEQ 2004a). The
14 location of the Rosharon Road Estates Water System, also referred to as the “study area”
15 in this report, is shown on Figure 1.1.



16 **1.1 PUBLIC HEALTH AND COMPLIANCE WITH MCLs**

17 The goal of this project is to promote compliance for PWSs that supply drinking
18 water exceeding regulatory MCLs. This project only addresses those contaminants and
19 does not address any other violations that may exist for a PWS. As mentioned above, the
20 Rosharon Road Estates Water System recently had sample results that exceeded the MCL
21 for arsenic. The health concerns related to drinking water above the MCL for arsenic are
22 briefly described below.

23 In general, contaminants in drinking water above MCLs can have both short-term
24 (acute) and long-term or lifetime (chronic) effects. Potential health effects from
25 long-term ingestion of water with levels of arsenic above the MCL (0.01 mg/L) include
26 non-cancerous effects, such as cardiovascular, pulmonary, immunological, neurological
27 and endocrine effects, and cancerous effects, including skin, bladder, lung, kidney, nasal
28 passage, liver and prostate cancer (USEPA 2005b).

29 **1.2 METHODOLOGY**

30 The methodology for this project follows that of the pilot study performed in 2004
31 and 2005 by TCEQ, BEG, and Parsons. The pilot study evaluated water supply
32 alternatives for PWSs that supply drinking water with nitrate concentrations above
33 USEPA and Texas drinking water standards. Three PWSs were evaluated in the pilot
34 study to develop the methodology (*i.e.*, decision tree approach) for analyzing options for
35 provision of compliant drinking water. This project is performed using the decision tree
36 approach developed in the pilot study.



- Study System
- ▲ Cities
- Counties
- ▭ City Limits
- ▬ Interstate
- ▬ Highway
- ▬ Major Road
- ▬ 15 Mile Radius

Figure 1.1
Rosharon Road Estates
Location Map

1 Other tasks of the feasibility study are as follows:

- 2 • Identifying available data sources;
- 3 • Gathering and compiling data;
- 4 • Conducting financial, managerial, and technical (FMT) evaluations of the
- 5 selected PWSs;
- 6 • Performing a geologic and hydrogeologic assessment of the study area;
- 7 • Developing treatment and non-treatment compliance alternatives;
- 8 • Assessing potential alternatives with respect to economic and non-
- 9 economic criteria;
- 10 • Preparing a feasibility report; and
- 11 • Suggesting refinements to the approach for future studies.

12 The remainder of Section 1 of this report addresses the regulatory background, and
13 provides a summary of compliance alternatives. Section 2 describes the methodology
14 used to develop and assess compliance alternatives. The groundwater sources of arsenic
15 are addressed in Section 3. Findings for the Rosharon Road Estates Water System, along
16 with compliance alternatives development and evaluation, can be found in Section 4.
17 Section 5 references the sources used in this report.

18 **1.3 REGULATORY PERSPECTIVE**

19 The Utilities & Districts and Public Drinking Water Sections of the TCEQ Water
20 Supply Division are responsible for implementing the federal Safe Drinking Water Act
21 (SDWA) requirements that include oversight of PWSs and water utilities. These
22 responsibilities include:

- 23 • Monitoring public drinking water quality;
- 24 • Processing enforcement referrals for MCL violators;
- 25 • Tracking and analyzing compliance options for MCL violators;
- 26 • Providing FMT assessment and assistance to PWSs;
- 27 • Participating in the Drinking Water State Revolving Fund (DWSRF)
- 28 program to assist PWSs in achieving regulatory compliance; and
- 29 • Setting rates for privately-owned water utilities.

30 This project was conducted to assist in achieving these responsibilities.

31 **1.4 ABATEMENT OPTIONS**

32 When a PWS exceeds a regulatory MCL, the PWS must take action to correct the
33 violation. The MCL exceedance at the Rosharon Road Estates PWS is for arsenic. The
34 following subsections explore alternatives considered as potential options for
35 obtaining/providing compliant drinking water.

1 1.4.1 Existing Public Water Supply Systems

2 A common approach to achieve compliance is for the PWS to make arrangements
3 with a neighboring PWS for water supply. For this arrangement to work, the PWS from
4 which water is being purchased (supplier PWS) must have water in sufficient quantity
5 and quality, the political will must exist, and it must be economically feasible.

6 1.4.1.1 Quantity

7 For purposes of this report, quantity refers to water volume, flow rate, and pressure.
8 Before approaching a potential supplier PWS, the non-compliant PWS should determine
9 its water demand on the basis of average day and maximum day. Peak instantaneous
10 demands can be met through proper sizing of storage facilities. Further, the potential for
11 obtaining the appropriate quantity of water to blend to achieve compliance should be
12 considered. The concept of blending involves combining water with low levels of
13 contaminants with non-compliant water in sufficient quantity that the resulting blended
14 water is compliant. The exact blend ratio would depend on the quality of the water a
15 potential supplier PWS can provide, and would likely vary over time. If high quality
16 water is purchased, produced or otherwise obtained, blending can reduce the amount of
17 high quality water required. Implementation of blending will require a control system to
18 ensure the blended water is compliant.

19 If the supplier PWS does not have sufficient quantity, the non-compliant community
20 could pay for the facilities necessary to increase the quantity to the extent necessary to
21 supply the needs of the non-compliant PWS. Potential improvements might include, but
22 are not limited to:

- 23 • Additional wells;
- 24 • Developing a new surface water supply;
- 25 • Additional or larger-diameter piping;
- 26 • Increasing water treatment plant capacity;
- 27 • Additional storage tank volume;
- 28 • Reduction of system losses;
- 29 • Higher-pressure pumps; or
- 30 • Upsized, or additional, disinfection equipment.

31 In addition to the necessary improvements, a transmission pipeline would need to be
32 constructed to tie the two PWSs together. The pipeline must tie-in at a point in the
33 supplier PWS where all the upstream pipes and appurtenances are of sufficient capacity
34 to handle the new demand. In the non-compliant PWS, the pipeline must tie in at a point
35 where no down stream bottlenecks are present. If blending is the selected method of
36 operation, the tie-in point must be at the proper point of the existing non-compliant PWS
37 to ensure that all the water in the system is blended to achieve regulatory compliance.

1 1.4.1.2 Quality

2 If a potential supplier PWS obtains its water from the same aquifer (or same portion
3 of the aquifer) as the non-compliant PWS, the quality of water may not be significantly
4 better. However, water quality can vary significantly due to well location, even within
5 the same aquifer. If localized areas with good water quality cannot be identified, the
6 non-compliant PWS would need to find a potential supplier PWS that obtains its water
7 from a different aquifer or from a surface water source. Additionally, a potential supplier
8 PWS may treat non-compliant raw water to an acceptable level.

9 Surface water sources may offer a potential higher-quality source. Since there are
10 significant treatment requirements, utilization of surface water for drinking water is
11 typically most feasible for larger local or regional authorities or other entities that may
12 provide water to several PWSs. Where PWSs that obtain surface water are neighbors, the
13 non-compliant PWS may need to deal with those systems as well as with the water
14 authorities that supply the surface water.

15 1.4.2 Potential for New Groundwater Sources

16 1.4.2.1 Existing Non-Public Supply Wells

17 Often there are wells not associated with PWSs that are located in the vicinity of the
18 non-compliant PWS. The current use of these wells may be for irrigation, industrial
19 purposes, domestic supply, stock watering, and other purposes. The process for
20 investigating existing wells is as follows:

- 21 • Use existing data sources (see below) to identify wells in the areas that
22 have satisfactory quality. For Brazoria County, the following standards
23 could be used in a rough screening to identify compliant groundwater:
 - 24 ○ Arsenic concentrations less than 0.008 mg/L (below the MCL of
25 0.01 mg/L); and
 - 26 ○ Total dissolved solids (TDS) concentrations less than 1,000 mg/L.
- 27 • Review the recorded well information to eliminate those wells that appear
28 to be unsuitable for the application. Often, the “Remarks” column in the
29 Texas Water Development Board (TWDB) hard-copy database provides
30 helpful information. Wells eliminated from consideration generally
31 include domestic and stock wells, dug wells, test holes, observation wells,
32 seeps and springs, destroyed wells, wells used by other communities, *etc.*
- 33 • Identify wells of sufficient size which have been used for industrial or
34 irrigation purposes. Often the TWDB database includes well yields which
35 may indicate the likelihood of a particular well being a satisfactory source.
- 36 • At this point in the process, the local groundwater control district (if one
37 exists) should be contacted to obtain information about pumping
38 restrictions. Also, preliminary cost estimates should be made to establish
39 the feasibility of pursuing further well development options.

- If particular wells appear to be acceptable, the owner(s) should be contacted to ascertain the willingness to work with the PWS. Once the owner agrees to participate with the program, questions should be asked about the wells. Many owners have more than one well, and would probably be the best source of information regarding the latest test dates, who tested the water, flow rates, and other well characteristics.
- After collecting as much information as possible from cooperative owners, the PWS would then narrow down the selection of wells and sample and analyze the selected wells for quality. Wells with good water quality would then be potential candidates for test pumping. In some cases, a particular well may need to be refurbished before test pumping. Information obtained from test pumping would then be used in combination with information about the general characteristics of the aquifer to determine whether a well at this location would be suitable as a supply source.
- It is recommended that new wells be installed instead of using existing wells to ensure the well characteristics are known and the well meets construction standards.
- Permit(s) would then be obtained from the groundwater control district or other regulatory authority, and an agreement with the owner (purchase or lease, access easements, *etc.*) would then be negotiated.

1.4.2.2 Develop New Wells

If no existing wells are available for development, the PWS or group of PWSs has an option of developing new wells. Records of existing wells, along with other hydrogeologic information and modern geophysical techniques, should be used to identify potential locations for new wells. In some areas, the TWDB's Groundwater Availability Model (GAM) may be applied to indicate potential sources. Once a general area has been identified, land owners and regulatory agencies should be contacted to determine an exact location for a new well or well field. Pump tests and water quality tests would be required to determine if a new well will produce an adequate quantity of good quality water. Permits from the local groundwater control district or other regulatory authority could also be required for a new well.

1.4.3 Potential for Surface Water Sources

Water rights law dominates the acquisition of water from surface water sources. For a PWS, 100 percent availability of water is required, except where a back-up source is available. For PWSs with an existing water source, although it may be non-compliant because of elevated concentrations of one or more parameters, water rights may not need to be 100 percent available.

1.4.3.1 Existing Surface Water Sources

“Existing surface water sources” of water refers to municipal water authorities and cities that obtain water from surface water sources. The process of obtaining water from such a source is generally less time consuming and less costly than the process of developing a new source; therefore, it should be a primary course of investigation. An existing source would be limited by its water rights, the safe yield of a reservoir or river, or by its water treatment or water conveyance capability. The source must be able to meet the current demand and honor contracts with communities it currently supplies. In many cases, the contract amounts reflect projected future water demand based on population or industrial growth.

A non-compliant PWS would look for a source with sufficient spare capacity. Where no such capacity exists, the non-compliant PWS could offer to fund the improvements necessary to obtain the capacity. This approach would work only where the safe yield could be increased (perhaps by enlarging a reservoir) or where treatment capacity could be increased. In some instances, where they are available, water rights could possibly be purchased.

In addition to securing the water supply from an existing source, the non-compliant PWS would have to arrange for the transmission of the water to the PWS. In some cases, this may require negotiations with, contracts with, and payments to an intermediate PWS (an intermediate PWS is one where the infrastructure is used to transmit water from a “supplier” PWS to a “supplied” PWS, but does not provide any additional treatment to the supplied water). The non-compliant PWS could be faced with having to fund improvements to the intermediate PWS in addition to constructing its own necessary transmission facilities.

1.4.3.2 New Surface Water Sources

Communication with the TCEQ and relevant planning groups from the beginning is essential in the process of obtaining a new surface water source. Preliminary assessment of the potential for acquiring new rights may be based on surface water availability maps located on the TWDB website. Where water rights appear to be available, the following activities need to occur:

- Discussions with TCEQ to indicate the likelihood of obtaining those rights. The TCEQ may use the Water Availability Model (WAM) to assist in the determination.
- Discussions with land owners to indicate potential treatment plant locations.
- Coordination with U.S. Army Corps of Engineers and local river authorities.
- Preliminary engineering design to determine the feasibility, costs, and environmental issues of a new intake, treatment plant, and conveyance system.

1 Should these discussions indicate that a new surface water source is the best option,
2 the community would proceed with more intensive planning (initially obtaining funding),
3 permitting, land acquisition, and detailed designs.

4 **1.4.4 Identification of Treatment Technologies**

5 Various treatment technologies were also investigated as compliance alternatives for
6 treatment of arsenic to the regulatory level (*i.e.*, MCL). Numerous options have been
7 identified by the USEPA as best available technologies (BAT) for the non-compliant
8 constituents. Identification and descriptions of the various BATs are provided in the
9 following sections.

10 **1.4.4.1 Treatment Technologies for Arsenic**

11 In January 2001, the USEPA published a final rule in the Federal Register that
12 established an MCL for arsenic of 0.01 mg/L (USEPA 2001). The regulation applies to
13 all community water systems and non-transient, non-community water systems,
14 regardless of size.

15 The new arsenic MCL of 0.01 mg/L becomes effective on January 23, 2006, at
16 which time the running average annual arsenic level must be at or below 0.01 mg/L at
17 each entry point to the distribution system, although point-of-use (POU) treatment can be
18 instituted in place of centralized treatment. All groundwater systems must complete
19 initial monitoring or have a State-approved waiver by December 31, 2007.

20 The following BATs were identified in the final rule for achieving compliance with
21 the arsenic MCL:

- 22 • Reverse Osmosis (RO);
- 23 • Ion Exchange (IX);
- 24 • Electrodialysis Reversal (EDR);
- 25 • Activated Alumina (AA);
- 26 • Oxidation/Filtration;
- 27 • Enhanced Coagulation/Filtration; and
- 28 • Enhanced Lime Softening.

29 In addition, the following technologies are listed in the final rule as Small System
30 Compliance Technologies (SSCT):

- 31 • RO (centralized and POU);
- 32 • IX;
- 33 • EDR;
- 34 • AA (centralized and POU);
- 35 • Oxidation/Filtration;

- Coagulation/Filtration, Enhanced Coagulation/Filtration, and Coagulation-Assisted Microfiltration; and
- Lime Softening and Enhanced Lime Softening.

1.4.5 Description of Treatment Technologies

According to a recent USEPA report for small water systems with <10,000 customers (EPA/600/R-05/001) a number of drinking water treatment technologies are available to reduce arsenic concentrations in source water to below the new MCL of 10 micrograms per liter ($\mu\text{g/L}$), including IX, membrane processes such as RO, adsorption, and coagulation/filtration-related processes. Many of the most effective arsenic removal processes available are iron-based treatment technologies such as chemical coagulation/filtration with iron salts, and adsorptive media with iron-based products. These processes are particularly effective at removing arsenic from aqueous systems because iron surfaces have a strong affinity for adsorbing arsenic. Other arsenic removal processes such as AA and enhanced lime softening are more applicable to larger water systems because of their operational complexity and cost. A description and discussion of arsenic removal technologies applicable to smaller systems follows.

1.4.5.1 Ion Exchange

Process – In solution, salts separate into positively charged cations and negatively charged anions. Ion exchange is a reversible chemical process in which ions from an insoluble, permanent, solid resin bed are exchanged for ions in water. The process relies on the fact that certain ions are preferentially adsorbed on the ion exchange resin. Operation begins with a fully charged cation or anion bed, having enough positively or negatively charged ions to carry out the cation or anion exchange. Usually a polymeric resin bed is composed of millions of spherical beads about the size of medium sand grains. As water passes the resin bed, the charged ions are released into the water, being substituted or replaced with the contaminants in the water (ion exchange). When the resin becomes exhausted of positively or negatively charged ions, the bed must be regenerated by passing a strong, sodium chloride, solution over the resin bed, displacing the contaminant ions with sodium ions for cation exchange and chloride ion for anion exchange. Many different types of resins can be used to reduce dissolved contaminant concentrations. The IX treatment train for groundwater typically includes cation or anion resin beds with a regeneration system, chlorine disinfection, and clear well storage. Treatment trains for surface water may also include raw water pumps, debris screens, and filters for pre-treatment. Additional treatment or management of the concentrate and the removed solids would be necessary prior to disposal. For arsenic removal, an anion exchange resin in the chloride form is used to remove arsenate [As(V)]. Because arsenite [As(III)] occurs in water below pH 9 with no ionic charge, As(III) is not consistently removed by the anionic exchange process.

Pretreatment – Pretreatment guidelines are available on accepted limits for pH, organics, turbidity, and other raw water characteristics. Pretreatment may be required to reduce excessive amounts of total suspended solids (TSS), iron, and manganese, which could plug the resin bed, and typically includes media or carbon filtration. In addition,

1 chlorination or oxidation may be required to convert As(III) to As(V) for effective
2 removal.

3 Maintenance – The IX resin requires regular on-site regeneration, the frequency of
4 which depends on raw water characteristics, the contaminant concentration, and the size
5 and number of IX vessels. Many systems have undersized the IX vessels only to realize
6 higher than necessary operating costs. Preparation of the sodium chloride solution is
7 required. If used, filter replacement and backwashing would be required.

8 Waste Disposal – Approval from local authorities is usually required for disposal of
9 concentrate from the regeneration cycle (highly concentrated salt solution); occasional
10 solid wastes (in the form of broken resin beads) which are backwashed during
11 regeneration; and if used, spent filters and backwash wastewater.

12 **Advantages (IX)**

- 13 • Well-established process for arsenic removal.
- 14 • Fully automated and highly reliable process.
- 15 • Suitable for small and large installations.

16 **Disadvantages (IX)**

- 17 • Requires salt storage; regular regeneration.
- 18 • Concentrate disposal.
- 19 • Resins are sensitive to the presence of competing ions such as sulfate.

20 In considering the application of IX for removal of inorganics, it is important to
21 understand what the effect of competing ions would be, and to what extent the brine can
22 be recycled. Similar to AA, IX exhibits a selectivity sequence, which refers to an order
23 in which ions are preferred. Sulfate competes with both nitrate and arsenic, but is more
24 aggressive with arsenic in anion exchange. Source waters with TDS levels above
25 500 mg/L or sulfate above 50 mg/L are not amenable to IX treatment for arsenic removal.
26 Spent regenerant is produced during IX bed regeneration, and it may have high
27 concentrations of the sorbed contaminants which would be expensive to treat and/or
28 dispose because of hazardous waste regulations. Research has been conducted to
29 minimize this effect; recent research on arsenic removal shows that the brine can be
30 reused as many as 25 times.

31 **1.4.5.2 Reverse Osmosis**

32 Process – RO is a pressure-driven membrane separation process capable of removing
33 dissolved solutes from water by means of particle size and electrical charge. The raw
34 water is typically called feed, the product water is called permeate, and the concentrated
35 reject is called concentrate. Common RO membrane materials include asymmetric
36 cellulose acetate and polyamide thin film composite. Common RO membrane
37 configurations include spiral wound hollow fine fiber, but most RO systems to date are
38 the spiral wound type. A typical RO installation includes a high pressure feed pump with

1 chemical feed, parallel first and second stage membrane elements in pressure vessels, and
2 valving and piping for feed, permeate, and concentrate streams. Factors influencing
3 membrane selection are cost, recovery, rejection, raw water characteristics, and
4 pretreatment. Factors influencing performance are raw water characteristics, pressure,
5 temperature, and regular monitoring and maintenance. RO is capable of achieving over
6 97 percent removal of As(V) and 92 percent removal of As(III). The treatment process is
7 relatively insensitive to pH. Water recovery is typically 60-80 percent, depending on the
8 raw water characteristics. The concentrate volume for disposal can be significant.

9 Pretreatment – RO requires careful review of raw water characteristics and
10 pretreatment needs to prevent membranes from fouling, scaling or other membrane
11 degradation. Removal or sequestering of suspended and colloidal solids is necessary to
12 prevent fouling, and removal of sparingly soluble constituents such as calcium,
13 magnesium, silica, sulfate, barium, *etc.* may be required to prevent scaling. Pretreatment
14 can include media filters, IO softening, acid and antiscalant feed, activated carbon or
15 bisulfite feed to dechlorinate, and cartridge filters to remove any remaining suspended
16 solids to protect membranes from upsets.

17 Maintenance – Monitoring rejection percentage is required to ensure contaminant
18 removal below MCL. Regular monitoring of membrane performance is necessary to
19 determine fouling, scaling, or other membrane degradation. Acidic or caustic solutions
20 are regularly flushed through the system at high volume/low pressure with a cleaning
21 agent to remove foulants and scalants. Frequency of membrane replacement is dependent
22 on raw water characteristics, pretreatment, and maintenance.

23 Waste Disposal – Pretreatment waste streams, concentrate flows, spent filters and
24 membrane elements all require approved disposal methods.

25 **Advantages (RO)**

- 26 • Can remove both As(III) and As(V) effectively.
- 27 • Can remove other undesirable dissolved constituents and excessive salts,
28 if required.

29 **Disadvantages (RO)**

- 30 • Relatively expensive to install and operate.
- 31 • Need sophisticated monitoring systems.
- 32 • Need to handle multiple chemicals.
- 33 • Waste of water because of the significant concentrate flows.
- 34 • Concentrated disposal.

35 RO is an expensive alternative to remove arsenic and is usually not economically
36 competitive with other processes unless nitrate and/or removal of TDS is also required.
37 The biggest drawback for using RO to remove arsenic is the waste of water through
38 concentrate disposal which is also difficult or expensive because of the volume involved.

1 1.4.5.3 Adsorption

2 Process – The adsorptive media process is a fixed-bed process by which ions in
3 solution, such as arsenic, are removed by available adsorptive sites on an adsorptive
4 media. When the available adsorptive sites are filled, spent media may be regenerated or
5 simply thrown away and replaced with new media. Granular AA was the first adsorptive
6 media successfully applied for the removal of arsenic from water supplies. More
7 recently, other adsorptive media (mostly iron-based) were developed and marketed for
8 arsenic removal. Recent USEPA studies demonstrated that iron-based adsorption media
9 typically have higher arsenic removal capacities compared to alumina-based media. In
10 the USEPA-sponsored Round 1 full-scale demonstration of arsenic removal technologies
11 for small water systems program, the selected arsenic treatment technologies included
12 nine adsorptive media systems, one IX system, one coagulation/filtration system, and one
13 process modification.

14 The selected adsorptive media systems used four different adsorptive media,
15 including three iron-based media (e.g., ADI's G2, Severn Trent and AdEdge's E33, and
16 US Filter's GFH), and one iron-modified AA media (e.g., Kinetico's AAFS50, a product
17 of Alcan). The G2 media is a dry powder of diatomaceous earth impregnated with a
18 coating of ferric hydroxide, developed by ADI specifically for arsenic adsorption. ADI
19 markets G2 for both As(V) and As(III) removal but it preferentially removes As(V). G2
20 media adsorbs arsenic most effectively at pH values within the 5.5 to 7.5 range, and less
21 effectively at a higher pH value.

22 The Bayoxide® E33 media was developed by Bayer AG for removal of arsenic from
23 drinking water supplies. It is a dry granular iron oxide media designed to remove
24 dissolved arsenic via adsorption onto its ferric oxide surface. Severn Trent markets the
25 media in the U.S. for As(III) and As(V) removal as Sorb-33, and offers several arsenic
26 package units with flow rates ranging from 150 to 300 gallons per minute (gpm).
27 Another company, AdEdge, provides similar systems using the same media (marketed as
28 AD-33) with flow rates ranging from 5 to 150 gpm. E33 adsorbs arsenic and other ions,
29 such as antimony, cadmium, chromate, lead, molybdenum, selenium and vanadium. The
30 adsorption is effective at pH values ranging between 6.0 and 9.0. At greater than 8.0 to
31 8.5, pH adjustment is recommended to maintain adsorption capacity. Two competing
32 ions that can reduce the adsorption capacity are silica (at levels greater than 40 mg/L) and
33 phosphate (at levels greater than 1 mg/L).

34 GFH is a moist granular ferric hydroxide media produced by GEH Wasserchemie
35 GmbH of Germany, and marketed by US Filter under an exclusive marketing agreement.
36 GFH is capable of adsorbing both As(V) and As(III). The GFH media adsorb arsenic
37 with a pH range of 5.5 to 9.0, but less effectively at the upper end of this range.
38 Competing ions such as silica and phosphate in source water can adsorb onto the GFH
39 media, thus reducing its arsenic removal capacity.

40 The AAFS50 is a dry granular media of 83 percent alumina and a proprietary
41 iron-based additive to enhance the arsenic adsorption performance. Standard AA was the
42 first adsorptive media successfully applied for removal of arsenic from water supplies.

1 However, it often requires pH adjustment to 5.5 to achieve optimum arsenic removal.
2 The AAFS50 product is modified with an iron-based additive to improve its performance
3 and increase the pH range within which it can achieve effective removal. Optimum
4 arsenic removal efficiency is achieved with a pH of the feed water less than 7.7.
5 Competing ions such as fluoride, sulfate, silica, and phosphate can adsorb onto the
6 AAFS50 media, and potentially can reduce its arsenic removal capacity. The adsorption
7 capacity of AAFS50 can be impacted by both high levels of silica (>40 mg/L) and
8 phosphate (>1 mg/L). The vendor recommends the system be operated in a series
9 configuration to minimize the chance for arsenic breakthrough to impact drinking water
10 quality.

11 All iron-based or iron-modified adsorptive media are of the throwaway type after
12 exhaustion. The operations of these adsorption systems are quite similar and simple.
13 Some technologies, such as the E33 and GFH, have been operated successfully on large
14 scale plants in Europe for several years.

15 Pretreatment – Adsorptive media are primarily used to remove dissolved arsenic and
16 not for suspended solids. Pretreatment to remove TSS may be required if raw water
17 turbidity is >0.3 NTU. However, most well water is low in turbidity and hence,
18 pre-filtration is usually not required. Pre-chlorination may be required to oxidize As(III)
19 to As(V) if the proportion of As(III) is high. No pH adjustment is required unless pH is
20 relatively high.

21 Maintenance – Maintenance for the adsorption media system is minimal if no
22 pretreatment is required. Backwash is required infrequently (monthly) and replacement
23 and disposal of the exhausted media occur between 1 to 3 years, depending on average
24 water consumption, the concentrations of arsenic and competing ions in the raw water,
25 and the media bed volume.

26 Waste Disposal – If no pretreatment is required there is minimal waste disposal
27 involved with the adsorptive media system. Disposal of backwash wastewater is required
28 especially during startup. Regular backwash is infrequent and disposal of the exhausted
29 media occurs once every 1 to 3 years, depending on operating conditions. The exhausted
30 media are usually considered non-hazardous wastes.

31 **Advantages (Adsorption)**

- 32 • Some adsorbents can remove both As(III) and As(V).
- 33 • Very simple to operate.

34 **Disadvantages (Adsorption)**

- 35 • Relatively new technology.
- 36 • Need replacement of adsorption media when exhausted.

37 The adsorption media process is the most simple and requires minimal operator
38 attention, compared to other arsenic removal processes. The process is most applicable
39 to small wellhead systems with low or moderate arsenic concentrations with no treatment

1 process in place (e.g. iron and manganese removal; if treatment facilities for iron and/or
2 manganese removal are already in place, incorporating ferric chloride coagulation in the
3 existing system would be a more cost-effective alternative for arsenic removal). The
4 choice of media would depend on raw water characteristics, life cycle cost, and
5 experience of the vendor. Many of the adsorption media are at the field-trial stage, but
6 others are already being used in full-scale applications throughout Europe and the United
7 States. Pilot testing may or may not be necessary prior to implementation depending on
8 the experience of the vendor with similar water characteristics.

9 **1.4.5.4 Coagulation/Filtration and Iron Removal Technologies**

10 Process – Iron removal processes can be used to removal arsenic from drinking
11 water supplies. Iron removal processes involved the oxidation of soluble iron and
12 As(III), adsorption and/or co-precipitation of As(V) onto iron hydroxides, and filtration.
13 The filtration can be accomplished with granular media filter or microfilter. When iron
14 in the raw water is inadequate to accomplish arsenic removal an iron salt such as ferric
15 chloride is added to the water to form ferric hydroxide. The iron removal process is
16 commonly called coagulation/filtration because iron in the form of ferric chloride is a
17 common coagulant. The actual capacity to remove arsenic during iron removal depends
18 on a number of factors, including the amount of arsenic present, arsenic speciation, pH,
19 amount and form of iron present, and existence of competing ions, such as phosphate,
20 silicate, and natural organic matter. The filters used in groundwater treatment are usually
21 pressure filters feeding directly by the well pumps. The filter media can be regular dual
22 media filters or proprietary media such as the engineered ceramic filtration media,
23 Macrolite[®], developed by Kinetico. Macrolite is a low-density, spherical media designed
24 to allow for filtration rates up to 10 gallons per minute per square foot (gpm/ft²), which is
25 a higher loading rate than commonly used for conventional filtration media.

26 Pretreatment – Pre-chlorination to oxidize As(III) to As(V) is usually required for
27 most groundwater sources. The adjustment of pH is required only for relatively high pH
28 value. Coagulation with the feed of ferric chloride is required for this process.
29 Sometimes a 5-minute contact tank is required ahead of the filters if the pH is high.

30 Maintenance – Maintenance is mainly to handle the ferric chloride chemical and feed
31 system, and for regular backwash of the filters. No filter replacement is required for this
32 process.

33 Waste Disposal – Waste from the coagulation/filtration process is mainly iron
34 hydroxide sludge with adsorbed arsenic in the backwash water. The backwash water can
35 be discharged to a public sewer if it is available. If a sewer is not available, the backwash
36 water can be discharged to a storage and settling tank from where the supernatant is
37 recycled in a controlled rate to the front of the treatment system and the settled sludge
38 can be disposed periodically to a landfill. Iron hydroxide sludge is usually not classified
39 as hazardous waste.

1 **Advantages**

- 2 • Very established technology for arsenic removal.
3 • Most economical process for arsenic removal.

4 **Disadvantages**

- 5 • Need to handle chemical.
6 • Need to dispose regular backwash wastewater.
7 • Sludge disposal.

8 The coagulation/filtration process is usually the most economical arsenic removal
9 alternative, especially if a public sewer is available for accepting the discharge of the
10 backwash water. However, because of the regular filter backwash requirements, more
11 operation and maintenance (O&M) attention is required from the utilities. Because of
12 potential interference by competing ions bench-scale or pilot scaling testing may be
13 required to ensure that the arsenic MCL can be met with this process alternative.

14 **1.4.6 Point-of-Entry and Point-of-Use Treatment Systems**

15 Point-of-entry (POE) and point-of-use (POU) treatment systems can be used to
16 provide compliant drinking water. For arsenic removal, these systems typically use small
17 RO treatment units that are installed “under the sink” in the case of POU, and where
18 water enters a house or building in the case of POE. It should be noted that the POU
19 treatment units would need to be more complex than units typically found in commercial
20 retail outlets in order to meet regulatory requirements, making purchase and installation
21 more expensive. POE and POU treatment units would be purchased and owned by the
22 PWS. These solutions are decentralized in nature, and require utility personnel entry into
23 houses or at least onto private property for installation, maintenance, and testing. Due to
24 the large number of treatment units that would be employed and would be largely out of
25 the control of the PWS, it is very difficult to ensure 100 percent compliance. Prior to
26 selection of a POE or POU program for implementation, consultation with TCEQ will be
27 required to address measurement and determination of level of compliance.

28 The SDWA [§1412(b)(4)(E)(ii)] regulates the design, management and operation of
29 POU and POE treatment units used to achieve compliance with an MCL. These
30 restrictions, relevant to arsenic are:

- 31 • POU and POE treatment units must be owned, controlled, and maintained
32 by the water system, although the utility may hire a contractor to ensure
33 proper O&M and MCL compliance. The water system must retain unit
34 ownership and oversight of unit installation, maintenance and sampling;
35 the utility ultimately is the responsible party when it comes to regulatory
36 compliance. The water system staff need not perform all installation,
37 maintenance, or management functions, as these tasks may be contracted
38 to a third party, but the final responsibility for quality and quantity of the
39 water supplied to the community resides with the water system, and the

1 utility must monitor all contractors closely. Responsibility for the O&M
2 of POU or POE devices installed for SDWA compliance may not be
3 delegated to homeowners.

- 4 • POU and POE units must have mechanical warning systems to
5 automatically notify customers of operational problems. Each POU or
6 POE treatment device must be equipped with a warning device
7 (e.g., alarm, light) that will alert users when their unit is no longer
8 adequately treating their water. As an alternative, units may be equipped
9 with an automatic shut-off mechanism to meet this requirement.
- 10 • If the American National Standards Institute has issued product standards
11 for a specific type of POU or POE treatment unit, only those units that
12 have been independently certified according to these standards may be
13 used as part of a compliance strategy.

14 The following observations with regard to using POE and POU devices for SDWA
15 compliance were made by Raucher, *et al.* (2004):

- 16 • If POU devices are used as an SDWA compliance strategy, certain
17 consumer behavioral changes would be necessary (e.g., encouraging
18 people to drink water only from certain treated taps) to ensure
19 comprehensive consumer health protection.
- 20 • Although not explicitly prohibited in SDWA, USEPA indicates that POU
21 treatment devices should not be used to treat for radon or for most volatile
22 organic contaminants to achieve compliance, because POU devices do not
23 provide 100 percent protection against inhalation or contact exposure to
24 those contaminants at untreated taps (e.g., shower heads).
- 25 • Liability – PWSs considering unconventional treatment options (POU,
26 POE, or bottled water) must address liability issues. These could be
27 meeting the drinking water standards, property entry and ensuing
28 liabilities, and damage arising from improper installation or improper
29 function of the POU and POE devices.

30 **1.4.7 Water Delivery or Central Drinking Water Dispensers**

31 Current USEPA regulations 40 Code of Federal Regulations (CFR) 141.101 prohibit
32 the use of bottled water to achieve compliance with an MCL, except on a temporary
33 basis. State regulations do not directly address the use of bottled water. Use of bottled
34 water at a non-compliant PWS would be on a temporary basis. Every 3 years, the PWSs
35 that employ interim measures are required to present the TCEQ with estimates of costs
36 for piping compliant water to their systems. As long as the projected costs remain
37 prohibitively high, the bottled water interim measure is extended. Until USEPA amends
38 the noted regulation, the TCEQ is unable to accept water delivery or central drinking
39 water dispensers as compliance solutions.

40 Central provision of compliant drinking water would consist of having one or more
41 dispensers of compliant water where customers could come to fill containers with

1 drinking water. The centralized water source could be from small to medium sized
2 treatment units or could be compliant water delivered to the central point by truck.

3 Water delivery is an interim measure for providing compliant water. As an interim
4 measure for a small impacted population, providing delivered drinking water may be cost
5 effective. If the susceptible population is large, the cost of water delivery would increase
6 significantly.

7 Water delivery programs require consumer participation to a varying degree.
8 Ideally, the consumer would have to do no more than he/she currently does for a piped-
9 water delivery system. Least desirable are those systems that require maximum effort on
10 the part of the customer (*e.g.*, customer has to travel to get the water, transport the water,
11 and physically handle the bottles). Such a system may appear to be lowest-cost to the
12 utility; however, should a consumer experience ill effects from contaminated water and
13 take legal action, the ultimate cost could increase significantly.

14 The ideal system would:

- 15 • Completely identify the susceptible population, if any. If bottled water is
16 only provided to customers who are part of the susceptible population, the
17 utility should have an active means of identifying the susceptible
18 population. Problems with illiteracy, language fluency, fear of legal
19 authority, desire for privacy, and apathy may be reasons that some
20 members of the susceptible population do not become known to the utility,
21 and do not take part in the water delivery program.
- 22 • Maintain customer privacy by eliminating the need for utility personnel to
23 enter the home.
- 24 • Have buffer capacity (*e.g.*, two bottles in service, so that when one is
25 empty, the other is being used over a time period sufficient to allow the
26 utility to change out the empty bottle).
- 27 • Provide for regularly scheduled delivery so that the customer would not
28 have to notify the utility when the supply is low.
- 29 • Use utility personnel and equipment to handle water containers, without
30 requiring customers to lift or handle bottles with water in them.
- 31 • Be sanitary (*e.g.*, where an outside connection is made, contaminants from
32 the environment must be eliminated).
- 33 • Be vandal-resistant.
- 34 • Avoid heating the water due to exterior temperatures and solar radiation.
- 35 • Avoid freezing the water.

SECTION 2 EVALUATION METHODOLOGY

2.1 DECISION TREE

The decision tree is a flow chart for conducting feasibility studies for a non-compliant PWS. The decision tree is shown in Figures 2.1 through 2.4. The tree guides the user through a series of phases in the design process. Figure 2.1 shows Tree 1, which outlines the process for defining the existing system parameters, followed by optimizing the existing treatment system operation. If optimizing the existing system does not correct the deficiency, the tree leads to six alternative preliminary branches for investigation. The groundwater branch leads through investigating existing wells to developing a new well field. The treatment alternatives address centralized and on-site treatment. The objective of this phase is to develop conceptual designs and cost estimates for the six types of alternatives. The work done for this report follows through Tree 1 and Tree 2, as well as a preliminary pass through Tree 4.

Tree 3, which begins at the conclusion of the work for this report, starts with a comparison of the conceptual designs, selecting the two or three alternatives that appear to be most promising, and eliminating those alternatives which are obviously infeasible. It is envisaged that a process similar to this would be used by the study PWS to refine the list of viable alternatives. The selected alternatives are then subjected to intensive investigation, and highlighted by an investigation into the socio-political aspects of implementation. Designs are further refined and compared, resulting in the selection of a preferred alternative. The steps for assessing the financial and economic aspects of the alternatives (one of the steps in Tree 3) are given in Tree 4 in Figure 2.4.

2.2 DATA SOURCES AND DATA COLLECTION

2.2.1 Data Search

2.2.1.1 Water Supply Systems

The TCEQ maintains a set of files on public water systems, utilities, and districts at its headquarters in Austin, Texas. The files are organized under two identifiers: a PWS identification number and a Certificate of Convenience and Necessity (CCN) number. The PWS identification number is used to retrieve four types of files:

- CO – Correspondence,
- CA – Chemical analysis,
- MOR – Monthly operating reports (quality/quantity), and
- FMT – Financial, managerial and technical issues.

The CCN files generally contain a copy of the system's Certificate of Convenience and Necessity, along with maps and other technical data.

Figure 2.1
TREE 1 – EXISTING FACILITY ANALYSIS




Figure 2.2
 TREE 2 – DEVELOP TREATMENT ALTERNATIVES





Figure 2.3


Tree 3 – PRELIMINARY ANALYSIS



End* -- Discard this alternative and reconsider next most-desirable alternative.

Develop financial model of top alternative:
 Existing rates, revenues, expenditures
 Existing reserves and debts
 Future rates, revenues, expenditures
 Future capital expenditures
 Future water demands

Figure 2.4
TREE 4 – FINANCIAL AND MANAGERIAL



1 These files were reviewed for the PWS and surrounding systems.

2 The following websites were consulted to identify the water supply systems in the
3 study area:

- 4 • Texas Commission on Environmental Quality
5 www.tnrc.state.tx.us/iwud/pws/index.cfm. Under “Advanced Search”,
6 type in the name(s) of the County(ies) in the study area to get a listing of
7 the public water supply systems.
- 8 • USEPA Safe Drinking Water Information System
9 www.epa.gov/safewater/data/getdata.html.

10 Groundwater control districts were identified on the TWDB web site, which has a
11 series of maps covering various groundwater and surface water subjects. One of those
12 maps shows groundwater control districts in the State of Texas.

13 **2.2.1.2 Existing Wells**

14 The TWDB maintains a groundwater database available at www.twdb.state.tx.us that
15 has two tables with helpful information. The “Well Data Table” provides a physical
16 description of the well, owner, location in terms of latitude and longitude, current use,
17 and for some wells, items such as flow rate, and nature of the surrounding formation.
18 The “Water Quality Table” provides information on the aquifer and the various chemical
19 concentrations in the water.

20 **2.2.1.3 Surface Water Sources**

21 Regional planning documents were consulted for lists of surface water sources.

22 **2.2.1.4 Groundwater Availability Model**

23 GAMs, developed by the TWDB, are planning tools and should be consulted as part
24 of a search for new or supplementary water sources. The GAM for the northern part of
25 the Gulf Coast aquifer was investigated as a potential tool for identifying available and
26 suitable groundwater resources.

27 **2.2.1.5 Water Availability Model**

28 The WAM is a computer-based simulation predicting the amount of water that would
29 be in a river or stream under a specified set of conditions. WAMs are used to determine
30 whether water would be available for a newly requested water right or amendment. If
31 water is available, these models estimate how often the applicant could count on water
32 under various conditions (*e.g.*, whether water would be available only 1 month out of the
33 year, half the year, or all year, and whether that water would be available in a repeat of
34 the drought of record).

35 WAMs provide information that assist TCEQ staff in determining whether to
36 recommend the granting or denial of an application.

1 **2.2.1.6 Financial Data**

2 Financial data were collected through a site visit. Data sought included:

- 3 • Annual Budget
- 4 • Audited Financial Statements
 - 5 ○ Balance Sheet
 - 6 ○ Income & Expense Statement
 - 7 ○ Cash Flow Statement
 - 8 ○ Debt Schedule
- 9 • Water Rate Structure
- 10 • Water Use Data
 - 11 ○ Production
 - 12 ○ Billing
 - 13 ○ Customer Counts

14 **2.2.1.7 Demographic Data**

15 Basic demographic data were collected from the 2000 Census to establish incomes
16 and eligibility for potential low cost funding for capital improvements. Median
17 household income (MHI) and number of families below poverty level were the primary
18 data points of significance. If available, MHI for the customers of the PWS should be
19 used. In addition, unemployment data were collected from current U.S. Bureau of Labor
20 Statistics. These data were collected for the following levels: national, state, and county.

21 **2.2.2 PWS Interviews**

22 **2.2.2.1 PWS Capacity Assessment Process**

23 A capacity assessment is the industry standard term for an evaluation of a water
24 system's financial, managerial, and technical capacity to effectively deliver safe drinking
25 water to its customers now and in the future at a reasonable cost, and to achieve, maintain
26 and plan for compliance with applicable regulations. The assessment process involves
27 interviews with staff and management who have a responsibility in the operations and the
28 management of the system.

29 Financial, managerial, and technical capacity are individual yet highly interrelated
30 components of a system's capacity. A system cannot sustain capacity without
31 maintaining adequate capability in all three components.

32 **Financial capacity** is a water system's ability to acquire and manage sufficient
33 financial resources to allow the system to achieve and maintain compliance with the
34 SDWA requirements. Financial capacity refers to the financial resources of the water

1 system, including but not limited to revenue sufficiency, credit worthiness, and fiscal
2 controls.

3 **Managerial capacity** is the ability of a water system to conduct its affairs so that the
4 system is able to achieve and maintain compliance with SDWA regulations. Managerial
5 capacity refers to the management structure of the water system, including but not limited
6 to ownership accountability, staffing and organization, and effective relationships to
7 customers and regulatory agencies.

8 **Technical capacity** is the physical and operational ability of a water system to
9 achieve and maintain compliance with SDWA regulations. It refers to the physical
10 infrastructure of the water system, including the adequacy of the source water, treatment,
11 storage and distribution infrastructure. It also refers to the ability of system personnel to
12 effectively operate and maintain the system and to otherwise implement essential
13 technical knowledge.

14 Many aspects of water system operations involve more than one component of
15 capacity. Infrastructure replacement or improvement, for example, requires financial
16 resources, management planning and oversight, and technical knowledge. A deficiency
17 in any one area could disrupt the entire effort. A system that is able to meet both its
18 immediate and long-term challenges demonstrates that it has sufficient financial,
19 managerial, and technical capacity.

20 Assessment of the FMT capacity of the PWS was based on an approach developed
21 by the New Mexico Environmental Finance Center (NMEFC), which is consistent with
22 the TCEQ FMT assessment process. This methodology was developed from work the
23 NMEFC did while assisting USEPA Region 6 in developing and piloting groundwater
24 comprehensive performance evaluations. The NMEFC developed a standard list of
25 questions that could be asked of water system personnel. The list was then tailored
26 slightly to have two sets of questions – one for managerial and financial personnel, and
27 one for operations personnel (the questions are included in Appendix A). Each person
28 with a role in the FMT capacity of the system was asked the applicable standard set of
29 questions individually. The interviewees were not given the questions in advance and
30 were not told the answers others provided. Also, most of the questions are open ended
31 type questions so they were not asked in a fashion to indicate what would be the “right”
32 or “wrong” answer. The interviews lasted between 45 minutes to 75 minutes depending
33 on the individual’s role in the system and the length of the individual’s answers.

34 In addition to the interview process, visual observations of the physical components
35 of the system were made. A technical information form was created to capture this
36 information. This form is contained in Appendix A. This information was considered
37 supplemental to the interviews because it served as a check on information provided in
38 the interviews. For example, if an interviewee stated he or she had an excellent
39 preventative maintenance schedule and the visit to the facility indicated a significant
40 amount of deterioration (more than would be expected for the age of the facility) then the
41 preventative maintenance program could be further investigated or the assessor could
42 decide that the preventative maintenance program was inadequate.

1 Following interviews and observations of the facility, answers that all personnel
2 provided were compared and contrasted to provide a clearer picture of the true operations
3 at the water system. The intent was to go beyond simply asking the question, “Do you
4 have a budget?” to actually finding out if the budget was developed and being used
5 appropriately. For example, if a water system manager was asked the question, “Do you
6 have a budget?” he or she may say, “yes” and the capacity assessor would be left with the
7 impression that the system is doing well in this area. However, if several different people
8 are asked about the budget in more detail, the assessor may find that although a budget is
9 present, operations personnel do not have input into the budget, the budget is not used by
10 the financial personnel, the budget is not updated regularly, or the budget is not used in
11 setting or evaluating rates. With this approach, the inadequacy of the budget would be
12 discovered and the capacity deficiency in this area would be noted.

13 Following the comparison of answers, the next step was to determine which items
14 noted as a potential deficiency truly had a negative effect on the system’s operations. If a
15 system had what appeared to be a deficiency, but this deficiency was not creating a
16 problem in terms of the operations or management of the system, it was not considered
17 critical and may not have needed to be addressed as a high priority. As an example, the
18 assessment may have revealed an insufficient number of staff members to operate the
19 facility. However, it may also have been revealed that the system was able to work
20 around that problem by receiving assistance from a neighboring system, so no severe
21 problems resulted from the number of staff members. Although staffing may not be
22 ideal, the system does not need to focus on this particular issue. The system needs to
23 focus on items that are truly affecting operations. As an example of this type of
24 deficiency, a system may lack a reserve account which can then lead the system to delay
25 much-needed maintenance or repair on its storage tank. In this case, the system needs to
26 address the reserve account issue so that proper maintenance can be completed.

27 The intent was to develop a list of capacity deficiencies with the greatest impact on
28 the system’s overall capacity. Those were the most critical items to address through
29 follow-up technical assistance or by the system itself.

30 **2.2.2.2 Interview Process**

31 PWS personnel were interviewed by the project team, and each was interviewed
32 separately. Interview forms were completed during each interview.

33 **2.3 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

34 The initial objective for developing alternatives to address compliance issues is to
35 identify a comprehensive range of possible options that can be evaluated to determine
36 which are the most promising for implementation. Once the possible alternatives are
37 identified, they must be defined in sufficient detail so that a conceptual cost estimate
38 (capital and O&M costs) can be developed. These conceptual cost estimates are used to
39 compare the affordability of compliance alternatives, and to give a preliminary indication
40 of rate impacts. Consequently, these costs are pre-planning level and should not be
41 viewed as final estimated costs for alternative implementation. The basis for the unit

1 costs used for the compliance alternative cost estimates is summarized in Appendix B.
2 Other non-economic factors for the alternatives, such as reliability and ease of
3 implementation, are also addressed. The compliance alternative conceptual cost
4 estimates are provided in Appendix C. Cost analyses for shared solutions with other
5 PWSs in the area are provided in Appendix G.

6 **2.3.1 Existing Public Water Systems**

7 The neighboring PWSs were identified, and the extents of their systems were
8 investigated. PWSs farther than 10 miles from the non-compliant PWS were not
9 considered because the length of the pipeline required would make the alternative cost
10 prohibitive. The quality of water provided was also investigated. For neighboring PWSs
11 with compliant water, options for water purchase and/or expansion of existing well fields
12 were considered. The neighboring PWSs with non-compliant water were considered as
13 possible partners in sharing the cost for obtaining compliant water either through
14 treatment or developing an alternate source.

15 The neighboring PWSs were investigated to get an idea of the water sources in use
16 and the quantity of water that might be available for sale. They were contacted to
17 identify key locations in their systems where a connection might be made to obtain water,
18 and to explore on a preliminary basis their willingness to partner or sell water. Then, the
19 major system components that would be required to provide compliant water were
20 identified. The major system components included treatment units, wells, storage tanks,
21 pump stations, and pipelines.

22 Once the major components were identified, a preliminary design was developed to
23 identify sizing requirements and routings. A capital cost estimate was then developed
24 based on the preliminary design of the required system components. An annual O&M
25 cost was also estimated to reflect the change in O&M expenditures that would be needed
26 if the alternative was implemented.

27 Non-economic factors were also identified. Ease of implementation was considered,
28 as well as the reliability for providing adequate quantities of compliant water. Additional
29 factors were whether implementation of an alternative would require significant increase
30 in the management or technical capability of the PWS, and whether the alternative had
31 the potential for regionalization.

32 **2.3.2 New Groundwater Source**

33 It was not possible in the scope of this study to determine conclusively whether new
34 wells could be installed to provide compliant drinking water. In order to evaluate
35 potential new groundwater source alternatives, three test cases were developed based on
36 distance from the PWS intake point. The test cases were based on distances of 10 miles,
37 5 miles, and 1 mile. It was assumed that a pipeline would be required for all three test
38 cases, and a storage tank and pump station would be required for the 10-mile and 5-mile
39 alternatives. It was also assumed that new wells would be installed, and that their depths
40 would be similar to the depths of the existing wells, or other existing drinking water wells
41 in the area.

1 A preliminary design was developed to identify sizing requirements for the required
2 system components. A capital cost estimate was then developed based on the
3 preliminary design of the required system components. An annual O&M cost was also
4 estimated to reflect the change (*i.e.*, from current expenditures) in O&M expenditures
5 that would be needed if the alternative was implemented.

6 Non-economic factors were also identified. Ease of implementation was considered,
7 as well as the reliability for providing adequate quantities of compliant water. Additional
8 factors were whether implementation of an alternative would require significant increase
9 in the management or technical capability of the PWS, and whether the alternative had
10 the potential for regionalization.

11 **2.3.3 New Surface Water Source**

12 New surface water sources were investigated. Availability of adequate quality water
13 was investigated for the main rivers in the study area, as well as the major reservoirs.
14 TCEQ WAMs were inspected, and the WAM was run, where appropriate.

15 **2.3.4 Treatment**

16 Treatment technologies considered potentially applicable are adsorption and
17 coagulation/filtration for arsenic removal since they are proven technologies with
18 numerous successful installations that can be implemented with relatively low cost.
19 Reverse osmosis and ion exchange were not deemed to be applicable in this study, since
20 they are typically more expensive and more difficult to operate.

21 Adsorption treatment is considered for central treatment alternatives, as well as POU
22 and POE alternatives. Coagulation/Filtration treatment is considered for central
23 treatment alternatives only. Adsorption treatment produces a spent media solid waste
24 stream, and both adsorption and coagulation/filtration treatment produce a liquid
25 backwash stream. The backwash volume from adsorption is much less than from
26 filtration/coagulation. As a result, the treated volume of water is less than the volume of
27 raw water that enters the treatment system. The treatment units were sized based on flow
28 rates, and capital and annual O&M cost estimates were made based on the size of the
29 treatment equipment required. Neighboring non-compliant PWSs were identified to look
30 for opportunities where the costs and benefits of central treatment could be shared
31 between systems.

32 Non-economic factors were also identified. Ease of implementation was considered,
33 as well as the reliability for providing adequate quantities of compliant water. Additional
34 factors were whether implementation of an alternative would require significant increase
35 in the management or technical capability of the PWS, and whether the alternative had
36 the potential for regionalization.

1 **2.4 COST OF SERVICE AND FUNDING ANALYSIS**

2 The primary purpose of cost of service and funding analysis was to determine the
3 financial impact of implementing compliance alternatives, primarily by examining the
4 required rate increases, and analyzing the fraction of household income that water bills
5 consume. The current financial situation was also reviewed to determine what rate
6 increases were necessary for the PWS to achieve or maintain financial viability.

7 **2.4.1 Financial Feasibility**

8 A key financial metric is comparison of the average annual household water bill for a
9 PWS customer to the MHI for the area. MHI data from the 2000 Census were used at the
10 most detailed level available for the community. Typically, county level data are used
11 for small water utilities due to small population sizes. Annual water bills were
12 determined for existing base conditions and included consideration of additional rate
13 increases needed under current conditions. Annual water bills were also calculated after
14 adding incremental capital and operating costs for each of the alternatives to determine
15 feasibility under several potential funding sources.

16 Additionally, the use of standard ratios provided insight into the financial condition
17 of any business. Three ratios are particularly significant for water utilities:

- 18 • Current Ratio = current assets divided by current liabilities provides
19 insight into the ability to meet short-term payments. For a healthy utility,
20 the value should be greater than 1.0.
- 21 • Debt to Net Worth Ratio = total debt divided by net worth shows to what
22 degree assets of the company have been funded through borrowing. A
23 lower ratio indicates a healthier condition.
- 24 • Operating Ratio = total operating revenues divided by total operating
25 expenses show the degree to which revenues cover ongoing expenses.
26 The value is greater than 1.0 if the utility is covering its expenses.

27 **2.4.2 Median Household Income**

28 The 2000 Census was used as the basis for MHI. In addition to consideration of
29 affordability, MHI may also be an important factor for sources of funds for capital
30 programs needed to resolve water quality issues. Many grant and loan programs are
31 available to lower income rural areas, based on comparisons of local income to statewide
32 incomes. In the 2000 Census, MHI for the State of Texas was \$39,927, compared to the
33 U.S. level of \$41,994. For service areas with a sparse population base, county data may
34 be the most reliable and, for many rural areas, correspond to census tract data.

35 **2.4.3 Annual Average Water Bill**

36 The annual average household water bill was calculated for existing conditions and
37 for future conditions incorporating the alternative solutions. Average residential
38 consumption was estimated and applied to the existing rate structure to estimate the

1 annual water bill. The estimates were generated from a long-term financial planning
2 model that detailed annual revenue, expenditure, and cash reserve requirements over a
3 30-year period.

4 **2.4.4 Financial Plan Development**

5 The financial planning model used available data to establish base conditions under
6 which the system operates. The model included, as available:

- 7 • Accounts and consumption data
- 8 • Water tariff structure
- 9 • Beginning available cash balance
- 10 • Sources of receipts:
 - 11 ○ Customer billings
 - 12 ○ Membership fees
 - 13 ○ Capital funding receipts from:
 - 14 ❖ Grants
 - 15 ❖ Proceeds from borrowing
- 16 • Operating expenditures:
 - 17 ○ Water purchases
 - 18 ○ Utilities
 - 19 ○ Administrative costs
 - 20 ○ Salaries
- 21 • Capital expenditures
- 22 • Debt service:
 - 23 ○ Existing principal and interest payments
 - 24 ○ Future principal and interest necessary to fund viable operations
- 25 • Net cash flow
- 26 • Restricted or desired cash balances:
 - 27 ○ Working capital reserve (based on 1-4 months of operating expenses)
 - 28 ○ Replacement reserves to provide funding for planned and unplanned
 - 29 repairs and replacements

30 From the model, changes in water rates were determined for existing conditions and
31 for implementing the compliance alternatives.

1 **2.4.5 Financial Plan Results**

2 Results from the financial planning model were summarized in two ways: by
3 percentage of household income and by total water rate increase necessary to implement
4 the alternatives and maintain financial viability.

5 **2.4.5.1 Funding Options**

6 Results, summarized in Table 4.8, show the following according to alternative and
7 funding source:

- 8 • Percentage of the median annual household income that the average
9 annual residential water bill represents.
- 10 • The first year in which a water rate increase would be required.
- 11 • The total increase in water rates required, compared to current rates.

12 Water rates resulting from the incremental capital costs of the alternative solutions
13 were examined under a number of funding options. The first alternative examined was
14 always funded from existing reserves plus future rate increases. Several funding options
15 were analyzed to frame a range of possible outcomes.

- 16 • Grant funds for 100 percent of required capital. In this case, the PWS was
17 only responsible for the associated O&M costs.
- 18 • Grant funds for 75 percent of required capital, with the balance treated as
19 if revenue bond funded.
- 20 • Grant funds for 50 percent of required capital, with the balance treated as
21 if revenue bond funded.
- 22 • State revolving fund loan at the most favorable available rates and terms
23 applicable to the communities.
- 24 • If local MHI is more than 75 percent of state MHI, standard terms,
25 currently at 3.8 percent interest for non-rated entities. Additionally:
 - 26 ○ If local MHI = 70-75 percent of state MHI, 1 percent interest rate on
27 loan.
 - 28 ○ If local MHI = 60-70 percent of state MHI, 0 percent interest rate on
29 loan.
 - 30 ○ If local MHI = 50-60 percent of state MHI, 0 percent interest and
31 15 percent forgiveness of principal.
 - 32 ○ If local MHI less than 50 percent of state MHI, 0 percent interest and
33 35 percent forgiveness of principal.
- 34 • Terms of revenue bonds assumed to be 25-year term at 6.0 percent interest
35 rate.

2.4.5.2 General Assumptions Embodied in Financial Plan Results

The basis used to project future financial performance for the financial plan model included:

- No account growth (either positive or negative).
- No change in estimate of uncollectible revenues over time.
- Average consumption per account unchanged over time.
- No change in unaccounted for water as percentage of total (more efficient water use would lower total water requirements and costs).
- No inflation included in the analyses (although the model had provisions to add escalation of O&M costs, doing so would mix water rate impacts from inflation with the impacts from the alternatives being examined).
- Minimum working capital fund established for each district, based on specified months of O&M expenditures.
- O&M for alternatives begins 1-year after capital implementation.
- Balance of capital expenditures not funded from primary grant program is funded through debt (bond equivalent).
- Cash balance drives rate increases, unless provision chosen to override where current net cash flow is positive.

2.4.5.3 Interpretation of Financial Plan Results

Results from the financial plan model, as presented in a Table 4.8, show the percentage of MHI represented by the annual water bill that resulted from any rate increases necessary to maintain financial viability over time. In some cases, this may require rate increases even without implementing a compliance alternative (the no action alternative). The table shows any increases such as these separately. The results table shows the total increase in rates necessary, including both the no-action alternative increase and any increase required for the alternative. For example, if the no action alternative required a 10 percent increase in rates and the results table shows a rate increase of 25 percent, then the impact from the alternative was an increase in water rates of 15 percent. Likewise, the percentage of household income in the table reflects the total impact from all rate increases.

2.4.5.4 Potential Funding Sources

A number of potential funding sources exist for small public water systems. Both state and federal agencies offer grant and loan programs to assist rural communities in meeting their infrastructure needs.

Within Texas, the following state agencies offer financial assistance if needed:

- Texas Water Development Board,
- Office of Rural Community Affairs, and

- 1 • Texas Department of Health (Texas Small Towns Environment Program).
- 2 Small rural communities can also get assistance from the federal government. The
- 3 primary agencies providing aid are:
- 4 • United States Department of Agriculture, Rural Utilities Service, and
- 5 • United States Housing and Urban Development.


1
2

SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS

3.1 ARSENIC IN THE GULF COAST AQUIFER

4 The Gulf Coast aquifer parallels the Texas Gulf Coast and extends from the
5 Texas-Louisiana border to the Rio Grande. Subunits of the Gulf Coast aquifer are, from
6 oldest to youngest, the Jasper, Evangeline, and Chicot aquifers. The aquifer is a leaky
7 artesian system composed of middle to upper Tertiary and younger interbedded and
8 hydrologically connected layers of clay, silt, sand, and gravel (Ashworth and
9 Hopkins 1992). The PWS wells of concern in Brazoria County are completed in the
10 Chicot aquifer. Figure 3.1 shows detectable arsenic concentrations in the Gulf Coast
11 aquifer from the TWDB database, and Figure 3.2 shows arsenic concentrations from the
12 National Geochemical Database, also known as the National Uranium Resource
13 Evaluation (NURE) database (<http://pubs.usgs.gov/of/1997/ofr-97-0492/index.html>).

14 **Figure 3.1 Detectable Arsenic Concentrations in Groundwater**



15
16

Source: (TWDB database, analyses from 1987 through 2004)

17 The most recent value is shown for each well (number of samples shown is 503).

1 sand, and fine-grained sand (Doering 1935). Water wells completed in the Beaumont
2 Formation section of the Chicot aquifer are usually no deeper than 75 to 100 feet and
3 probably do not provide large quantities of water.

4 The lithology of geologic units within the Chicot aquifer is similar to that of the
5 underlying Evangeline aquifer, which makes it difficult for drillers to determine in which
6 aquifer they are completing water wells along the Texas Gulf Coast. The combined
7 thickness of geologic units in the Chicot aquifer in the vicinity of Brazoria County varies
8 among different researchers between 400 and 1,200 feet. According to Baker (1979), the
9 maximum thickness of the entire Gulf Coast aquifer along the northern Gulf Coast is
10 approximately 1,300 feet.

11 The 11 PWS wells of concern in Brazoria County are identified as being in the
12 Chicot aquifer; completion depths are grouped around 300, 400, and 600 feet. It is
13 possible the deeper wells are completed in the Evangeline aquifer or that screened
14 intervals in these wells span both Chicot and Evangeline aquifers. A recognized geologic
15 source of arsenic in groundwater is volcanic ash. Arsenic is often associated with other
16 chemical elements such as fluoride, vanadium, molybdenum, selenium, and uranium.
17 The association is generally seen at the subregional level, although not necessarily at the
18 well level because of different geochemical behavior of individual elements. There are
19 no reports of volcanic material in the geologic units that compose the Chicot aquifer.
20 However, layers of bentonite (altered volcanic ash beds) and devitrified ash have been
21 recognized in some parts of the Evangeline aquifer especially in South Texas. The major
22 geologic unit of the Evangeline aquifer in South Texas is the Goliad Formation, but it is
23 not present in outcrops north of the Colorado River (Hoel 1982). General hydrologic
24 patterns with upward cross-formational flow along the coast support this hypothesis.
25 However, other sources of arsenic are also possible. Arsenic hot spots exist in older
26 formations (Catahoula and Goliad); some of those have eroded and are now part of the
27 Chicot aquifer sediment. Additional potential sources include upwelling of highly
28 mineralized water from salt domes. However, the spatial mismatch between salt dome
29 distribution and areas with high arsenic concentration, as well as the lack of correlation
30 between chloride and arsenic concentrations, precludes such an association, as discussed
31 later.


32 Using uranium and radioactivity as proxies for arsenic sources, geophysical logs in
33 Brazoria County near the PWS wells were analyzed to assess potential linkages between
34 geologic units and elevated arsenic concentrations. Given the common association
35 between uranium deposits and occurrences of arsenic, it was reasonable to inspect local
36 oilfield geophysical logs for evidence of radioactive fluids in sandstone strata at depths
37 sufficiently shallow to potentially contact fresh groundwater. A total of 40 hydrocarbon
38 wells were identified with geophysical well logs that had (1) recorded geophysical
39 responses within the upper 500 feet of the subsurface; and (2) latitude/longitude
40 coordinates. Of these wells, 17 were selected on the basis of proximity to the
41 aforementioned PWS wells. Among these 17 hydrocarbon wells, only one provided the
42 gamma ray and resistivity logs necessary for analysis. Wells range in depth between 295
43 and 625 feet and are completed in the Chicot aquifer. Only one well log for the area

1 recorded sufficiently shallow data and also showed gamma ray and resistivity responses
2 necessary to detect radioactively elevated pore fluids in the geologic section. The well is
3 the Kilmarovo Jamison located at west longitude 95.3483° and north latitude 29.2586°.
4 The nearest PWS wells are operated by the City of Danbury a few miles to the south of
5 the logged well. Elevated gamma ray values greater than 150 American Petroleum
6 Institute units occurred in sandstone beds with resistivities greater than 10 ohms at
7 1,520- to 1,550-foot depths in the Jamison well. An additional bed containing fluids with
8 elevated radioactivity occurred at the depth of approximately 177 feet. Both of these
9 stratigraphic intervals dip toward the south and are, therefore, at greater depths in more
10 southerly locations. The City of Danbury PWS wells are completed at depths of 295 to
11 304 feet. Unless groundwater flow is upward between excessively radioactive strata
12 contacted by the Jamison well and the Danbury PWS wells, it appears unlikely that
13 radioactive fluids and associated ionic constituents, including possible arsenic, would
14 contact the Chicot aquifer in the Danbury area.

15 3.3 GENERAL TRENDS IN ARSENIC CONCENTRATIONS

16 The geochemistry of arsenic is described in Appendix E. A general analysis of
17 arsenic trends in the vicinity of Brazoria County was conducted to assess spatial trends,
18 as well as correlations with other water quality parameters. Arsenic measurements from
19 the TWDB database, the TCEQ database, and from a subset of the National Geochemical
20 Database, also known as NURE (National Uranium Resource Evaluation) database, were
21 used to assess arsenic trends. Figures 3.3 and 3.4 show spatial distribution of arsenic
22 concentrations from TWDB (Figure 3.3) and NURE (Figure 3.4) databases.


23 **Figure 3.3 Spatial Distribution of Arsenic Concentrations**



Source: TWDB database

1

Figure 3.4 Spatial Distribution of Arsenic Concentrations



2

3

Source: NURE database

4

The databases were queried in an area delineated by the following coordinates: bottom left, -97.45, 28.18; top right, -94.30, 30.64. Seven hundred thirty measurements were extracted from the TWDB database. Measurements representing the most recent arsenic measurement taken at a specific well, and wells not in the Gulf Coast aquifer were excluded. The NURE database contained 2,118 groundwater (sample type 03) arsenic measurements within the defined boundary. Because the wells have no aquifer identifier, no measurements were excluded.

10


11

Relationships between arsenic and well depth, pH, SO₄, fluoride, chloride, TDS, dissolved oxygen, phosphorus, iron, selenium, boron, vanadium, uranium, and molybdenum, were evaluated using data separately from the NURE and TWDB databases. Correlations between arsenic concentrations and most parameters were weak (r square values < 0.1); the highest correlation was found between arsenic and molybdenum. The relationship between the probability of arsenic > 10 µg/L and molybdenum concentration levels is shown for the NURE (Figure 3.5) and TWDB (Figure 3.6) databases.

18

1

Figure 3.5 Relationship Between Arsenic and Molybdenum



2


3

Source: NURE database

4

5

Figure 3.6 Relationship Between Arsenic and Molybdenum



6

7

Source: TWDB database

8


N represents the number of measurements used from each database. Numbers on top of the graph columns show the number of arsenic measurements exceeding 10 $\mu\text{g/L}$ and total number of measurements in each bin. For example, “7/76” in the bin of molybdenum > 20 means that seven of 76 arsenic measurements were greater than 10 $\mu\text{g/L}$.

13

Elevated arsenic concentrations and pH are also related (Figure 3.7). The absence of high arsenic concentrations (>10 $\mu\text{g/L}$) at pH less than 6.5 is notable.

14

1 **Figure 3.7 Relationship Between High Arsenic Concentrations and pH**




2

3 Correlations between arsenic, molybdenum, and pH suggest natural sources of
4 elevated arsenic in Brazoria County; however, data are insufficient to make this
5 conclusion definitively.

6 **3.4 ARSENIC AND POINT SOURCES OF CONTAMINATION**

7 Information regarding the location of potential source of contamination (PSOC) is
8 collected as part of the TCEQ Source Water Assessment Program. Arsenic
9 concentrations from TWDB (Figure 3.8) and NURE (Figure 3.9) databases were
10 compared with PSOC coverage. A density map of PSOCs was generated (number of
11 PSOCs per square kilometer), and PSOC density values were compared with arsenic
12 concentrations from the NURE database.

13 **Figure 3.8 Potential Sources of Arsenic Contamination and Arsenic**
14 **Concentrations**




Source: TWDB database

15

16

1
2

Figure 3.9 Potential Sources of Arsenic Contamination and Arsenic Concentrations



3
4

Source: NURE database

5
6
7

No correlation was found between high arsenic concentrations and density of potential sources of contamination, strengthening the conclusion that sources of arsenic in this area are natural.


8 **3.5 SALT DOMES**

9
10

Elevated arsenic concentrations were not correlated with salt dome locations (Figure 3.10).

11

Figure 3.10 Salt Dome Locations and Arsenic Concentrations




12
13

Source: TWDB and NURE databases

1 **3.6 CORRELATION WITH DEPTH**

2 Arsenic concentrations were compared with well depth in an attempt to assess
3 relationships between elevated arsenic concentrations and specific stratigraphic units
4 (Figure 3.11). Data do not show a definite correlation between arsenic levels and well
5 depth. Lack of geologic descriptions and geophysical logs makes it difficult to further
6 evaluate relationships between arsenic concentrations and depth distributions of geologic
7 units.

8 **Figure 3.11 Relationship Between Arsenic Concentrations and Well Depth**



9

10 The most recent sample was used for each well. N represents total number of wells
11 in the analysis (719), and numbers above each column represent number of arsenic
12 measurements > 10 µg/L and total number of analyses in the bin. For example, 5/181
13 represents five samples > 10 µg/L out of 181 analyses at a well depth between 0 and
14 200 feet.

15 **3.7 DETAILED ASSESSMENT**

16 There are eight wells with arsenic samples > 10 µg/L near the assessed PWS wells,
17 seven from the TCEQ database, and one from the TWDB database (Figure 3.12).
18 Samples from the TCEQ PWS database include only those that could be related to a
19 specific well.

1 regarding local correlation of arsenic with well or screen depth. Lack of geologic
2 descriptions of these wells also prohibits a more comprehensive evaluation of
3 relationships between arsenic concentrations and geology.

4 **3.7.1 ROSHARON ROAD ESTATES SUBDIVISION (PWS 0200346)**

5 Two wells are in the Rosharon Road Estates PWS, wells G0200346A and
6 G0200346B. The depth of Well A, 615 feet, is screened between 597 and 615 feet.
7 Well B has a depth of 625 feet and is screened between 595 and 625 feet. Both wells are
8 related to the same entry point of the water supply, thus making it difficult to separate the
9 source of arsenic. Table 3.2 summarizes arsenic measurements from the TCEQ database
10 (no samples are in the TWDB database).

11 Groundwater arsenic concentrations can have a high degree of spatial variability.
12 Because of this variability, an investigation of the existing wells should be conducted to
13 determine whether both or only one produces non-compliant water. If one well is found
14 to produce compliant water, as much production as possible should be shifted to the
15 compliant well. Also, if one well is found to produce compliant water, the wells should
16 be compared in terms of depths and well logs to try and identify differences that could be
17 responsible for the elevated concentration of arsenic in the other well. Then if blending
18 of water from the existing wells does not produce a sufficient quantity of compliant
19 water, it may be possible to install a new well similar to the existing compliant well that
20 also would provide compliant water.


21 **Table 3.2 Arsenic Concentrations in Rosharon Road Estates Subdivision PWS**

Date	As (µg/L)	Source
8/6/1996	18.6	TCEQ
3/16/1998	24.7	TCEQ
5/16/2001	24.1	TCEQ
3/22/2004	22.7	TCEQ
2/17/2005	25.5	TCEQ


22 Five water quality measurements from the TCEQ database were collected at the
23 PWS between 1996 and 2005. All samples had elevated arsenic (>10 µg/L). Figure 3.13
24 shows arsenic concentrations from TWDB and NURE databases measured at wells in
25 5- and 10-km buffers of PWS wells.

1 **Figure 3.13 Arsenic Concentrations in 5- and 10-km Buffers of Rosharon Road**
 2 **Estates Subdivision PWS Wells (TWDB and NURE Databases)**

3




4



5 The top figure shows arsenic concentrations from the TWDB database. Wells are
 6 symbolized by maximum concentrations, and labels show maximum, minimum, and
 7 number of samples, as well as first and last sample year. Values from the NURE
 8 database were taken between 1976 and 1980. Negative values are less than detection
 9 limit (0.5 µg/L). One well in the 10-km buffer range had high arsenic levels (16 µg/L).
 10 In addition to the TWDB and NURE databases, samples from the TCEQ PWS database
 11 were analyzed (Figure 3.14).

1 **Figure 3.14 Arsenic Concentrations in 5- and 10-km Buffers of Rosharon Road**
2 **Estates Subdivision PWS Wells (TCEQ Database)**



3
4 Two types of samples were used in the analysis: raw samples that can be related to a
5 single well and entry-point samples taken from a single entry point, which can be related
6 to a single well. Table 3.3 details arsenic concentrations, well depth, and screen depths
7 of wells in 5- and 10-km buffers of PWS wells.

8 **Table 3.3 Maximum and Minimum Arsenic Concentrations in the 5- and 10-km**
9 **Buffers of Rosharon Road Estates Subdivision PWS**

Water source	Max.-Min.-No. of As samples (µg/L)	Well depth (feet)	Screen depth (feet)
G0200346A	25.5 – 18.6 – 5	615	597-615
G0200346B		625	595-625
G0200566A	10.3 – 9.4 – 4	310	NA
G0200036A	14.8 – 9.2 – 3	324	307-323
G0200410A	2.0 – 2 – 2	210	NA
G0200573A	2.7 – 2.3 – 2	510	NA
G0200423A	2.0 – 2 – 1	166	NA
G0200146A	2.0 – 2 – 3	147	NA
G0200243A	2.0 – 2 – 1	400	NA
G0200570A	55.2 – 8 – 3	740	710-740
G0200569A	5.3 – 5.3 – 1	550	NA
G0200381A	2.0 – 2 – 1	132	NA

10 In addition to assessed PWS wells (G0200346A and G0200346B), three wells
11 (G0200566A, G0200036A, and G0200570A) have concentrations greater than 10 µg/L,

- 1 and one well (G0200569A) has concentrations above 5 µg/L. Wells with high
- 2 concentrations have depths between 310 and 740 feet, and known screens have depths of
- 3 307 to 740 feet.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

SECTION 4
ANALYSIS OF THE ROSHARON ROAD ESTATES PWS

4.1 DESCRIPTION OF EXISTING SYSTEM

4.1.1 Existing System

The Rosharon Road Estates PWS is shown on Figure 4.1. The system consists of two wells (G0200346A or State Well No. 6546101 and G0200346B or State Well No. 6546102, also referred to as Well A and Well B) completed in the Chicot aquifer (Code 112CHCT). The well depths are 615 and 625 feet, respectively. The water system includes two submersible pumps (55 gpm at Well A and 65 gpm at Well B), one ground storage tank (20,000 gallons), two service pumps (200 gpm each), and one pressure tank (2,500 gallons). The system has a peak production capacity of 0.172 million gallons per day (mgd). Treatment consists of polyphosphate and hypochlorination. Arsenic and manganese have been detected above the respective MCLs of 0.01 and 0.05 mg/L. Arsenic has been detected at concentrations ranging between 0.023 to 0.026 mg/L and manganese has been detected at concentrations ranging between 0.0524 and 0.12 mg/L. The average TDS for samples collected from 3/16/98 to 3/11/04 was 496.5 mg/L.

Groundwater from the wells is treated by hypochlorination for disinfection and polyphosphate injection to sequester manganese prior to discharge to the ground storage tank. The treatment employed is not appropriate or effective for removal of arsenic so optimization is not expected to be effective at increasing arsenic removal.

There is, however, a potential opportunity for system optimization to reduce arsenic concentration. The system has more than one well, and since arsenic concentrations can vary significantly between wells, arsenic concentrations should be determined for each well. If one or more wells happens to produce water with acceptable arsenic levels, as much production as possible should be shifted to that well. It may also be possible to identify arsenic-producing strata through comparison of well logs or through sampling of water produced by various strata within the well screen interval.

Basic system information from 2004 as provided by Orbit Systems, Inc. (Orbit) the company that handles the administration of the RRE water supply is as follows:

- Population served: 230
- Connections: 76
- Average daily demand: 0.015 mgd
- Maximum daily demand: 0.06 mgd
- Peak production capacity of the water supply system: 0.172 mgd
- Typical arsenic range: 0.023 to 0.026 mg/L (from the TCEQ database for samples collected from 3/16/98 to 2/17/05)






Figure 4.1

Rosharon Road Estates Pipeline Alternatives

- 1 • Typical manganese range: 0.0524 to 0.12 mg/L (from the TCEQ database
2 for samples collected from 3/16/98 to 3/11/04)
- 3 • Average TDS: 496.5 mg/L (from TCEQ database for samples collected
4 from 3/16/98 to 3/11/04).

5 **4.1.2 Capacity Assessment for Orbit Systems, Inc.**

6 The following personnel involved with Orbit were interviewed:

- 7 • Peggy Paul, Environmental Engineer.
8 • Jeff Walker, Operations Supervisor.

9 All interviews were conducted in person.

10 **4.1.2.1 General Structure**

11 Orbit is an investor-owned utility. Management includes a President, an Operations
12 Supervisor, and an Engineer who handle all of the financial, management, and technical
13 (FMT) issues for the system. These individuals also establish policies and supervise the
14 three water operators. There is also an office worker who handles administrative duties.

15 Orbit manages 33 regional water systems. The population ranges from 170 for the
16 smallest system to 450 for the largest system. The Orbit systems included in this study –
17 Sandy Meadow Estates, Rosharon Township, Rosharon Road Estates, Grasslands, and
18 Mark V Estates – had approximately 56, 85, 76, 150, and 94 connections, respectively
19 and populations of 170, 255, 230, 450, and 285, respectively. All are metered
20 groundwater systems.

21 The managerial structure of all of the water systems is the same, so only one capacity
22 assessment was completed that covers all of the Orbit systems.

23 **4.1.2.2 General Assessment of Capacity**

24 Overall, the system had an adequate level of capacity. The system had some areas
25 that needed improvement to be able to address future compliance issues; however, the
26 system has many positive aspects.

27 **4.1.2.3 Positive Aspects of Capacity**

28 In assessing a system’s overall capacity, it is important to look at all aspects –
29 positive and negative. It is important for systems to understand what those positive
30 characteristics are so they can be continued or strengthened. These positive aspects assist
31 the system in addressing capacity deficiencies or concerns. For example, this particular
32 system has been able to manage 33 small regional water systems so that greater
33 efficiencies are achieved through economy of scale. The factors that are particularly
34 important for Orbit are listed below.

- 1 • Staff Longevity – The system is owned and the main managerial positions
2 are staffed by one family. As such, the system has had the same President,
3 Engineer, and Operator/Operations Supervisor for over 20 years. This
4 longevity in staff creates a long-term memory of system components and
5 system characteristics. The staff is very dedicated, and other than general
6 operators, has experienced little turnover.
- 7 • Communication – There is excellent communication among the staff.
8 There is also good communication between the system and the customers.
9 Communication occurs through Consumer Confidence Reports, personal
10 visits with customers who have a complaint, and monthly billing
11 statements.
- 12 • In-House Expertise – The system has an engineer on staff that is able to
13 meet the systems engineering needs. Also, the system installs many of its
14 own lines (less than 6 inches in diameter). Part of the reason for doing so
15 is to ensure that the lines are installed properly. In the past, the system
16 had problems with poorly constructed lines installed by private
17 developers.
- 18 • Planning for System Growth – The systems are installed with
19 consideration given to potential future connections. All connections for
20 future use are initially installed and the lines sized accordingly to ensure
21 that build-out of the developments can be accommodated easily.
- 22 • Regional Nature of the System – There is a single rate structure to cover
23 all the systems operated by Orbit. This combined rate allows the overall
24 system to create an economy of scale and an efficiency that helps all the
25 systems. As new rules that would require more complex treatment are
26 introduced, the ability to take advantage of this regional approach would
27 be critical. Orbit is willing to explore regionalization opportunities with
28 neighboring systems that wish to work with them.
- 29 • The system maintains a good set of maps and uses them regularly. The
30 maps are updated as the system is changed. Some private systems
31 purchased by Orbit did not have good mapping of system components, and
32 it is working on improving these maps over time.

33 **4.1.2.4 Capacity Deficiencies**

34 The following capacity deficiencies were noted in conducting the assessment.

- 35 • Training – The managerial staff does not regularly attend training. This
36 lack of training may become a greater issue as new and more complex
37 rules are established. None of the staff, other than the President, are
38 members of any water-related organization. Attendance at organization
39 meetings could help keep staff members current on operational procedures
40 and regulatory changes.
- 41 • Safety – The systems rely on gas chlorination which has inherent dangers.
42 The chlorination buildings do not have mechanical ventilation, no alarm

1 systems, and no self-contained breathing apparatus (SCBA). There are no
2 written procedures for handling chlorine gas, and a buddy system is not
3 used.

- 4 • Budget – Orbit does not have an official budget. Also, there are no
5 budgets for each of the individual systems to track what is needed by each
6 system. There is no process of preparing and approving budgets.
- 7 • Capital Improvements Planning – There is no long-term capital
8 improvements planning done for the overall system or the individual
9 systems. Issues are addressed as they arise, rather than planned for in
10 advance. Needs are considered but they are not written down or included
11 in a plan.
- 12 • Emergency Planning – The system does not have a written emergency
13 plan, nor does it have emergency equipment such as generators or SCBAs.
14 The absence of a back-up generator caused a problem when an electrical
15 storm knocked out power for 3 days and the system was not able to deliver
16 water.
- 17 • Audited Financial Report – There is no independently audited financial
18 report. An annual financial statement is generated in house for the
19 facilities. However, because there is no budget, there is nothing to
20 evaluate the annual financial statements against.

21 **4.1.2.5 Potential Capacity Concerns**

22 The following items were concerns regarding capacity, but there are no particular
23 operational, managerial, or financial problems that can be attributed to these items. The
24 system should focus on the deficiencies noted above in the capacity deficiency section.
25 Addressing the items listed below would help in further improving FMT capabilities.

- 26 • Source Water Protection – The system has not implemented any type of
27 source water protection program.
- 28 • Written Operational Procedures – There are no written operational
29 procedures. Currently, due to the family nature of the business and the
30 longevity of the staff, no problems are created by a lack of these
31 procedures. However, if there is a turn over in staff, the lack of written
32 procedures could be a major problem for the system. In addition, written
33 procedures would help the general operators.
- 34 • Emergency Funding – Orbit should have a fund to cover emergencies.
35 Currently, emergencies or other conditions that cause a short fall in
36 funding are covered by private investment by the President. This practice
37 has been able to sustain the system in the past, but it may not be a
38 sustainable practice in the future. Orbit should consider some other means
39 of covering these emergencies, such as reserve accounts.

1 **4.2 ALTERNATIVE WATER SOURCE DEVELOPMENT**

2 **4.2.1 Identification of Alternative Existing Public Water Supply Sources**

3 Table 4.1 is a list of the existing groundwater-supplied public water systems within
4 approximately 15 miles of the Rosharon Road Estates PWS. These water systems are
5 shown on Figure 4.1. From these water systems, eight were selected for further
6 evaluation based on factors such as water quality, distance from the RRE PWS, sufficient
7 total production capacity for selling or sharing water, and willingness of the system to
8 sell or share water or drill a new well. The PWSs selected for further evaluation are
9 shown in Table 4.2.

10 **Table 4.1 Surrounding Public Water Systems within 15 miles of RRE**

System Name (PWS ID)	Approximate Distance from RRE (miles)	Comments/Issues
Sandy Meadow Estates Subdivision	1.2	Nearby study system; WQ issues: As, Mn; Owned by Orbit Systems.
Grasslands	4.2	Nearby study system; WQ issues: As; Owned by Orbit Systems.
Rosharon Township	5.34	Nearby study system; WQ issues: As, Mn; Owned by Orbit Systems.
Mark V Estates	5.7	Nearby study system; WQ issues: As; Owned by Orbit Systems.
City of Danbury	8.85	Nearby study system; WQ issues: As, Fe, Mn; Owned by Orbit Systems.
City of Angleton/Brazosport Water Authority (BWA)	11.6	The City purchases supplemental treated water from BWA. BWA has excess capacity and is willing to sell. There is an 18-inch BWA main to north of city. Evaluate further.
City of Alvin	9.04	WQ within acceptable range, excess capacity, and willing to sell. Evaluate further.
Best Sea Pack	7.81	No WQ issues, no excess capacity, willing to drill new well. Evaluate further.
Briar Meadows	1.22	WQ is acceptable, owned by Orbit Systems, no excess capacity. Evaluate further.
City of Pearland	15.34	WQ acceptable, adequate total production, distance may be a limiting factor.
City of Hillcrest Village	9.53	WQ acceptable, adequate total production, distance may be a limiting factor. Evaluate further.
Chocolate Bayou Marina	13.93	WQ acceptable, adequate total production, distance may be a limiting factor.
TDCJ ID Darrington Unit	7.67	WQ acceptable, adequate production, distance may be a limiting factor, excess capacity. Evaluate further.
Sienna Plantation MUD 1	12.6	WQ acceptable, adequate total production, distance may be a limiting factor.
Sam's Country Store	3.89	WQ issues: Mn; low total production.

System Name (PWS ID)	Approximate Distance from RRE (miles)	Comments/Issues
JMP Utilities Inc	4.07	WQ issues: Mn; low total production. Possible excess capacity. Evaluate further.
Bayou Shadows Water	4.32	WQ issues: As, Mn; low total production.
Monsanto Park Chocolate Bayou	4.42	WQ issues: Mn; unknown total production.
Schlumberger Reservoir Comp	4.45	WQ issues: As, Mn.
Oak Bend Estates	4.5	WQ issues: Mn; low total production. Consider installing a well. Evaluate further.
Oak Meadows Estates Subdivision	4.71	WQ issues: As, Fe; low total production.
Oak Manor Municipal Utility	4.97	WQ issues: As, Mn; low total production.
Yellow Rose Tavern	5.19	No WQ issues (but limited analyses); low total production.
Alvin Food Mart 2	5.39	WQ within acceptable range; low total production.
Davenport Mammoet LLC	5.42	WQ within acceptable range; unknown total production.
Red Oak 102 Chevron	5.82	WQ issues: Mn; low total production.
Brandi Estates	7.05	WQ issues: Mn; distance; low total production.
City of Liverpool	7.13	WQ issues: As; low total production.
Susie's Corner	7.18	WQ issues: Fe, Mn; low total production.
Wolf Glen Water System	7.28	WQ issues: TDS, Fe, Mn; low total production.
Country Acres Estates	7.35	WQ issues: Mn; low total production.
Weybridge Subdivision	7.4	WQ issues: Mn; low total production.
Country Meadows	7.56	WQ issues: Mn; low total production.
Brazoria Cnty Detention	7.67	WQ issues: As.
Coastal Mini Mart 335	7.7	WQ issues: Mn; low total production.
Diamond Mini Mart 316	7.71	WQ issues: As, Mn; low total production.
City of Manvel	7.78	WQ issues: Mn; low total production.
PT Food Mart	7.79	WQ issues: Fe, Mn; unknown total production.
Wee Mart	7.86	WQ acceptable; low total production.
The Bend at Brazoria Golf	7.92	WQ issues: Mn; unknown total production.
Lee Ridge Subdivision	7.96	WQ issues: Mn; low total production.
Columbus Club Association	7.98	WQ issues: Mn; low total production.
Willow Wood Duplex	8.03	WQ issues: Mn; low total production.
Almeda Water Well Service	8.18	WQ issues: Fe, Mn.
Calico Farms Subdivision	8.27	WQ issues: Mn; low total production.
Bateman Water Works	8.34	WQ issues: Mn; low total production.
Ashley Oaks Mobile Home	8.43	WQ issues: Mn; low total production.
Malt n Burger	8.53	WQ issues: Mn; unknown total production.
Hot Market	8.54	WQ issues: Fe, Mn; unknown total production.
Alvin Country Club	8.63	No WQ issues; unknown total production.
Handi Plus 42	9	WQ issues: Mn; low total production.
A & A Stop and Shop	9.15	WQ issues: Mn; low total production.
City of Liverpool	9.18	WQ acceptable; low total production.
Wolfe Air Park	9.57	Water quality within acceptable range; low total production.

System Name (PWS ID)	Approximate Distance from RRE (miles)	Comments/Issues
Colony Cove Subdivision Water System	9.79	WQ issues: Mn; low total production.
Spin N Market 11	9.86	WQ issues: Mn; low total production.
Pleasant Meadows Subdivision	9.95	WQ issues: Mn; low total production.
Pleasantdale Subdivision	9.95	WQ issues: Mn; low total production.
Southwood Estates Inc	9.96	WQ issues: Fe, Mn; low total production.
Country Creek Estates	10.15	WQ issues: Mn; low total production.
Meadowland Subdivision	10.16	WQ issues: Mn; low total production.
Heights Country Subdivision	10.36	WQ issues: Mn; low total production.
Custom Food Group	10.37	WQ acceptable; distance; low total production.
TDCJ Ramsey Area	10.41	WQ issues: Fe; distance.
Beachwood Subdivision	10.44	WQ issues: Fe, Mn; distance; low total production.
Kickin Up at Eddies	10.5	WQ issues: Fe, Mn; distance; low total production.
Pine Colony Mobile Home Park	10.77	WQ issues: Mn; distance; low total production.
Moreland Subdivision Block 3&4	10.83	WQ issues: Mn; distance; low total production.
Moreland Subdivision Block 1&2	11.09	WQ issues: Fe; distance; low total production.
Mooreland Subdivision Water	11.12	WQ issues: Mn; distance; low total production.
Cross Country Stores	11.23	WQ issues: As, Mn; distance; low total production.
Anglecrest Subdivision	11.24	WQ issues: Mn; distance; low total production.
Brazoria Co Parks - Resoft Pk	11.33	Water quality within acceptable range; distance; low total production.
Sandy Ridge Subdivision	11.35	WQ issues: Mn; distance; low total production.
Meadowview Subdivision	11.45	WQ issues: Mn; distance; low total production.
Almost Heaven Campground	11.5	WQ issues: Fe, Mn; distance; low total production.
Bedrock Café	11.51	WQ issues: Fe, Mn; distance; low total production.
Cedar Grove Park	11.53	WQ acceptable; distance; low total production.
Ryan Long Subdivision 2 Water	11.56	WQ issues: Mn; distance; low total production.
Palmetto Subdivision	11.59	WQ issues: Mn; distance; low total production.
Village Trace Water System	11.59	WQ acceptable; distance; low total production.
Coastal Mini Mart 338	11.66	No WQ issues; distance; unknown total production.
Westwood Subdivision	11.78	WQ issues: Mn; distance; low total production.
Behavior Training Research	11.8	No WQ issues; distance; low total production.
Houston Southwest Airport	11.83	WQ issues: Mn; distance; low total production.
Windsong Subdivision	11.96	WQ issues: Mn; distance; low total production.
Frontier Water Co.	12.06	WQ issues: Fe, Mn; distance; low total production.
Arcola Food Market	12.11	WQ issues: Fe, Mn; distance; low total production.
Centennial Place	12.14	WQ acceptable; distance; low total production.
Televue Terrace Subdivision	12.18	WQ issues: Fe, Mn; distance; low total production.
Flora 7	12.21	WQ issues: Mn; distance; low total production.
Johns Countryette	12.37	No WQ issues; distance; low total production.
Algoa Skating Rink	12.37	WQ issues: Fe, Mn; distance; low total production.
Riverside Estates	12.4	WQ issues: Mn; distance; low total production.
Gene's Country Store	12.48	WQ issues: Mn, TDS; distance; unknown total production.

System Name (PWS ID)	Approximate Distance from RRE (miles)	Comments/Issues
Alvin Pantry 261 Citgo	12.52	No WQ issues; distance; unknown total production.
Anchor Road Mobile Road	12.55	WQ issues: Fe, Mn; distance; low total production.
Hastings Home Owners Water	12.56	No WQ issues; distance; low total production.
Fresno Food Market	12.59	Water quality within acceptable range; distance; low total production.
End of the Trail	12.6	WQ issues: Mn; distance; low total production.
Country Oaks Arbor MHP	12.61	WQ issues: Fe, Mn; distance; low total production.
Meadowlark Subdivision	12.71	WQ issues: Mn; distance; low total production.
Flora 6	12.72	WQ issues: Fe, Mn; distance; low total production.
Coronado Country	12.76	WQ issues: Mn; distance; low total production.
West Lea Water System	12.78	WQ issues: Mn; distance; low total production.
Sharondale Subdivision	12.84	WQ issues: Mn; distance; low total production.
Wellborn Acres	12.85	WQ issues: Fe, Mn; distance; low total production.
Halliburton Services Fresno	12.88	WQ issues: Mn; distance; low total production.
Niagra Public Water Supply	12.89	WQ issues: Fe, Mn; distance; low total production.
A Place to Grow Day Care	12.93	WQ issues: Mn; distance; low total production.
Rozi's Mini Mart 3	12.95	WQ issues: Mn; distance; low total production.
Quail Meadows Subdivision	13.036	WQ issues: Mn; distance; low total production.
City of Holiday Lake	13.13	WQ issues: Fe, TDS; distance.
Blue Sage Gardens	13.21	WQ issues: Mn; distance; low total production.
Manvel Road Terrace	13.3	WQ issues: Mn; distance; low total production.
Fort Bend County MUD 43	13.31	WQ issues: Fe; distance.
Johnson's Water Service	13.34	WQ issues: Mn; distance; low total production.
Schmidt Manufacturing	13.34	WQ issues: As, Fe, Mn; distance; low total production.
Wagon Wheel Utility Co.	13.38	WQ issues: Mn; distance; low total production.
Turner Water Service	13.42	WQ issues: Mn; distance; low total production.
TPWD Brazos Bend State Park 2	13.48	WQ issues: Fe; distance; low total production.
Fresno Mobile Home Park	13.49	WQ issues: Mn; distance; low total production.
Camp Wind A Mere	13.5	WQ issues: Mn; distance; low total production.
Angle Acres Water System	13.59	WQ issues: Fe, Mn; distance; low total production.
Champion Technologies Inc	13.65	WQ acceptable; distance; low total production.
Third coast Packaging Inc	13.7	No WQ issues (but limited analyses); distance; low total production.
Equistar Chemicals LP	13.87	WQ issues: Fe, Mn, TDS; distance; low total production.
Crossroad Market	13.9	WQ issues: Fe, Mn; distance; unknown total production.
Brazoria County MUD 2	14.01	WQ issues: Fe; distance; unknown total production.
Racetrac Petroleum 527	14.01	WQ issues: Mn; distance; unknown total production.
Rudy's Tavern Inc.	14.15	WQ issues: Mn; distance; unknown total production.
The Old Place	14.2	WQ issues: Mn; distance; unknown total production.

System Name (PWS ID)	Approximate Distance from RRE (miles)	Comments/Issues
Market Square Food Mart	14.21	WQ issues: Mn; distance; unknown total production.
Oak Hollow Mobile Home Park	14.22	WQ issues: Fe, Mn; distance; unknown total production.
Friendswood Industrial Park	14.22	WQ issues: Mn; distance; unknown total production.
Exxon Mobile-Thompson Field	14.26	No WQ issues; distance; low total production.
La Casita Restaurant	14.33	WQ issues: Mn; distance; low total production.
Back to Basic Christian Day Care	14.35	WQ issues: Mn; distance; low total production.
Brazoria Cnty Parks Brazos Rvr Pk	14.37	WQ issues: As, Mn; distance; low total production.
Salt Grass Kountry 1	14.38	WQ issues: As, Mn, TDS; distance; unknown total production.
Bill Holley Cntr	14.46	WQ issues: Fe, Mn; distance; unknown total production.
TPWD Brazos Bend State Park 1	14.52	No WQ issues; distance; low total production.
Chaplans Mobile Home	14.55	WQ issues: Fe, Mn; distance; low total production.
Roger Lewis Water System	14.55	WQ issues: Fe, Mn; distance; unknown total production.
Sterling Estates	14.76	WQ issues: Fe, Mn; distance; low total production.
City of Friendswood	15.11	WQ issues: Fe, Mn; distance; low total production.

1

2 **Table 4.2 Public Water Systems within 15 Miles of RRE Selected for Further**
3 **Evaluation**

System Name	Population	Conn	Total Production (mgd)	Ave Daily Demand (mgd)	Approx. Dist. from RRE	Comments/Other Issues
Best Sea Pack, Inc.	30	1	0.345	nd	7.8 miles	No excess capacity. However, based on WQ data, this PWS may provide a suitable location for a new well.
City of Angleton/Brazosport Water Authority	19,167 ^(a)	6,389 ^(a)	5.112 ^(b)	1.910 ^(a)	11.6 miles	The City purchases supplemental treated water from BWA. BWA has excess capacity and is willing to sell. There is an 18-inch BWA main to north of city.
City of Hillcrest Village	756	252	0.583	0.045	9.5 miles	Excess capacity and adequate production, but distance may be an issue.

System Name	Population	Conn	Total Production (mgd)	Ave Daily Demand (mgd)	Approx. Dist. from RRE	Comments/Other Issues
Briar Meadows	111	37	0.101	0.015 (est)	1.2 miles	Not sufficient excess capacity for RRE. However, based on WQ data and proximity to RRE, this PWS may provide a suitable location for a new well.
JMP Utilities	57	19	0.086	0.008 (est)	4.1 miles	Mn above MCL; low total production.
Oak Bend Estates	114	38	0.05	0.015 (est)	4.5 miles	Mn above MCL; low total production.
TDCJ ID Darrington Unit	2037	1250	1.886	0.5	7.7 miles	Adequate production with excess capacity, but not willing to sell water at this time.
City of Alvin	17,916	5,972	8.739	1.307	9 miles	Has excess capacity and is willing to sell water.

- 1 *nd – no data*
- 2 *est – estimated*
- 3 *a – City of Angleton*
- 4 *b – Brazosport Water Authority*

5 **4.2.1.1 Briar Meadows**

6 Briar Meadows is located on FM 1462, approximately 1.2 miles to the northeast of
7 RRE. The PWS is owned by Orbit and is supplied by a single groundwater well. The
8 well, completed in the Chicot aquifer (Code 112CHCT), is 210 feet deep and rated for
9 0.086 mgd. The system has 5,000 gallons of storage capacity. Briar Meadows serves a
10 population of 111 with 37 metered connections. The water delivery system has a total
11 peak production of 0.101 mgd, and water is hypochlorinated and treated with
12 polyphosphate (for iron and manganese) before distribution.

13 The estimated average and maximum daily demand is 0.015 mgd and 0.059 mgd,
14 respectively. The well does not have enough capacity to meet the peak demand flow rate
15 of RRE. However, based on water quality data for Briar Meadows and its proximity to
16 RRE, Briar Meadows may provide a suitable location for a new well.

17 **4.2.1.2 J M P Utilities**

18 J M P Utilities serves a mobile home park located adjacent to County Road 184
19 approximately 1 mile north of FM 1462. The PWS is approximately 4.1 miles from
20 RRE, and is operated by J M P Utilities in Manvel, Texas. The PWS serves a population
21 of 57 (19 metered connections) with one well with a total capacity of 0.288 mgd and a
22 3,000-gallon pressure tank. The water delivery system has a total peak production of

1 0.086 mgd. The well, completed in the Chicot aquifer (Code 112CHCT), is 510 feet
2 deep.

3 The estimated average and maximum daily demand is 0.008 mgd and 0.030 mgd,
4 respectively. The PWS's 200 gpm (0.288 mgd) well pump is large enough to also
5 provide water to RRE.

6 **4.2.1.3 Oak Bend Estates**

7 Oak Bend Estates is located on County Road 864A off of County Road 172,
8 approximately 4.5 miles east of RRE. The PWS is operated by Southwest Utilities, Inc.
9 in El Campo, Texas. Oak Bend Estates serves a population of 114 with 38 connections.
10 The well is 145 feet deep with a rated capacity of 0.050 mgd. The water is
11 hypochlorinated and treated with polyphosphate (for iron and manganese) before
12 distribution. The system has a 21,000-gallon ground storage tank, two 125 gpm service
13 pumps, and one 2,500-gallon pressure tank. The water delivery system has a total peak
14 production of 0.055 mgd. The estimated average and maximum daily demand is
15 0.015 mgd and 0.060 mgd, respectively.

16 There is no excess capacity at Oak Bend Estates to supplement the existing supply of
17 the RRE; however, based on the available water quality data, the location may be a
18 suitable point for a new groundwater well.

19 **4.2.1.4 TDCJ Darrington Unit**

20 The Texas Department of Criminal Justice (TDCJ) Darrington Unit is located
21 approximately 7.7 miles northwest of RRE. The PWS is supplied by three local
22 groundwater wells, two of which are completed in the Lower Chicot aquifer and one of
23 which is completed in the Evangeline aquifer. The wells G0200204A, G0200204B, and
24 G0200204C were drilled to depths of 595 feet, 537 feet, and 1,140 feet, respectively.
25 The tested flow rates of each well are 360, 350, and 600 gpm for a total system
26 production capacity of 1.886 mgd. The treatment process consists of sequestration and
27 chlorination. The average daily demand is 0.5 mgd which means TDCJ Darrington is
28 utilizing approximately 27 percent of the total system capacity. If TDCJ Darrington
29 provided the necessary 15,000 gallons per day to RRE, it would consume approximately
30 1 percent of the total system capacity. Based on water quality data reported in the TCEQ
31 database, there are no water quality issues associated with the TDCJ Darrington water
32 supply system. At this time, TDCJ Darrington is unable to provide extra water to any
33 other communities, but the area may be a suitable location for a well.

34 **4.2.1.5 Best Sea Pack**

35 Best Sea Pack, Inc. is located 7.8 miles south of the Rosharon Road Estates PWS and
36 is a privately-owned industrial facility that produces ice for shrimp packing. The water
37 system for the facility (PWS ID# 0200505) consists of a single well that draws water
38 from the Chicot aquifer (Code 112CHCT), is 302 feet deep, and has a total production of
39 0.345 mgd. The groundwater is chlorinated before being discharged to a storage tank.

1 Best Sea Pack, Inc. does not have sufficient capacity to supplement the RRE PWS;
2 however, based on the available water quality data and the proximity to Rosharon Road
3 Estates, the location may be a suitable point for a new groundwater well.

4 **4.2.1.6 City of Alvin**

5 The City of Alvin is located approximately 9 miles northeast of the RRE. The PWS
6 is supplied by four local groundwater wells, three of which are completed in the Lower
7 Chicot aquifer (Code 112CHCTL) and one of which is completed in the Evangeline
8 aquifer (Code 121EVGL). The four wells are between 688 and 711 feet deep, and have a
9 total production of 8.739 mgd. Well water is treated with polyphosphate and
10 hypochlorite before being discharged to several ground and elevated storage tanks. The
11 City serves a population of 17,916 and has 5,817 metered connections. The reported
12 average daily demand is 1.307 mgd. The peak demand is estimated to be 5.228 mgd.

13 The City of Alvin currently provides finished water to several small PWSs within its
14 extra-territorial jurisdiction and is building lines out toward Manvel, located to the west
15 along Highway 6. The City eventually plans to build lines past Manvel. Alvin is
16 planning to build a new plant and storage tank in that region sometime in the next couple
17 of years. The City currently has up to 4 mgd of excess capacity, and is willing to
18 negotiate to sell water to other PWSs outside its extra-territorial jurisdiction.

19 The Gulf Coast Water Authority plans build a 150 mgd water treatment plant (WTP)
20 to treat Brazos River water. The new WTP may be built on 80 acres of land currently
21 owned by the Fort Bend County Water Control and Improvement District (WC&ID)
22 No. 2 (<http://www.fortbendcountycid2.com/WaterSource.htm>). This would be a
23 regional WTP that may serve west Harris County, the cities of Sugar Land, Missouri
24 City, Arcola, Pearland, Alvin, Manvel, Friendswood, and the area within the boundaries
25 of Fort Bend County WC&ID No. 2, which includes the City of Stafford. RRE may be
26 able to connect to this regional WTP distribution system within the City of Alvin.

27 **4.2.1.7 City of Hillcrest Village**

28 The City of Hillcrest Village is located approximately 9.5 miles east of RRE. There
29 are 252 connections serving a population of 756. The system consists of two wells,
30 Well #1 and Well #2 that pump 190 gpm and 200 gpm respectively for a total system
31 production capacity of 583,000 gallons per day (gpd). Both wells are set in the Upper
32 Chicot aquifer. The current treatment system is chlorination only. The average daily
33 demand is 45,000 gpd which means that the City of Hillcrest is utilizing less than
34 8 percent of the total system capacity. The City of Hillcrest Village is willing to sell a
35 portion of their water supply and provide the necessary 15,000 gpd to Rosharon Road
36 Estates. The effect on the Hillcrest Village System would be the consumption of another
37 3 percent of the total system capacity.

38 It should be noted that Hillcrest Village is a designated water supplier to Alvin in
39 cases where Alvin is in need of emergency water supplies. The emergency pipeline is an

1 8-inch pipeline that runs north near Timber Lane in the City of Hillcrest to Alvin. A
2 TCEQ inspection in December 2003 indicated no violations.

3 **4.2.1.8 City of Angleton/Brazosport Water Authority**

4 The City of Angleton is located approximately 11.6 miles to the south of RRE. The
5 PWS is supplied by six local groundwater wells, which are supplemented by fully treated
6 surface water purchased from the Brazosport Water Authority (BWA). The BWA is a
7 wholesale water provider that operates a WTP located in the City of Lake Jackson and
8 supplies many communities in Brazoria County with treated water. Its primary water
9 source is the Brazos River.

10 The City of Angleton's six wells draw water from the Chicot aquifer
11 (Code 112CHCT), are between 650 and 960 feet deep, and have a total production of
12 5.112 mgd. Well water is aerated, and treated with polyphosphate and chlorine before
13 being discharged to two storage tanks. The City uses the purchased water from BWA to
14 mix with the water from the wells. The City of Angleton serves a population of
15 19,200 and has approximately 6,400 metered connections. It is currently not in a position
16 to sell water to third parties.

17 The BWA has up to 5 mgd of excess treated water capacity it is willing to sell,
18 assuming that suitable arrangements can be negotiated. It has an 18-inch supply line that
19 terminates on the north side of the City of Angleton, near the corner of Vasquez and
20 Henderson. The BWA requires that all of its customers provide for a minimum of
21 8 hours storage capacity to sustain supply in the event BWA is conducting maintenance
22 activities. Based on recent experience with Dow Chemical, the negotiation and approval
23 process could take up to 2 years; however, it expects the process would be less difficult
24 for another PWS.

25 **4.2.2 Potential for New Groundwater Sources**

26 **4.2.2.1 Existing Non-Public Supply Wells**

27 Developing new wells or well fields is recommended, provided good quality
28 groundwater available in sufficient quantity can be identified. Since a number of water
29 systems in the area also have problems with arsenic and/or manganese, it should be
30 possible to share in the cost and effort of identifying compliant groundwater and
31 constructing well fields.

32 Installation of a new well in the vicinity of the system intake point is likely to be an
33 attractive option provided compliant groundwater can be found, since the PWS is already
34 familiar with operation of water well. As a result, existing wells with good water quality
35 should be investigated. Re-sampling and test pumping would be required to verify and
36 determine the quality and quantity of water at those wells.

37 The use of existing wells should probably be limited to use as indicators of
38 groundwater quality and availability. If a new groundwater source is to be developed, it

1 is recommended that a new well or wells be installed instead of using existing wells.
2 This would ensure the well characteristics are known and the well construction meets
3 standards for drinking water wells.

4 **4.2.2.2 Results of Groundwater Availability Modeling**

5 Regional groundwater withdrawal in the RRE system is extensive and is likely to
6 steadily increase over the next decades. In Brazoria County, the Chicot aquifer
7 constitutes the primary groundwater source for public supplies. This aquifer is the upper
8 unit of the Gulf Coast aquifer system that extends along the entire Texas coastal region.
9 Throughout the northern part of the Gulf Coast aquifer system, large groundwater
10 withdrawals since the 1900s have resulted in declines in the aquifer's potentiometric
11 surface from tens to hundreds of feet. The largest declines have occurred in the Harris-
12 Galveston Coastal Subsidence District (HGCSA), around the Houston metropolitan area,
13 whose area of influence encompasses most of Brazoria County, including the RRE
14 system.

15 A GAM for northern part of the Gulf Coast aquifer was recently developed by the
16 TWDB. Modeling was performed by the U.S. Geological Survey to simulate historical
17 conditions (Kasmerek and Robinson 2004), and to develop long-term groundwater
18 projections (Kasmerek *et al.* 2005). Two projections were evaluated, a TWDB scenario
19 based on 50-year regional projections by regional user groups, and a HGCSA scenario
20 that incorporates 30-year projections by the HGCSA for the Houston Metropolitan area.
21 Modeling of both projections anticipates extensive groundwater use and drop in aquifer
22 levels, with far more critical groundwater availability conditions anticipated under the
23 30-year HGCSA scenario.

24 Under the HGCSA scenario, withdrawals from the Chicot aquifer and underlying
25 Evangeline aquifer would increase by 2030 to an estimated 1,520 mgd, a 74 percent
26 increase from 1995 conditions. Modeling of these projections indicates a significant
27 increase in the aquifer's cone of depression by 2030, with depth increases of over 200
28 feet relative to current conditions (Kasmerek, *et al.* 2005). The percent of withdrawals
29 supplied by net aquifer recharges would also steadily decrease, from an estimated
30 72 percent in 1995 to a projected 43 percent in 2030 (Kasmerek, *et al.* 2005).

31 Under the TWDB scenario, long-term withdrawals from the Chicot aquifer and
32 underlying Evangeline aquifer would moderately increase or remain level over the
33 50-year simulation period. The largest increase in withdrawal would occur between 2000
34 and 2010, with an 8 percent increase from 850 to 920 mgd (Kasmerek, *et al.* 2005).
35 Modeling of the TWDB scenario showed relatively little change in elevation of the
36 Chicot aquifer's potentiometric surface. In Matagorda County, however, a drop of
37 elevation from 50 to 100 feet would occur under 2010 withdrawal conditions. The
38 simulated net recharge of the aquifer, in contrast with the HGCSA scenario, would
39 moderately increase under the TWDB scenario (Kasmerek, *et al.* 2005).

40 The GAM of the northern part of the Gulf Coast aquifer was not run for the RRE
41 system as groundwater availability would reflect regional HGCSA conditions. Water use

1 by the system would represent a minor addition to the regional HGCSO groundwater
2 withdrawal, making potential changes in aquifer levels well beyond the spatial resolution
3 of the regional GAM model.

4 **4.2.3 Potential for New Surface Water Sources**

5 There is a low potential for development of new surface water sources for the
6 Rosharon Road Estates system as indicated by limited water availability within the site
7 vicinity. The system is located within the San Jacinto-Brazos Basin where current
8 surface water availability is expected to remain at current levels over the next 50 years
9 according to the TWDB's 2002 Water Plan (approximately 47,692 acre-feet per year
10 (AFY) during drought conditions). Approximately 12 miles west of the site, the San
11 Jacinto-Brazos Basin transitions into the Brazos River basin where water availability is
12 expected to decrease up to 17 percent over the next 50 years.

13 The vicinity of the Rosharon Road Estates system has a minimum availability of
14 surface water for new uses. The TCEQ availability map for the San Jacinto-Brazos Basin
15 and Brazos Basin indicates that, over a 20-mile radius of the site, unappropriated flows
16 for new uses are typically available less than 50 percent of the time. This supply is
17 inadequate as the TCEQ requires 100 percent supply availability for a municipal water
18 supply.

19 **4.2.4 Options for Detailed Consideration**

20 The initial review of alternative sources of water results in the following eight
21 options for more-detailed consideration:

- 22 1. J M P Utilities. Treated water would be purchased from J M P Utilities to
23 supply RRE. A pipeline would be constructed to tie into the system
24 (Alternative RR-1).
- 25 2. TDCJ Darrington. A new well would be completed in the vicinity of the well
26 at TDCJ Darrington. A pipeline would be constructed and the water would be
27 piped to RRE (Alternative RR-2).
- 28 3. City of Alvin. Treated water would be purchased from the City of Alvin to
29 supply RRE. A pipeline would be constructed to tie into the existing City of
30 Alvin system (Alternative RR-3).
- 31 4. Hillcrest Village. Treated water would be purchased from the Hillcrest
32 Village to supply RRE. A pipeline would be constructed to tie into the
33 existing Hillcrest Village system (Alternative RR-4).
- 34 5. City of Angleton/BWA. Treated water would be purchased from BWA to
35 supply RRE. A pipeline would be constructed to tie into the existing main
36 north of the City of Angleton (Alternative RR-5).

- 1 6. Briar Meadows. A new well would be completed in the vicinity of the
2 existing well at Briar Meadows. A pipeline would be constructed and the
3 water would be piped to RRE (Alternative RR-6).
- 4 7. Oak Bend Estates. A new well would be completed in the vicinity of the
5 existing well at Oak Bend Estates. A pipeline would be constructed and the
6 water would be piped to RRE (Alternative RR-7).
- 7 8. Best Sea Pack, Inc. A new well would be completed in the vicinity of the
8 well at Best Sea Pack, Inc. A pipeline would be constructed and the water
9 would be piped to RRE (Alternative RR-8).

10 In addition to the location-specific alternatives above, three hypothetical alternatives
11 are considered in which new wells would be installed 10-, 5-, and 1-miles from the RRE
12 PWS. Under each of these alternatives, it is assumed that a source of compliant water
13 can be located and then a new well would be completed and a pipeline would be
14 constructed to transfer the compliant water to RRE. These alternatives are RR-13,
15 RR-14, and RR-15.

16 **4.3 TREATMENT OPTIONS**

17 **4.3.1 Centralized Treatment Systems**

18 Centralized treatment of the well field water is identified as a potential option. Both
19 adsorption and coagulation could be potentially applicable. The central adsorption
20 treatment alternative is Alternative RR-9, and the central coagulation treatment
21 alternative is Alternative RR-10.

22 **4.3.2 Point-of-Entry Systems**

23 Point-of-entry treatment using iron-based adsorption technology is valid for arsenic
24 removal. The POE adsorption treatment alternative is RR-12.

25 **4.3.3 Point-of-Use Systems**

26 Point-of-use treatment using iron based adsorption technology is valid for arsenic
27 removal. The POU adsorption treatment alternative is RR-11.

28 **4.4 BOTTLED WATER**

29 Provision of bottled water is considered an interim measure to be used until a
30 compliance alternative is implemented. Even though the community is small and people
31 know each other; it would be reasonable to require a quarterly communication advising
32 customers of the need to take advantage of the bottled water program. An alternative to
33 providing delivered bottled water is to provide a central, publicly accessible dispenser for
34 treated drinking water. Alternatives addressing bottled water are RR-16, RR-17, and
35 RR-18.

1 **4.5 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

2 A number of potential alternatives have been identified. Each of the potential
3 alternatives is described in the following subsections. It should be noted that the cost
4 information given is the capital cost and change in O&M costs associated with
5 implementing the particular alternative. Appendix C contains cost estimates for the
6 compliance alternatives. These compliance alternatives represent a range of possibilities,
7 and a number of them are likely not feasible. However, all have been presented to
8 provide a complete picture of the range of alternatives considered. It is anticipated that a
9 PWS will be able to use the information contained herein to select the most attractive
10 alternative(s) for more detailed evaluation and possible subsequent implementation. Cost
11 analyses for shared solutions with other PWSs in the area are provided in Appendix G.

12 Some of the alternatives suggest new wells be drilled in areas where existing wells
13 are compliant with the future arsenic MCL of 10 µg/L. In developing the cost estimates,
14 Parsons assumed that the aquifer in these areas would produce the required amount of
15 water with only one well. Site investigations and geological research, which is beyond
16 the scope of this study, may indicate that the aquifer at a particular site and depth may not
17 provide the amount of water needed or more than one well would need to be drilled in
18 separate areas.

19 **4.5.1 Alternative RR-1: Purchase Treated Water from J M P Utilities**

20 The alternative consists of connecting directly to the J M P Utilities PWS well. The
21 well capacity is 0.288 mgd. The estimated peak demand is 0.030 mgd (57 people)
22 providing an excess capacity of 0.258 mgd. Its water would need to be sequestered for
23 manganese, which averages 128 µg/L. This alternative would require installation of a
24 small ground storage tank, a pump station with two transfer pumps, and a pipeline to the
25 RRE system. One of the two pumps in the pump station is for backup in the event the
26 other pump fails. The pipeline would be 5.8 miles long, and would be a 4-inch
27 polyvinylchloride (PVC) line that discharges to the existing storage tank at RRE.

28 This alternative presents a limited regional solution, since PWSs in the area also
29 need compliant water. Regional facilities serving 250 connections or more require at
30 least two wells.

31 The estimated capital cost for this alternative includes constructing the pipeline and
32 pump station. The estimated O&M cost for this alternative includes the purchase price
33 for treated water minus the cost RRE currently pays to operate its well field, plus
34 maintenance cost for the pipeline, power, O&M labor, and materials for the pump station.
35 The estimated capital cost for this alternative is \$1.48 million, and the estimated annual
36 O&M cost for this alternative is \$15,500.

37 The feasibility of this alternative is dependent on the capability and willingness of
38 J M P Utilities to sell treated drinking water to RRE.

1 The reliability of adequate amounts of compliant water under this alternative should
2 be good. From the perspective of Orbit, this alternative would be characterized as easy to
3 operate and repair, since O&M and repair of pipelines and pump stations is well
4 understood, and Orbit currently operates pipelines and a pump station.

5 **4.5.2 Alternative RR-2: New Well at TDCJ Darrington**

6 This alternative consists of the installation of a well at the TDCJ Darrington well
7 field in place of using the RRE well field. This alternative would also require
8 construction of a pipeline from TDCJ Darrington to the existing intake point for the RRE
9 system. A pump station would also be required to overcome pipe friction and elevation
10 difference between the two locations. The pipeline would be 9.4 miles long, and would
11 be a 4-inch PVC line that discharges to the existing storage tank at the RRE well field.
12 The pump station would include two pumps, including one standby, and would be housed
13 in a building.

14 The estimated capital cost for this alternative includes installing the well, pump, and
15 storage tank along with construction of the pipeline and pump station. The estimated
16 O&M cost for this alternative includes the purchase price for treated water minus the cost
17 RRE currently pays to operate its well field, plus maintenance cost for the well, pipeline,
18 power, and O&M labor and materials for the pump station. The estimated capital cost for
19 this alternative is \$2.29 million, and the estimated annual O&M cost for this alternative is
20 \$19,400.

21 The feasibility of this alternative is dependent on RRE being able to reach an
22 agreement with TDCJ Darrington with regard to completing a new groundwater well.

23 **4.5.3 Alternative RR-3: Purchase Treated Water from the City of Alvin**

24 This alternative consists of connecting directly to the City of Alvin's PWS system.
25 The City's wells have a total capacity 8.739 mgd. The reported average daily demand is
26 1.307 mgd. The peak demand is estimated to be 5.228 mgd. Its water would not need
27 additional treatment.

28 This alternative would require installation of two ground storage tanks, two pump
29 stations with two transfer pumps at each station, and a pipeline to the RRE system. One
30 of the two pumps in each pump station is for backup in the event the other pump fails.
31 The pipeline would be a maximum of 10.2 miles long, and would be a 4-inch PVC line
32 that discharges to the existing storage tank at RRE. There may be a closer connection
33 point that can be tapped into, which would help reduce the length of the transfer pipeline.

34 This alternative presents a regional solution, since the PWSs in the area also need
35 compliant water. The Gulf Coast Water Authority's proposed regional surface WTP
36 would replace some of the groundwater from wells in the Alvin area.

37 The estimated capital cost for this alternative includes constructing the pipeline and
38 pump stations. The estimated O&M cost for this alternative includes the purchase price

1 for treated water minus the cost RRE currently pays to operate its well field, plus
2 maintenance cost for the pipeline, power, and O&M labor and materials for the pump
3 stations. The estimated capital cost for this alternative is \$2.80 million, and the estimated
4 annual O&M cost for this alternative is \$39,800.

5 The reliability of adequate amounts of compliant water under this alternative should
6 be good. From the perspective of Orbit, this alternative would be characterized as easy to
7 operate and repair, since O&M and repair of pipelines and pump stations is well
8 understood, and Orbit currently operates pipelines and a pump station.

9 The feasibility of this alternative is dependent on the capability and willingness of
10 the City of Alvin to sell treated drinking water to RRE.

11 **4.5.4 Alternative RR-4: Purchase Treated Water from Hillcrest Village**

12 This alternative consists of the purchase of treated water from Hillcrest Village in
13 place of using the RRE well field. This alternative would require constructing a pipeline
14 from Hillcrest Village to the existing intake point for the RRE system. Two pump
15 stations would also be required to overcome pipe friction and elevation difference
16 between the two locations. The pipeline would be 10.6 miles long, and would be a 4-inch
17 PVC line that discharges to the existing storage tank at the RRE well field. Each pump
18 station would include two pumps, including one standby, and would be housed in a
19 building.

20 The estimated capital cost for this alternative includes constructing the pipeline and
21 pump stations. The estimated O&M cost for this alternative includes the purchase price
22 for treated water minus the cost RRE currently pays to operate its well field, plus
23 maintenance cost for the pipeline, power, and O&M labor and materials for the pump
24 stations. The estimated capital cost for this alternative is \$2.79 million, and the estimated
25 annual O&M cost for this alternative is \$39,700.

26 The feasibility of this alternative is dependent on the capability and willingness of
27 Hillcrest Village to sell treated drinking water to RRE.

28 **4.5.5 Alternative RR-5: Purchase Treated Water from Brazos Water 29 Authority**

30 This alternative involves purchasing treated surface water from BWA. BWA
31 currently has sufficient excess capacity for this alternative to be feasible and has
32 indicated it would be amenable to negotiating an agreement to supply water to PWSs in
33 the area.

34 This alternative would require installation of two storage tanks, two pump stations,
35 and a pipeline from the BWA 18-inch water main located adjacent to State Highway 227
36 in the City of Angleton to the existing intake point for the RRE system. The pump
37 stations are required to overcome pipe friction and elevation differences between
38 Angleton and RRE. The required pipeline would follow Route 171, be 14.6 miles long,

1 and constructed of 4-inch PVC pipe. The pipeline would terminate at the existing RRE
2 storage tank.

3 Each pump station would include two pumps, including one standby, and would be
4 housed in a building. It is assumed the pumps and piping would be installed with
5 capacity to meet all water demand for RRE, since the incremental cost would be
6 relatively small, and it would provide operational flexibility.

7 The estimated capital cost for this alternative includes constructing the pipeline and
8 pump stations. The estimated O&M cost for this alternative includes the purchase price
9 for the treated water plus maintenance cost for the pipeline, power, and O&M labor and
10 materials for the pump stations minus the cost RRE currently pays to operate its well
11 field. The estimated capital cost for this alternative is \$3.77 million, and the estimated
12 annual O&M cost is \$42,800. If the purchased water is used for blending rather than full
13 water supply, the annual O&M cost for this alternative could be reduced because of
14 reduced pumping costs and reduced water purchase costs. However, additional costs
15 would be incurred for equipment to ensure proper blending, and additional monitoring to
16 ensure the finished water is compliant.

17 The reliability of adequate amounts of compliant water under this alternative should
18 be good. BWA provides treated surface water on a large scale, facilitating adequate
19 O&M resources. From the perspective of Orbit, this alternative would be characterized
20 as easy to operate and repair, since O&M and repair of pipelines and pump stations is
21 well understood, and Orbit currently operates pipelines and a pump station. If the
22 decision was made to perform blending, then the operational complexity would increase.

23 The feasibility of this alternative is dependent on the capability and willingness of
24 BWA to sell treated drinking water to RRE.

25 **4.5.6 Alternative RR-6: New Well at Briar Meadows**

26 This alternative would require completing one new well at Briar Meadows, and
27 constructing a storage tank and pipeline from that tank to the existing intake point for the
28 RRE PWS. A pump station would also be required to overcome pipe friction. The
29 required pipeline would be constructed of 4-inch PVC pipe and would be 1.8 miles in
30 length. The pipeline would terminate at the existing storage tanks owned by RRE. An
31 agreement would need to be negotiated with Briar Meadows PWS to expand its well
32 field. Based on the water quality data in the TCEQ database, it is expected that
33 groundwater from this well would be compliant with drinking water MCLs.

34 The pump station would include two pumps, including one standby, and would be
35 housed in a building. It is assumed the pumps and piping would be installed with the
36 capacity to meet all water demand for RRE, since the incremental cost would be
37 relatively small, and it would provide operational flexibility.

38 The estimated capital cost for this alternative includes installing the well, pump, and
39 storage tank along with the constructing the pipeline and pump station. The estimated

1 O&M cost for this alternative includes the purchase price for treated water minus the cost
2 RRE currently pays to operate its well field, plus maintenance cost for the well, pipeline,
3 power, and O&M labor and materials for the pump station. The estimated capital cost for
4 this alternative is \$0.60 million, and the estimated annual O&M cost for this alternative is
5 \$13,000.

6 The reliability of adequate amounts of compliant water under this alternative should
7 be good. From the perspective of RRE, this alternative would be characterized as easy to
8 operate and repair, since O&M and repair of pipelines and pump stations is well
9 understood, and the RRE currently operates pipelines and a pump station.

10 This alternative also presents opportunity for a shared solution, since expansion of
11 the Briar Meadows well field could also be used to supply Mark V Estates, Danbury,
12 Sandy Meadows Estates Subdivision, Grasslands, and Rosharon Township to the north.
13 However, this scheme would require construction of separate pipelines.

14 The feasibility of this alternative is dependent on RRE being able to reach an
15 agreement with Briar Meadows with regard to completing a new groundwater well.

16 **4.5.7 Alternative RR-7: New Well at Oak Bend**

17 This alternative consists of drilling a new well in the Oak Bend Estates area that
18 would replace RRE's wells. Records indicate there is no detectable amount of arsenic in
19 the Oak Bend Estates well water; however manganese is sometimes above 50 µg/L,
20 which requires sequestering. Blending is a marginal option since RRE well water has an
21 arsenic concentration of 26 µg/L and would require more than a 3:1 ratio to achieve a
22 reasonable factor of safety.

23 This alternative would require drilling of a new well and installation of a well pump,
24 small ground storage tank, a pump station with two transfer pumps, and a pipeline to the
25 RRE system. One of the two pumps in the pump station is for backup in the event the
26 other pump fails. The pipeline would be 7.1 miles long, and would be a 4-inch PVC line
27 that discharges to the existing storage tank at RRE.

28 This alternative presents a limited regional solution, since PWSs in the area also
29 need compliant water. Some regionalization could be accomplished by sharing the cost
30 of drilling the well with other non-compliant PWSs in the area.

31 The estimated capital cost for this alternative includes installing the well, pump and
32 storage tank and constructing the pipeline and pump station. The estimated O&M cost
33 for this alternative includes the purchase price for treated water minus the cost RRE
34 currently pays to operate its well field, plus maintenance cost for the well, pipeline,
35 power, and O&M labor and materials for the pump station. The estimated capital cost for
36 this alternative is \$1.80 million, and the estimated annual O&M cost for this alternative is
37 \$17,100.

1 The reliability of adequate amounts of compliant water under this alternative should
2 be good. From the perspective of Orbit, this alternative would be characterized as easy to
3 operate and repair, since O&M and repair of pipelines and pump stations is well
4 understood, and Orbit currently operates pipelines and a pump station.

5 The feasibility of this alternative is dependent on RRE being able to reach an
6 agreement with Briar Meadows for finding a suitable well site at Oak Bend with regard
7 to completing a new groundwater well.

8 **4.5.8 Alternative RR-8: New Well at Best Sea Pack, Inc.**

9 This alternative at Best Sea Pack, Inc., a local commercial shrimp packing business,
10 involves completing a new well, a pump station, and a pipeline to transfer the pumped
11 groundwater to RRE. Based on water quality data in the TCEQ database, it is expected
12 that groundwater from this well would be compliant with drinking water MCLs. An
13 agreement would need to be negotiated with Best Sea Pack, Inc. to expand its well field.

14 This alternative would require completing one new well constructing a storage tank
15 and a pipeline from the tank to the existing intake point for the RRE PWS. A pump
16 station would also be required to overcome pipe friction. The required pipeline would be
17 constructed of 4-inch PVC pipe and would follow roadways for a distance of 12.3 miles.
18 The pipeline would terminate at the existing storage tanks owned by RRE.

19 The pump station would include two pumps, including one standby, and would be
20 housed in a building. It is assumed the pumps and piping would be installed with the
21 capacity to meet all water demand for RRE, since the incremental cost would be
22 relatively small, and it would provide operational flexibility.

23 The estimated capital cost for this alternative includes installing the well, pump, and
24 storage tank along with constructing the pipeline and pump station. The estimated O&M
25 cost for this alternative includes the purchase price for treated water minus the cost RRE
26 currently pays to operate its well field, plus maintenance cost for the well, pipeline,
27 power, and O&M labor and materials for the pump station. The estimated capital cost for
28 this alternative is \$2.96 million, and the estimated annual O&M cost for this alternative is
29 \$20,600.

30 The reliability of adequate amounts of compliant water under this alternative should
31 be good. From RRE's perspective, this alternative would be characterized as easy to
32 operate and repair, since O&M and repair of pipelines and pump stations is well
33 understood, and RRE currently operates pipelines and a pump station.

34 The feasibility of this alternative is dependent on RRE being able to reach an
35 agreement with Best Sea Pack, Inc. for a new groundwater well.

1 **4.5.9 Alternative RR-9: Central Iron-Based Adsorption Treatment**

2 RRE would treat groundwater from both Wells A and B using an iron-based
3 adsorption system prior to distribution. This alternative consists of constructing the
4 adsorption treatment plant at or near one of the two wells. The plant comprises a
5 400 square foot building with a paved driveway, the pre-constructed adsorption system
6 on a skid (*e.g.*, two Model APU-300 package units from Severn Trent), and a 5,000-
7 gallon backwash wastewater equalization tank. The entire facility would be fenced. The
8 water would be pre-chlorinated to oxidize As(III) to As(V) and post-chlorinated for
9 disinfection prior to flowing to the distribution system. Backwash with raw well water
10 supplied directly by the well pump would be required monthly. The backwash
11 wastewater would be equalized in the 5,000-gallon tank and discharged to the sewer at a
12 controlled rate. The adsorption media are expected to last approximately 2 years before
13 replacement and disposal. Media replacement cost would be approximately \$54,000.

14 The estimated capital cost for this alternative is \$391,400, and the estimated annual
15 O&M cost is \$45,000 which includes the annualized media replacement cost of \$27,000.
16 The reliability of adequate amounts of compliant water under this alternative is good as
17 the adsorption technology has been demonstrated effective in full-scale and pilot-scale
18 facilities. The technology is simple and requires minimal O&M effort.

19 The feasibility of this alternative is not dependent on the cooperation, willingness, or
20 capability of other water supply entities.

21 **4.5.10 Alternative RR-10: Central Coagulation/Filtration Treatment**

22 RRE would treat groundwater from both Wells A and B using a
23 coagulation/filtration system prior to distribution. This alternative consists of
24 constructing the coagulation/filtration plant at or near one of the two wells. The plant
25 comprises a 400 square foot building with a paved driveway, the pre-constructed
26 coagulation/filtration system on a skid (*e.g.*, three Macrolite filters from Kinetico), a
27 ferric chloride feed and storage system, and a 5,000-gallon backwash wastewater
28 equalization tank. The entire facility would be fenced. The water would be pre-
29 chlorinated to oxidize As (III) to As(V) and post-chlorinated for disinfection prior to
30 flowing to the distribution system. Ferric chloride solution would be fed to the well
31 water after pre-chlorination and before entering the filters. The filters would be
32 backwashed once every 1 to 2 days by well water directly from the well pump. The
33 backwash wastewater would be equalized in the 5,000-gallon tank and discharged to the
34 sewer at a controlled rate. The Macrolite media do not need replacement.

35 The estimated capital cost for this alternative is \$313,300, and the estimated annual
36 O&M cost is \$59,800. This alternative requires more O&M labor cost and sewer
37 disposal charges than the adsorption alternative.

38 The reliability of adequate amounts of compliant water under this alternative is good
39 because coagulation/filtration is a well-established technology. The technology is simple
40 but requires significant effort for chemical handling and backwash monitoring.

1 The feasibility of this alternative is not dependent on the cooperation, willingness, or
2 capability of other water supply entities.

3 **4.5.11 Alternative RR-11: Point-of-Use Treatment - Adsorption**

4 This alternative consists of the continued operation of the RRE well field, plus
5 treatment to remove arsenic from water to be used for drinking or food preparation at the
6 POU. The purchase, installation, and maintenance of POU treatment systems to be
7 installed “under the sink” would be necessary for this alternative. Blending is not an
8 option in this alternative.

9 This alternative would require installation of the POU treatment units in dwellings
10 and other buildings that provide potable water. RRE would be responsible for purchasing
11 and maintaining the treatment units, including media and filter replacement, periodic
12 sampling, and necessary repairs. In residences, the most convenient point for installation
13 of the treatment units is typically under the kitchen sink, with a separate tap installed for
14 dispensing treated water. Installation of the treatment units in kitchens would require
15 entry of RRE or contract personnel into the houses of customers. As a result, the
16 cooperation of customers would be important for success in implementing this
17 alternative. The treatment units could be installed so they could be accessed without
18 house entry, but that would complicate installation and increase costs.

19 Point-of-use arsenic treatment processes typically produce spent media that require
20 disposal and possibly a small backwash waste stream. The backwash waste stream
21 results in a slight increase in the overall volume of water used. POU systems have the
22 advantage of using a minimum volume of water for human consumption only. This
23 minimizes size of the treatment units, the increase in water required, and waste for
24 disposal. For this alternative, it is assumed that the increase in water consumption would
25 be insignificant in terms of supply cost, and that the backwash waste stream could be
26 discharged to the house septic or sewer system.

27 This alternative does not present options for a regional solution.

28 The estimated capital cost for this alternative includes the cost of purchasing and
29 installing the POU treatment systems. The estimated O&M cost for this alternative
30 includes the purchase and replacement of filters and media, as well as periodic sampling
31 and record keeping. The estimated capital cost for this alternative is \$50,200, and the
32 estimated annual O&M cost for this alternative is \$59,300. For the cost estimate, it is
33 assumed that one POU treatment unit would be required for each of the 76 existing
34 connections to the RRE system. It should be noted that the POU treatment units would
35 need to be more complex than units typically found in commercial retail outlets in order
36 to meet regulatory requirements, making purchase and installation more expensive.

37 The reliability of adequate amounts of compliant water under this alternative is fair,
38 since it relies on the active cooperation of the customers for system installation, use, and
39 maintenance, and only provides compliant water to single tap within a residence.
40 Additionally, the O&M efforts required for the POU systems would be significant, and

1 RRE personnel are inexperienced in this type of work. From the perspective of RRE this
2 alternative would be characterized as more difficult to operate due to the in-home
3 requirements and the large number of individual units.

4 The feasibility of this alternative is not dependent on the cooperation, willingness, or
5 capability of other water supply entities.

6 **4.5.12 Alternative RR-12: Point-of-Entry Treatment - Adsorption**

7 This alternative consists of the continued operation of the RRE well field, plus
8 treatment of water as it enters residences to remove arsenic. The purchase, installation,
9 and maintenance of the treatment systems at the POE to households would be necessary
10 for this alternative. Blending is not an option in this alternative.

11 This alternative would require installation of the POE treatment units at dwellings
12 and other buildings that provide potable water. RRE would be responsible for purchasing
13 and maintaining the treatment units, including media and filter replacement, periodic
14 sampling, and necessary repairs. It may also be desirable to modify piping so water for
15 non-consumptive uses could be withdrawn upstream of the treatment unit. The POE
16 treatment units would be installed outside the houses, so entry would not be necessary for
17 O&M. Some cooperation from customers would be necessary for installation and
18 maintenance of the treatment systems.

19 Point-of-entry arsenic treatment processes typically produce spent adsorption media
20 as a waste, as well as possibly backwash water that requires disposal. The backwash
21 water stream results in a slight increased overall volume of water used. Point-of-entry
22 systems treat a greater volume of water than POU systems. For this alternative, it is
23 assumed the increase in water consumption would be insignificant in terms of supply
24 cost, and the backwash waste stream can be discharged to the house septic or sewer
25 system.

26 This alternative does not present options for a regional solution.

27 The estimated capital cost for this alternative includes purchasing and installing the
28 POE treatment systems. The estimated O&M cost for this alternative includes the
29 purchase and replacement of filters and media, as well as periodic sampling and record
30 keeping. The estimated capital cost for this alternative is \$877,800, and the estimated
31 annual O&M cost is \$118,200. For the cost estimate, it is assumed that one POE
32 treatment unit would be required for each of the 76 existing connections to the RRE
33 system.

34 The reliability of adequate amounts of compliant water under this alternative are fair,
35 but better than POU systems since it relies less on the active cooperation of the customers
36 for system installation, use, and maintenance, and compliant water is supplied to all taps
37 within a house. Additionally, the O&M efforts required for the POE systems would be
38 significant, and RRE personnel are inexperienced in this type of work. From the

1 perspective of RRE, this alternative would be characterized as more difficult to operate
2 due to the on-property requirements and the large number of individual units.

3 The feasibility of this alternative is not dependent on the cooperation, willingness, or
4 capability of other water supply entities.

5 **4.5.13 Alternative RR-13: New Well at 10 Miles**

6 This alternative consists of installing one new well within 10 miles of RRE that
7 would produce compliant water in place of the water produced by the RRE well field. At
8 this level of study, it is not possible to positively identify an existing well or the location
9 where a new well could be installed.

10 This alternative would require construction of one new 310-foot deep well, a new
11 pump station with storage tank near the new well, and a pipeline from the new well/tank
12 to the existing intake point for the RRE system. The pump station and storage tank
13 would be necessary to overcome pipe friction and changes in land elevation. For this
14 alternative, the pipeline is assumed to be approximately 10 miles long, and would be a
15 4-inch PVC line that discharges to the existing storage tank at RRE. The pump station
16 would include two pumps, including one standby, and would be housed in a building.

17 Depending on well location and capacity, this alternative could present some options
18 for a more regional solution. It may be possible to share water and costs with another
19 nearby system.

20 The estimated capital cost for this alternative includes installing the wells, and
21 constructing the pipeline and pump station. The estimated O&M cost for this alternative
22 includes O&M for the pipeline and pump station, plus an amount for plugging and
23 abandoning (in accordance with TCEQ requirements) the existing RRE wells. The
24 estimated capital cost for this alternative is \$2.56 million, and the estimated annual O&M
25 cost for this alternative is \$19,500.

26 The reliability of adequate amounts of compliant water under this alternative should
27 be good, since water wells, pump stations and pipelines are commonly employed. From
28 the perspective of RRE, this alternative would be similar to operating the existing system.
29 RRE has experience with O&M of wells, pipelines, and pump stations.

30 The feasibility of this alternative is dependent on the ability to find an adequate
31 existing well or success in installing a well that produces an adequate supply of
32 compliant water. It is likely that the alternate groundwater source would not be found on
33 RRE-controlled land, so landowner cooperation would likely be required.

34 **4.5.14 Alternative RR-14: New Well at 5 Miles**

35 This alternative consists of installing one new well within 5 miles of RRE that would
36 produce compliant water in place of the water produced by the RRE well field. At this

1 level of study, it is not possible to positively identify an existing well or the location
2 where a new well could be installed.

3 This alternative would require constructing one new 310-foot deep well, a new pump
4 station with storage tank near the new well, and a pipeline from the new well/tank to the
5 existing intake point for the RRE system. The pump station and storage tank would be
6 necessary to overcome pipe friction and changes in land elevation. For this alternative,
7 the pipeline is assumed to be approximately 5 miles long, and would be a 4-inch PVC
8 line that discharges to the existing storage tank at RRE. The pump station would include
9 two pumps, including one standby, and would be housed in a building.

10 Depending on well location and capacity, this alternative could present options for a
11 more regional solution. It may be possible to share water and costs with another nearby
12 system.

13 The estimated capital cost for this alternative includes installing the wells and
14 constructing the pipeline and pump station. The estimated O&M cost for this alternative
15 includes O&M for the pipeline and pump station, plus an amount for plugging and
16 abandoning (in accordance with TCEQ requirements) the existing RRE wells. The
17 estimated capital cost for this alternative is \$1.34 million, and the estimated annual O&M
18 cost for this alternative is \$15,300.

19 The reliability of adequate amounts of compliant water under this alternative should
20 be good, since water wells, pump stations, and pipelines are commonly employed. From
21 the perspective of RRE, this alternative would be similar to operating the existing system.
22 RRE has experience with O&M of wells, pipelines, and pump stations.

23 The feasibility of this alternative is dependent on the ability to find an adequate
24 existing well or success in installing a well that produces an adequate supply of
25 compliant water. It is likely that the alternate groundwater source would not be found on
26 the RRE's controlled land, so landowner cooperation would likely be required.

27 **4.5.15 Alternative RR-15: New Well at 1 Mile**

28 This alternative consists of installing one new well within 1 mile of RRE that would
29 produce compliant water in place of the water produced by the RRE well field. At this
30 level of study, it is not possible to positively identify an existing well or the location
31 where a new well could be installed.

32 This alternative would require construction of one new 310-foot deep well, and a
33 pipeline from the new well/tank to the existing intake point for the RRE system. For this
34 alternative, the pipeline is assumed to be approximately 1 mile long, and would be a
35 4-inch PVC line that discharges to the existing storage tank at RRE.

36 Depending on well location and capacity, this alternative could present some options
37 for a more regional solution. It may be possible to share water and costs with another
38 nearby system.

1 The estimated capital cost for this alternative includes installing the wells and
2 constructing the pipeline. The estimated O&M cost for this alternative includes O&M
3 for the pipeline, plus an amount for plugging and abandoning (in accordance with TCEQ
4 requirements) the existing RRE wells. The estimated capital cost for this alternative is
5 \$0.29 million, and the estimated annual O&M cost for this alternative is \$9,200 less than
6 current costs.

7 The reliability of adequate amounts of compliant water under this alternative should
8 be good, since water wells, pump stations and pipelines are commonly employed. From
9 the perspective of RRE, this alternative would be similar to operating the existing system.
10 RRE has experience with O&M of wells, pipelines, and pump stations.

11 The feasibility of this alternative is dependent on the ability to find an adequate
12 existing well or success in installing a well that produces an adequate supply of
13 compliant water. It is likely that an alternate groundwater source would not be found on
14 RRE-controlled land, so landowner cooperation would likely be required.

15 **4.5.16 Alternative RR-16: Public Dispenser for Treated Drinking Water**

16 This alternative consists of the continued operation of the RRE well field, plus
17 dispensing treated water for drinking and cooking at a publicly accessible location.
18 Implementing this alternative would require purchasing and installing a treatment unit
19 where customers would be able to come to fill their own containers. This alternative also
20 includes notifying customers of the importance of obtaining drinking water from the
21 dispenser. In this way, only a relatively small volume of water requires treatment, but
22 customers would be required to pick up and deliver their own water.

23 Blending is not an option in this alternative. It should be noted that this alternative
24 would be considered an interim measure until a compliance alternative is implemented.

25 RRE would be responsible for maintenance of the treatment unit, including media
26 replacement, periodic sampling, and necessary repairs. The spent media would require
27 disposal. This alternative relies on a great deal of cooperation and action from the
28 customers in order to be effective.

29 This alternative does not present options for a regional solution.

30 The estimated capital cost for this alternative includes purchasing and installing the
31 treatment system to be used for the drinking water dispenser. The estimated O&M cost
32 for this alternative includes purchasing and replacing filters and media, as well as
33 periodic sampling and record keeping. The estimated capital cost for this alternative is
34 \$11,600, and the estimated annual O&M cost for this alternative is \$22,300.

35 The reliability of adequate amounts of compliant water under this alternative is fair,
36 because of the large amount of effort required from the customers and the associated
37 inconvenience. RRE has not provided this type of service in the past. From the

1 perspective of RRE, this alternative would be characterized as relatively easy to operate,
2 since these types of treatment units are highly automated, and there is only one unit.

3 The feasibility of this alternative is not dependent on the cooperation, willingness, or
4 capability of other water supply entities.

5 **4.5.17 Alternative RR-17: 100 Percent Bottled Water Delivery**

6 This alternative consists of the continued operation of the RRE well field, but
7 compliant drinking water would be delivered in containers to customers. This alternative
8 involves setting up and operating a bottled water delivery program to serve all customers
9 in the system. It is expected that RRE would find it most convenient and economical to
10 contract a bottled water service. The bottle delivery program would need to be flexible
11 enough to allow for delivery of smaller containers should customers be incapable of
12 lifting and manipulating 5-gallon bottles. Blending is not an option in this alternative. It
13 should be noted that this alternative would be considered an interim measure until a
14 compliance alternative is implemented.

15 This alternative does not involve capital costs for construction, but would require
16 initial costs for system set up, and then ongoing costs to furnish the bottled water. It is
17 assumed for this alternative that bottled water would be provided to 100 percent of
18 RRE's customers.

19 This alternative does not present options for a regional solution.

20 The estimated initial capital cost is for setting up the program. The estimated O&M
21 cost for this alternative includes program administration and purchase of the bottled
22 water. The estimated capital cost for this alternative is \$36,300, and the estimated annual
23 O&M cost for this alternative is \$167,600. For the cost estimate, it is assumed that each
24 person requires 1 gallon of bottled water per day.

25 The reliability of adequate amounts of compliant water under this alternative is fair,
26 since it relies on the active cooperation of customers to order and utilize the water.
27 Management and administration of the bottled water delivery program would require
28 attention from RRE.

29 The feasibility of this alternative is not dependent on the cooperation, willingness, or
30 capability of other water supply entities.

31 **4.5.18 Alternative RR-18: Public Dispenser for Trucked Drinking Water**

32 This alternative consists of continued operation of the RRE well field, plus
33 dispensing compliant potable water at a publicly accessible location. The compliant
34 water would be purchased from BWA, and delivered by truck to a tank at a central
35 location where customers would be able to fill their own containers. This alternative also
36 includes notifying customers of the importance of obtaining drinking water from the
37 dispenser. In this way, only a relatively small volume of water would need to be

1 purchased, but customers would be required to pick up and deliver their own water.
2 Blending is not an option in this alternative. It should be noted that this alternative would
3 be considered an interim measure until a compliance alternative is implemented.

4 RRE would purchase a truck suitable for hauling potable water, and install a storage
5 tank. It is assumed the storage tank would be filled once a week, and that the chlorine
6 residual would be tested for each truckload. The truck would need to meet requirements
7 for potable water, and each load would be treated with bleach. This alternative relies on
8 a great deal of cooperation and action from the customers for it to be effective.

9 This alternative presents limited options for a regional solution if two or more
10 systems share the purchase and operation of the water truck.

11 The estimated capital cost for this alternative includes purchasing a water truck and
12 constructing a storage tank to be used for the drinking water dispenser. The estimated
13 O&M cost for this alternative includes O&M for the truck, maintenance for the tank,
14 water quality testing, record keeping, and water purchase. The estimated capital cost for
15 this alternative is \$103,000, and the estimated annual O&M cost for this alternative is
16 \$20,200.

17 The reliability of adequate amounts of compliant water under this alternative is fair
18 because of the large amount of effort required from the customers and the associated
19 inconvenience. RRE has not provided this type of service in the past. From the
20 perspective of RRE, this alternative would be characterized as relatively easy to operate,
21 but water hauling and storage would have to be done with care to ensure sanitary
22 conditions.

23 The feasibility of this alternative is not dependent on the cooperation, willingness, or
24 capability of other water supply entities.

25 **4.5.19 Summary of Alternatives**

26 Table 4.3 provides a summary of the key features of each alternative for RRE.

1 **Table 4.3 Summary of Compliance Alternatives for RRE**

Alt No.	Alternative Description	Major Components	Capital Cost ¹	Annual O&M Cost	Total ² Annualized Cost	Reliability	System Impact	Remarks
RR-1	Purchase groundwater from J M P Utilities	- Pump station - 5.8-mile pipeline	\$1,476,700	\$15,500	\$144,300	Good	N	Alternative assumes J M P Utilities is willing to sell water.
RR-2	New well near TDCJ Darrington	- Well - Pump station - 9.4-mile pipeline	\$2,291,100	\$19,400	\$219,200	Good	N	Alternative assumes adequate quantity of compliant water is available from this part of the Chicot aquifer, and land is available.
RR-3	Purchase treated water from City of Alvin	- Pump stations - 10.2-mile pipeline	\$2,801,300	\$39,800	\$284,000	Good	N	Agreement must be successfully negotiated with the City of Alvin. Blending may be possible.
RR-4	Purchase treated water from Hillcrest Village	- Pump stations - 10.6-mile pipeline	\$2,791,000	\$39,700	\$283,100	Good	N	Agreement must be successfully negotiated with Hillcrest Village. Blending may be possible.
RR-5	Purchase treated water from BWA	- Pump stations - 14.6-mile pipeline	\$3,765,600	\$42,800	\$371,100	Good	N	Agreement must be successfully negotiated with BWA. Blending may be possible.
RR-6	New well near Briar Meadows	- Well - Pump station - 1.8-mile pipeline	\$597,000	\$13,000	\$65,100	Good	N	Alternative assumes adequate quantity of compliant water is available from this part of the Chicot aquifer, and land is available.
RR-7	New well near Oak Bend Estates	- Well - Pump station - 7.1-mile pipeline	\$1,802,400	\$17,100	\$174,200	Good	N	Alternative assumes adequate quantity of compliant water is available from this part of the Chicot aquifer, and land is available.
RR-8	New well at Best Sea Pack, Inc.	- Well - Pump station - 12.3-mile pipeline	\$2,962,000	\$20,600	\$278,800	Good	N	Agreement must be successfully negotiated with Best Sea Pack, or land must be purchased. Blending may be possible.
RR-9	Continue operation of RRE well field w/ central treatment (adsorption)	- Central adsorption treatment plant	\$391,400	\$45,000	\$79,200	Good	T	No nearby system to possibly share treatment plant cost.
RR-10	Continue operation of RRE well field w/ central treatment (coagulation)	- Central coagulation treatment plant	\$313,300	\$59,800	\$87,100	Good	T	No nearby system to possibly share treatment plant cost.
RR-11	Continue operation of RRE well field, and point-of-use treatment	- Point-of-use treatment units	\$50,200	\$59,300	\$63,700	Fair	T, M	Only one compliant tap in home. Cooperation of residents required for installation, maintenance, and testing.
RR-12	Continue operation of RRE well field, and point-of-entry treatment	- Point-of-entry treatment units	\$877,800	\$118,200	\$194,700	Fair	T, M	All home taps compliant and less resident cooperation required.

No.	Alternative Description	Major Components	Capital Cost ¹	Annual O&M Cost	Total ² Annualized Cost	Reliability	System Impact	Remarks
RR-13	Install new compliant well within 10 miles	- New well - Storage tank - Pump station - 10-mile pipeline	\$2,559,000	\$19,500	\$242,700	Good	N	May be difficult to find well with good water quality.
RR-14	Install new compliant well within 5 miles	- New well - Storage tank - Pump station - 5-mile pipeline	\$1,337,100	\$15,300	\$131,900	Good	N	May be difficult to find well with good water quality.
RR-15	Install new compliant well within 1 mile	- New well - 1-mile pipeline	\$290,100	\$(9,200)	\$16,100	Good	N	May be difficult to find well with good water quality.
RR-16	Continue operation of RRE well field, but furnish public dispenser for treated drinking water	- Water treatment and dispenser unit	\$11,600	\$22,300	\$23,300	Fair/interim measure	T	INTERIM SOLUTION: Does not provide compliant water to all taps, and requires a lot of effort by customers.
RR-17	Continue operation of RRE well field, but furnish bottled drinking water for all customers	- Set up bottled water system	\$36,300	\$167,600	\$170,800	Fair/interim measure	M	INTERIM SOLUTION: Does not provide compliant water to all taps, and requires customers to order and use. Management of program may be significant.
RR-18	Continue operation of RRE well field, but furnish public dispenser for trucked drinking water	- Construct storage tank and dispenser - Purchase potable water truck	\$103,000	\$20,200	\$29,100	Fair/interim measure	M	INTERIM SOLUTION: Does not provide compliant water to all taps, and requires a lot of effort by customers.

- 1 Notes: N – No significant increase required in technical or management capability
2 T – Implementation of alternative would require increase in technical capability
3 M – Implementation of alternative would require increase in management capability
4 1 – See cost breakdown in Appendix C
5 2 – 20-year return period and 6 percent interest

1 **4.6 COST OF SERVICE AND FUNDING ANALYSIS**

2 To evaluate the financial impact of implementing compliance alternatives, a 30-year
3 financial planning model was developed. This model can be found in Appendix D. The
4 financial model is based on estimated cash flows, with and without implementation of the
5 compliance alternatives. Data for such models are typically derived from established
6 budgets, audited financial reports, published water tariffs, and consumption data. Orbit
7 manages 33 small rural PWSs and three wastewater treatment plants. The only financial
8 data available were a consolidated Profit and Loss Statement and a Water and
9 Wastewater Utilities Annual Report for 2004. The Water Utility Tariff and water usage
10 records for all 33 Orbit PWSs were also available.

11 This analysis will need to be performed in a more detailed fashion and applied to
12 alternatives that are deemed attractive and worthy of more detailed evaluation. A more
13 detailed analysis should include additional factors such as:

- 14 • Cost escalation,
- 15 • Price elasticity effects where increased rates may result in lower water
16 consumption,
- 17 • Costs for other system upgrades and rehabilitation needed to maintain
18 compliant operation.

19 **4.6.1 Financial Plan Development**

20 **4.6.1.1 Rosharon Road Estates Financial Data**

21 Since Orbit does not keep separate financial records for each of the 33 PWSs it
22 manages, revenues and expenses had to be estimated for Rosharon Road Estates. Annual
23 revenue was estimated using a base rate of \$21 per month per connection plus actual
24 usage at a rate of \$1.90 per 1,000 gallons assuming a water loss of 11.4 percent. These
25 values were plugged into the financial model resulting in 2004 revenue of \$29,870
26 (operating revenue plus required reserve) for Rosharon Road Estates compared to
27 \$7,780,508 total 2004 revenue for Orbit as summarized in Table 4.4.

1 **Table 4.4 Summary of Orbit Systems 2004 Water Revenues**

PWS Name	2004 Water Usage (gallons)	No. Connections	2004 Water Revenue
Rosharon Township	8,055,400	85	\$40,038
Rosharon Roads Estates	5,455,900	76	\$29,870
Sandy Meadow	3,735,400	56	\$24,456
Mark V Estates	7,178,900	94	\$37,858
Grasslands	12,465,400	150	\$67,595
Other Systems - Water	88,671,400	1,236	\$503,096
Other Systems - Sewer	125,562,400	---	\$77,595
Total		1,697	\$780,508

2 Annual expenses for Rosharon Road Estates were estimated based on its percentage
3 water usage of 4.3 percent as shown by Appendix F. This resulted in 2004 expenses of
4 \$32,866 (including depreciation) compared to \$770,256 total expenses for Orbit as
5 summarized in Table 4.5.

6 **Table 4.5 Summary of Orbit Systems 2004 Expenses**

PWS NAME	2004 WATER USAGE (GALLONS)	% WATER USAGE	2004 WATER EXPENSES
Rosharon Township	8,055,400	6.4	\$48,917
Rosharon Roads Estates	5,455,900	4.3	\$32,866
Sandy Meadow	3,735,400	3.0	\$22,930
Mark V Estates	7,178,900	5.7	\$43,566
Grasslands	12,465,400	10.3	\$79,317
Other Systems	88,671,400	70.3	\$542,660
Total	125,562,400	100.0	\$770,256

7 **4.6.1.2 Current Financial Condition**

8 **4.6.1.2.1 Cash Flow Needs**

9 Table 4.6 shows the 2004 revenues and expenses for Rosharon Road Estates
10 compared to other Orbit PWSs included in this study. The shortfall for Rosharon Road
11 Estates of \$2,996 is based on current operations without any capital expenditures to
12 address the arsenic problem. This means that Orbit Systems is not currently charging its
13 Rosharon Road Estates customers enough for water usage to sustain this portion of the
14 operation.

1 **Table 4.6 Summary of Orbit Systems 2004 Operations**

PWS NAME	2004 WATER EXPENSES	2004 WATER REVENUE	OVER / (UNDER)
Rosharon Township	\$ 48,917	\$ 40,038	(\$ 8,879)
Rosharon Road Estates	\$ 32,866	\$ 29,870	(\$ 2,996)
Sandy Meadow	\$ 22,930	\$ 24,456	\$1,526
Mark V Estates	\$ 43,566	\$ 37,858	(\$ 5,708)
Grasslands	\$ 79,317	\$ 67,595	(\$11,722)

2 Analysis of the long-term financial plan indicates that Rosharon Road Estates will
3 need to increase rates over the next few years to maintain financial viability even without
4 considering any possible solutions for the arsenic problem. The average annual bill for
5 Rosharon Road Estates customers must be increased by 10.0 percent just to meet
6 operating expenses for this system based on the assumptions used in this analysis.

7 Table 4.7 shows how a 1.3 percent increase would impact the average annual bill for
8 Rosharon Road Estates customers as a percent of the MHI for Brazoria County compared
9 to other Orbit PWSs included in this study. The average annual bill in Rosharon Road
10 Estates would increase from \$373 to \$378 based on the no action alternative.

11 **Table 4.7 Summary of Orbit Systems Required Revenue Increases**

PWS NAME	CURRENT AVERAGE ANNUAL BILL	CURRENT % MHI	% INCREASE NEEDED	NEW AVERAGE ANNUAL BILL	NEW % MHI
Rosharon Township	\$ 252	0.52 %	71.4%	\$ 432	0.89 %
Rosharon Road Estates	\$ 373	0.77 %	1.3 %	\$ 378	0.81 %
Sandy Meadow	\$ 344	0.86 %	None	\$ 295	0.74 %
Mark V Estates	\$ 381	0.78 %	6.3 %	\$ 405	0.90 %
Grasslands	\$ 375	0.77 %	8.8 %	\$ 408	0.87 %

12 **4.6.1.2.2 Ratio Analysis**

13 There is not enough financial information available for Orbits or Rosharon Road
14 Estates to calculate the Current Ratio or the Debt to Net Worth Ratio. However, an
15 Operating Ratio of 0.91 was calculated from available financial information. An
16 Operating Ratio of 1.0 means that a utility is collecting just enough money to meet
17 expenses; thus, an Operating Ratio of 0.91 is just another indication that Orbit must raise
18 its water rates for its Rosharon Road Estates customers in the future based on the no
19 action alternative.

1 **4.6.1.3 Financial Plan Results**

2 Each compliance alternative for Rosharon Road Estates was evaluated using the
3 financial model to determine the overall increase in water rates that would be necessary
4 to pay for the improvements. Each alternative was examined under the various funding
5 options described in Section 2.4.

6 The financial model results for all the alternatives are summarized in Table 4.8 and
7 Figure 4.2. Figure 4.2 shows the current average annual bill for Rosharon Road Estates
8 of \$373, and the average annual bill of \$378 needed to fully fund existing operations.
9 There are two bars shown for each of the alternatives. The lowest bar is based on
10 100 percent grant funding of capital improvements for the compliance alternative. Thus,
11 the higher average annual water bill reflects only higher O&M costs associated with the
12 compliance alternative. The highest bar is based on entirely funding capital requirements
13 with either loans or bonds, which represents the highest cost scenario. Therefore, the
14 higher average annual water bill in this case reflects both higher O&M costs and the
15 principal and interests costs to service debt associated with the compliance alternative.
16 Figure 4.2 also shows the annual residential water bill as a percent of MHI for Brazoria
17 County.

1


Table 4.8 Financial Impact on Households for RRE

		Funding Source #	0	1	2	3	4	5
#	ALTERNATIVES		All Revenue	100% Grant	75% Grant	50% Grant	SRF	Loan/Bond
RR-1	JMP Utilities	Average Annual Water Bill Maximum % of HH Income Percentage Rate Increase Compared to Current Year First Rate Increase Needed	\$ 19,227.17 42% 5408% 2005	\$ 833.14 2% 138% 2005	\$ 1,546.07 3% 346% 2005	\$ 2,259.00 5% 554% 2005	\$ 3,340.44 7% 869% 2005	\$ 3,684.86 8% 970% 2005
RR-2	TDCJ Darrington	Average Annual Water Bill Maximum % of HH Income Percentage Rate Increase Compared to Current Year First Rate Increase Needed	\$ 29,503.47 65% 8355% 2005	\$ 925.82 2% 166% 2005	\$ 2,031.95 5% 488% 2005	\$ 3,138.08 7% 811% 2005	\$ 4,815.96 11% 1300% 2005	\$ 5,350.33 12% 1456% 2005
RR-3	Alvin	Average Annual Water Bill Maximum % of HH Income Percentage Rate Increase Compared to Current Year First Rate Increase Needed	\$ 36,158.88 79% 10265% 2005	\$ 1,410.01 3% 312% 2005	\$ 2,762.49 6% 707% 2005	\$ 4,114.97 9% 1101% 2005	\$ 6,166.54 14% 1700% 2005	\$ 6,819.93 15% 1890% 2005
RR-4	Hillcrest	Average Annual Water Bill Maximum % of HH Income Percentage Rate Increase Compared to Current Year First Rate Increase Needed	\$ 36,029.40 79% 10228% 2005	\$ 1,409.37 3% 312% 2005	\$ 2,756.88 6% 705% 2005	\$ 4,104.40 9% 1098% 2005	\$ 6,148.44 14% 1694% 2005	\$ 6,799.43 15% 1884% 2005
RR-5	Brazos Water Author.	Average Annual Water Bill Maximum % of HH Income Percentage Rate Increase Compared to Current Year First Rate Increase Needed	\$ 48,307.77 106% 13749% 2005	\$ 1,483.55 3% 334% 2005	\$ 3,301.58 7% 865% 2005	\$ 5,119.61 11% 1395% 2005	\$ 7,877.38 18% 2200% 2005	\$ 8,755.67 20% 2456% 2005
RR-6	Briar Meadows	Average Annual Water Bill Maximum % of HH Income Percentage Rate Increase Compared to Current Year First Rate Increase Needed	\$ 8,147.74 18% 2231% 2005	\$ 773.75 2% 120% 2005	\$ 1,061.96 2% 204% 2005	\$ 1,350.17 3% 288% 2005	\$ 1,787.36 4% 415% 2005	\$ 1,926.59 4% 456% 2005
RR-7	Oak Bend	Average Annual Water Bill Maximum % of HH Income Percentage Rate Increase Compared to Current Year First Rate Increase Needed	\$ 23,336.89 51% 6586% 2005	\$ 869.96 2% 149% 2005	\$ 1,740.15 4% 403% 2005	\$ 2,610.33 6% 656% 2005	\$ 3,930.31 9% 1042% 2005	\$ 4,350.69 10% 1164% 2005

1

RR-16	Dispenser	Average Annual Water Bill	\$ 1,004.41	\$ 994.36	\$ 999.96	\$ 1,005.56	\$ 1,014.05	\$ 1,016.76
		Maximum % of HH Income	2%	2%	2%	2%	2%	2%
		Percentage Rate Increase Compared to Current	186%	186%	188%	190%	192%	193%
		Year First Rate Increase Needed	2005	2005	2005	2005	2005	2005
RR-17	100% Bottled	Average Annual Water Bill	\$ 4,487.80	\$ 4,456.35	\$ 4,473.88	\$ 4,491.41	\$ 4,518.00	\$ 4,526.47
		Maximum % of HH Income	10%	10%	10%	10%	10%	10%
		Percentage Rate Increase Compared to Current	1233%	1233%	1238%	1243%	1251%	1253%
		Year First Rate Increase Needed	2005	2005	2005	2005	2005	2005
RR-18	Central Trucked	Average Annual Water Bill	\$ 2,029.80	\$ 943.45	\$ 993.17	\$ 1,042.90	\$ 1,118.32	\$ 1,142.34
		Maximum % of HH Income	4%	2%	2%	2%	2%	3%
		Percentage Rate Increase Compared to Current	478%	171%	185%	200%	222%	229%
		Year First Rate Increase Needed	2005	2005	2005	2005	2005	2005

Figure 4-2 Alternative Cost Summary



Current Rates:
 Monthly: \$31.08
 Median Household Income: \$48,632
 Average Monthly Residential Usage: 5,300 gallons

**SECTION 5
REFERENCES**

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31

Ashworth J. B., and Hopkins, J. 1995. Aquifers of Texas: Texas Water Development Board Report 345, 68 p.

Barnes, V. E., and Schofield, D. A. 1964. Potential low-grade iron ore and hydraulic-fracturing sand in Cambrian sandstones, northwestern Llano region, Texas: The University of Texas at Austin, Bureau of Economic Geology Report of Investigations No. 53, 58 p.

Black, C. W. 1988. Hydrogeology of the Hickory Sandstone aquifer, upper Cambrian Riley Formation, Mason, and McCulloch Counties: The University of Texas at Austin, Department of Geological Sciences, Master’s thesis, 195 p.

Bluntzer R. L. 1992. Evaluation of ground-water resources of the Paleozoic and Cretaceous aquifers in the Hill Country of Central Texas: Texas Water Development Board Report 339, 130 p.

EPA. 2004. National primary drinking water regulations: analytical method for uranium: final rule: Federal Register: August 25, 2004 (Volume 69, Number 164). <http://www.epa.gov/fedrgstr/EPA-WATER/2004/August/Day-25/w19333.htm>

Finch, W. I. 1967. Geology of epigenetic uranium deposits in sandstone of the United States: U.S. Geological Survey Prof. Paper 538, 212 p.

Mason, C. C. 1961. Ground-water geology of the Hickory sandstone member of the Riley Formation, McCulloch County, Texas: Texas Water Development Board Bulletin 6017, 84 p.

McBride, E. F., Abdel-Wahab, A. A., and Milliken, K. 2002. Petrography and diagenesis of a half-billion-year-old cratonic sandstone (Hickory), Llano Region, Texas: The University of Texas at Austin, Bureau of Economic Geology Report of Investigations No. 264, 77 p.

Pettigrew, R. J. 1991. Geology and flow systems of the Hickory aquifer, San Saba County, Texas: Baylor Geological Studies Bulletin No. 51, 51 p.

Riemenschneider, J. J. 1995. Recharge flow patterns, and a water budget for a portion of the Hickory aquifer in Mason and McCulloch Counties, Texas: Baylor University unpublished Master’s thesis, 82 p.

Walker, L. E. 1979. Occurrence, availability, and chemical quality of ground water in the Edwards Plateau region of Texas: Texas Water Development Board Report 235, 114 p.

1
2

**APPENDIX A
PWS INTERVIEW FORM**

CAPACITY DEVELOPMENT ASSESSMENT FORM

Prepared By _____

Date _____

Section 1. Public Water System Information

1. PWS ID #	<input type="text"/>	2. Water System Name	<input type="text"/>
3. County	<input type="text"/>		
4. Owner	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
5. Admin	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
6. Operator	<input type="text"/>	Address	<input type="text"/>
Tele.	<input type="text"/>	E-mail	<input type="text"/>
Fax	<input type="text"/>	Message	<input type="text"/>
7. Population Served	<input type="text"/>	8. No. of Service Connections	<input type="text"/>
9. Ownership Type	<input type="text"/>	10. Metered (Yes or No)	<input type="text"/>
11. Source Type	<input type="text"/>		
12. Total PWS Annual Water Used	<input type="text"/>		
13. Number of Water Quality Violations (Prior 36 months)			
Total Coliform	<input type="text"/>	Chemical/Radiological	<input type="text"/>
Monitoring (CCR, Public Notification, etc.)	<input type="text"/>	Treatment Technique, D/DBP	<input type="text"/>

A. Basic Information

1. Name of Water System:
2. Name of Person Interviewed:
3. Position:
4. Number of years at job:
5. Number of years experience with drinking water systems:
6. Percent of time (day or week) on drinking water system activities, with current position (how much time is dedicated exclusively to the water system, not wastewater, solid waste or other activities):
7. Certified Water Operator (Yes or No):

 If Yes,
 7a. Certification Level (water):

 7b. How long have you been certified?
8. Describe your water system related duties on a typical day.

B. Organization and Structure

1. Describe the organizational structure of the Utility. Please provide an organizational chart. (Looking to find out the governance structure (who reports to whom), whether or not there is a utility board, if the water system answers to public works or city council, etc.)

2. If not already covered in Question 1, to whom do you report?
3. Do all of the positions have a written job description?

3a. If yes, is it available to employees?

3b. May we see a copy?

C. Personnel

1. What is the current staffing level (include all personnel who spend more than 10% of their time working on the water system)?

2. Are there any vacant positions? How long have the positions been vacant?

3. In your opinion, is the current staffing level adequate? If not adequate, what are the issues or staffing needs (how many and what positions)?

4. What is the rate of employee turnover for management and operators? What are the major issues involved in the turnover (e.g., operator pay, working conditions, hours)?

5. Is the system staffed 24 hours a day? How is this handled (on-site or on-call)? Is there an alarm system to call an operator if an emergency occurs after hours?

D. Communication

1. Does the utility have a mission statement? If yes, what is it?
2. Does the utility have water quality goals? What are they?
3. How are your work priorities set?
4. How are work tasks delegated to staff?
5. Does the utility have regular staff meetings? How often? Who attends?
6. Are there separate management meetings? If so, describe.
7. Do management personnel ever visit the treatment facility? If yes, how often?
8. Is there effective communication between utility management and state regulators (e.g., NMED)?
9. Describe communication between utility and customers.

E. Planning and Funding

1. Describe the rate structure for the utility.

2. Is there a written rate structure, such as a rate ordinance? May we see it?
 - 2a. What is the average rate for 6,000 gallons of water?

3. How often are the rates reviewed?

4. What process is used to set or revise the rates?

5. In general, how often are the new rates set?

6. Is there an operating budget for the water utility? Is it separate from other activities, such as wastewater, other utilities, or general city funds?

7. Who develops the budget, how is it developed and how often is a new budget created or the old budget updated?

8. How is the budget approved or adopted?

9. In the last 5 years, how many budget shortfalls have there been (i.e., didn't collect enough money to cover expenses)? What caused the shortfall (e.g., unpaid bills, an emergency repair, weather conditions)?

9a. How are budget shortfalls handled?
10. In the last 5 years how many years have there been budget surpluses (i.e., collected revenues exceeded expenses)?

10a. How are budget surpluses handled (i.e., what is done with the money)?
11. Does the utility have a line-item in the budget for emergencies or some kind of emergency reserve account?
12. How do you plan and pay for short-term system needs?
13. How do you plan and pay for long- term system needs?
14. How are major water system capital improvements funded? Does the utility have a written capital improvements plan?
15. How is the facility planning for future growth (either new hook-ups or expansion into new areas)?
16. Does the utility have and maintain an annual financial report? Is it presented to policy makers?

17. Has an independent financial audit been conducted of the utility finances? If so, how often? When was the last one?
18. Will the system consider any type of regionalization with any other PWS, such as system interconnection, purchasing water, sharing operator, emergency water connection, sharing bookkeeper/billing or other?

F. Policies, Procedures, and Programs
--

1. Are there written operational procedures? Do the employees use them?
2. Who in the utility department has spending authorization? What is the process for obtaining needed equipment or supplies, including who approves expenditures?
3. Does the utility have a source water protection program? What are the major components of the program?
4. Are managers and operators familiar with current SDWA regulations?
5. How do the managers and operators hear about new or proposed regulations, such as arsenic, DBP, Groundwater Rule? Are there any new regulations that will be of particular concern to the utility?
6. What are the typical customer complaints that the utility receives?
7. Approximately how many complaints are there per month?

8. How are customer complaints handled? Are they recorded?
9. (If not specifically addressed in Question 7) If the complaint is of a water quality nature, how are these types of complaints handled?
10. Does the utility maintain an updated list of critical customers?
11. Is there a cross-connection control plan for the utility? Is it written? Who enforces the plan's requirements?
12. Does the utility have a written water conservation plan?
13. Has there been a water audit of the system? If yes, what were the results?
14. (If not specifically answered in 11 above) What is the estimated percentage for loss to leakage for the system?
15. Are you, or is the utility itself, a member of any trade organizations, such as AWWA or Rural Water Association? Are you an active member (i.e., attend regular meetings or participate in a leadership role)? Do you find this membership helpful? If yes, in what ways does it help you?

G. Operations and Maintenance

1. How is decision-making authority split between operations and management for the following items:
 - a. Process Control
 - b. Purchases of supplies or small equipment
 - c. Compliance sampling/reporting
 - d. Staff scheduling

2. Describe your utility's preventative maintenance program.

3. Do the operators have the ability to make changes or modify the preventative maintenance program?

4. How does management prioritize the repair or replacement of utility assets? Do the operators play a role in this prioritization process?

5. Does the utility keep an inventory of spare parts?

6. Where does staff have to go to buy supplies/minor equipment? How often?
 - 6a. How do you handle supplies that are critical, but not in close proximity (for example if chlorine is not available in the immediate area or if the components for a critical pump are not in the area)

7. Describe the system's disinfection process. Have you had any problems in the last few years with the disinfection system?

7a. Who has the ability to adjust the disinfection process?

8. How often is the disinfectant residual checked and where is it checked?

8a. Is there an official policy on checking residuals or is it up to the operators?

9. Does the utility have an O & M manual? Does the staff use it?

10. Are the operators trained on safety issues? How are they trained and how often?

11. Describe how on-going training is handled for operators and other staff. How do you hear about appropriate trainings? Who suggests the trainings – the managers or the operators? How often do operators, managers, or other staff go to training? Who are the typical trainers used and where are the trainings usually held?

12. In your opinion is the level of your on-going training adequate?

13. In your opinion is the level of on-going training for other staff members, particularly the operators, adequate?

14. Does the facility have mapping of the water utility components? Is it used on any routine basis by the operators or management? If so, how is it used? If not, what is the process used for locating utility components?
15. In the last sanitary survey, were any deficiencies noted? If yes, were they corrected?
16. How often are storage tanks inspected? Who does the inspection?
 - 16a. Have you experienced any problems with the storage tanks?

H. SDWA Compliance

1. Has the system had any violations (monitoring or MCL) in the past 3 years? If so, describe.
2. How were the violations handled?
3. Does the system properly publish public notifications when notified of a violation?
4. Is the system currently in violation of any SDWA or state regulatory requirements, including failure to pay fees, fines, or other administrative type requirements?
5. Does the utility prepare and distribute a Consumer Confidence Report (CCR)? Is it done every year? What type of response does the utility get to the CCR from customers?

I. Emergency Planning

1. Does the system have a written emergency plan to handle emergencies such as water outages, weather issues, loss of power, loss of major equipment, etc?
2. When was the last time the plan was updated?
3. Do all employees know where the plan is? Do they follow it?
4. Describe the last emergency the facility faced and how it was handled.

Attachment A

A. Technical Capacity Assessment Questions

1. Based on available information of water rights on record and water pumped has the system exceeded its water rights in the past year? YES NO

In any of the past 5 years? YES NO How many times? _____

2. Does the system have the proper level of certified operator? *(Use questions a – c to answer.)*
 YES NO

a. What is the Classification Level of the system by NMED? _____

b. Does the system have one or more certified operator(s)? [20 NMAC 7.4.20]

YES NO

c. If YES, provide the number of operators at each New Mexico Certification Level. [20 NMAC 7.4.12]

_____ NM Small System _____ Class 2

_____ NM Small System Advanced _____ Class 3

_____ Class 1 _____ Class 4

3. Did the system correct any sanitary deficiency noted on the most recent sanitary survey within 6 months of receiving that information? [20 NMAC 7.20.504]

YES NO No Deficiencies

What was the type of deficiency? *(Check all that are applicable.)*

Source Storage

Treatment Distribution

Other _____

From the system's perspective, were there any other deficiencies that were not noted on the sanitary survey? Please describe.

4. Will the system's current treatment process meet known future regulations?

Radionuclides YES NO Doesn't Apply

Arsenic YES NO Doesn't Apply

Stage 1 Disinfectants and Disinfection By-Product (DBP)

YES NO Doesn't Apply

Surface Water Treatment Rule YES NO Doesn't Apply

5. Does the system have a current site plan/map? [20 NMAC 7.10.302 A.1.]

YES NO

6. Has the system had a water supply outage in the prior 24 months?

YES NO

What were the causes of the outage(s)? (Include number of outages for each cause.)

Drought _____ Limited Supply _____

System Failure _____ Other _____

7. Has the system ever had a water audit or a leak evaluation?

YES NO Don't Know

If YES, please complete the following table.

Type of Investigation	Date Done	Water Loss (%)	What approach or technology was used to complete the investigation?	Was any follow-up done? If so, describe

8. Have all drinking water projects received NMED review and approval? [20 NMAC 7.10.201]

YES NO

If NO, what types of projects have not received NMED review and approval.

Source Storage

Treatment Distribution

Other _____

9. What are the typical customer complaints that the utility receives?

10. Approximately how many complaints are there per month? _____

11. How are customer complaints handled? Are they recorded?

12. What is the age and composition of the distribution system? *(Collect this information from the Sanitary Survey)*

Pipe Material	Approximate Age	Percentage of the system	Comments
			Sanitary Survey Distribution System Records Attached

13. Are there any dead end lines in the system?
 YES NO

14. Does the system have a flushing program?
 YES NO
 If YES, please describe.

15. Are there any pressure problems within the system?
 YES NO
 If YES, please describe.

16. Does the system disinfect the finished water?
 YES NO
 If yes, which disinfectant product is used? _____

Interviewer Comments on Technical Capacity:

B. Managerial Capacity Assessment Questions

17. Has the system completed a 5-year Infrastructure Capital Improvement Plan (ICIP) plan?
 YES NO

If YES, has the plan been submitted to Local Government Division?
 YES NO

18. Does the system have written operating procedures?
 YES NO

19. Does the system have written job descriptions for all staff?
 YES NO

20. Does the system have:
- A preventative maintenance plan?
YES NO
 - A source water protection plan?
YES NO N/A
 - An emergency plan?
YES NO
 - A cross-connection control program?
YES NO
 - An emergency source?
YES NO
 - System security measures?
YES NO
21. Does the system report and maintain records in accordance with the drinking water regulations concerning:
- Water quality violations
YES NO
 - Public notification
YES NO
 - Sampling exemptions
YES NO
22. Please describe how the above records are maintained:
23. Describe the management structure for the water system, including board and operations staff. Please include examples of duties, if possible.
24. Please describe type and quantity of training or continuing education for staff identified above.
25. Describe last major project undertaken by the water system, including the following: project in detail, positive aspects, negative aspects, the way in which the project was funded, any necessary rate increases, the public response to the project, whether the project is complete or not, and any other pertinent information.

26. Does the system have any debt? YES NO

If yes, is the system current with all debt payments?

YES NO

If no, describe the applicable funding agency and the default.

27. Is the system currently contemplating or actively seeking funding for any project?

YES NO

If yes, from which agency and how much?

Describe the project?

Is the system receiving assistance from any agency or organization in its efforts?

28. Will the system consider any type of regionalization with other PWS? (Check YES if the system has already regionalized.)

YES NO

If YES, what type of regionalization has been implemented/considered/discussed? (Check all that apply.)

System interconnection

Sharing operator

Sharing bookkeeper

Purchasing water

Emergency water connection

Other: _____

29. Does the system have any of the following? (Check all that apply.)

Water Conservation Policy/Ordinance Current Drought Plan

Water Use Restrictions Water Supply Emergency Plan

Interviewer Comments on Managerial Capacity:

C. Financial Capacity Assessment

30. Does the system have a budget?
 YES NO
 If YES, what type of budget?
 Operating Budget
 Capital Budget
31. Have the system revenues covered expenses and debt service for the past 5 years?
 YES NO
 If NO, how many years has the system had a shortfall? _____
32. Does the system have a written/adopted rate structure?
 YES NO
33. What was the date of the last rate increase? _____
34. Are rates reviewed annually?
 YES NO
 IF YES, what was the date of the last review? _____
35. Did the rate review show that the rates covered the following expenses? *(Check all that apply.)*
- | | |
|-------------------------------------|--------------------------|
| Operation & Maintenance | <input type="checkbox"/> |
| Infrastructure Repair & replacement | <input type="checkbox"/> |
| Staffing | <input type="checkbox"/> |
| Emergency/Reserve fund | <input type="checkbox"/> |
| Debt payment | <input type="checkbox"/> |
36. Is the rate collection above 90% of the customers?
 YES NO
37. Is there a cut-off policy for customers who are in arrears with their bill or for illegal connections?
 YES NO
 If yes, is this policy implemented?
38. What is the residential water rate for 6,000 gallons of usage in one month. _____
39. In the past 12 months, how many customers have had accounts frozen or dropped for non-payment? _____
 [Convert to % of active connections
 Less than 1% 1% - 3% 4% - 5% 6% - 10%
 11% - 20% 21% - 50% Greater than 50%]

40. The following questions refer to the process of obtaining needed equipment and supplies.

a. Can the water system operator buy or obtain supplies or equipment when they are needed?

YES NO

b. Is the process simple or burdensome to the employees?

c. Can supplies or equipment be obtained quickly during an emergency?

YES NO

d. Has the water system operator ever experienced a situation in which he/she couldn't purchase the needed supplies?

YES NO

e. Does the system maintain some type of spare parts inventory?

YES NO

If yes, please describe.

41. Has the system ever had a financial audit?

YES NO

If YES, what is the date of the most recent audit? _____

42. Has the system ever had its electricity or phone turned off due to non-payment? Please describe.

Interviewer Comments on Financial Assessment:

43. What do you think the system capabilities are now and what are the issues you feel your system will be facing in the future? In addition, are there any specific needs, such as types of training that you would like to see addressed by NMED or its contractors?

APPENDIX B
COST BASIS

This section presents the basis for unit costs used to develop the conceptual cost estimates for the compliance alternatives. Cost estimates are conceptual in nature (+50%/-30%), and are intended to make comparisons between compliance options and to provide a preliminary indication of possible rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. Capital cost includes an allowance for engineering and construction management. It is assumed that adequate electrical power is available near the site. The cost estimates specifically do not include costs for the following:

- Obtaining land or easements.
- Surveying.
- Mobilization/demobilization for construction.
- Insurance and bonds.

In general, unit costs are based on recent construction bids for similar work in the area; when possible, consultations with vendors or other suppliers; published construction and O&M cost data; and USEPA cost guidance. Unit costs used for the cost estimates are summarized in Table B.1.

Unit costs for pipeline components are based on recent bids on Texas Department of Highways projects. The amounts of boring and encasement and open cut and encasement were estimated by counting the road, highway, railroad, stream, and river crossings for a conceptual routing of the pipeline. The number of air release valves is estimated by examining the land surface profile along the conceptual pipeline route. It is assumed gate valves and flush valves would be installed on average every 5,000 feet along the pipeline. Pipeline cost estimates are based on use of C-900 PVC pipe. Other pipe materials could be considered for more detailed development of attractive alternatives.

Pump station unit costs are based on experience with similar installations. The cost estimate for the pump stations include two pumps, station piping and valves, station electrical and instrumentation, minor site improvement, installation of a concrete pad and building, and tools. Construction cost of a storage tank is based on similar recent installations.

Electrical power cost is estimated to be \$0.136 per kWh, as supplied by Reliant Energy, Houston, Texas. The annual cost for power to a pump station is calculated based on the pumping head and volume, and includes 11,800 kWh for pump building heating, cooling, and lighting, as recommended in USEPA publication, *Standardized Costs for Water Supply Distribution Systems* (1992).

1 In addition to the cost of electricity, pump stations have other maintenance costs.
2 These costs cover: materials for minor repairs to keep the pumps operating; purchase of
3 a maintenance vehicle, fuel costs, and vehicle maintenance costs; utilities; office
4 supplies, small tools and equipment; and miscellaneous materials such as safety, clothing,
5 chemicals, and paint. The non-power O&M costs are estimated based on the USEPA
6 publication, *Standardized Costs for Water Supply Distribution Systems* (1992), which
7 provides cost curves for O&M components. Costs from the 1992 report are adjusted to
8 2005 dollars based on the ENR construction cost index.

9 Pipeline maintenance costs include routine cleaning and flushing, as well as minor
10 repairs to lines. The unit rate for pipeline maintenance is calculated based on the USEPA
11 technical report, *Innovative and Alternate Technology Assessment Manual MCD 53*
12 (1978). Costs from the 1978 report are adjusted to 2005 dollars based on the ENR
13 construction cost index.

14 Storage tank maintenance costs include cleaning and renewal of interior lining and
15 exterior coating. Unit costs for storage tank O&M are based on USEPA publication
16 *Standardized Costs for Water Supply Distribution Systems* (1992). Costs from the 1992
17 report are adjusted to 2005 dollars based on the ENR construction cost index.

18 The purchase price for point-of-use (POU) water treatment units is based on vendor
19 price lists for treatment units, plus installation. O&M costs for POU treatment units are
20 also based on vendor price lists. It is assumed that a yearly water sample would be
21 analyzed for the contaminant of concern.

22 The purchase price for point-of-entry (POE) water treatment units is based on vendor
23 price lists for treatment units, plus an allowance for installation, including a concrete pad
24 and shed, piping modifications, and electrical connection. O&M costs for POE treatment
25 units are also based on vendor price lists. It is assumed that a yearly water sample would
26 be analyzed for the contaminant of concern.

27 Central treatment plant costs, for both adsorption and coagulation/filtration, include
28 pricing for buildings, utilities, and site work. Costs are based on pricing given in the
29 various R.S. Means Construction Cost Data References, as well as prices obtained from
30 similar work on other projects. Pricing for treatment equipment is from a USEPA arsenic
31 removal demonstration project (USEPA 2004).

32 Well installation costs are based on quotations from drillers for installation of similar
33 depth wells in the area. Well installation costs include drilling, a well pump, electrical
34 and instrumentation installation, well finishing, piping, and water quality testing. O&M
35 costs for water wells include power, materials, and labor. It is assumed that new wells
36 located more than 1 mile from the intake point of an existing system would require a
37 storage tank and pump station.

38 Purchase price for the treatment unit dispenser is based on vendor price lists, plus an
39 allowance for installation at a centralized public location. The O&M costs are also based

1 on vendor price lists. It is assumed that weekly water samples would be analyzed for the
2 contaminant of concern.

3 Costs for bottled water delivery alternatives are based on consultation with vendors
4 that deliver residential bottled water. The cost estimate includes an initial allowance for
5 set-up of the program, and a yearly allowance for program administration.

6 The cost estimate for a public dispenser for trucked water includes the purchase price
7 for a water truck and construction of a storage tank. Annual costs include labor for
8 purchasing the water, picking up and delivering the water, truck maintenance, and water
9 sampling and testing. It is assumed the water truck would be required to make one trip
10 each week, and that chlorine residual would be determined for each truck load.

Table B.1
Summary of General Data
Orbit Systems, Inc. - Rosharon Road Estates
PWS #0200346
General PWS Information

Service Population 230
Total PWS Daily Water Usage 0.015 (mgd)

Number of Connections 76
Source 2005 Report

Unit Cost Data
East Texas

General Items	Unit	Unit Cost	Central Treatment Unit Costs	Unit	Unit Cost
Treated water purchase cost	<i>See alternative</i>		Site preparation	acre	\$ 4,000
Water purchase cost (trucked)	\$/1,000 gals	\$ 1.80	Slab	CY	\$ 1,000
			Building	SF	\$ 60
Contingency	20%	n/a	Building electrical	SF	\$ 8
Engineering & Constr. Management	25%	n/a	Building plumbing	SF	\$ 8
Procurement/admin (POU/POE)	20%	n/a	Heating and ventilation	SF	\$ 7
			Fence	LF	\$ 15
			Paving	SF	\$ 2
Pipeline Unit Costs	Unit	Unit Cost	Electrical, Adsorption	JOB	\$ 50,000
PVC water line, Class 200, 04"	LF	\$ 27	Electrical, Coagulation	JOB	\$ 30,000
Bore and encasement, 10"	LF	\$ 60	Piping, Adsorption	JOB	\$ 20,000
Open cut and encasement, 10"	LF	\$ 35	Piping, Coagulation	JOB	\$ 10,000
Gate valve and box, 04"	EA	\$ 370	Adsorption package	UNIT	\$ 115,000
Air valve	EA	\$ 1,000	Coagulation package	UNIT	\$ 89,700
Flush valve	EA	\$ 750	Sewer connection fee	EA	\$ 15,000
Metal detectable tape	LF	\$ 0.15	Chlorination point	EA	\$ 2,000
			Backwash recycle pumpset	EA	\$ 5,000
Bore and encasement, length	Feet	200	Coagulant tank	GAL	\$ 3
Open cut and encasement, length	Feet	50	Backwash tank	GAL	\$ 2.00
			Excavation	CYD	\$ 3.00
Pump Station Unit Costs	Unit	Unit Cost	Compacted fill	CYD	\$ 7.00
Pump	EA	\$ 7,500	Lining	SF	\$ 0.50
Pump Station Piping, 04"	EA	\$ 4,000	Vegetation	SY	\$ 1.00
Gate valve, 04"	EA	\$ 405	Access road	LF	\$ 30
Check valve, 04"	EA	\$ 595			
Electrical/Instrumentation	EA	\$ 10,000	Building Power	kwh/yr	\$ 0.136
Site work	EA	\$ 2,000	Equipment power	kwh/yr	\$ 0.136
Building pad	EA	\$ 4,000	Labor	hr	\$ 40
Pump Building	EA	\$ 10,000	Adsorption Materials	year	\$ 18,167
Fence	EA	\$ 5,870	Coagulation/Filtration Materials	year	\$ 2,000
Tools	EA	\$ 1,000	Backwash discharge to sewer	MG/year	\$ 2,000
			Chemicals, Coagulation	year	\$ 2,000
Well Installation Unit Costs	Unit	Unit Cost	Analyses	test	\$ 200
Well installation	<i>See alternative</i>		Spent media disposal	CY	\$ 20
Water quality testing	EA	\$ 1,500	Truck rental	day	\$ 700
Well pump	EA	\$ 7,500	Mileage	mile	\$ 1.00
Well electrical/instrumentation	EA	\$ 5,000	Disposal fee	kgal	\$ 5.00
Well cover and base	EA	\$ 3,000			
Piping	EA	\$ 2,500			
Storage Tank - 5,000 gals	EA	\$ 7,025			
Electrical Power	\$/kWH	\$ 0.136			
Building Power	KWH	11,800			
Labor	\$/hr	\$ 46			
Materials	EA	\$ 1,200			
Transmission main O&M	\$/mile	\$ 200			
Tank O&M	EA	\$ 1,000			
POU/POE Unit Costs					
POU treatment unit purchase	EA	\$ 250			
POU treatment unit installation	EA	\$ 150			
POE treatment unit purchase	EA	\$ 3,000			
POE - pad and shed, per unit	EA	\$ 2,000			
POE - piping connection, per unit	EA	\$ 1,000			
POE - electrical hook-up, per unit	EA	\$ 1,000			
POU treatment O&M, per unit	\$/year	\$ 225			
POE treatment O&M, per unit	\$/year	\$ 1,000			
Contaminant analysis	\$/year	\$ 100			
POU/POE labor support	\$/hr	\$ 46			
Dispenser/Bottled Water Unit Costs					
Treatment unit purchase	EA	\$ 3,000			
Treatment unit installation	EA	\$ 5,000			
Treatment unit O&M	EA	\$ 500			
Administrative labor	hr	\$ 61			
Bottled water cost (inc. delivery)	gallon	\$ 1.60			
Water use, per capita per day	gpcd	1.0			
Bottled water program materials	EA	\$ 5,000			
Storage Tank - 5,000 gals	EA	\$ 7,025			
Site improvements	EA	\$ 4,000			
Potable water truck	EA	\$ 60,000			
Water analysis, per sample	EA	\$ 100			
Potable water truck O&M costs	\$/mile	\$ 1.00			

1
2

**APPENDIX C
COMPLIANCE ALTERNATIVE CONCEPTUAL COST ESTIMATES**

3 This appendix presents the conceptual cost estimates developed for the compliance
4 alternatives. The conceptual cost estimates are given in Tables C.1 through C.18. The
5 cost estimates are conceptual in nature (+50%/-30%), and are intended for making
6 comparisons between compliance options and to provide a preliminary indication of
7 possible water rate impacts. Consequently, these costs are pre-planning level and should
8 not be viewed as final estimated costs for alternative implementation.

Table C.1

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *Purchase Water from JMP Util.*
Alternative Number *RR-1*

Distance from Alternative to PWS (along pipe) 5.8 miles
Total PWS annual water usage 5.475 MG
Treated water purchase cost \$ 1.60 per 1,000 gals
Number of Pump Stations Needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	9	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	30,866	LF	\$ 27.00	\$ 833,382
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	150	LF	\$ 35.00	\$ 5,250
Gate valve and box, 04"	6	EA	\$ 370.00	\$ 2,284
Air valve	6	EA	\$ 1,000.00	\$ 6,000
Flush valve	6	EA	\$ 750.00	\$ 4,630
Metal detectable tape	30,866	LF	\$ 0.15	\$ 4,630
Subtotal				\$ 964,176

Pump Station(s) Installation

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205

Subtotal of Component Costs \$ 1,018,381

Contingency 20% \$ 203,676
 Design & Constr Management 25% \$ 254,595

TOTAL CAPITAL COSTS \$ 1,476,652

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	5.8	mile	\$ 200	\$ 1,169
Subtotal				\$ 1,169
<i>Water Purchase Cost</i>				
From BWA	5,475	1,000 gal	\$ 1.60	\$ 8,760
Subtotal				\$ 8,760

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	29,850	kWH	\$ 0.136	\$ 4,060
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 46	\$ 16,608
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 24,472

O&M Credit for Existing Well Closure

Pump power	595	kWH	\$ 0.136	\$ (81)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 46	\$ (16,380)
Subtotal				\$ (18,861)

TOTAL ANNUAL O&M COSTS \$ 15,540

Table C.2

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *New Well at TCDJ Darrington*
Alternative Number *RR-2*

Distance from PWS to new well location 9.37 miles
Estimated well depth 600 feet
Number of wells required 1
Well installation cost (location specific) \$25 per foot
Number of pump stations needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	10	n/a	n/a	n/a
Number of Crossings, open cut	4	n/a	n/a	n/a
PVC water line, Class 200, 04"	49,457	LF	\$ 27.00	\$ 1,335,339
Bore and encasement, 10"	2,000	LF	\$ 60.00	\$ 120,000
Open cut and encasement, 10"	200	LF	\$ 35.00	\$ 7,000
Gate valve and box, 04"	10	EA	\$ 370.00	\$ 3,660
Air valve	9	EA	\$ 1,000.00	\$ 9,000
Flush valve	10	EA	\$ 750.00	\$ 7,419
Metal detectable tape	49,457	LF	\$ 0.15	\$ 7,419
Subtotal				\$ 1,489,836

Pump Station(s) Installation

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205

Well Installation

Well installation	600	LF	\$ 25	\$ 15,000
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
Subtotal				\$ 36,000

Subtotal of Component Costs \$ 1,580,041

Contingency 20% \$ 316,008
 Design & Constr Management 25% \$ 395,010

TOTAL CAPITAL COSTS \$ 2,291,059

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	9.4	mile	\$ 200	\$ 1,873
Subtotal				\$ 1,873

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	47,500	kWH	\$ 0.136	\$ 6,460
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 46	\$ 16,608
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 26,872

Well O&M

Pump power	1,152	kWH	\$ 0.136	\$ 157
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 46	\$ 8,190
Subtotal				\$ 9,547

O&M Credit for Existing Well Closure

Pump power	595	kWH	\$ 0.136	\$ (81)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 46	\$ (16,380)
Subtotal				\$ (18,861)

TOTAL ANNUAL O&M COSTS \$ 19,431

Table C.3

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *Purchase Water from City of Alvin*
Alternative Number *RR-3*

Distance from Alternative to PWS (along pipe) 10.2 miles
Total PWS annual water usage 5,475 MG
Treated water purchase cost \$ 1.65 per 1,000 gals
Number of Pump Stations Needed 2

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	28	n/a	n/a	n/a
Number of Crossings, open cut	4	n/a	n/a	n/a
PVC water line, Class 200, 04"	53,720	LF	\$ 27.00	\$ 1,450,440
Bore and encasement, 10"	5,600	LF	\$ 60.00	\$ 336,000
Open cut and encasement, 10"	200	LF	\$ 35.00	\$ 7,000
Gate valve and box, 04"	11	EA	\$ 370.00	\$ 3,975
Air valve	10	EA	\$ 1,000.00	\$ 10,000
Flush valve	11	EA	\$ 750.00	\$ 8,058
Metal detectable tape	53,720	LF	\$ 0.15	\$ 8,058
Subtotal				\$ 1,823,531

Pump Station(s) Installation

Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	8	EA	\$ 405	\$ 3,240
Check valve, 04"	4	EA	\$ 595	\$ 2,380
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 5,000 gals	2	EA	\$ 7,025	\$ 14,050
Subtotal				\$ 108,410

Subtotal of Component Costs \$ 1,931,941

Contingency 20% \$ 386,388
 Design & Constr Management 25% \$ 482,985

TOTAL CAPITAL COSTS **\$ 2,801,315**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	10.2	mile	\$ 200	\$ 2,035
Subtotal				\$ 2,035
<i>Water Purchase Cost</i>				
From BWA	5,475	1,000 gal	\$ 1.65	\$ 9,034
Subtotal				\$ 9,034

Pump Station(s) O&M

Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	49,450	kWH	\$ 0.136	\$ 6,725
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 46	\$ 33,215
Tank O&M	2	EA	\$ 1,000	\$ 2,000
Subtotal				\$ 47,550

O&M Credit for Existing Well Closure

Pump power	595	kWH	\$ 0.136	\$ (81)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 46	\$ (16,380)
Subtotal				\$ (18,861)

TOTAL ANNUAL O&M COSTS **\$ 39,757**

Table C.4

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *Purchase Water from City of Hillcrest Village*
Alternative Number *RR-4*

Distance from Alternative to PWS (along pipe) 10.6 miles
Total PWS annual water usage 5.475 MG
Treated water purchase cost \$ 1.60 per 1,000 gals
Number of Pump Stations Needed 2

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	22	n/a	n/a	n/a
Number of Crossings, open cut	9	n/a	n/a	n/a
PVC water line, Class 200, 04"	55,735	LF	\$ 27.00	\$ 1,504,845
Bore and encasement, 10"	4,400	LF	\$ 60.00	\$ 264,000
Open cut and encasement, 10"	450	LF	\$ 35.00	\$ 15,750
Gate valve and box, 04"	11	EA	\$ 370.00	\$ 4,124
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	11	EA	\$ 750.00	\$ 8,360
Metal detectable tape	55,735	LF	\$ 0.15	\$ 8,360
Subtotal				\$ 1,816,440

Pump Station(s) Installation

Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	8	EA	\$ 405	\$ 3,240
Check valve, 04"	4	EA	\$ 595	\$ 2,380
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 5,000 gals	2	EA	\$ 7,025	\$ 14,050
Subtotal				\$ 108,410

Subtotal of Component Costs \$ 1,924,850

Contingency 20% \$ 384,970
 Design & Constr Management 25% \$ 481,212

TOTAL CAPITAL COSTS **\$ 2,791,032**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	10.6	mile	\$ 200	\$ 2,111
Subtotal				\$ 2,111
<i>Water Purchase Cost</i>				
From BWA	5,475	1,000 gal	\$ 1.60	\$ 8,760
Subtotal				\$ 8,760

Pump Station(s) O&M

Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	50,700	kWH	\$ 0.136	\$ 6,895
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 46	\$ 33,215
Tank O&M	2	EA	\$ 1,000	\$ 2,000
Subtotal				\$ 47,720

O&M Credit for Existing Well Closure

Pump power	595	kWH	\$ 0.136	\$ (81)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 46	\$ (16,380)
Subtotal				\$ (18,861)

TOTAL ANNUAL O&M COSTS **\$ 39,730**

Table C.5

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *Purchase Water from BWA*
Alternative Number *RR-5*

Distance from Alternative to PWS (along pipe) 14.6 miles
Total PWS annual water usage 5.475 MG
Treated water purchase cost \$ 1.60 per 1,000 gals
Number of Pump Stations Needed 2

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	29	n/a	n/a	n/a
Number of Crossings, open cut	9	n/a	n/a	n/a
PVC water line, Class 200, 04"	77,073	LF	\$ 27.00	\$ 2,080,971
Bore and encasement, 10"	5,800	LF	\$ 60.00	\$ 348,000
Open cut and encasement, 10"	450	LF	\$ 35.00	\$ 15,750
Gate valve and box, 04"	15	EA	\$ 370.00	\$ 5,703
Air valve	15	EA	\$ 1,000.00	\$ 15,000
Flush valve	15	EA	\$ 750.00	\$ 11,561
Metal detectable tape	77,073	LF	\$ 0.15	\$ 11,561
Subtotal				\$ 2,488,546

Pump Station(s) Installation

Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	8	EA	\$ 405	\$ 3,240
Check valve, 04"	4	EA	\$ 595	\$ 2,380
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 5,000 gals	2	EA	\$ 7,025	\$ 14,050
Subtotal				\$ 108,410

Subtotal of Component Costs **\$ 2,596,956**

Contingency 20% \$ 519,391
 Design & Constr Management 25% \$ 649,239

TOTAL CAPITAL COSTS **\$ 3,765,587**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	14.6	mile	\$ 200	\$ 2,919
Subtotal				\$ 2,919
<i>Water Purchase Cost</i>				
From BWA	5,475	1,000 gal	\$ 1.60	\$ 8,760
Subtotal				\$ 8,760

Pump Station(s) O&M

Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	67,650	kWH	\$ 0.136	\$ 9,200
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 46	\$ 33,215
Tank O&M	2	EA	\$ 1,000	\$ 2,000
Subtotal				\$ 50,025

O&M Credit for Existing Well Closure

Pump power	595	kWH	\$ 0.136	\$ (81)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 46	\$ (16,380)
Subtotal				\$ (18,861)

TOTAL ANNUAL O&M COSTS **\$ 42,844**

Table C.6

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *New Well at Briar Meadows*
Alternative Number *RR-6*

Distance from PWS to new well location 1.85 miles
Estimated well depth 215 feet
Number of wells required 1
Well installation cost (location specific) \$25 per foot
Number of pump stations needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	5	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	9,767	LF	\$ 27.00	\$ 263,709
Bore and encasement, 10"	1,000	LF	\$ 60.00	\$ 60,000
Open cut and encasement, 10"	50	LF	\$ 35.00	\$ 1,750
Gate valve and box, 04"	2	EA	\$ 370.00	\$ 723
Air valve	2	EA	\$ 1,000.00	\$ 2,000
Flush valve	2	EA	\$ 750.00	\$ 1,465
Metal detectable tape	9,767	LF	\$ 0.15	\$ 1,465
Subtotal				\$ 331,112

Pump Station(s) Installation

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205

Well Installation

Well installation	215	LF	\$ 25	\$ 5,375
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
Subtotal				\$ 26,375

Subtotal of Component Costs **\$ 411,692**

Contingency 20% \$ 82,338
 Design & Constr Management 25% \$ 102,923

TOTAL CAPITAL COSTS **\$ 596,953**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	1.8	mile	\$ 200	\$ 370
Subtotal				\$ 370

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	12,350	kWH	\$ 0.136	\$ 1,680
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 46	\$ 16,608
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 22,092

Well O&M

Pump power	413	kWH	\$ 0.136	\$ 56
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 46	\$ 8,190
Subtotal				\$ 9,446

O&M Credit for Existing Well Closure

Pump power	595	kWH	\$ 0.136	\$ (81)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 46	\$ (16,380)
Subtotal				\$ (18,861)

TOTAL ANNUAL O&M COSTS **\$ 13,047**

Table C.7

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *New Well at Oak Bend*
Alternative Number *RR-7*

Distance from PWS to new well location 7.10 miles
Estimated well depth 150 feet
Number of wells required 1
Well installation cost (location specific) \$25 per foot
Number of pump stations needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	10	n/a	n/a	n/a
Number of Crossings, open cut	6	n/a	n/a	n/a
PVC water line, Class 200, 04"	37,501	LF	\$ 27.00	\$ 1,012,527
Bore and encasement, 10"	2,000	LF	\$ 60.00	\$ 120,000
Open cut and encasement, 10"	300	LF	\$ 35.00	\$ 10,500
Gate valve and box, 04"	8	EA	\$ 370.00	\$ 2,775
Air valve	7	EA	\$ 1,000.00	\$ 7,000
Flush valve	8	EA	\$ 750.00	\$ 5,625
Metal detectable tape	37,501	LF	\$ 0.15	\$ 5,625
Subtotal				\$ 1,164,052

Pump Station(s) Installation

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205

Well Installation

Well installation	150	LF	\$ 25	\$ 3,750
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
Subtotal				\$ 24,750

Subtotal of Component Costs **\$ 1,243,007**

Contingency 20% \$ 248,601
 Design & Constr Management 25% \$ 310,752

TOTAL CAPITAL COSTS **\$ 1,802,361**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	7.1	mile	\$ 200	\$ 1,420
Subtotal				\$ 1,420

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	34,450	kWH	\$ 0.136	\$ 4,685
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 46	\$ 16,608
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 25,098

Well O&M

Pump power	288	kWH	\$ 0.136	\$ 39
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 46	\$ 8,190
Subtotal				\$ 9,429

O&M Credit for Existing Well Closure

Pump power	595	kWH	\$ 0.136	\$ (81)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 46	\$ (16,380)
Subtotal				\$ (18,861)

TOTAL ANNUAL O&M COSTS **\$ 17,086**

Table C.8

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *New Well at Best Sea Pack, Inc.*
Alternative Number *RR-8*

Distance from PWS to new well location 12.25 miles
Estimated well depth 310 feet
Number of wells required 1
Well installation cost (location specific) \$25 per foot
Number of pump stations needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	14	n/a	n/a	n/a
Number of Crossings, open cut	5	n/a	n/a	n/a
PVC water line, Class 200, 04"	64,698	LF	\$ 27.00	\$ 1,746,846
Bore and encasement, 10"	2,800	LF	\$ 60.00	\$ 168,000
Open cut and encasement, 10"	250	LF	\$ 35.00	\$ 8,750
Gate valve and box, 04"	13	EA	\$ 370.00	\$ 4,788
Air valve	12	EA	\$ 1,000.00	\$ 12,000
Flush valve	13	EA	\$ 750.00	\$ 9,705
Metal detectable tape	64,698	LF	\$ 0.15	\$ 9,705
Subtotal				\$ 1,959,793

Pump Station(s) Installation

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205

Well Installation

Well installation	310	LF	\$ 25	\$ 7,750
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
Subtotal				\$ 28,750

Subtotal of Component Costs \$ 2,042,748

Contingency 20% \$ 408,550
 Design & Constr Management 25% \$ 510,687

TOTAL CAPITAL COSTS \$ 2,961,985

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	12.3	mile	\$ 200	\$ 2,451
Subtotal				\$ 2,451

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	52,350	kWH	\$ 0.136	\$ 7,120
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 46	\$ 16,608
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 27,532

Well O&M

Pump power	595	kWH	\$ 0.136	\$ 81
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 46	\$ 8,190
Subtotal				\$ 9,471

O&M Credit for Existing Well Closure

Pump power	595	kWH	\$ 0.136	\$ (81)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 46	\$ (16,380)
Subtotal				\$ (18,861)

TOTAL ANNUAL O&M COSTS \$ 20,593

Table C.9

PWS Name
Alternative Name
Alternative Number

Orbit Systems, Inc. - Rosharon Road Estates
Central Treatment - Adsorption
RR-9

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
Adsorption				
Site preparation	0.50	acre	\$ 4,000	\$ 2,000
Slab	15	CY	\$ 1,000	\$ 15,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8	\$ 3,200
Building plumbing	400	SF	\$ 8	\$ 3,200
Heating and ventilation	400	SF	\$ 7	\$ 2,800
Fence	300	LF	\$ 15	\$ 4,500
Paving	1,600	SF	\$ 2	\$ 3,200
Electrical	1	JOB	\$ 50,000	\$ 50,000
Piping	1	JOB	\$ 20,000	\$ 20,000
Adsorption package including:				
4 Adsorption vessels				
E33 Iron oxide media				
Controls & instruments	1	UNIT	\$ 115,000	\$ 115,000
Backwash Tank	5,000	GAL	\$ 2.00	\$ 10,000
Sewer Connection Fee	1	EA	\$ 15,000	\$ 15,000
Chlorination Point	1	EA	\$ 2,000	\$ 2,000
	Subtotal			\$ 269,900
Contingency	20%			53,980
Design & CM	25%			67,475
	Total			\$ 391,355

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
O&M				
Building Power	6,000	kwh/yr	\$ 0.136	\$ 816
Equipment power	1000	kwh/yr	\$ 0.136	\$ 136
Labor	500	hrs/yr	\$ 40	\$ 20,000
Materials	1	year	\$ 18,167	\$ 18,167
Analyses	24	test	\$ 200	\$ 4,800
Backwash discharge to sewer	0.5	Mg/yr	\$ 2,000	\$ 1,000
Spent Media Disposal	6	CY	\$ 20	\$ 120
	Total			\$ 45,039
				Total
				\$ 45,039

Table C.10

PWS Name
Alternative Name
Alternative Number

Orbit Systems, Inc. - Rosharon Road Estates
Central Treatment - Coag-Filt
RR-10

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
Central-Coagulation/Filtration				
Site preparation	0.50	acre	\$ 4,000	\$ 2,000
Slab	15	CY	\$ 1,000	\$ 15,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8	\$ 3,200
Building plumbing	400	SF	\$ 8	\$ 3,200
Heating and ventilation	400	SF	\$ 7	\$ 2,800
Fence	300	LF	\$ 15	\$ 4,500
Paving	1,600	SF	\$ 2	\$ 3,200
Electrical	1	JOB	\$ 30,000	\$ 30,000
Piping	1	JOB	\$ 10,000	\$ 10,000
Coagulant/Filter package including:				
Chemical feed system				
Pressure ceramic filters				
Controls & Instruments	1	UNIT	\$ 89,700	\$ 89,700
Backwash Tank	5,000	GAL	\$ 2.00	\$ 10,000
Sewer Connection Fee	1	EA	\$ 15,000	\$ 15,000
Chlorination Point	1	EA	\$ 2,000	\$ 2,000
Coagulant Tank	500	GAL	\$ 3	\$ 1,500
Subtotal				\$ 216,100
Contingency	20%			43,220
Design & CM	25%			54,025
Total				\$ 313,345

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
O&M				
Building Power	6,000	kwh/yr	\$ 0.136	\$ 816
Equipment power	1000	kwh/yr	\$ 0.136	\$ 136
Labor	1,000	hrs/yr	\$ 40	\$ 40,000
Materials	1	year	\$ 2,000	\$ 2,000
Chemicals	1	year	\$ 2,000	\$ 2,000
Analyses	24	test	\$ 200	\$ 4,800
Backwash discharge to sewer	5	Mg/yr	\$ 2,000	\$ 10,000
Total				\$ 59,752
Total				\$ 59,752

Table C.11

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *Point-of-Use Treatment*
Alternative Number *RR-11*

Number of Connections for POU Unit Installation 76

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>POU-Treatment - Purchase/Installation</i>				
POU treatment unit purchase	76	EA	\$ 250	\$ 19,000
POU treatment unit installation	76	EA	\$ 150	\$ 11,400
Subtotal				\$ 30,400
Subtotal of Component Costs				\$ 30,400
Contingency	20%		\$	6,080
Design & Constr Management	25%		\$	7,600
Procurement & Administration	20%		\$	6,080
TOTAL CAPITAL COSTS				\$ 50,160

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>O&M</i>				
POU materials, per unit	76	EA	\$ 225	\$ 17,100
Contaminant analysis, 1/yr per unit	76	EA	\$ 100	\$ 7,600
Program labor, 10 hrs/unit	760	hrs	\$ 46	\$ 34,580
Subtotal				\$ 59,280
TOTAL ANNUAL O&M COSTS				\$ 59,280

Table C.12

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *Point-of-Entry Treatment*
Alternative Number *RR-12*

Number of Connections for POE Unit Installation 76

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>POE-Treatment - Purchase/Installation</i>				
POE treatment unit purchase	76	EA	\$ 3,000	\$ 228,000
Pad and shed, per unit	76	EA	\$ 2,000	\$ 152,000
Piping connection, per unit	76	EA	\$ 1,000	\$ 76,000
Electrical hook-up, per unit	76	EA	\$ 1,000	\$ 76,000
Subtotal				\$ 532,000

Subtotal of Component Costs **\$ 532,000**

Contingency	20%	\$ 106,400
Design & Constr Management	25%	\$ 133,000
Procurement & Administration	20%	\$ 106,400

TOTAL CAPITAL COSTS **\$ 877,800**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>O&M</i>				
POE materials, per unit	76	EA	\$ 1,000	\$ 76,000
Contaminant analysis, 1/yr per unit	76	EA	\$ 100	\$ 7,600
Program labor, 10 hrs/unit	760	hrs	\$ 46	\$ 34,580
Subtotal				\$ 118,180

TOTAL ANNUAL O&M COSTS **\$ 118,180**

Table C.13

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *New Well at 10 Miles*
Alternative Number *RR-13*

Distance from PWS to new well location 10.0 miles
 Estimated well depth 310 feet
 Number of wells required 1
 Well installation cost (location specific) \$25 per foot
 Number of pump stations needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	18	n/a	n/a	n/a
Number of Crossings, open cut	6	n/a	n/a	n/a
PVC water line, Class 200, 04"	52,800	LF	\$ 27.00	\$ 1,425,600
Bore and encasement, 10"	3,600	LF	\$ 60.00	\$ 216,000
Open cut and encasement, 10"	300	LF	\$ 35.00	\$ 10,500
Gate valve and box, 04"	11	EA	\$ 370.00	\$ 3,907
Air valve	10	EA	\$ 1,000.00	\$ 10,000
Flush valve	11	EA	\$ 750.00	\$ 7,920
Metal detectable tape	52,800	LF	\$ 0.15	\$ 7,920
Subtotal				\$ 1,681,847

Pump Station(s) Installation

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205

Well Installation

Well installation	310	LF	\$ 25	\$ 7,750
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
Subtotal				\$ 28,750

Subtotal of Component Costs \$ 1,764,802

Contingency 20% \$ 352,960
 Design & Constr Management 25% \$ 441,201

TOTAL CAPITAL COSTS \$ 2,558,963

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	10.0	mile	\$ 200	\$ 2,000
Subtotal				\$ 2,000

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	47,989	kWH	\$ 0.136	\$ 6,527
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 46	\$ 16,608
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 26,939

Well O&M

Pump power	595	kWH	\$ 0.136	\$ 81
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 46	\$ 8,190
Subtotal				\$ 9,471

O&M Credit for Existing Well Closure

Pump power	595	kWH	\$ 0.136	\$ (81)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 46	\$ (16,380)
Subtotal				\$ (18,861)

TOTAL ANNUAL O&M COSTS \$ 19,549

Table C.14

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *New Well at 5 Miles*
Alternative Number *RR-14*

Distance from PWS to new well location 5.0 miles
Estimated well depth 310 feet
Number of wells required 1
Well installation cost (location specific) \$25 per foot
Number of pump stations needed 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	9	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	26,400	LF	\$ 27.00	\$ 712,800
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	100	LF	\$ 35.00	\$ 3,500
Gate valve and box, 04"	5	EA	\$ 370.00	\$ 1,954
Air valve	5	EA	\$ 1,000.00	\$ 5,000
Flush valve	5	EA	\$ 750.00	\$ 3,960
Metal detectable tape	26,400	LF	\$ 0.15	\$ 3,960
Subtotal				\$ 839,174

Pump Station(s) Installation

Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205

Well Installation

Well installation	310	LF	\$ 25	\$ 7,750
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
Subtotal				\$ 28,750

Subtotal of Component Costs **\$ 922,129**

Contingency 20% \$ 184,426
 Design & Constr Management 25% \$ 230,532

TOTAL CAPITAL COSTS **\$ 1,337,086**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	5.0	mile	\$ 200	\$ 1,000
Subtotal				\$ 1,000

Pump Station(s) O&M

Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	23,994	kWH	\$ 0.136	\$ 3,263
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 46	\$ 16,608
Tank O&M	1	EA	\$ 1,000	\$ 1,000
Subtotal				\$ 23,676

Well O&M

Pump power	595	kWH	\$ 0.136	\$ 81
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 46	\$ 8,190
Subtotal				\$ 9,471

O&M Credit for Existing Well Closure

Pump power	595	kWH	\$ 0.136	\$ (81)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 46	\$ (16,380)
Subtotal				\$ (18,861)

TOTAL ANNUAL O&M COSTS **\$ 15,286**

Table C.15

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *New Well at 1 Mile*
Alternative Number *RR-15*

Distance from PWS to new well location 1.0 miles
 Estimated well depth 310 feet
 Number of wells required 1
 Well installation cost (location specific) \$25 per foot
 Number of pump stations needed 0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	5,280	LF	\$ 27.00	\$ 142,560
Bore and encasement, 10"	400	LF	\$ 60.00	\$ 24,000
Open cut and encasement, 10"	50	LF	\$ 35.00	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370.00	\$ 391
Air valve	1.00	EA	\$ 1,000.00	\$ 1,000
Flush valve	1	EA	\$ 750.00	\$ 792
Metal detectable tape	5,280	LF	\$ 0.15	\$ 792
Subtotal				\$ 171,285

Pump Station(s) Installation

Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
Subtotal				\$ -

Well Installation

Well installation	310	LF	\$ 25	\$ 7,750
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
Subtotal				\$ 28,750

Subtotal of Component Costs \$ 200,035

Contingency 20% \$ 40,007
 Design & Constr Management 25% \$ 50,009

TOTAL CAPITAL COSTS \$ 290,050

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&M</i>				
Pipeline O&M	1.0	mile	\$ 200	\$ 200
Subtotal				\$ 200

Pump Station(s) O&M

Building Power	-	kWH	\$ 0.136	\$ -
Pump Power	-	kWH	\$ 0.136	\$ -
Materials	-	EA	\$ 1,200	\$ -
Labor	-	Hrs	\$ 46	\$ -
Tank O&M	-	EA	\$ 1,000	\$ -
Subtotal				\$ -

Well O&M

Pump power	595	kWH	\$ 0.136	\$ 81
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 46	\$ 8,190
Subtotal				\$ 9,471

O&M Credit for Existing Well Closure

Pump power	595	kWH	\$ 0.136	\$ (81)
Well O&M matl	2	EA	\$ 1,200	\$ (2,400)
Well O&M labor	360	Hrs	\$ 46	\$ (16,380)
Subtotal				\$ (18,861)

TOTAL ANNUAL O&M COSTS \$ (9,190)

Table C.16

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *Public Dispenser for Treated Drinking Water*
Alternative Number *RR-16*

Number of Treatment Units Recommended 1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Public Dispenser Unit Installation</i>				
POE-Treatment unit(s)	1	EA	\$ 3,000	\$ 3,000
Unit installation costs	1	EA	\$ 5,000	\$ 5,000
Subtotal				\$ 8,000
Subtotal of Component Costs				\$ 8,000
Contingency	20%			\$ 1,600
Design & Constr Management	25%			\$ 2,000
TOTAL CAPITAL COSTS				11,600

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Treatment unit O&M, 1 per unit	1	EA	\$ 500	\$ 500
Contaminant analysis, 1/wk per unit	52	EA	\$ 100	\$ 5,200
Sampling/reporting, 1 hr/day	365	HRS	\$ 46	\$ 16,608
Subtotal				\$ 22,308
TOTAL ANNUAL O&M COSTS				\$ 22,308

Table C.17

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *Supply Bottled Water to Population*
Alternative Number *RR-17*

Service Population 230
Percentage of population requiring supply 100%
Water consumption per person 1.00 gpcd
Calculated annual potable water needs 83,950 gallons

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Implementation</i>				
Initial program set-up	500	hours	\$ 61	\$ 30,258
Subtotal				\$ 30,258
Subtotal of Component Costs				\$ 30,258
Contingency	20%			\$ 6,052
TOTAL CAPITAL COSTS				\$ 36,309

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water purchase costs	83,950	gals	\$ 1.60	\$ 134,320
Program admin, 9 hrs/wk	468	hours	\$ 61	\$ 28,321
Program materials	1	EA	\$ 5,000	\$ 5,000
Subtotal				\$ 167,641
TOTAL ANNUAL O&M COSTS				\$ 167,641

Table C.18

PWS Name *Orbit Systems, Inc. - Rosharon Road Estates*
Alternative Name *Central Trucked Drinking Water*
Alternative Number *RR-18*

Service Population 230
Percentage of population requiring supply 100%
Water consumption per person 1.00 gpcd
Calculated annual potable water needs 83,950 gallons
Travel distance to compliant water source (roundtrip) 12 miles

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Storage Tank Installation</i>				
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Site improvements	1	EA	\$ 4,000	\$ 4,000
Potable water truck	1	EA	\$ 60,000	\$ 60,000
Subtotal				\$ 71,025

Subtotal of Component Costs \$ 71,025

Contingency 20% \$ 14,205
 Design & Constr Management 25% \$ 17,756

TOTAL CAPITAL COSTS **\$ 102,986**

Annual Operations and Maintenance Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water delivery labor, 4 hrs/wk	208	hrs	\$ 46	\$ 9,464
Truck operation, 1 round trip/wk	624	miles	\$ 1.00	\$ 624
Water purchase	84	1,000 g	\$ 1.80	\$ 151
Water testing, 1 test/wk	52	EA	\$ 100	\$ 5,200
Sampling/reporting, 2 hrs/wk	104	hrs	\$ 46	\$ 4,732
Subtotal				\$ 20,171

TOTAL ANNUAL O&M COSTS **\$ 20,171**

1
2

**APPENDIX D
EXAMPLE FINANCIAL MODEL**

Table D.1 Example Financial Model

Step 1
Water System: Rosharon Road Subdivision

Step 2
[Click Here to Update Verification and Raw](#)

Water System	Rosharon Road Subdivision
Alternative Description	Central Treatment - Adsorption

Sum of Amount		Year		Funding Alternative	
		2007			
Group	Type	100% Grant	Bond		
Capital Expenditures	Capital Expenditures-Funded from Bonds	\$ 500	\$ 391,855		
	Capital Expenditures-Funded from Grants	\$ 391,355	\$ -		
	Capital Expenditures-Funded from Revenue/Reserves	\$ -	\$ -		
	Capital Expenditures-Funded from SRF Loans	\$ -	\$ -		
Capital Expenditures Sum		\$ 391,855	\$ 391,855		
Debt Service	Revenue Bonds	\$ 39	\$ 30,654		
	State Revolving Funds	\$ -	\$ -		
Debt Service Sum		\$ 39	\$ 30,654		
Operating Expenditures	Administrative Expenses	\$ 2,941	\$ 2,941		
	Chemicals, Treatment	\$ 871	\$ 871		
	Contract Labor	\$ 1,025	\$ 1,025		
	Insurance	\$ 597	\$ 597		
	Other Operating Expenditures 1	\$ 687	\$ 687		
	Other Operating Expenditures 2	\$ 8,364	\$ 8,364		
	Professional and Directors Fees	\$ 129	\$ 129		
	Repairs	\$ 698	\$ 698		
	Salaries & Benefits	\$ 8,428	\$ 8,428		
	Supplies	\$ 698	\$ 698		
	Utilities	\$ 3,529	\$ 3,529		
	Maintenance	\$ 698	\$ 698		
	Accounting and Legal Fees	\$ 50	\$ 50		
	Auto and Travel	\$ 11	\$ 11		
Operating Expenditures Sum		\$ 28,725	\$ 28,725		
Residential Operating Reven	Residential Base Monthly Rate	\$ 18,769	\$ 18,769		
	Residential Tier 1 Monthly Rate	\$ 9,001	\$ 9,001		
	Residential Tier2 Monthly Rate	\$ -	\$ -		
	Residential Tier3 Monthly Rate	\$ -	\$ -		
	Residential Tier4 Monthly Rate	\$ -	\$ -		
	Residential Unmetered Monthly Rate	\$ -	\$ -		
Residential Operating Revenues Sum		\$ 27,770	\$ 27,770		

Location_Name	Rosharon Road Subdivision
Alt_Desc	Central Treatment - Adsorption


Funding_Alt	Data	Current_Year	
		2007	
100% Grant	Sum of Beginning_Cash_Bal	\$ (2,455)	
	Sum of Total_Expenditures	\$ 420,619	
	Sum of Total_Receipts	\$ 419,125	
	Sum of Net_Cash_Flow	\$ (1,494)	
	Sum of Ending_Cash_Bal	\$ (3,949)	
	Sum of Working_Cap	\$ -	
	Sum of Repl_Resv	\$ 2,070	
	Sum of Total_Reqd_Resv	\$ 2,070	
	Sum of Net_Avail_Bal	\$ (6,019)	
	Sum of Add_Resv_Needed	\$ (6,019)	
	Sum of Rate_Inc_Needed	22%	
	Sum of Percent_Rate_Increase	0%	
	Bond	Sum of Beginning_Cash_Bal	\$ (2,455)
		Sum of Total_Expenditures	\$ 451,234
Sum of Total_Receipts		\$ 419,125	
Sum of Net_Cash_Flow		\$ (32,109)	
Sum of Ending_Cash_Bal		\$ (34,564)	
Sum of Working_Cap		\$ -	
Sum of Repl_Resv		\$ 2,070	
Sum of Total_Reqd_Resv		\$ 2,070	
Sum of Net_Avail_Bal		\$ (36,633)	
Sum of Add_Resv_Needed		\$ (36,633)	
Sum of Rate_Inc_Needed		132%	
Sum of Percent_Rate_Increase		0%	

1 **APPENDIX E**
2 **GENERAL ARSENIC GEOCHEMISTRY**

3 Geochemistry of arsenic is complex because of (1) the possible coexistence of two or
4 even three redox states, (2) the complex chemistry of organo-arsenicals, and (3) the
5 strong interaction of most arsenic compounds with soil particles, particularly iron oxides
6 (and to a lesser degree, aluminum and manganese oxides). Fully deprotonated arsenate
7 AsO_4^{-3} is the expected form of arsenic in most soil under aerobic conditions only at high
8 pH (Figure E.1). At more neutral and acid pH's, HAsO_4^{-2} and $\text{H}_2\text{AsO}_4^{-1}$ forms,
9 respectively, are dominant. General understanding of arsenic mobility in soil and
10 aquifers is that it increases with increasing pH and phosphate concentration and with
11 decreasing clay and iron oxide content. As pH increases, the negative charge of the
12 arsenate ion increases, making it less likely to sorb on negatively charged soil particles.
13 Phosphates have a chemical structure similar to that of arsenates and sorb to soil
14 preferentially in some conditions. Nitrogen also belongs to the same group in the
15 periodic table but does not show the same competing behavior as phosphate. Other
16 structurally similar oxyanions, sulfate and selenate, are also weak sorbers. Under less
17 oxidizing conditions, arsenite ion H_3AsO_3 is most stable. Lack of charge renders the ion
18 more mobile and less likely to sorb to soil particles. Its pH stability spread ranges from
19 acid to alkaline. The first deprotonated form, $\text{H}_2\text{AsO}_3^{-1}$, exists at significant
20 concentrations only above a pH of approximately 9. Redox processes seem to be
21 mediated by microorganisms (Welch, *et al.*, 2000) and to take place next to mineral
22 surfaces.

23 Under even more reducing conditions, arsenide is the stable ionic form of arsenic.
24 Arsenic has a complex geochemistry with sulfur, both in solution where several
25 thioarsenic ions can form and in associated minerals. Arsenic metal –As(0)- rarely
26 occurs. Methylated arsenic compounds are generally present at low aqueous
27 concentrations (<1ppb), if at all, except perhaps when there is an abundance of organic
28 matter (Welch, *et al.*, 2000).

29 As(V) and As(III) minerals are fairly soluble and do not control arsenic solubility in
30 oxidizing or mildly reducing conditions, except, perhaps, if barium is present (Henry, *et*
31 *al.* 1982). This situation is in contrast to that of other companion oxyanions which are
32 not as mobile under reducing conditions, except vanadium. In reducing conditions,
33 arsenic precipitates as arsenopyrite (FeAsS), although more commonly in solid solution
34 with pyrite. Realgar (AsS) and orpiment (As_2S_3) require high sulfur activity and are
35 unlikely in the southern Gulf Coast.



2

3

4

5

Figure E.1
Eh-pH Diagram for Arsenic Aqueous Species in the As-O₂-H₂O System
at 25°C and 1 bar (Smedley and Kinniburgh 2002)

1
2

**APPENDIX F
ORBIT SYSTEMS WATER USAGE**

**Orbit Systems, Inc.
2004 Water Usage**

No.	System Name	2004 Water Usage (gal/yr)	% Water Usage %	No. Connections #	Usage Per Connection (gal/yr)	No. Customers #	Annual Usage Per Customer (gal/yr)	Daily Usage Per Customer (gpcd)
1	Coronado Country	2,083,300	1.7	44	47,348	132	15,783	43.2
2	Country Acres	6,766,800	5.4	88	76,895	264	25,632	70.2
3	Colony Cove	4,239,800	3.4	48	88,329	144	29,443	80.7
4	Country Meadows	3,446,900	2.7	48	71,810	144	23,937	65.6
5	Blue Sage Gardens	2,976,800	2.4	43	69,228	129	23,076	63.2
6	Brandi Estates	3,524,700	2.8	43	81,970	129	27,323	74.9
7	Sandy Meadows	3,735,400	3.0	68	54,932	204	18,311	50.2
8	Rosharon Road Estates	5,455,900	4.3	76	71,788	228	23,929	65.6
9	Grasslands	12,465,400	9.9	171	72,897	513	24,299	66.6
10	Rosharon Township	8,055,400	6.4	99	81,368	297	27,123	74.3
11	Demi-John Island	3,973,000	3.2	99	40,131	297	13,377	36.6
12	San Bernard River	4,595,500	3.7	49	93,786	147	31,262	85.6
13	Angle Acres	3,330,500	2.7	44	75,693	132	25,231	69.1
14	Spanish Bait	672,000	0.5	8	84,000	24	28,000	76.7
15	Briar meadow	5,231,700	4.2	41	127,602	123	42,534	116.5
16	Mooreland	4,605,600	3.7	48	95,950	144	31,983	87.6
17	Raynlong	2,736,600	2.2	32	85,519	96	28,506	78.1
18	Snug Harbor	2,030,600	1.6	33	61,533	99	20,511	56.2
19	Bernard Oaks	4,280,000	3.4	71	60,282	213	20,094	55.1
20	Demi-John Place	2,844,500	2.3	88	32,324	264	10,775	29.5
21	Televew Terrace	5,997,600	4.8	47	127,609	141	42,536	116.5
22	Wolf Glen	2,809,900	2.2	35	80,283	105	26,761	73.3
23	Larkspur	420,000	0.3	5	84,000	15	28,000	76.7
24	Wilco Water	4,037,100	3.2	49	82,390	147	27,463	75.2
25	Beechwood	5,655,000	4.5	73	77,466	219	25,822	70.7
26	Oak Meadows	1,542,000	1.2	33	46,727	99	15,576	42.7
27	Mark V	7,178,900	5.7	94	76,371	282	25,457	69.7
28	Riverside Estates	3,695,400	2.9	48	76,988	144	25,663	70.3
29	Lee Ridge	1,926,900	1.5	22	87,586	66	29,195	80.0
30	Quail Valley Ranches IV	785,600	0.6	8	98,200	24	32,733	89.7
31	Paloma Acres	1,484,500	1.2	25	59,380	75	19,793	54.2
32	Colony Trails	2,254,100	1.8	45	50,091	135	16,697	45.7
33	Other	725,000	0.6	19	38,158	57	12,719	34.8
	TOTAL	125,562,400	100	1,744		5,232		
	AVERAGE				74,504		24,835	68.0

1 **APPENDIX G**
2 **ANALYSIS OF SHARED SOLUTIONS FOR OBTAINING WATER FROM**
3 **BWA AND CITY OF ALVIN**

4 **G.1 Overview of Method**

5 There are a number of small PWSs with water quality problems located in the
6 vicinity of the Oak Meadows Estates PWS that could benefit from joining together and
7 cooperating to share the cost for obtaining compliant drinking water. This cooperation
8 could involve creating a formal organization of individual PWSs to address obtaining
9 compliant drinking water, consolidating to form a single PWS, or having the individual
10 PWSs be taken over or bought out by a larger regional entity.

11 The small PWSs with water quality problems near the Oak Meadows Estates PWS
12 are summarized in Table G.1. Most of them are owned by Orbit. It is assumed for this
13 analysis that all of the systems would participate in a shared solution.

14 This analysis focuses on compliance alternatives related to obtaining water from
15 large water providers that are interested in providing water outside their current area,
16 either by wholesaling to PWSs, or by expanding their service areas. This type of solution
17 is most likely to have the best prospects for sustainability, and a reliable provision of
18 compliant drinking water.

19 The purpose of this analysis is to approximate the level of capital cost savings that
20 could be expected from pursuing a shared solution versus a solution where the study
21 PWS obtains compliant drinking water on its own. Regardless of the form a group
22 solution would take, one way or another the water consumers would have to pay for the
23 infrastructure needed for obtaining compliant water. In order to keep this analysis as
24 straightforward and realistic as possible, it is assumed the individual PWSs would remain
25 independent, and would share the capital cost for the infrastructure required. Also, to
26 maintain simplicity this analysis is limited to estimating capital cost savings. A shared
27 solution could also produce savings in O&M expenses as a result of reduction in
28 redundant facilities and the potential for shared O&M resources, and these savings would
29 have to be evaluated if the PWSs are interested in implementing a shared solution.

30 There are many ways capital costs could be divided between participating PWSs and
31 the final apportioning of costs would likely be based on negotiation between the
32 participating entities. At this preliminary stage of analysis it is not possible to project
33 results from negotiations regarding cost sharing. For this reason, two methods are used
34 to allocate cost between PWSs in an effort to give an approximation of the range of
35 savings that might be attainable for an individual PWS. This range is considered to be
36 representative of possible savings that could result from an agreement that should be fair
37 and equitable to all parties involved.

38 Method A is based on allocating capital cost of the shared solution proportionate to
39 the amount of water used by the PWSs. In this case, the total capital cost for the pipeline
40 and the necessary pump stations is estimated, and then capital cost for each component is

1 allocated based on the fraction of the total water used by each PWS. This method is a
2 reasonable method for allocating cost when all of the PWSs are different in size but are
3 relatively equidistant from the shared water source.

4 Method B is based on allocating capital cost of the shared solution proportionate to
5 the cost each PWS would have to pay to obtain compliant water if it were to implement
6 an individual solution. In this case, the total capital cost for the shared pipeline and the
7 necessary pump stations is estimated as well as the capital cost each PWS would have for
8 obtaining its own pipeline. The total capital cost for the shared solution is then allocated
9 between the participating PWSs based on what each PWS would have to pay to construct
10 its own pipeline. This method is a reasonable method for allocating cost when the PWS
11 are not equidistant from the water source.

12 **G.2 Shared Solution for Obtaining Water from City of Alvin**

13 This alternative would consist of constructing a main pipeline from the southwest
14 part of the City of Alvin that would run southwest and west along FM 1462 to Rosharon
15 Township. Each PWS would connect to this main with a spur line. Spur lines would
16 convey the water from the main line to the storage tanks of each PWS. The main
17 pipeline would start out as 6 inches in diameter, and reduce to 4 inches in diameter at the
18 end. All of the spur pipelines would be 4 inches in diameter. It is assumed two pump
19 stations would be required to transfer the water from the City of Alvin to the end of the
20 pipeline. The pipeline routing is shown on Figure G.1.

21 The capital costs for each pipe segment and the total capital cost for the shared
22 pipeline are summarized in Table G.2. Tables G.3, G.4 and G.5 show the capital costs
23 allocated to each PWS using Methods A, B and C respectively while Table G.6 compares
24 the found values from each method. More detailed cost estimates for the pipe segments
25 are shown in Tables G.12 through G.22 and G.35 through G.40.

26 Based on these estimates, the range of capital cost savings to the Rosharon Road
27 Estates PWS could be between \$0.71 million and \$1.27 million, or 43 and 76 percent if it
28 implemented a shared solution like this. These estimates are hypothetical and are only
29 provided to approximate the magnitude of potential savings if this shared solution is
30 implemented as described.

31 **G.3 Group Solution for Obtaining Water from Brazosport Water Authority**

32 This alternative would consist of constructing a main pipeline that starts at the north
33 part of the City of Angleton where the Brazosport Water Authority line currently
34 terminates. The line would run north along Highway 288 to Rosharon Township and turn
35 to run east along FM 1462 to Rosharon Road Estates. Spur lines would convey the water
36 from the main line to the storage tanks. The main pipeline would start out as 6 inches in
37 diameter, and reduce to 4 inches in diameter at the end. All of the spur pipelines would
38 be 4 inches in diameter. It is assumed three pump stations would be required to transfer
39 the water from the Brazosport Water Authority line to the end of the pipeline. The
40 pipeline routing is shown on Figure G.2.

1 The capital costs for each pipe segment and the total capital cost for the shared
2 pipeline are summarized in Table G.7. Table G.8, G.9 and G.10 show the capital costs
3 allocated to each PWS using Methods A, B and C respectively while Table G.11
4 compares the found values from each method. More detailed cost estimates for the pipe
5 segments are shown in Tables G.23 through G.17 and G.41 through G.46.

6 Based on these estimates, the range of capital cost savings to the Rosharon Road
7 Estates PWS could be between \$2.17 million and \$2.69 million, or 65 and 80 percent, if
8 they were to implement a shared solution like this. These estimates are hypothetical and
9 are only provided to approximate the magnitude of potential savings if this shared
10 solution is implemented as described.





Figure G.1

**Regional Solution
Water from City of Alvin**



- Participating PWS
- Source Location
- Regional Pipeline
- Water Features
- Roads
- City Limits







Figure G.2
Regional Solution
Water from
Brazosport Water Authority

Table G.1

PWS	Average Water Demand (mgd)	Water Demand as Percent of Total
Rosharon Road Estates Subdivision	0.10443	28%
Sandy Meadows Estates Subdivision	0.08943	24%
Stoneridge Lakes	0.07343	19%
Grasslands	0.06485	17%
Oak Meadows	0.02585	7%
Rosharon Township	0.0191	5%
0	0	0%
0	0	0%
0	0	0%

Table G.2
Capital Cost for Shared Pipeline from the City of Alvin

Pipe Segment	Capital Cost
Pipe 1	\$ 1,867,972
Pipe 2	\$ 231,354
Pipe 3	\$ 771,954
Pipe 4	\$ 66,985
Pipe 5	\$ 110,723
Pipe 6	\$ -
Pipe 7	\$ -
Pipe 8	\$ -
Pipe 9	\$ -
Pipe A	\$ 83,183
Pipe B	\$ 56,081
Pipe C	\$ 28,781
Pipe D	\$ 20,947
Pipe E	\$ 121,746
Pipe F	\$ 81,115
Pipe G	\$ -
Pipe H	\$ -
Pipe I	\$ -
Total	\$ 3,440,840

Table G.3
Cost Solution A

PWS	Percentage Based On Flow	Total Costs
Rosharon Road Estates Subdivision	28%	\$ 952,894
Sandy Meadows Estates Subdivision	24%	\$ 816,024
Stoneridge Lakes	19%	\$ 670,028
Grasslands	17%	\$ 591,738
Oak Meadows	7%	\$ 235,874
Rosharon Township	5%	\$ 174,282
0	0%	\$ -
0	0%	\$ -
0	0%	\$ -
Total	100%	\$ 3,440,840

Table G.4
Cost Solution B

PWS	Costs Incurred due to Shared Pipeline	Costs Incurred due to Personal Pipeline	Total Costs
Rosharon Road Estates Subdivision	\$ 517,310	\$ 83,183	\$ 600,493
Sandy Meadows Estates Subdivision	\$ 518,887	\$ 56,081	\$ 574,968
Stoneridge Lakes	\$ 735,416	\$ 28,781	\$ 764,196
Grasslands	\$ 689,048	\$ 20,947	\$ 709,995
Oak Meadows	\$ 338,338	\$ 121,746	\$ 460,083
Rosharon Township	\$ 249,990	\$ 81,115	\$ 331,105
0	\$ -	\$ -	\$ -
0	\$ -	\$ -	\$ -
0	\$ -	\$ -	\$ -
Total	\$ 3,048,988	\$ 391,852	\$ 3,440,840

Table G.5
Cost Solution C

PWS	Percentage based on Individual Solutions	Total Costs
Rosharon Road Estates Subdivision	12%	\$ 397,613
Sandy Meadows Estates Subdivision	13%	\$ 449,660
Stoneridge Lakes	18%	\$ 614,387
Grasslands	18%	\$ 623,111
Oak Meadows	20%	\$ 673,214
Rosharon Township	20%	\$ 682,855
0	0%	\$ -
0	0%	\$ -
0	0%	\$ -
Total	100%	\$ 3,440,840

Table G.6
Summation Table

PWS	Individual Pipeline Cost	Capital Cost Option A	Capital Cost Option B	Capital Cost Option C	Percent Savings A	Percent Savings B	Percent Savings C
Rosharon Road Estates Subdivision	\$ 1,660,177	\$ 952,894	\$ 600,493	\$ 397,613	43%	64%	76%
Sandy Meadows Estates Subdivision	\$ 1,877,491	\$ 816,024	\$ 574,968	\$ 449,660	57%	69%	76%
Stoneridge Lakes	\$ 2,565,286	\$ 670,028	\$ 764,196	\$ 614,387	74%	70%	76%
Grasslands	\$ 2,601,709	\$ 591,738	\$ 709,995	\$ 623,111	77%	73%	76%
Oak Meadows	\$ 2,810,908	\$ 235,874	\$ 460,083	\$ 673,214	92%	84%	76%
Rosharon Township	\$ 2,851,163	\$ 174,282	\$ 331,105	\$ 682,855	94%	88%	76%
0	\$ -	\$ -	\$ -	\$ -	false	false	false
0	\$ -	\$ -	\$ -	\$ -	false	false	false
0	\$ -	\$ -	\$ -	\$ -	false	false	false
Total	\$ 14,366,734	\$ 3,440,840	\$ 3,440,840	\$ 3,440,840	73%	75%	76%

Table G.7
Capital Cost for Shared Pipeline from BWA

Pipe Segment	Capital Cost
Pipe 1	\$ 2,988,751
Pipe 2	\$ 92,141
Pipe 3	\$ 110,723
Pipe 4	\$ 66,985
Pipe 5	\$ 786,817
Pipe 6	\$ 231,354
Pipe 7	\$ -
Pipe 8	\$ -
Pipe 9	\$ -
Pipe A	\$ 74,108
Pipe B	\$ 121,746
Pipe C	\$ 20,947
Pipe D	\$ 28,769
Pipe E	\$ 56,085
Pipe F	\$ 83,254
Pipe G	\$ -
Pipe H	\$ -
Pipe I	\$ -
Total	\$ 4,661,678

Table G.8
Cost Solution A

PWS	Percentage Based On Flow	Total Costs
Rosharon Township	18%	\$ 852,611
Oak Meadows	6%	\$ 301,315
Grasslands	37%	\$ 1,740,934
Stoneridge Lakes	8%	\$ 383,005
Sandy Meadows Estates Subdivision	15%	\$ 714,222
Rosharon Road Estates Subdivision	14%	\$ 669,590
0	0%	\$ -
0	0%	\$ -
0	0%	\$ -
Total	100%	\$ 4,661,678

Table G.9
Cost Solution B

PWS	Costs Incurred due to Shared Pipeline	Costs Incurred due to Personal Pipeline	Total Costs
Rosharon Township	\$ 546,636	\$ 74,108	\$ 620,744
Oak Meadows	\$ 200,472	\$ 121,746	\$ 322,217
Grasslands	\$ 1,213,235	\$ 20,947	\$ 1,234,181
Stoneridge Lakes	\$ 281,432	\$ 28,769	\$ 310,202
Sandy Meadows Estates Subdivision	\$ 930,908	\$ 56,085	\$ 986,992
Rosharon Road Estates Subdivision	\$ 1,104,088	\$ 83,254	\$ 1,187,342
0	\$ -	\$ -	\$ -
0	\$ -	\$ -	\$ -
0	\$ -	\$ -	\$ -
Total	\$ 4,276,771	\$ 384,908	\$ 4,661,678

Table G.10
Cost Solution C

PWS	Percentage based on Individual Solutions	Total Costs
Rosharon Township	15%	\$ 699,159
Oak Meadows	16%	\$ 744,220
Grasslands	15%	\$ 703,840
Stoneridge Lakes	15%	\$ 698,313
Sandy Meadows Estates Subdivision	19%	\$ 891,538
Rosharon Road Estates Subdivision	20%	\$ 924,609
0	0%	\$ -
0	0%	\$ -
0	0%	\$ -
Total	100%	\$ 4,661,678

Table G.11
Summation Table

PWS	Individual Pipeline Cost	Capital Cost Option A	Capital Cost Option B	Capital Cost Option C	Percent Savings A	Percent Savings B	Percent Savings C
Rosharon Township	\$ 2,540,184	\$ 852,611	\$ 620,744	\$ 699,159	66%	76%	72%
Oak Meadows	\$ 2,703,899	\$ 301,315	\$ 322,217	\$ 744,220	89%	88%	72%
Grasslands	\$ 2,557,190	\$ 1,740,934	\$ 1,234,181	\$ 703,840	32%	52%	72%
Stoneridge Lakes	\$ 2,537,109	\$ 383,005	\$ 310,202	\$ 698,313	85%	88%	72%
Sandy Meadows Estates Subdivision	\$ 3,239,135	\$ 714,222	\$ 986,992	\$ 891,538	78%	70%	72%
Rosharon Road Estates Subdivision	\$ 3,359,289	\$ 669,590	\$ 1,187,342	\$ 924,609	80%	65%	72%
0	\$ -	\$ -	\$ -	\$ -	false	false	false
0	\$ -	\$ -	\$ -	\$ -	false	false	false
0	\$ -	\$ -	\$ -	\$ -	false	false	false
Total	\$ 16,936,806	\$ 4,661,678	\$ 4,661,678	\$ 4,661,678	72%	73%	72%

Table G.12

Obtain Water From the City of Alvin

Main Link # 1

Total Pipe Length

6.67 miles

Number of Pump Stations Needed

1

Pipe Size

06" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	4	n/a	n/a	n/a
Number of Crossings, open cut	14	n/a	n/a	n/a
PVC water line, Class 200, 06"	35,210	LF	\$ 32	\$ 1,126,720
Bore and encasement, 10"	800	LF	\$ 60	\$ 48,000
Open cut and encasement, 10"	700	LF	\$ 35	\$ 24,500
Gate valve and box, 06"	8	EA	\$ 465	\$ 3,720
Air valve	7	EA	\$ 1,000	\$ 7,000
Flush valve	8	EA	\$ 750	\$ 6,000
Metal detectable tape	35,210	LF	\$ 0.15	\$ 5,282
Subtotal				\$ 1,221,222
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 06"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 06"	4	EA	\$ 590	\$ 2,360
Check valve, 06"	2	EA	\$ 890	\$ 1,780
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 67,035
Subtotal of Component Costs				\$ 1,288,257
Contingency	20%			\$ 257,651
Design & Constr Management	25%			\$ 322,064
TOTAL CAPITAL COSTS				\$ 1,867,972

Table G.13

Obtain Water From the City of Alvin

Main Link # 2

Total Pipe Length

0.99 miles

Number of Pump Stations Needed

0

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	5,251	LF	\$ 27	\$ 141,777
Bore and encasement, 10"	200	LF	\$ 60	\$ 12,000
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	2	EA	\$ 370	\$ 740
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	2	EA	\$ 750	\$ 1,500
Metal detectable tape	5,251	LF	\$ 0.15	\$ 788
Subtotal				\$ 159,555
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 159,555
Contingency	20%			\$ 31,911
Design & Constr Management	25%			\$ 39,889
TOTAL CAPITAL COSTS				\$ 231,354

Table G.14

Obtain Water From the City of Alvin

Main Link # 3

Total Pipe Length

2.92 miles

Number of Pump Stations Needed

1

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	3	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	15,394	LF	\$ 27	\$ 415,638
Bore and encasement, 10"	600	LF	\$ 60	\$ 36,000
Open cut and encasement, 10"	150	LF	\$ 35	\$ 5,250
Gate valve and box, 04"	4	EA	\$ 370	\$ 1,480
Air valve	3	EA	\$ 1,000	\$ 3,000
Flush valve	4	EA	\$ 750	\$ 3,000
Metal detectable tape	15,394	LF	\$ 0.15	\$ 2,309
Subtotal				\$ 466,677
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 65,705
Subtotal of Component Costs				\$ 532,382
Contingency	20%			\$ 106,476
Design & Constr Management	25%			\$ 133,096
TOTAL CAPITAL COSTS				\$ 771,954

Table G.15

Obtain Water From the City of Alvin

Main Link # 4

Total Pipe Length

0.30 miles

Number of Pump Stations Needed

0

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,559	LF	\$ 27	\$ 42,093
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,559	LF	\$ 0.15	\$ 234
	Subtotal			\$ 46,197
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
	Subtotal			\$ -
			Subtotal of Component Costs	\$ 46,197
Contingency	20%			\$ 9,239
Design & Constr Management	25%			\$ 11,549
			TOTAL CAPITAL COSTS	\$ 66,985

Table G.16

Obtain Water From the City of Alvin

Main Link # 5

Total Pipe Length

0.51 miles

Number of Pump Stations Needed

0

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	2,670	LF	\$ 27	\$ 72,090
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	2,670	LF	\$ 0.15	\$ 401
Subtotal				\$ 76,361
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 76,361
Contingency	20%			\$ 15,272
Design & Constr Management	25%			\$ 19,090
TOTAL CAPITAL COSTS				\$ 110,723

Table G.17

Segment A

Obtain Water From the City of Alvin

Rosharon Road Estates Subdivision

Private Pipe Size

04"

Total Pipe Length

0.28 miles

Total PWS annual water usage

38.1 MG

Treated water purchase cost

\$ 1.25 per 1,000 gals

Number of Pump Stations Needed

0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	2	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,464	LF	\$ 27	\$ 39,528
Bore and encasement, 10"	200	LF	\$ 60	\$ 12,000
Open cut and encasement, 10"	100	LF	\$ 35	\$ 3,500
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,464	LF	\$ 0.15	\$ 220
	Subtotal			\$ 57,368
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
	Subtotal			\$ -
Subtotal of Component Costs				\$ 57,368
Contingency	20%			\$ 11,474
Design & Constr Management	25%			\$ 14,342
TOTAL CAPITAL COSTS				\$ 83,183

Table G.18

Segment B

Obtain Water From the City of Alvin

Sandy Meadows Estates Subdivision

Private Pipe Size	04"
Total Pipe Length	0.24 miles
Total PWS annual water usage	32.6 MG
Treated water purchase cost	\$ 1.25 per 1,000 gals
Number of Pump Stations Needed	0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,282	LF	\$ 27	\$ 34,614
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,282	LF	\$ 0.15	\$ 192
		Subtotal		\$ 38,676
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		Subtotal		\$ -
		Subtotal of Component Costs		\$ 38,676
Contingency	20%			\$ 7,735
Design & Constr Management	25%			\$ 9,669
		TOTAL CAPITAL COSTS		\$ 56,081

Table G.19

**Segment C
Obtain Water From the City of Alvin
Stoneridge Lakes**

Private Pipe Size	04"
Total Pipe Length	0.12 miles
Total PWS annual water usage	26.8 MG
Treated water purchase cost	\$ 1.25 per 1,000 gals
Number of Pump Stations Needed	0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	-	n/a	n/a	n/a
PVC water line, Class 200, 04"	653	LF	\$ 27	\$ 17,631
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	-	LF	\$ 35	\$ -
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	653	LF	\$ 0.15	\$ 98
		Subtotal		\$ 19,849
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		Subtotal		\$ -
		Subtotal of Component Costs		\$ 19,849
Contingency	20%			\$ 3,970
Design & Constr Management	25%			\$ 4,962
		TOTAL CAPITAL COSTS		\$ 28,781

Table G.20

Segment D

Obtain Water From the City of Alvin

Grasslands

Private Pipe Size	04"
Total Pipe Length	0.09 miles
Total PWS annual water usage	23.7 MG
Treated water purchase cost	\$ 1.25 per 1,000 gals
Number of Pump Stations Needed	0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	-	n/a	n/a	n/a
PVC water line, Class 200, 04"	454	LF	\$ 27	\$ 12,258
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	-	LF	\$ 35	\$ -
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	454	LF	\$ 0.15	\$ 68
			Subtotal	\$ 14,446
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
			Subtotal	\$ -
			Subtotal of Component Costs	\$ 14,446
Contingency	20%			\$ 2,889
Design & Constr Management	25%			\$ 3,612
			TOTAL CAPITAL COSTS	\$ 20,947

Table G.21

Segment E

Obtain Water From the City of Alvin

Oak Meadows

Private Pipe Size	04"
Total Pipe Length	0.56 miles
Total PWS annual water usage	9.4 MG
Treated water purchase cost	\$ 1.25 per 1,000 gals
Number of Pump Stations Needed	0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	2,950	LF	\$ 27	\$ 79,650
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	2,950	LF	\$ 0.15	\$ 443
		Subtotal		\$ 83,963
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		Subtotal		\$ -
		Subtotal of Component Costs		\$ 83,963
Contingency	20%			\$ 16,793
Design & Constr Management	25%			\$ 20,991
		TOTAL CAPITAL COSTS		\$ 121,746

Table G.22

Segment F

Obtain Water From the City of Alvin

Rosharon Township

Private Pipe Size

04"

Total Pipe Length

0.34 miles

Total PWS annual water usage

7.0 MG

Treated water purchase cost

\$ 1.25 per 1,000 gals

Number of Pump Stations Needed

0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,789	LF	\$ 27	\$ 48,303
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	150	LF	\$ 35	\$ 5,250
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,789	LF	\$ 0.15	\$ 268
		Subtotal		\$ 55,941
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		Subtotal		\$ -
		Subtotal of Component Costs		\$ 55,941
Contingency	20%			\$ 11,188
Design & Constr Management	25%			\$ 13,985
		TOTAL CAPITAL COSTS		\$ 81,115

Table G.23

Obtain Water From the City of Alvin

Main Link # 1

Total Pipe Length

11.36 miles

Number of Pump Stations Needed

1

Pipe Size

06" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	9	n/a	n/a	n/a
PVC water line, Class 200, 06"	59,964	LF	\$ 32	\$ 1,918,848
Bore and encasement, 10"	400	LF	\$ 60	\$ 24,000
Open cut and encasement, 10"	450	LF	\$ 35	\$ 15,750
Gate valve and box, 06"	12	EA	\$ 465	\$ 5,580
Air valve	12	EA	\$ 1,000	\$ 12,000
Flush valve	12	EA	\$ 750	\$ 9,000
Metal detectable tape	59,964	LF	\$ 0.15	\$ 8,995
	Subtotal			\$ 1,994,173
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 06"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 06"	4	EA	\$ 590	\$ 2,360
Check valve, 06"	2	EA	\$ 890	\$ 1,780
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5000 gals	1	EA	\$ 7,025	\$ 7,025
	Subtotal			\$ 67,035
			Subtotal of Component Costs	\$ 2,061,208
Contingency	20%			\$ 412,242
Design & Constr Management	25%			\$ 515,302
			TOTAL CAPITAL COSTS	\$ 2,988,751

Table G.24

Obtain Water From the City of Alvin

Main Link # 2

Total Pipe Length

0.33 miles

Number of Pump Stations Needed

0

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,756	LF	\$ 27	\$ 47,412
Bore and encasement, 10"	200	LF	\$ 60	\$ 12,000
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,756	LF	\$ 0.15	\$ 263
Subtotal				\$ 63,545
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 63,545
Contingency	20%			\$ 12,709
Design & Constr Management	25%			\$ 15,886
TOTAL CAPITAL COSTS				\$ 92,141

Table G.25

Obtain Water From the City of Alvin

Main Link # 3

Total Pipe Length

0.51 miles

Number of Pump Stations Needed

0

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	2,670	LF	\$ 27	\$ 72,090
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	2,670	LF	\$ 0.15	\$ 401
Subtotal				\$ 76,361
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 76,361
Contingency	20%			\$ 15,272
Design & Constr Management	25%			\$ 19,090
TOTAL CAPITAL COSTS				\$ 110,723

Table G.26

Obtain Water From the City of Alvin

Main Link # 4

Total Pipe Length

0.30 miles

Number of Pump Stations Needed

0

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,559	LF	\$ 27	\$ 42,093
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,559	LF	\$ 0.15	\$ 234
	Subtotal			\$ 46,197
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
	Subtotal			\$ -
		Subtotal of Component Costs		\$ 46,197
Contingency	20%			\$ 9,239
Design & Constr Management	25%			\$ 11,549
		TOTAL CAPITAL COSTS		\$ 66,985

Table G.27

Obtain Water From the City of Alvin

Main Link # 5

Total Pipe Length

2.92 miles

Number of Pump Stations Needed

1

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	4	n/a	n/a	n/a
Number of Crossings, open cut	2	n/a	n/a	n/a
PVC water line, Class 200, 04"	15,394	LF	\$ 27	\$ 415,638
Bore and encasement, 10"	800	LF	\$ 60	\$ 48,000
Open cut and encasement, 10"	100	LF	\$ 35	\$ 3,500
Gate valve and box, 04"	4	EA	\$ 370	\$ 1,480
Air valve	3	EA	\$ 1,000	\$ 3,000
Flush valve	4	EA	\$ 750	\$ 3,000
Metal detectable tape	15,394	LF	\$ 0.15	\$ 2,309
	Subtotal			\$ 476,927
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 04"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5000 gals	1	EA	\$ 7,025	\$ 7,025
	Subtotal			\$ 65,705
			Subtotal of Component Costs	\$ 542,632
Contingency	20%			\$ 108,526
Design & Constr Management	25%			\$ 135,658
			TOTAL CAPITAL COSTS	\$ 786,817

Table G.28

Obtain Water From the City of Alvin

Main Link # 6

Total Pipe Length

0.99 miles

Number of Pump Stations Needed

0

Pipe Size

04" inches

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	5,251	LF	\$ 27	\$ 141,777
Bore and encasement, 10"	200	LF	\$ 60	\$ 12,000
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	2	EA	\$ 370	\$ 740
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	2	EA	\$ 750	\$ 1,500
Metal detectable tape	5,251	LF	\$ 0.15	\$ 788
Subtotal				\$ 159,555
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5000 gals	-	EA	\$ 7,025	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 159,555
Contingency	20%			\$ 31,911
Design & Constr Management	25%			\$ 39,889
TOTAL CAPITAL COSTS				\$ 231,354

Table G.29

Segment A

Obtain Water From the City of Alvin

Rosharon Township

Private Pipe Size

04"

Total Pipe Length

0.31 miles

Total PWS annual water usage

4,841.3 MG

Treated water purchase cost

\$ 1.25 per 1,000 gals

Number of Pump Stations Needed

0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,611	LF	\$ 27	\$ 43,497
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	150	LF	\$ 35	\$ 5,250
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,611	LF	\$ 0.15	\$ 242
Subtotal				\$ 51,109
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
Subtotal				\$ -
Subtotal of Component Costs				\$ 51,109
Contingency	20%			\$ 10,222
Design & Constr Management	25%			\$ 12,777
TOTAL CAPITAL COSTS				\$ 74,108

Table G.30

Segment B

Obtain Water From the City of Alvin

Oak Meadows

Private Pipe Size

04"

Total Pipe Length

0.56 miles

Total PWS annual water usage

1,710.9 MG

Treated water purchase cost

\$ 1.25 per 1,000 gals

Number of Pump Stations Needed

0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	2,950	LF	\$ 27	\$ 79,650
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	2,950	LF	\$ 0.15	\$ 443
		Subtotal		\$ 83,963
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		Subtotal		\$ -
		Subtotal of Component Costs		\$ 83,963
Contingency	20%			\$ 16,793
Design & Constr Management	25%			\$ 20,991
		TOTAL CAPITAL COSTS		\$ 121,746

Table G.31

Segment C

Obtain Water From the City of Alvin

Grasslands

Private Pipe Size	04"
Total Pipe Length	0.09 miles
Total PWS annual water usage	9,885.4 MG
Treated water purchase cost	\$ 1.25 per 1,000 gals
Number of Pump Stations Needed	0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	-	n/a	n/a	n/a
PVC water line, Class 200, 04"	454	LF	\$ 27	\$ 12,258
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	-	LF	\$ 35	\$ -
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	454	LF	\$ 0.15	\$ 68
			Subtotal	\$ 14,446
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
			Subtotal	\$ -
			Subtotal of Component Costs	\$ 14,446
Contingency	20%			\$ 2,889
Design & Constr Management	25%			\$ 3,612
			TOTAL CAPITAL COSTS	\$ 20,947

Table G.32

**Segment D
Obtain Water From the City of Alvin
Stoneridge Lakes**

Private Pipe Size	04"
Total Pipe Length	0.12 miles
Total PWS annual water usage	2,174.8 MG
Treated water purchase cost	\$ 1.25 per 1,000 gals
Number of Pump Stations Needed	0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	-	n/a	n/a	n/a
PVC water line, Class 200, 04"	653	LF	\$ 27	\$ 17,623
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	-	LF	\$ 35	\$ -
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	653	LF	\$ 0.15	\$ 98
		Subtotal		\$ 19,841
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		Subtotal		\$ -
		Subtotal of Component Costs		\$ 19,841
Contingency	20%			\$ 3,968
Design & Constr Management	25%			\$ 4,960
		TOTAL CAPITAL COSTS		\$ 28,769

Table G.33

Segment E

Obtain Water From the City of Alvin

Sandy Meadows Estates Subdivision

Private Pipe Size	04"
Total Pipe Length	0.24 miles
Total PWS annual water usage	4,055.5 MG
Treated water purchase cost	\$ 1.25 per 1,000 gals
Number of Pump Stations Needed	0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	1	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,282	LF	\$ 27	\$ 34,617
Bore and encasement, 10"	-	LF	\$ 60	\$ -
Open cut and encasement, 10"	50	LF	\$ 35	\$ 1,750
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,282	LF	\$ 0.15	\$ 192
		Subtotal		\$ 38,679
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
		Subtotal		\$ -
		Subtotal of Component Costs		\$ 38,679
Contingency	20%			\$ 7,736
Design & Constr Management	25%			\$ 9,670
		TOTAL CAPITAL COSTS		\$ 56,085

Table G.34

Segment F

Obtain Water From the City of Alvin

Rosharon Road Estates Subdivision

Private Pipe Size

04"

Total Pipe Length

0.28 miles

Total PWS annual water usage

3,802.1 MG

Treated water purchase cost

\$ 1.25 per 1,000 gals

Number of Pump Stations Needed

0

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	2	n/a	n/a	n/a
PVC water line, Class 200, 04"	1,466	LF	\$ 27	\$ 39,577
Bore and encasement, 10"	200	LF	\$ 60	\$ 12,000
Open cut and encasement, 10"	100	LF	\$ 35	\$ 3,500
Gate valve and box, 04"	1	EA	\$ 370	\$ 370
Air valve	1	EA	\$ 1,000	\$ 1,000
Flush valve	1	EA	\$ 750	\$ 750
Metal detectable tape	1,466	LF	\$ 0.15	\$ 220
			Subtotal	\$ 57,416
<i>Pump Station(s) Installation</i>				
Pump	-	EA	\$ 7,500	\$ -
Pump Station Piping, 04"	-	EA	\$ 4,000	\$ -
Gate valve, 04"	-	EA	\$ 405	\$ -
Check valve, 04"	-	EA	\$ 595	\$ -
Electrical/Instrumentation	-	EA	\$ 10,000	\$ -
Site work	-	EA	\$ 2,000	\$ -
Building pad	-	EA	\$ 4,000	\$ -
Pump Building	-	EA	\$ 10,000	\$ -
Fence	-	EA	\$ 5,870	\$ -
Tools	-	EA	\$ 1,000	\$ -
Storage Tank - 5,000 gals	-	EA	\$ 7,025	\$ -
			Subtotal	\$ -
			Subtotal of Component Costs	\$ 57,416
Contingency	20%			\$ 11,483
Design & Constr Management	25%			\$ 14,354
			TOTAL CAPITAL COSTS	\$ 83,254

Table G.35

Alvin to each PWS

Alternative Name *Purchase Water from Alvin to Rosharon Road*
Alternative Number *RR*

Distance from Alternative to PWS (along pipe)	7.0	miles
Total PWS annual water usage	5.475	MG
Treated water purchase cost	\$ 1.65	per 1,000 gals
Number of Pump Stations Needed	1	

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	4	n/a	n/a	n/a
Number of Crossings, open cut	17	n/a	n/a	n/a
PVC water line, Class 200, 04"	36,750	LF	\$ 27.00	\$ 992,250
Bore and encasement, 10"	800	LF	\$ 60.00	\$ 48,000
Open cut and encasement, 10"	850	LF	\$ 35.00	\$ 29,750
Gate valve and box, 04"	7	EA	\$ 370.00	\$ 2,720
Air valve	7	EA	\$ 1,000.00	\$ 7,000
Flush valve	7	EA	\$ 750.00	\$ 5,513
Metal detectable tape	36,750	LF	\$ 0.15	\$ 5,513
Subtotal				\$ 1,090,745
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205
Subtotal of Component Costs				\$ 1,144,950
Contingency	20%		\$	228,990
Design & Constr Management	25%		\$	286,237
TOTAL CAPITAL COSTS				\$ 1,660,177

Table G.36

Alvin to each PWS

Alternative Name *Purchase Water from Alvin to Sandy Meadow*
Alternative Number *SM*

Distance from Alternative to PWS (along pipe)	7.9	miles
Total PWS annual water usage	5.840	MG
Treated water purchase cost	\$ 1.65	per 1,000 gals
Number of Pump Stations Needed	1	

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	5	n/a	n/a	n/a
Number of Crossings, open cut	16	n/a	n/a	n/a
PVC water line, Class 200, 04"	41,814	LF	\$ 27.00	\$ 1,128,978
Bore and encasement, 10"	1,000	LF	\$ 60.00	\$ 60,000
Open cut and encasement, 10"	800	LF	\$ 35.00	\$ 28,000
Gate valve and box, 04"	8	EA	\$ 370.00	\$ 3,094
Air valve	8	EA	\$ 1,000.00	\$ 8,000
Flush valve	8	EA	\$ 750.00	\$ 6,272
Metal detectable tape	41,814	LF	\$ 0.15	\$ 6,272
Subtotal				\$ 1,240,616
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205
Subtotal of Component Costs				\$ 1,294,821
Contingency	20%		\$	258,964
Design & Constr Management	25%		\$	323,705
TOTAL CAPITAL COSTS				\$ 1,877,491

Table G.37

Alvin to each PWS

Alternative Name *Purchase Water from Alvin to Stoneridge*
Alternative Number *SR*

Distance from Alternative to PWS (along pipe)	10.7	miles
Total PWS annual water usage	3.132	MG
Treated water purchase cost	\$ 1.65	per 1,000 gals
Number of Pump Stations Needed	1	

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	10	n/a	n/a	n/a
Number of Crossings, open cut	20	n/a	n/a	n/a
PVC water line, Class 200, 04"	56,585	LF	\$ 27.00	\$ 1,527,795
Bore and encasement, 10"	2,000	LF	\$ 60.00	\$ 120,000
Open cut and encasement, 10"	1,000	LF	\$ 35.00	\$ 35,000
Gate valve and box, 04"	11	EA	\$ 370.00	\$ 4,187
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	11	EA	\$ 750.00	\$ 8,488
Metal detectable tape	56,585	LF	\$ 0.15	\$ 8,488
Subtotal				\$ 1,714,958
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205
Subtotal of Component Costs				\$ 1,769,163
Contingency	20%		\$	353,833
Design & Constr Management	25%		\$	442,291
TOTAL CAPITAL COSTS				\$ 2,565,286

Table G.38

Alvin to each PWS

Alternative Name *Purchase Water from Alvin to Grasslands*
Alternative Number *Grass*

Distance from Alternative to PWS (along pipe)	11.0	miles
Total PWS annual water usage	14.235	MG
Treated water purchase cost	\$ 1.65	per 1,000 gals
Number of Pump Stations Needed	1	

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	9	n/a	n/a	n/a
Number of Crossings, open cut	20	n/a	n/a	n/a
PVC water line, Class 200, 04"	57,941	LF	\$ 27.00	\$ 1,564,407
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	1,000	LF	\$ 35.00	\$ 35,000
Gate valve and box, 04"	12	EA	\$ 370.00	\$ 4,288
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	12	EA	\$ 750.00	\$ 8,691
Metal detectable tape	57,941	LF	\$ 0.15	\$ 8,691
Subtotal				\$ 1,740,077
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205
Subtotal of Component Costs				\$ 1,794,282
Contingency	20%		\$	358,856
Design & Constr Management	25%		\$	448,570
TOTAL CAPITAL COSTS				\$ 2,601,709

Table G.39

Alvin to each PWS

Alternative Name *Purchase Water from Alvin to Oak Meadows*
Alternative Number *OM*

Distance from Alternative to PWS (along pipe)	12.0	miles
Total PWS annual water usage	5.475	MG
Treated water purchase cost	\$ 1.65	per 1,000 gals
Number of Pump Stations Needed	1	

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	9	n/a	n/a	n/a
Number of Crossings, open cut	20	n/a	n/a	n/a
PVC water line, Class 200, 04"	63,175	LF	\$ 27.00	\$ 1,705,725
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	1,000	LF	\$ 35.00	\$ 35,000
Gate valve and box, 04"	13	EA	\$ 370.00	\$ 4,675
Air valve	12	EA	\$ 1,000.00	\$ 12,000
Flush valve	13	EA	\$ 750.00	\$ 9,476
Metal detectable tape	63,175	LF	\$ 0.15	\$ 9,476
Subtotal				\$ 1,884,352
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205
Subtotal of Component Costs				\$ 1,938,557
Contingency	20%		\$	387,711
Design & Constr Management	25%		\$	484,639
TOTAL CAPITAL COSTS				\$ 2,810,908

Table G.40

Alvin to each PWS

Alternative Name *Purchase Water from Alvin to Rosharon Township*
Alternative Number *RT*

Distance from Alternative to PWS (along pipe)	12.0	miles
Total PWS annual water usage	6.972	MG
Treated water purchase cost	\$ 1.65	per 1,000 gals
Number of Pump Stations Needed	1	

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	10	n/a	n/a	n/a
Number of Crossings, open cut	23	n/a	n/a	n/a
PVC water line, Class 200, 04"	63,559	LF	\$ 27.00	\$ 1,716,093
Bore and encasement, 10"	2,000	LF	\$ 60.00	\$ 120,000
Open cut and encasement, 10"	1,150	LF	\$ 35.00	\$ 40,250
Gate valve and box, 04"	13	EA	\$ 370.00	\$ 4,703
Air valve	12	EA	\$ 1,000.00	\$ 12,000
Flush valve	13	EA	\$ 750.00	\$ 9,534
Metal detectable tape	63,559	LF	\$ 0.15	\$ 9,534
Subtotal				\$ 1,912,114
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205
Subtotal of Component Costs				\$ 1,966,319
Contingency	20%		\$	393,264
Design & Constr Management	25%		\$	491,580
TOTAL CAPITAL COSTS				\$ 2,851,163

Table G.41

**Angleton to each PWS
Purchase Water from Angleton to RoshTownship
RT**

Distance from Alternative to PWS (along pipe)	11.4 miles
Total PWS annual water usage	6.972 MG
Treated water purchase cost	\$ 1.60 per 1,000 gals
Number of Pump Stations Needed	1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	12	n/a	n/a	n/a
PVC water line, Class 200, 04"	59,971	LF	\$ 27.00	\$ 1,619,217
Bore and encasement, 10"	400	LF	\$ 60.00	\$ 24,000
Open cut and encasement, 10"	600	LF	\$ 35.00	\$ 21,000
Gate valve and box, 04"	12	EA	\$ 370.00	\$ 4,438
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	12	EA	\$ 750.00	\$ 8,996
Metal detectable tape	59,971	LF	\$ 0.15	\$ 8,996
Subtotal				\$ 1,697,646
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205
Subtotal of Component Costs				\$ 1,751,851
Contingency	20%		\$	350,370
Design & Constr Management	25%		\$	437,963
TOTAL CAPITAL COSTS				\$ 2,540,184

Table G.42

**Angleton to each PWS
Purchase Water from Angleton to Oak Meadow
OM**

Distance from Alternative to PWS (along pipe)	12.1 miles
Total PWS annual water usage	2,464 MG
Treated water purchase cost	\$ 1.60 per 1,000 gals
Number of Pump Stations Needed	1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	11	n/a	n/a	n/a
PVC water line, Class 200, 04"	64,123	LF	\$ 27.00	\$ 1,731,321
Bore and encasement, 10"	400	LF	\$ 60.00	\$ 24,000
Open cut and encasement, 10"	550	LF	\$ 35.00	\$ 19,250
Gate valve and box, 04"	13	EA	\$ 370.00	\$ 4,745
Air valve	12	EA	\$ 1,000.00	\$ 12,000
Flush valve	13	EA	\$ 750.00	\$ 9,618
Metal detectable tape	64,123	LF	\$ 0.15	\$ 9,618
Subtotal				\$ 1,810,553
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205
Subtotal of Component Costs				\$ 1,864,758
Contingency	20%		\$	372,952
Design & Constr Management	25%		\$	466,190
TOTAL CAPITAL COSTS				\$ 2,703,899

Table G.43

Angleton to each PWS

Alternative Name *Purchase Water from Angleton to Grasslands*
Alternative Number *Grass*

Distance from Alternative to PWS (along pipe)	11.4 miles
Total PWS annual water usage	14.235 MG
Treated water purchase cost	\$ 1.60 per 1,000 gals
Number of Pump Stations Needed	1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	3	n/a	n/a	n/a
Number of Crossings, open cut	11	n/a	n/a	n/a
PVC water line, Class 200, 04"	60,025	LF	\$ 27.00	\$ 1,620,675
Bore and encasement, 10"	600	LF	\$ 60.00	\$ 36,000
Open cut and encasement, 10"	550	LF	\$ 35.00	\$ 19,250
Gate valve and box, 04"	12	EA	\$ 370.00	\$ 4,442
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	12	EA	\$ 750.00	\$ 9,004
Metal detectable tape	60,025	LF	\$ 0.15	\$ 9,004
Subtotal				\$ 1,709,374
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205
Subtotal of Component Costs				\$ 1,763,579
Contingency	20%		\$	352,716
Design & Constr Management	25%		\$	440,895
TOTAL CAPITAL COSTS				\$ 2,557,190

Table G.44

Angleton to each PWS

Alternative Name *Purchase Water from Angleton to Stoneridge*
Alternative Number *SR*

Distance from Alternative to PWS (along pipe)	11.1 miles
Total PWS annual water usage	3.132 MG
Treated water purchase cost	\$ 1.60 per 1,000 gals
Number of Pump Stations Needed	1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	4	n/a	n/a	n/a
Number of Crossings, open cut	15	n/a	n/a	n/a
PVC water line, Class 200, 04"	58,825	LF	\$ 27.00	\$ 1,588,275
Bore and encasement, 10"	800	LF	\$ 60.00	\$ 48,000
Open cut and encasement, 10"	750	LF	\$ 35.00	\$ 26,250
Gate valve and box, 04"	12	EA	\$ 370.00	\$ 4,353
Air valve	11	EA	\$ 1,000.00	\$ 11,000
Flush valve	12	EA	\$ 750.00	\$ 8,824
Metal detectable tape	58,825	LF	\$ 0.15	\$ 8,824
Subtotal				\$ 1,695,526
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205
Subtotal of Component Costs				\$ 1,749,731
Contingency	20%		\$	349,946
Design & Constr Management	25%		\$	437,433
TOTAL CAPITAL COSTS				\$ 2,537,109

Table G.45

Angleton to each PWS

Alternative Name *Purchase Water from Ang to Sandy Meadow*
Alternative Number *SM*

Distance from Alternative to PWS (along pipe)	14.2 miles
Total PWS annual water usage	5.840 MG
Treated water purchase cost	\$ 1.60 per 1,000 gals
Number of Pump Stations Needed	1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	7	n/a	n/a	n/a
Number of Crossings, open cut	15	n/a	n/a	n/a
PVC water line, Class 200, 04"	75,087	LF	\$ 27.00	\$ 2,027,349
Bore and encasement, 10"	1,400	LF	\$ 60.00	\$ 84,000
Open cut and encasement, 10"	750	LF	\$ 35.00	\$ 26,250
Gate valve and box, 04"	15	EA	\$ 370.00	\$ 5,556
Air valve	14	EA	\$ 1,000.00	\$ 14,000
Flush valve	15	EA	\$ 750.00	\$ 11,263
Metal detectable tape	75,087	LF	\$ 0.15	\$ 11,263
Subtotal				\$ 2,179,682
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Subtotal				\$ 54,205
Subtotal of Component Costs				\$ 2,233,887
Contingency	20%		\$	446,777
Design & Constr Management	25%		\$	558,472
TOTAL CAPITAL COSTS				\$ 3,239,135

Table G.46

Angleton to each PWS

Alternative Name *Purchase Water from Ang to Roasharon Road*
Alternative Number *RR*

Distance from Alternative to PWS (along pipe)	14.6 miles
Total PWS annual water usage	5.475 MG
Treated water purchase cost	\$ 1.60 per 1,000 gals
Number of Pump Stations Needed	1

Capital Costs

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	9	n/a	n/a	n/a
Number of Crossings, open cut	17	n/a	n/a	n/a
PVC water line, Class 200, 04"	77,073	LF	\$ 27.00	\$ 2,080,971
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	850	LF	\$ 35.00	\$ 29,750
Gate valve and box, 04"	15	EA	\$ 370.00	\$ 5,703
Air valve	15	EA	\$ 1,000.00	\$ 15,000
Flush valve	15	EA	\$ 750.00	\$ 11,561
Metal detectable tape	77,073	LF	\$ 0.15	\$ 11,561
	Subtotal			\$ 2,262,546
<i>Pump Station(s) Installation</i>				
Pump	1	EA	\$ 7,500	\$ 7,500
Pump Station Piping, 04"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 04"	4	EA	\$ 405	\$ 1,620
Check valve, 04"	2	EA	\$ 595	\$ 1,190
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
	Subtotal			\$ 54,205
	Subtotal of Component Costs			\$ 2,316,751
Contingency	20%		\$	463,350
Design & Constr Management	25%		\$	579,188
	TOTAL CAPITAL COSTS			\$ 3,359,289