

# DRAFT FEASIBILITY REPORT FEASIBILITY ANALYSIS OF WATER SUPPLY FOR SMALL PUBLIC WATER SYSTEMS

PARADISE ACRES WATER SYSTEM

PWS ID# 1870076, CCN# 10147

*Prepared for:*

THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



*Prepared by:*

THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC GEOLOGY

AND

**PARSONS**

*Preparation of this report was financed by the Texas Commission on Environmental Quality through the Drinking Water State Revolving Fund Small Systems Assistance Program*

AUGUST 2006

**DRAFT FEASIBILITY REPORT**

**FEASIBILITY ANALYSIS OF WATER SUPPLY  
FOR SMALL PUBLIC WATER SYSTEMS**

**VISTA VERDE  
PWS ID# 1700694, CCN# 13034**

*Prepared for:*

**THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY**

*Prepared by:*

**THE UNIVERSITY OF TEXAS BUREAU OF ECONOMIC  
GEOLOGY**

**AND**

**PARSONS**

*Preparation of this report was financed by the Texas Commission on Environmental Quality  
through the Drinking Water State Revolving Fund Small Systems Assistance Program*

THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF INTERIM REVIEW UNDER THE  
AUTHORITY OF ERIC J. DAWSON, P.E. 79564 ON AUGUST 31, 2006. IT IS NOT TO BE USED FOR  
CONSTRUCTION, BIDDING, OR PERMIT PURPOSES.

**AUGUST 2006**

## EXECUTIVE SUMMARY

### INTRODUCTION

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Infrastructure and Technology Group Inc. (Parsons), was contracted by the Texas Commission on Environmental Quality (TCEQ) to conduct a study to assist with identifying and analyzing alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

The overall goal of this project was to promote compliance with Texas water quality standards using sound engineering and financial methods and data for PWSs that had recently recorded sample results exceeding maximum contaminant levels (MCL). The primary objectives of this project were to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS for future implementation.

This feasibility report provides an evaluation of water supply alternatives for the Vista Verde Water Systems Inc., PWS ID# 1700694, Certificate of Convenience and Necessity (CCN) # 13034, located in Montgomery County (hereinafter referred to as the Vista Verde PWS). Vista Verde is the water system for Marvin Gardens, a 166-lot rural subdivision located outside of Conroe, Texas. It consists of one 340-foot well, two 900-gallon hydro-pneumatic tanks, a treatment shed, and a distribution system. Recent sample results from the Vista Verde water system exceeded the MCL for combined radium-226 and -228 of 5 picoCuries per liter (pCi/L) and the MCL for gross alpha particle activity of 15 pCi/L (USEPA 2005; TCEQ 2004).

Basic system information for the Vista Verde PWS is shown in Table ES.1.

**Table ES.1**  
**Vista Verde PWS**  
**Basic System Information**

Parameter	Result
Population served	66 current, 432 at full build out
Connections	22 current, 144 at full build out
Average daily flow rate	0.056 million gallons per day
Peak demand flow rate	0.2 gallons per minute estimated
Water system peak capacity	0.047 mgd
Typical radium-226 range	5.8 – 7.5 pCi/L
Typical gross alpha particle range	34 pCi/L to 38 pCi/L

## STUDY METHODS

The methods used for this study were based on a pilot study performed in 2004 and 2005 by TCEQ, BEG, and Parsons. Methods for identifying and analyzing compliance options were developed in the pilot study (a decision tree approach).

The process for developing the feasibility study used the following general steps:

1. Gather data from the TCEQ and Texas Water Development Board databases, from TCEQ files, and from information maintained by the PWS;
2. Conduct financial, managerial, and technical (FMT) evaluations of the PWS;
3. Perform a geologic and hydrogeologic assessment of the study area;
4. Develop treatment and non-treatment compliance alternatives which, in general, consist of the following possible options:
  - a. Connecting to neighboring PWSs via new pipeline or by pumping water from a newly installed well or an available surface water supply within the jurisdiction of the neighboring PWS;
  - b. Installing new wells within the vicinity of the PWS into other aquifers with confirmed water quality standards meeting the MCLs;
  - c. Installing a new intake system within the vicinity of the PWS to obtain water from a surface water supply with confirmed water quality standards meeting the MCLs;
  - d. Treating the existing non-compliant water supply by various methods depending on the type of contaminant; and
  - e. Delivering potable water by way of a bottled water program or a treated water dispenser as an interim measure only.
5. Assess each potential alternatives with respect to economic and non-economic criteria;
6. Prepare a feasibility report and present the results to the PWS.

This basic approach is summarized in Figure ES-1.

## HYDROGEOLOGICAL ANALYSIS

The Vista Verde PWS obtains groundwater from the Evangeline subunit of the Gulf Coast Aquifer. Radium and gross alpha particles are not commonly found in area wells at concentrations greater than the MCL. The Evangeline and Jasper subunit aquifers are known to be very productive in the area. Other nearby PWS well screens are generally set either shallower or deeper than the well screen of the Vista Verde PWS. Historic aquifer elevation maps indicate that the Vista Verde well screen is set in between the two subunit aquifers. It is likely there could be good quality groundwater nearby. However,

1 the variability of radium and gross alpha particle concentrations makes it difficult to  
2 determine where wells could be located to produce acceptable water. It may be possible  
3 to do down-hole testing on the Vista Verde well to determine the source of the  
4 contaminants. If the contaminants derive primarily from a single part of the formation,  
5 that part could be excluded by modifying the existing well, or avoided altogether by  
6 completing a new well.

## 7 **COMPLIANCE ALTERNATIVES**

8 The Vista Verde PWS is owned by Karl Painter and is operated by a certified  
9 operator who also operates two other water systems in the region. Overall, the system  
10 had an inadequate level of FMT capacity due to several factors. The system does have  
11 positive aspects, including an enforced shut-off policy for delinquent bills, and efforts  
12 made to improve the distribution system. Areas of concern for the system included  
13 inadequate financial accounting for the water system, lack of a reserve account, lack of  
14 long-term planning, an unclear rate schedule, inadequate production capacity, lack of  
15 technical capability, and operator safety issues.

16 There are several PWSs within a few miles of Vista Verde PWS, and most of the  
17 nearby systems have good quality water. In general, feasibility alternatives were  
18 developed based on obtaining water from the nearest PWSs, either by directly purchasing  
19 water, or by expanding the existing well field. Another alternative considered is  
20 modifying the existing well or installing a new well at Vista Verde. There is a minimum  
21 of surface water available in the area.


22 A number of centralized treatment alternatives for radium and alpha particle removal  
23 have been developed and were considered for this report; for example, ion exchange (IX),  
24 WRT Z-88 adsorption, and  $\text{KMnO}_4$  greensand filtration. Point-of-use (POU) and point-  
25 of-entry (POE) treatment alternatives were also considered. Temporary solutions such as  
26 providing bottled water or providing a centralized dispenser for treated or trucked-in  
27 water, were also considered as alternatives.

28 Developing a new well at or near to Vista Verde is likely to be an attractive solution  
29 if compliant groundwater can be found, and would likely to be one of the lower cost  
30 alternatives since the PWS already possesses the technical and managerial expertise  
31 needed to implement this option. The cost of new well alternatives quickly increases  
32 with pipeline length, making proximity of the alternate source a key concern.  
33 Additionally, there are a number of large water suppliers within a short distance from  
34 Vista Verde that would be willing to sell water. Purchasing water or joining one of the  
35 larger water systems may also be attractive options for the Vista Verde PWS. Installing a  
36 new compliant well or obtaining water from a neighboring compliant PWS have the  
37 advantage of providing compliant water to all taps in the system.

38

1  
2

**Figure ES-1**  
**Summary of Project Methods**



1 Central treatment can be cost-competitive with the alternative of new nearby wells, but  
2 would require significant institutional changes to manage and operate. Similar to obtaining an  
3 alternate compliant water source, central treatment would provide compliant water to all water  
4 taps.

5 POU treatment can be cost competitive, but does not supply compliant water to all taps.  
6 Additionally, significant efforts would be required for maintenance and monitoring of the POU  
7 treatment units.

8 Providing compliant water through a central dispenser is significantly less expensive than  
9 providing bottled water to 100 percent of the population, but a significant effort is required for  
10 clients to fill their containers at the central dispenser.

## 11 **FINANCIAL ANALYSIS**

12 Financial analysis of the Vista Verde PWS indicated that current water rates are funding  
13 operations, and a rate increase of would not be necessary to meet operating expenses. The  
14 current average water bill of \$432 represents approximately 1.2 percent of the median  
15 household income (MHI) for the area. Table ES.2 provides a summary of the financial impact  
16 of implementing selected compliance alternatives, including the rate increase necessary to meet  
17 current operating expenses. The alternatives were selected to highlight results for the lowest  
18 cost alternatives from each different type or category.

19 Some of the compliance alternatives offer potential for shared or regional solutions. A  
20 group of PWSs could work together to implement alternatives for developing a new  
21 groundwater source or expanding an existing source, obtaining compliant water from a large  
22 regional provider, or for central treatment. Sharing the cost for implementation of these  
23 alternatives could reduce the cost on a per user basis. Additionally, merging PWSs or  
24 management of several PWSs by a single entity offers the potential for reduction in  
25 administrative costs.

**Table ES.2**  
**Selected Financial Analysis Results**

Alternative	Funding Option	Average Annual Water Bill	Percent of MHI
Current	NA	\$432	1.2
New well at Vista Verde	100% Grant	\$387	1.1
	Loan/Bond	\$510	1.4
New well at Stanley Lake MUD	100% Grant	\$499	1.4
	Loan/Bond	\$1,082	2.9
Central treatment - IX	100% Grant	\$473	1.3
	Loan/Bond	\$648	1.8
Point-of-use	100% Grant	\$903	2.5
	Loan/Bond	\$957	2.6



## TABLE OF CONTENTS

<b>EXECUTIVE SUMMARY .....</b>	<b>ES-1</b>
<b>LIST OF TABLES.....</b>	<b>IV</b>
<b>LIST OF FIGURES.....</b>	<b>IV</b>
<b>ACRONYMS AND ABBREVIATIONS .....</b>	<b>VI</b>
<b>SECTION 1 INTRODUCTION .....</b>	<b>1-1</b>
1.1 Public Health and Compliance with MCLs.....	1-1
1.2 Method.....	1-2
1.3 Regulatory Perspective.....	1-5
1.4 Abatement Options.....	1-5
1.4.1 Existing Public Water Supply Systems .....	1-5
1.4.2 Potential for New Groundwater Sources.....	1-7
1.4.3 Potential for Surface Water Sources.....	1-8
1.4.4 Identification of Treatment Technologies for Radionuclides.....	1-9
1.4.5 Description of Treatment Technologies .....	1-10
1.4.6 Point-of-Entry and Point-of-Use Treatment Systems.....	1-16
1.4.7 Water Delivery or Central Drinking Water Dispensers .....	1-17
<b>SECTION 2 EVALUATION METHODS.....</b>	<b>2-1</b>
2.1 Decision Tree.....	2-1
2.2 Data Sources and Data Collection.....	2-1
2.2.1 Data Search.....	2-1
2.2.2 PWS Interviews .....	2-7
2.3 Alternative Development and Analysis.....	2-9
2.3.1 Existing PWS.....	2-10
2.3.2 New Groundwater Source .....	2-10
2.3.3 New Surface Water Source .....	2-11
2.3.4 Treatment.....	2-11
2.4 Cost of Service and Funding Analysis .....	2-12
2.4.1 Financial Feasibility .....	2-12
2.4.2 Median Household Income.....	2-12
2.4.3 Annual Average Water Bill.....	2-12
2.4.4 Financial Plan Development.....	2-13
2.4.5 Financial Plan Results .....	2-14
<b>SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS .....</b>	<b>3-1</b>

1	3.1	Gross Alpha and Radium in the Gulf Coast Aquifer.....	3-1
2	3.1.1	Gross Alpha and Radium Trends .....	3-3
3	3.1.2	Uranium in the Gulf Coast Aquifer .....	3-6
4	3.2	Hydrogeology of Polk and Montgomery Counties .....	3-9
5	3.3	Detailed Assessment for Vista Verde PWS – PWS 1700694 .....	3-10
6	3.3.1	Summary of Alternative Groundwater Sources for the Vista	
7		Verde PWS (1700694) .....	3-14
8	<b>SECTION 4</b>	<b>ANALYSIS OF THE VISTA VERDE PWS .....</b>	<b>4-1</b>
9	4.1	Description of Existing System .....	4-1
10	4.1.1.	Existing System .....	4-1
11	4.1.2	Capacity Assessment for the Vista Verde .....	4-3
12	4.2	Alternative Water Source Development.....	4-8
13	4.2.1	Identification of Alternative Existing Public Water Supply Sources.....	4-8
14	4.2.2	Potential for New Groundwater Sources .....	4-12
15	4.2.3	Potential for New Surface Water Sources .....	4-13
16	4.2.4	Alternative Water Source Options for Detailed Consideration.....	4-14
17	4.3	Treatment Options .....	4-15
18	4.3.1	Centralized Treatment Systems .....	4-15
19	4.3.2	Point-of-Use Systems .....	4-15
20	4.3.3	Point-of-Entry Systems .....	4-15
21	4.4	Bottled Water.....	4-15
22	4.5	Alternative Development and Analysis.....	4-16
23	4.5.1	Alternative VV-1: New Well at the Current Vista Verde Location .....	4-16
24	4.5.2	Alternative VV-2: Purchase Water from Montgomery County	
25		Utility District 3.....	4-16
26	4.5.3	Alternative VV-3: New Well at Water from Stanley Lake	
27		Municipal Utility District .....	4-17
28	4.5.4	Alternative VV-4: Purchase Water from Montgomery County	
29		Utility District 4.....	4-18
30	4.5.5	Alternative VV-5: Purchase Water from Montgomery County	
31		Utility District 9.....	4-19
32	4.5.6	Alternative VV-6: Purchase Water from Montgomery County	
33		Utility District 8.....	4-20
34	4.5.7	Alternative VV-7: New Well at 5 miles .....	4-21
35	4.5.8	Alternative VV-8: New Well at 1 mile.....	4-21
36	4.5.9	Alternative VV-9: Central IX Treatment .....	4-22

1	4.5.10	Alternative VV-10: WRT Z-88 Treatment.....	4-23
2	4.5.11	Alternative VV-11: KMnO <sub>4</sub> -Greensand Filtration.....	4-23
3	4.5.12	Alternative VV-12: Point-of-Use Treatment.....	4-24
4	4.5.13	Alternative VV-13: Point-of-Entry Treatment .....	4-25
5	4.5.14	Alternative VV-14: Public Dispenser for Treated Drinking Water .....	4-26
6	4.5.15	Alternative VV-15: 100 Percent Bottled Water Delivery .....	4-26
7	4.5.16	Alternative VV-16: Public Dispenser for Trucked Drinking Water .....	4-27
8	4.5.17	Summary of Alternatives.....	4-28
9	4.6	Cost of Service and Funding Analysis .....	4-31
10	4.6.1	Vista Verde Financial data .....	4-31
11	4.6.2	Current Financial Condition .....	4-31
12	4.6.3	Financial Plan Results .....	4-32
13	<b>SECTION 5</b>	<b>REFERENCES .....</b>	<b>5-11</b>
14			
15	<b>APPENDICES</b>		
16	Appendix A	PWS Interview Forms	
17	Appendix B	Cost Basis	
18	Appendix C	Compliance Alternative Conceptual Cost Estimates	
19	Appendix D	Example Financial Models	
20	Appendix E	Radionuclide Chemistry	

## LIST OF TABLES

1		
2	Table ES.1	Vista Verde PWS Basic System Information ..... ES-1
3	Table ES.2	Selected Financial Analysis Results ..... ES-6
4	Table 3.1	Distribution of Gross Alpha and Radium within the Gulf Coast Aquifers (Most Recent Data for Wells in the TCEQ Database) ..... 3-5
5		
6	Table 3.2	Most Recent Gross Alpha and Radium Levels within the 5-km Buffer of the Vista Verde PWS Well and Surrounding Wells (Figures 3.8 and 3.9) ..... 3-13
7		
8	Table 3.3	History of Gross Alpha, Combined Radium, and Combined Uranium in Vista Verde and Two Nearby Wells (see Figure 3.8 for Locations) ..... 3-13
9		
10	Table 4.1	Selected PWSs within 6.5 Miles of the Vista Verde PWS ..... 4-8
11	Table 4.2	Public Water Systems Within the Vicinity of the Vista Verde PWS Selected for Further Evaluation ..... 4-9
12		
13	Table 4.3	Summary of Compliance Alternatives for Vista Verde PWS ..... 4-29
14	Table 4.4	Financial Impact on Households ..... 4-34
15	Table E.1	Uranium, Thorium, and Radium Abundance and Half-Lives ..... 2
16		

## LIST OF FIGURES

17		
18	Figure ES-1	Summary of Project Methods ..... ES-4
19	Figure 1.1	Vista Verde Location Map ..... 1-3
20	Figure 1.2	Groundwater Districts, Conservation Areas, Municipal Authorities, and Planning Groups ..... 1-4
21		
22	Figure 2.1	Decision Tree – Tree 1 Existing Facility Analysis ..... 2-2
23	Figure 2.2	Decision Tree – Tree 2 Develop Treatment Alternatives ..... 2-3
24	Figure 2.3	Decision Tree – Tree 3 Preliminary Analysis ..... 2-4
25	Figure 2.4	Decision Tree – Tree 4 Financial ..... 2-5
26	Figure 3.1	Gross Alpha in Groundwater of the Gulf Coast Aquifer (TCEQ Database, 1095 Data Points from 2001 to 2005) ..... 3-1
27		
28	Figure 3.2	Radium in Groundwater of the Gulf Coast Aquifer (TCEQ Database, Data from 1998 to 2005, and TWDB Database, Data from 1988 to 1990) ..... 3-3
29		
30	Figure 3.3	Radium-226 vs. Gross Alpha in Groundwater of the Gulf Coast Aquifer (TCEQ Database from 2001 to 2005, 434 Samples) ..... 3-4
31		
32	Figure 3.4	Radium Concentrations vs. Well Depth (434 Wells in the Chicot, Evangeline and Jasper Aquifers) ..... 3-5
33		
34	Figure 3.5	Relationship Between Radium and Chloride Concentrations (186 Wells) and Radium and Total Dissolved Solids TDS Concentrations (163 Wells) in the Chicot, Evangeline and Jasper Aquifers ..... 3-6
35		
36		

---

1	Figure 3.6 Uranium Concentrations in Groundwater of the Gulf Coast Aquifer .....	3-7
2	Figure 3.7 Relationships Between Uranium, Radium-226, and Gross Alpha in	
3	Groundwater of the Gulf Coast Aquifer (Data from the TCEQ database	
4	from 2001 to 2005, total of 55 samples).....	3-8
5	Figure 3.8 Gross Alpha (pCi/L) in the 5- and 1-km buffers of the Vista Verde	
6	PWS Wells (TCEQ Database).....	3-11
7	Figure 3.9 Combined Radium (pCi/L) in the 5- and 1-km Buffers of the Vista	
8	Verde PWS Wells (TCEQ Database) .....	3-12
9	Figure 4.1 Vista Verde .....	4-2
10	Figure 4.2 Alternative Cost Summary: Vista Verde PWS.....	4-36
11		

1

## ACRONYMS AND ABBREVIATIONS

AFY	acre-feet per year
BEG	Bureau of Economic Geology
BV	bed volume
CA	chemical analysis
CCN	Certificate of Convenience and Necessity
CFR	Code of Federal Regulations
CO	correspondence
EDR	electrodialysis reversal
ft <sup>2</sup>	square foot
GAM	Groundwater Availability Model
gpm	gallons per minute
IX	Ion exchange
MCL	Maximum contaminant level
MG	million gallons
mg/L	milligrams per Liter
mgd	million gallons per day
MHI	median household income
MnO <sub>2</sub>	Manganese dioxide
MOR	monthly operating report
mrem	millirem
MUD	municipal utility district
NMEFC	New Mexico Environmental Financial Center
NURE	National Uranium Resource Evaluation
O&M	operation and maintenance
Parsons	Parsons Infrastructure and Technology Group Inc.
pCi/L	picoCuries per liter
POE	Point-of-entry
POU	Point-of-use
PWS	public water system
RO	Reverse osmosis
SDWA	Safe Drinking Water Act
TCEQ	Texas Commission on Environmental Quality
TDS	Total dissolved solids
TSS	Total suspended solids
TWDB	Texas Water Development Board
UD	utility district
USEPA	United States Environmental Protection Agency
WAM	Water Availability Model
WRT	Water Remediation Technologies, Inc.

2

## **SECTION 1 INTRODUCTION**

The University of Texas Bureau of Economic Geology (BEG) and its subcontractor, Parsons Infrastructure and Technology Group Inc. (Parsons), were contracted by the Texas Commission on Environmental Quality (TCEQ) to assist with identifying and analyzing compliance alternatives for use by Public Water Systems (PWS) to meet and maintain Texas drinking water standards.

The overall goal of this project is to promote compliance using sound engineering and financial methods and data for PWSs that have recently had sample results that exceed maximum contaminant levels (MCL). The primary objectives of this project are to provide feasibility studies for PWSs and the TCEQ Water Supply Division that evaluate water supply compliance options, and to suggest a list of compliance alternatives that may be further investigated by the subject PWS with regard to future implementation. The feasibility studies identify a range of potential compliance alternatives, and present basic data that can be used for evaluating feasibility. The compliance alternatives addressed include a description of what would be required for implementation, conceptual cost estimates for implementation, and non-cost factors that could be used to differentiate between alternatives. The cost estimates are intended for comparing compliance alternatives, and to give a preliminary indication of potential impacts on water rates resulting from implementation.

It is anticipated the PWS will review the compliance alternatives in this report to determine if there are promising alternatives, and then select the most attractive alternative(s) for more detailed evaluation and possible subsequent implementation. This report contains a decision tree approach that guided the efforts for this study, and also contains steps to guide a PWS through the subsequent evaluation, selection, and implementation of a compliance alternative.

This feasibility report provides an evaluation of water supply compliance options for the Vista Verde Water System, PWS ID# 1700694, Certificate of Convenience and Necessity (CCN) #13034 located in Montgomery County, Texas (hereinafter referred to as the Vista Verde PWS). Recent sample results from the Vista Verde PWS exceeded the MCL for combined radium-226 and radium-228 of 5 picoCuries per liter (pCi/L) and the MCL for gross alpha particle activity at 15 pCi/L (USEPA 2005; TCEQ 2004). The location of the Vista Verde PWS, also referred to as the “study area” in this report, is shown on Figure 1.1. Various water supply and planning jurisdictions are shown on Figure 1.2. These water supply and planning jurisdictions are used in the evaluation of alternate water supplies that may be available in the area.

### **1.1 PUBLIC HEALTH AND COMPLIANCE WITH MCLS**

The goal of this project is to promote compliance for PWSs that supply drinking water containing contaminants that exceed regulatory MCLs. This project only addresses those

contaminants, and does not address any other violations that may exist for a PWS. As mentioned above, the Vista Verde PWS had recent sample results exceeding the MCL for combined radium-226 and radium-228 and gross alpha particles. In general, contaminant(s) in drinking water above the MCL(s) can have both short-term (acute) and long-term or lifetime (chronic) effects. Long-term ingestion of drinking water with radium-226 and/or radium-228 and/or gross alpha particles above the MCL may increase the risk of cancer (USEPA 2005).

## 1.2 METHOD


The method for this project follows that of the pilot study performed in 2004 and 2005 by TCEQ, BEG, and Parsons. The pilot study evaluated water supply alternatives for PWSs that supply drinking water with nitrate concentrations above U.S. Environmental Protection Agency (USEPA) and Texas drinking water standards. Three PWSs were evaluated in the pilot study to develop the methodology (*i.e.*, decision tree approach) for analyzing options for provision of compliant drinking water. This project is performed using the decision tree approach developed in the pilot study.

Other tasks of the feasibility study are as follows:

- Identifying available data sources;
- Gathering and compiling data;
- Conducting financial, managerial, and technical (FMT) evaluations of the selected PWSs;
- Performing a geologic and hydrogeologic assessment of the study area;
- Developing treatment and non-treatment compliance alternatives;
- Assessing potential alternatives with respect to economic and non-economic criteria;
- Preparing a feasibility report; and
- Suggesting refinements to the approach for future studies.


The remainder of Section 1 of this report addresses the regulatory background, and provides a summary of radium abatement options. Section 2 describes the methodology used to develop and assess compliance alternatives. The groundwater sources of radium-226 and radium-228 and gross alpha particles are addressed in Section 3. Findings for the Vista Verde PWS, along with development and evaluation of compliance alternatives, can be found in Section 4. Section 5 references the sources used in this report.






**Figure 1.1**

**Vista Verde Water System  
Location Map**





**Figure 1.2**

**Vista Verde  
Groundwater Conservation  
Districts and Planning Groups**



### **1.3 REGULATORY PERSPECTIVE**

The Utilities & Districts and Public Drinking Water Sections of the TCEQ Water Supply Division are responsible for implementing requirements of the Federal Safe Drinking Water Act (SDWA), including oversight of PWSs and water utilities. These responsibilities include:

- Monitoring public drinking water quality;
- Processing enforcement referrals for MCL violators;
- Tracking and analyzing compliance options for MCL violators;
- Providing FMT assessment and assistance to PWSs;
- Participating in the Drinking Water State Revolving Fund program to assist PWSs in achieving regulatory compliance; and
- Setting rates for privately-owned water utilities.

This project was conducted to assist in achieving these responsibilities.

### **1.4 ABATEMENT OPTIONS**

When a PWS exceeds a regulatory MCL, the PWS must take action to correct the violation. The MCL exceedances at the Vista Verde PWS involve radium-226 and 228 and alpha particle activity. The following subsections explore alternatives considered as potential options for obtain/providing compliant drinking water.

#### **1.4.1 Existing Public Water Supply Systems**

A common approach to achieving compliance is for the PWS to make arrangements with a neighboring PWS for water supply. For this arrangement to work, the PWS from which water is being purchased (supplier PWS) must have water in sufficient quantity and quality, the political will must exist, and it must be economically feasible.

##### **1.4.1.1 Quantity**

For purposes of this report, quantity refers to water volume, flowrate, and pressure. Before approaching a potential supplier PWS, the non-compliant PWS should determine its water demand on the basis of average day and maximum day. Peak instantaneous demands can be met through proper sizing of storage facilities. Further, the potential for obtaining the appropriate quantity of water to blend to achieve compliance should be considered. The concept of blending involves combining water with low levels of contaminants with non-compliant water in sufficient quantity so the resulting blended water is compliant. The exact blend ratio would depend on the quality of the water a potential supplier PWS can provide, and would likely vary over time. If high quality water is purchased, produced or otherwise obtained, blending can reduce the amount of high quality water required. Implementation of blending will require a control system to ensure the blended water is compliant.

If the supplier PWS does not have sufficient quantity, the non-compliant community could pay for the facilities necessary to increase the quantity to the extent necessary to supply the needs of the non-compliant PWS. Potential improvements might include, but are not limited to:

- Additional wells;
- Developing a new surface water supply,;
- Additional or larger-diameter piping;
- Increasing water treatment plant capacity;
- Additional storage tank volume;
- Reduction of system losses;
- Higher-pressure pumps; or
- Upsized, or additional, disinfection equipment.

In addition to the necessary improvements, a transmission pipeline would need to be constructed to tie the two PWSs together. The pipeline must tie-in at a point in the supplier PWS where all the upstream pipes and appurtenances are of sufficient capacity to handle the new demand. In the non-compliant PWS, the pipeline must tie in at a point where no down stream bottlenecks are present. If blending is the selected method of operation, the tie-in point must be at the proper point of the existing non-compliant PWS to ensure that all water in the system is blended to achieve regulatory compliance.

#### **1.4.1.2 Quality**

If a potential supplier PWS obtains its water from the same aquifer (or same portion of the aquifer) as the non-compliant PWS, the quality of water may not be significantly better. However, water quality can vary significantly due to well location, even within the same aquifer. If localized areas with good water quality cannot be identified, the non-compliant PWS would need to find a potential supplier PWS that obtains its water from a different aquifer or from a surface water source. Additionally, a potential supplier PWS may treat non-compliant raw water to an acceptable level.

Surface water sources may offer a potential higher-quality source. Since there are significant treatment requirements, utilization of surface water for drinking water is typically most feasible for larger local or regional authorities or other entities that may provide water to several PWSs. Where PWSs that obtain surface water are neighbors, the non-compliant PWS may need to deal with those systems as well as with the water authorities that supply the surface water.

## 1.4.2 Potential for New Groundwater Sources

### 1.4.2.1 Existing Non-Public Supply Wells

Often there are wells not associated with PWSs located in the vicinity of the non-compliant PWS. The current use of these wells may be for irrigation, industrial purposes, domestic supply, stock watering, and other purposes. The process for investigating existing wells is as follows:

- Use existing data sources (see below) to identify wells in the areas that have satisfactory quality. For the Vista Verde PWS, the following standards could be used in a rough screening to identify compliant groundwater in surrounding systems:
  - Radium (total radium for radium-226 and radium-228) less than 4 pCi/L (below the MCL of 5 pCi/L); and
  - Gross alpha particle activity less than 12 pCi/L (below the MCL of 15 pCi/L).
- Review the recorded well information to eliminate those wells that appear to be unsuitable for the application. Often, the “Remarks” column in the Texas Water Development Board (TWDB) hard-copy database provides helpful information. Wells eliminated from consideration generally include domestic and stock wells, dug wells, test holes, observation wells, seeps and springs, destroyed wells, wells used by other communities, *etc.*
- Identify wells of sufficient size that have been used for industrial or irrigation purposes. Often the TWDB database will include well yields, which may indicate the likelihood that a particular well is a satisfactory source.
- At this point in the process, the local groundwater control district (if one exists) should be contacted to obtain information about pumping restrictions. Also, preliminary cost estimates should be made to establish the feasibility of pursuing further well development options.
- If particular wells appear to be acceptable, the owner(s) should be contacted to ascertain their willingness to work with the PWS. Once the owner agrees to participate in the program, questions should be asked about the wells. Many owners have more than one well, and would probably be the best source of information regarding the latest test dates, who tested the water, flowrates, and other well characteristics.
- After collecting as much information as possible from cooperative owners, the PWS would then narrow the selection of wells and sample and analyze them for quality. Wells with good quality would then be potential candidates for test pumping. In some cases, a particular well may need to be refurbished before test pumping. Information obtained from test pumping would then be used in

combination with information about the general characteristics of the aquifer to determine whether a well at this location would be suitable as a supply source.

- It is recommended that new wells be installed instead of using existing wells to ensure that well characteristics are known and the well meets construction standards.
- Permit(s) would then be obtained from the groundwater control district or other regulatory authority, and an agreement with the owner (purchase or lease, access easements, *etc.*) would then be negotiated.

#### 1.4.2.2 Develop New Wells

If no existing wells are available for development, the PWS or group of PWSs has an option of developing new wells. Records of existing wells, along with other hydrogeologic information and modern geophysical techniques, should be used to identify potential locations for new wells. In some areas, the TWDB's Groundwater Availability Model (GAM) may be applied to indicate potential sources. Once a general area has been identified, land owners and regulatory agencies should be contacted to determine an exact location for a new well or well field. Pump tests and water quality tests would be required to determine if a new well will produce an adequate quantity of good quality water. Permits from the local groundwater control district or other regulatory authority could also be required for a new well.

#### 1.4.3 Potential for Surface Water Sources

Water rights law dominates the acquisition of water from surface water sources. For a PWS, 100 percent availability of water is required, except where a back-up source is available. For PWSs with an existing water source, although it may be non-compliant because of elevated concentrations of one or more parameters, water rights may not need to be 100 percent available.

##### 1.4.3.1 Existing Surface Water Sources

"Existing surface water sources" refers to water authorities and cities that obtain water from surface water sources. The process of obtaining water from such a source is generally less time consuming and less costly than the process of developing a new source; therefore, it should be a primary course of investigation. An existing source would be limited by its water rights, the safe yield of a reservoir or river, or by its water treatment capability. The source must be able to meet the current demand and honor contracts with communities it currently supplies. In many cases, the contract amounts reflect projected future water demand based on population or industrial growth.

A non-compliant PWS would look for a source with sufficient spare capacity. Where no such capacity exists, the non-compliant PWS could offer to fund the improvements necessary to obtain the capacity. This approach would work only where the safe yield could be increased (perhaps by enlarging a reservoir) or where treatment capacity could be increased. In some instances water rights, where they are available, could possibly be purchased.

In addition to securing the water supply from an existing source, the non-compliant PWS would need to arrange for transmission of the water to the PWS. In some cases, that could require negotiations with, contracts with, and payments to an intermediate PWS (an intermediate PWS is one where the infrastructure is used to transmit water from a “supplier” PWS to a “supplied” PWS, but does not provide any additional treatment to the supplied water). The non-compliant PWS could be faced with having to fund improvements to the intermediate PWS in addition to constructing its own necessary transmission facilities.

#### 1.4.3.2 New Surface Water Sources

Communication with the TCEQ and relevant planning groups from the beginning is essential in the process of obtaining a new surface water source. Preliminary assessment of the potential for acquiring new rights may be based on surface water availability maps located on the TWDB website. Where water rights appear to be available, the following activities need to occur:

- Discussions with TCEQ to indicate the likelihood of obtaining those rights. The TCEQ may use the Water Availability Model (WAM) to assist in the determination.
- Discussions with land owners to indicate potential treatment plant locations.
- Coordination with U.S. Army Corps of Engineers and local river authorities.
- Preliminary engineering design to determine the feasibility, costs, and environmental issues of a new treatment plant.

Should these discussions indicate that a new surface water source is the best option, the community would proceed with more intensive planning (initially obtaining funding), permitting, land acquisition, and detailed designs.

#### 1.4.4 Identification of Treatment Technologies for Radionuclides

Various treatment technologies were also investigated as compliance alternatives for treatment of radium to regulatory level (*i.e.*, MCL). The removal of radium would also remove gross alpha activity because the radium appears to be responsible for most of the gross alpha activity of the groundwater. Radium-226 and radium-228 are cations ( $Ra^{2+}$ ) dissolved in water and are not easily removed by particle filtration. A 2002 USEPA document (*Radionuclides in Drinking Water: A Small Entity Compliance Guide*, EPA 815-R-02-001) lists a number of small system compliance technologies that can remove radium (combined radium-226 and radium-228) from water. These technologies include ion exchange (IX), reverse osmosis (RO), electrodialysis/ electrodialysis reversal (ED/EDR), lime softening, greensand filtration, re-formed hydrous manganese oxide filtration ( $KMnO_4$  filtration), and co-precipitation with barium sulfate. A relatively new process using the WRT Z-88<sup>TM</sup> media that is specific for radium adsorption has been demonstrated to be an effective radium technology. Lime softening and co-precipitation with barium sulfate are technologies that are relatively complex and require chemistry skills that are not practical for small systems with limited resources and hence, are not evaluated further.

## 1.4.5 Description of Treatment Technologies

The application radium removal treatment technologies include IX, WRT-Z88 media adsorption, RO, ED/EDR, and  $\text{KMnO}_4$ -greensand filtration. A description of these technologies follows.

### 1.4.5.1 Ion Exchange

Process – In solution, salts separate into positively-charged cations and negatively-charged anions. Ion exchange (IX) is a reversible chemical process in which ions from an insoluble, permanent, solid resin bed are exchanged for ions in the water. The process relies on the fact that certain ions are preferentially adsorbed on the ion exchange resin. Operation begins with a fully charged cation or anion bed, having enough positively or negatively charged ions to carry out the cation or anion exchange. Usually a polymeric resin bed is composed of millions of spherical beads about the size of medium sand grains. As water passes the resin bed, the charged ions are released into the water, being substituted or replaced with the contaminants in the water (ion exchange). When the resin becomes exhausted of positively or negatively charged ions, the bed must be regenerated by passing a strong, sodium chloride, solution over the resin, displacing the contaminants ions with sodium ions for cation exchange and chloride ion for anion exchange. Many different types of resins can be used to reduce dissolved contaminant concentrations. The IX treatment train for groundwater typically includes cation or anion resins beds with a regeneration system, chlorine disinfection, and clear well storage. Treatment trains for surface water may also include raw water pumps, debris screens, and filters for pre-treatment. Additional treatment or management of the concentrate and the removed solids will be necessary prior to disposal, especially for radium removal resins which have elevated radioactivity.

For radium removal, a strong acid cation exchange resin in the sodium form can remove 99 percent of the radium. The strong acid resin has less capacity for radium on water with high hardness, and has the following adsorption preference:  $\text{Ra}^{2+} > \text{Ba}^{2+} > \text{Ca}^{2+} > \text{Mg}^{2+} > \text{Na}^+$ . Because of the selectivity, radium and barium are much more difficult to remove from the resin during regeneration than calcium and magnesium. Economical regeneration removes most of the hardness ions, but radium and barium build up on the resin after repeated cycles to the point where equilibrium is reached, and then radium and barium will begin to break through shortly after hardness. Regeneration of the sodium forms strong acid resin for water with 200 mg/L of hardness, and with application of 6.5-lb  $\text{NaCl}/\text{ft}^3$  resin, would produce 2.4 bed volumes (BV) of 16,400 mg/L TDS brine per 100 BV of product water (2.4%). The radium concentration in the regeneration waste would be approximately 40 times the influent radium concentration in groundwater.

Pretreatment – Pretreatment guidelines are available on accepted limits for pH, organics, turbidity, and other raw water characteristics. Pretreatment may be required to reduce excessive amounts of TSS, iron, and manganese, which could plug the resin bed, and typically includes media or carbon filtration.



Maintenance – The IX resin requires regular on-site regeneration, the frequency of which depends on raw water characteristics (especially hardness), the contaminant concentration, and the size and number of IX vessels. Many systems have undersized the IX vessels only to realize higher than necessary operating costs. Preparation of the sodium chloride solution is required. If used, filter replacement and backwashing will be required.

Waste Disposal – Approval from local authorities is usually required for disposal of concentrate from the regeneration cycle (highly concentrated salt solution with radioactivity); occasional solids wastes (in the form of broken resin beads) which are backwashed during regeneration; and if used, spent filters and backwash wastewater.

#### **Advantages (IX)**

- Well-established process for radium removal.
- Fully automated and highly reliable process.
- Suitable for small and large installations.

#### **Disadvantages (IX)**

- Requires salt storage; regular regeneration.
- Concentrate disposal.
- Resins are sensitive to the presence of competing ions such as calcium and magnesium.

In considering application of IX for inorganic, it is important to understand what the effect of competing ions will be, and to what extent the brine can be recycled. Conventional IX cationic resin removes calcium and magnesium in addition to radium and, thus, the capacity for radium removal and frequency of regeneration depend on the hardness of the water to be treated. Spent regenerant is produced during IX bed regeneration, and may have concentrations of the sorbed contaminants that will be expensive to treat and/or dispose because of hazardous waste regulations.

#### **1.4.5.2 WRT Z-88 Media**

Process – The WRT Z-88 radium treatment process is a proprietary process using a radium specific adsorption resin or zeolite supplied by Water Remediation Technologies, Inc. (WRT). The Z-88 process is similar to IX except that no regeneration of the resin is conducted and the resin is disposed upon exhaustion. The Z-88 does not remove calcium and magnesium and can last for 2-4 years (according to WRT) before replacement is necessary. The process is operated in an upflow, fluidized mode with a surface loading rate of 10.5 gpm/ft<sup>2</sup>. Pilot testing of this technology for radium removal has been conducted successfully in many locations, including the State of Texas. Seven full-scale systems with capacities of 750 to 1,200 gpm have been constructed in the Village of Oswego, Illinois since July 2005. The treatment equipment is owned by WRT, and the ownership of spent media would be transferred to an approved

disposal site. The customer pays WRT based on an agreed upon treated water unit cost (e.g., \$3.00/kgal for small systems).

Pretreatment – Pretreatment may be required to reduce excess amounts of total suspended solids (TSS), iron, and manganese, which could plug the resin bed, and typically includes media or carbon filtration. No chemical addition is required for radium removal.

Maintenance – Maintenance is relatively low for this technology as no regeneration or chemical handling is required. Periodic water quality monitoring and inspection of mechanical equipment are required.

Waste Disposal – The Z-88 media would be disposed in an approved low level radioactive waste landfill by WRT once every 2-4 years. No liquid waste is generated for this process. However, if pretreatment filters are used, then spent filters and backwash wastewater disposal is required.

#### **Advantages (Z-88)**

- Simple and fully automated process.
- No liquid waste disposal.
- No chemical handling, storage, or feed systems.
- No change in water quality except radium reduction.
- Low capital cost as WRT owns the equipment.

#### **Disadvantages (Z-88)**

- Relatively new technology.
- Proprietary technology without direct competition.
- Long term contract with WRT required.

From the point of view of a small utilities, the Z-88 process is a desirable technology for radium removal because the operation and maintenance (O&M) effort is minimal and no regular liquid waste is generated. However, this technology is very new and without long-term full-scale operating experience. But since the equipment is owned by WRT and the performance is guaranteed by WRT the risk to the utilities is minimized.

### **1.4.5.3 Reverse Osmosis**

Process – RO is a pressure-driven membrane separation process capable of removing dissolved solutes from water by means of particle size and electrical charge. The raw water is typically called feed; the product water is called permeate, and the concentrated reject is called concentrate. Common RO membrane materials include asymmetric cellulose acetate and polyamide thin film composite. Common RO membrane configurations include spiral wound and hollow fine fiber but most RO systems to date are of the spiral wound type. A typical RO

installation includes a high pressure feed pump with chemical feed, parallel first and second stage membrane elements in pressure vessels, and valving and piping for feed, permeate, and concentrate streams. Factors influencing membrane selection are cost, recovery, rejection, raw water characteristics, and pretreatment. Factors influencing performance are raw water characteristics, pressure, temperature, and regular monitoring and maintenance. RO is capable of achieving over 95 percent removal of radium. The treatment process is relatively insensitive to pH. Water recovery is 60-80 percent, depending on the raw water characteristics. The concentrate volume for disposal can be significant.

Pretreatment – RO requires careful review of raw water characteristics and pretreatment needs to prevent membranes from fouling, scaling or other membrane degradation. Removal or sequestering of suspended and colloidal solids is necessary to prevent fouling, and removal of sparingly soluble constituents such as calcium, magnesium, silica, sulfate, barium, etc. may be required to prevent scaling. Pretreatment can include media filters, ion exchange softening, acid and antiscalant feed, activated carbon or bisulfite feed to dechlorinate, and cartridge filters to remove any remaining suspended solids to protect membranes from upsets.

Maintenance – Monitoring rejection percentage is required to ensure contaminant removal below MCL. Regular monitoring of membrane performance is necessary to determine fouling, scaling, or other membrane degradation. Acidic or caustic solutions are regularly flushed through the system at high volume/low pressure with a cleaning agent to remove foulants and scalants. Frequency of membrane replacement is dependent on raw water characteristics, pretreatment, and maintenance.

Waste Disposal – Pretreatment waste streams, concentrate flows, spent filters and membrane elements all required approved disposal methods. The disposal of the significant volume of the concentrate stream is a problem for many utilities.

#### **Advantages (RO)**

- Can remove radium effectively.
- Can remove other undesirable dissolved constituents.

#### **Disadvantages (RO)**

- Relatively expensive to install and operate.
- Needs sophisticated monitoring systems.
- Needs to handle multiple chemicals.
- Waste of water because of the significant concentrate flows.
- Reject requires disposal

RO is an expensive alternative to remove radium and is usually not economically competitive with other processes unless nitrate and/or TDS removal is also required. The

biggest drawback for using RO to remove radium is the waste of water through concentrate disposal which is also difficult or expensive because of the volume involved.

#### 1.4.5.4 Electrodialysis/Electrodialysis Reversal

Process – Electrodialysis (ED) is an electrochemical separation process in which ions migrate through ion-selective semi-permeable membranes as a result of their attraction to two electrically charged electrodes. The driving force for ion transfer is direct electric current. ED is different from RO in that it removes only dissolved inorganics but not particulates, organics, and silica. Electrodialysis reversal (EDR) is an improved form of ED in which the polarity of the direct current is changed approximately every 15 minutes. The change of polarity helps reduce the formation of scale and fouling films resulting in a higher water recovery. EDR has been the dominant form of the ED system used for the past 25-30 years. A typical EDR system includes a membrane stack with a number of cell pairs, each consisting of a cation transfer membrane, a demineralized water flow spacer, an anion transfer membrane, and a concentrate flow spacer. Electrode compartments are at opposite ends of the stack. The influent feed water (chemically treated to prevent precipitation) and concentrate reject flow in parallel across the membranes and through the demineralized water and concentrate flow spacers, respectively. The electrodes are continually flushed to reduce fouling or scaling. Careful consideration of flush feed water is required. Typically, the membranes are cation or anion exchange resins cast in sheet form; the spacers are high density polyethylene; and the electrodes are inert metal. EDR stacks are tank-contained and often staged. Membrane selection is based on review of raw water characteristics. A single-stage EDR system usually removes 40-50 percent of the dissolved salts including radium, and multiple stages may be required to meet the MCL if radium concentration is high. The conventional EDR treatment train typically includes EDR membranes, chlorine disinfection, and clearwell storage.

Pretreatment – Guidelines are available on acceptable limits on pH, organics, turbidity, and other raw water characteristics. EDR typically requires acid and antiscalant feed to prevent scaling and a cartridge filter for prefiltration. Treatment of surface water may also require pretreatment steps such as raw water pumps, debris screens, rapid mix with addition of a coagulant, flocculation basin, sedimentation basin or clarifier, and gravity filters. Microfiltration (MF) could be used in place of flocculation, sedimentation, and filtration.

Maintenance – EDR membranes are durable, can tolerate pH from 1-10, and temperatures to 115 degrees Fahrenheit (°F) for cleaning. They can be removed from the unit and scrubbed. Solids can be washed off by turning the power off and letting water circulate through the stack. Electrode washes flush out byproducts of electrode reaction. The byproducts are hydrogen, formed in the cathode space, and oxygen and chlorine gas, formed in the anode spacer. If the chlorine is not removed, toxic chlorine gas may form. Depending on raw water characteristics, the membranes will require regular maintenance or replacement. If used, pretreatment filter replacement and backwashing will be required. The EDR stack must be disassembled, mechanically cleaned, and reassembled at regular intervals.

Waste Disposal – Highly concentrated reject flows, electrode cleaning flows, and spent membranes require approved disposal methods. Pretreatment process residuals and spent materials also require approved disposal methods.

#### **Advantages (EDR)**

- EDR can operate with minimal fouling, scaling, or chemical addition.
- Low pressure requirements; typically quieter than RO.
- Long membrane life expectancy.
- More flexible than RO in tailoring treated water quality requirements.

#### **Disadvantages (EDR)**

- Not suitable for high levels of iron, manganese, hydrogen sulfide, and hardness.
- Relatively expensive process and high energy consumption.
- Does not remove particulates, organics, or silica.
- Reject requires disposal

EDR can be quite expensive to run because of the energy it uses. If radium removal is the only purpose it is probably more expensive than other technologies. However, if nitrate and/or TDS removal is also required, then EDR is a competitive process.

### **1.4.5.5 Potassium Permanganate Greensand Filtration**

Process – Manganese dioxide ( $\text{MnO}_2$ ) is known to have capacity to adsorb radium from water.  $\text{MnO}_2$  can be formed by oxidation of  $\text{Mn}^{2+}$  occurring in natural waters and/or reduction of  $\text{KMnO}_4$  added to the water. The  $\text{MnO}_2$  is in the form of colloidal  $\text{MnO}_2$  which has a large surface area for adsorption. The  $\text{MnO}_2$  does not adsorb calcium and magnesium so hardness is not a factor, but iron and manganese and other heavy metal cations can compete strongly with radium adsorption. If these cations are present it would be necessary to install a good iron and manganese removal process before the  $\text{MnO}_2$ -filtration process or making sure that some  $\text{MnO}_2$  is still available for radium sorption. The  $\text{KMnO}_4$ -greensand filtration process can accomplish this purpose because greensand is coated with  $\text{MnO}_2$  which is regenerated by the continuous feeding of  $\text{KMnO}_4$ . Many operating treatment systems utilizing continuous feed  $\text{KMnO}_4$ , 30-minute contact time, and manganese greensand remove radium to concentrations below the MCL. The treatment system equipment includes a  $\text{KMnO}_4$  feed system, a pressurized reaction tank, and a manganese greensand filter. Backwashing of the greensand filter is usually required, but periodic regeneration is not required.

Pretreatment – The  $\text{KMnO}_4$ -greensand filtration process usually does not require pretreatment except if turbidity is very high. The greensand filter usually has an anthracite layer to filter larger particles while the greensand adsorbs dissolved cations such as radium.

Maintenance – The greensand requires periodic backwashing to rid of suspended materials and metal oxides.  $\text{KMnO}_4$  is usually supplied in the powder form and preparation of  $\text{KMnO}_4$  solution is required. Occasional monitoring to ensure no overfeeding of  $\text{KMnO}_4$  (pink water) is important to avoid problems in distribution system and household fixtures.

Waste Disposal – Approval from local authorities is usually required for the backwash wastewater. If local sewer is not available a backwash water storage and settling tank would be required to recycle settled water to the process and disposed of the settled solids periodically.

#### **Advantages (Greensand Filtration)**

- Well established process for radium removal.
- No regeneration waste generated.
- Low pressure operation and no repumping required.
- No additional process for iron and manganese removal.

#### **Disadvantages (Greensand Filtration)**

- Need to handle powdered  $\text{KMnO}_4$ , which is an oxidant.
- Need to monitor and backwash regularly.

The  $\text{KMnO}_4$ -greensand filtration is a well established iron and manganese removal process and is effective for radium removal. It is suitable for small and large systems and is cost competitive with other alternative technologies.

### **1.4.6 Point-of-Entry and Point-of-Use Treatment Systems**

Point-of-entry (POE) and point-of-use (POU) treatment systems can be used to provide compliant drinking water. For radium and gross alpha particle removal, these systems typically use small RO treatment units that are installed “under the sink” in the case of POU, and where water enters a house or building in the case of POE. It should be noted that the POU treatment units would need to be more complex than units typically found in commercial retail outlets in order to meet regulatory requirements, making purchase and installation more expensive. POE and POU treatment units would be purchased and owned by the PWS. These solutions are decentralized in nature, and require utility personnel entry into houses or at least onto private property for installation, maintenance, and testing. Due to the large number of treatment units that would be employed and would be largely out of the control of the PWS, it is very difficult to ensure 100 percent compliance. Prior to selection of a point-of-entry or point-of-use program for implementation, consultation with TCEQ would be required to address measurement and determination of level of compliance.

The SDWA [§1412(b)(4)(E)(ii)] regulates the design, management and operation of POU and POE treatment units used to achieve compliance with an MCL. These restrictions, relevant to radium and gross alpha particles are:

- POU and POE treatment units must be owned, controlled, and maintained by the water system, although the utility may hire a contractor to ensure proper O&M and compliance with MCLs. The water system must retain unit ownership and oversight of unit installation, maintenance and sampling; the utility ultimately is the responsible party for regulatory compliance. The water system staff need not perform all installation, maintenance, or management functions, as these tasks may be contracted to a third party-but the final responsibility for the quality and quantity of the water supplied to the community resides with the water system, and the utility must monitor all contractors closely. Responsibility for O&M of POU or POE devices installed for SDWA compliance may not be delegated to homeowners.
- POU and POE units must have mechanical warning systems to automatically notify customers of operational problems. Each POU or POE treatment device must be equipped with a warning device (*e.g.*, alarm, light) that would alert users when their unit is no longer adequately treating their water. As an alternative, units may be equipped with an automatic shut-off mechanism to meet this requirement.
- If the American National Standards Institute (ANSI) has issued product standards for a specific type of POU or POE treatment unit, only those units that have been independently certified according to those standards may be used as part of a compliance strategy.

The following observations with regard to using POE and POU devices for SDWA compliance were made by Raucher, *et al.* (2004):

- If POU devices are used as an SDWA compliance strategy, certain consumer behavioral changes will be necessary (*e.g.*, encouraging people to drink water only from certain treated taps) to ensure comprehensive consumer health protection.
- Although not explicitly prohibited in the SDWA, USEPA indicates that POU treatment devices should not be used to treat for radon or for most volatile organic contaminants (VOC) to achieve compliance, because POU devices do not provide 100 percent protection against inhalation or contact exposure to those contaminants at untreated taps (*e.g.*, shower heads).
- Liability – PWSs considering unconventional treatment options (POU, POE, or bottled water) must address liability issues. These could be meeting drinking water standards, property entry and ensuing liabilities, and damage arising from improper installation or improper function of the POU and POE devices.

#### **1.4.7 Water Delivery or Central Drinking Water Dispensers**

Current USEPA regulations (40 Code of Federal Regulations [CFR] 141.101) prohibit the use of bottled water to achieve compliance with an MCL, except on a temporary basis. State regulations do not directly address the use of bottled water. Use of bottled water at a non-compliant PWS would be on a temporary basis. Every 3 years, the PWSs that employ interim measures are required to present the TCEQ with estimates of costs for piping compliant water

to their systems. As long as the projected costs remain prohibitively high, the bottled water interim measure is extended. Until USEPA amends the noted regulation, the TCEQ is unable to accept water delivery or central drinking water dispensers as compliance solutions.

Central provision of compliant drinking water would consist of having one or more dispensers of compliant water where customers could come to fill containers with drinking water. The centralized water source could be from small to medium-sized treatment units or could be compliant water delivered to the central point by truck.

Water delivery is an interim measure for providing compliant water. As an interim measure for a small impacted population, providing delivered drinking water may be cost effective. If the susceptible population is large, the cost of water delivery would increase significantly.

Water delivery programs require consumer participation to a varying degree. Ideally, consumers would have to do no more than they currently do for a piped-water delivery system. Least desirable are those systems that require maximum effort on the part of the customer (*e.g.*, customer has to travel to get the water, transport the water, and physically handle the bottles). Such a system may appear to be lowest-cost to the utility; however, should a consumer experience ill effects from contaminated water and take legal action, the ultimate cost could increase significantly.

The ideal system would:

- Completely identify the susceptible population. If bottled water is only provided to customers who are part of the susceptible population, the utility should have an active means of identifying the susceptible population. Problems with illiteracy, language fluency, fear of legal authority, desire for privacy, and apathy may be reasons that some members of the susceptible population do not become known to the utility, and do not take part in the water delivery program.
- Maintain customer privacy by eliminating the need for utility personnel to enter the home.
- Have buffer capacity (*e.g.*, two bottles in service, so when one is empty, the other is being used over a time period sufficient to allow the utility to change out the empty bottle).
- Provide for regularly scheduled delivery so the customer would not have to notify the utility when the supply is low.
- Use utility personnel and equipment to handle water containers, without requiring customers to lift or handle bottles with water in them.
- Be sanitary (*e.g.*, where an outside connection is made, contaminants from the environment must be eliminated).
- Be vandal-resistant.



- 1
  - Avoid heating the water due to exterior temperatures and solar radiation.
- 2
  - Avoid freezing the water.

## **SECTION 2 EVALUATION METHODS**

### **2.1 DECISION TREE**

The decision tree is a flow chart for conducting feasibility studies for a non-compliant PWS. The decision tree is shown in Figures 2.1 through 2.4. The tree guides the user through a series of phases in the design process. Figure 2.1 shows Tree 1, which outlines the process for defining the existing system parameters, followed by optimizing the existing treatment system operation. If optimizing the existing system does not correct the deficiency, the tree leads to six alternative preliminary branches for investigation. The groundwater branch leads through investigating existing wells to developing a new well field. The treatment alternatives address centralized and on-site treatment. The objective of this phase is to develop conceptual designs and cost estimates for the six types of alternatives. The work done for this report follows through Tree 1 and Tree 2, as well as a preliminary pass through Tree 4.

Tree 3, which begins at the conclusion of the work for this report, starts with a comparison of the conceptual designs, selecting the two or three alternatives that appear to be most promising, and eliminating those alternatives which are obviously infeasible. It is envisaged that a process similar to this would be used by the study PWS to refine the list of viable alternatives. The selected alternatives are then subjected to intensive investigation, and highlighted by an investigation into the socio-political aspects of implementation. Designs are further refined and compared, resulting in selection of a preferred alternative. The steps for assessing the financial and economic aspects of the alternatives (one of the steps in Tree 3) are given in Tree 4 in Figure 2.4.

### **2.2 DATA SOURCES AND DATA COLLECTION**

#### **2.2.1 Data Search**

##### **2.2.1.1 Water Supply Systems**

The TCEQ maintains a set of files on public water systems, utilities, and districts at its headquarters in Austin, Texas. The files are organized under two identifiers: a PWS identification number and a Certificate of Convenience and Necessity (CCN) number. The PWS identification number is used to retrieve four types of files:

- CO – Correspondence,
- CA – Chemical analysis,
- MOR – Monthly operating reports (quality/quantity), and
- FMT – Financial, managerial and technical issues.

Figure 2.1  
TREE 1 – EXISTING FACILITY ANALYSIS




Figure 2.2  
TREE 2 – DEVELOP TREATMENT ALTERNATIVES






Figure 2.3

Tree 3 – PRELIMINARY ANALYSIS



**Figure 2.4**  
**TREE 4 – FINANCIAL**



The CCN files generally contain a copy of the system's Certificate of Convenience and Necessity, along with maps and other technical data.

These files were reviewed for the Vista Verde PWS and surrounding systems.

The following websites were consulted to identify the water supply systems in the study area:

- Texas Commission on Environmental Quality  
[www3.tnrc.state.tx.us/iwud/pws/index.cfm?](http://www3.tnrc.state.tx.us/iwud/pws/index.cfm?) Under "Advanced Search", type in the name(s) of the County(ies) in the study area to get a listing of the public water supply systems.
- USEPA Safe Drinking Water Information System  
[www.epa.gov/safewater/data/getdata.html](http://www.epa.gov/safewater/data/getdata.html)

Groundwater Control Districts were identified on the TWDB web site, which has a series of maps covering various groundwater and surface water subjects. One of those maps shows groundwater control districts in the State of Texas.

#### **2.2.1.2 Existing Wells**

The TWDB maintains a groundwater database available at [www.twdb.state.tx.us](http://www.twdb.state.tx.us) that has two tables with helpful information. The "Well Data Table" provides a physical description of the well, owner, location in terms of latitude and longitude, current use, and for some wells, items such as flowrate, and nature of the surrounding formation. The "Water Quality Table" provides information on the aquifer and the various chemical concentrations in the water.

#### **2.2.1.3 Surface Water Sources**

Regional planning documents were consulted for lists of surface water sources.

#### **2.2.1.4 Groundwater Availability Model**

GAMs, developed by the TWDB, are planning tools and should be consulted as part of a search for new or supplementary water sources. The GAM for the Gulf Coast Aquifer (northern part), which includes the Evangeline and Jasper aquifers, was investigated as a potential tool for identifying available and suitable groundwater resources.

#### **2.2.1.5 Water Availability Model**

The WAM is a computer-based simulation predicting the amount of water that would be in a river or stream under a specified set of conditions. WAMs are used to determine whether water would be available for a newly requested water right or amendment. If water is available, these models estimate how often the applicant could count on water under various conditions (*e.g.*, whether water would be available only 1 month out of the year, half the year, or all year, and whether that water would be available in a repeat of the drought of record).

WAMs provide information that assist TCEQ staff in determining whether to recommend the granting or denial of an application.

#### **2.2.1.6 Financial Data**

Financial data were collected through a site visit. Data sought included:

- Annual Budget
- Audited Financial Statements
  - Balance Sheet
  - Income and Expense Statement
  - Cash Flow Statement
  - Debt Schedule
- Water Rate Structure
- Water Use Data
  - Production
  - Billing
  - Customer Counts

#### **2.2.1.7 Demographic Data**

Basic demographic data were collected from the 2000 U.S. Census to establish incomes and eligibility for potential low cost funding for capital improvements. Median household income (MHI) and number of families below poverty level were the primary data points of significance. If available, MHI for the customers of the PWS should be used. In addition, unemployment data were collected from current U.S. Bureau of Labor Statistics. These data were collected for the following levels: national, state, and county.

### **2.2.2 PWS Interviews**

#### **2.2.2.1 PWS Capacity Assessment Process**

A capacity assessment is the industry standard term for an evaluation of a water system's FMT capacity to effectively deliver safe drinking water to its customers now and in the future at a reasonable cost, and to achieve, maintain and plan for compliance with applicable regulations. The assessment process involves interviews with staff and management who have a responsibility in the O&M of the system.

FMT capacity is made up of individual yet highly interrelated components of a system's capacity. A system cannot sustain capacity without maintaining adequate capability in all three components.



**Financial capacity** is a water system's ability to acquire and manage sufficient financial resources to allow the system to achieve and maintain compliance with SDWA regulations. Financial capacity refers to the financial resources of the water system, including but not limited to revenue sufficiency, credit worthiness, and fiscal controls.

**Managerial capacity** is the ability of a water system to conduct its affairs so that the system is able to achieve and maintain compliance with SDWA requirements. Managerial capacity refers to the management structure of the water system, including but not limited to ownership accountability, staffing and organization, and effective relationships to customers and regulatory agencies.

**Technical capacity** is the physical and operational ability of a water system to achieve and maintain compliance with the SDWA regulations. It refers to the physical infrastructure of the water system, including the adequacy of the source water, treatment, storage and distribution infrastructure. It also refers to the ability of system personnel to effectively operate and maintain the system and to otherwise implement essential technical knowledge.

Many aspects of water system operations involve more than one component of capacity. Infrastructure replacement or improvement, for example, requires financial resources, management planning and oversight, and technical knowledge. A deficiency in any one area could disrupt the entire effort. A system that is able to meet both its immediate and long-term challenges demonstrates that it has sufficient FMT capacity.

Assessment of the FMT capacity of the PWS was based on an approach developed by the New Mexico Environmental Finance Center (NMEFC), which is consistent with TCEQ FMT assessment process. This method was developed from work the NMEFC did while assisting USEPA Region 6 in developing and piloting groundwater comprehensive performance evaluations. The NMEFC developed a standard list of questions that could be asked of water system personnel. The list was then tailored slightly to have two sets of questions – one for managerial and financial personnel, and one for operations personnel (the questions are included in Appendix A). Each person with a role in the FMT capacity of the system was asked the applicable standard set of questions individually. The interviewees were not given the questions in advance and were not told the answers others provided. Also, most of the questions are open ended type questions so they were not asked in a fashion to indicate what would be the “right” or “wrong” answer. The interviews lasted between 45 to 75 minutes depending on the individual's role in the system and the length of the individual's answers.

In addition to the interview process, visual observations of the physical components of the system were made. A technical information form was created to capture this information. This form is also contained in Appendix A. This information was considered supplemental to the interviews because it served as a check on information provided in the interviews. For example, if an interviewee stated he or she had an excellent preventative maintenance schedule and the visit to the facility indicated a significant amount of deterioration (more than would be expected for the age of the facility) then the preventative maintenance program could be further investigated or the assessor could decide that the preventative maintenance program was inadequate.

Following interviews and observations of the facility, answers that all personnel provided were compared and contrasted to provide a clearer picture of the true operations at the water system. The intent was to go beyond simply asking the question, “Do you have a budget?” to actually finding out if the budget was developed and being used appropriately. For example, if a water system manager was asked the question, “Do you have a budget?” he or she may say, “yes” and the capacity assessor would be left with the impression that the system is doing well in this area. However, if several different people are asked about the budget in more detail, the assessor may find that although a budget is present, operations personnel do not have input into the budget, the budget is not used by the financial personnel, the budget is not updated regularly, or the budget is not used in setting or evaluating rates. With this approach, the inadequacy of the budget would be discovered and the capacity deficiency in this area would be noted.

Following the comparison of answers, the next step was to determine which items noted as a potential deficiency truly had a negative effect on the system’s operations. If a system had what appeared to be a deficiency, but this deficiency was not creating a problem in terms of the operations or management of the system, it was not considered critical and may not have needed to be addressed as a high priority. As an example, the assessment may have revealed an insufficient number of staff members to operate the facility. However, it may also have been revealed that the system was able to work around that problem by receiving assistance from a neighboring system, so no severe problems resulted from the number of staff members. Although staffing may not be ideal, the system does not need to focus on this particular issue. The system needs to focus on items that are truly affecting operations. As an example of this type of deficiency, a system may lack a reserve account which can then lead the system to delay much-needed maintenance or repair on its storage tank. In this case, the system needs to address the reserve account issue so that proper maintenance can be completed.

The intent was to develop a list of capacity deficiencies with the greatest impact on the system’s overall capacity. Those were the most critical items to address through follow-up technical assistance or by the system itself.

#### **2.2.2.2 Interview Process**

PWS personnel were interviewed by the project team, and each was interviewed separately. Interview forms were completed during each interview.

### **2.3 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

The initial objective for developing alternatives to address compliance issues was to identify a comprehensive range of possible options that can be evaluated to determine which are the most promising for implementation. Once the possible alternatives are identified, they must be defined in sufficient detail so a conceptual cost estimate (capital and O&M costs) can be developed. These conceptual cost estimates are used to compare the affordability of compliance alternatives, and to give a preliminary indication of rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. The basis for the unit costs used for the compliance alternative

cost estimates is summarized in Appendix B. Other non-economic factors for the alternatives, such as reliability and ease of implementation, are also addressed.

### **2.3.1 Existing PWS**

The neighboring PWSs were identified, and the extents of their systems were investigated. PWSs farther than 10 miles from the non-compliant PWSs were not considered because the length of the pipeline required would make the alternative cost prohibitive. The quality of water provided was also investigated. For neighboring PWSs with compliant water, options for water purchase and/or expansion of existing well fields were considered. The neighboring PWSs with non-compliant water were considered as possible partners in sharing the cost for obtaining compliant water either through treatment or developing an alternate source.

The neighboring PWSs were investigated to get an idea of the water sources in use and the quantity of water that might be available for sale. They were contacted to identify key locations in their systems where a connection might be made to obtain water, and to explore on a preliminary basis their willingness to partner or sell water. Then, the major system components that would be required to provide compliant water were identified. The major system components included treatment units, wells, storage tanks, pump stations, and pipelines.

Once the major components were identified, a preliminary design was developed to identify sizing requirements and routings. A capital cost estimate was then developed based on the preliminary design of the required system components. An annual O&M cost was also estimated to reflect the change in O&M expenditures that would be needed if the alternative was implemented.

Non-economic factors were also identified. Ease of implementation was considered, as well as the reliability for providing adequate quantities of compliant water. Additional factors were whether implementation of an alternative would require significant increase in the management or technical capability of the PWS, and whether the alternative had the potential for regionalization.

### **2.3.2 New Groundwater Source**

It was not possible in the scope of this study to determine conclusively whether new wells could be installed to provide compliant drinking water. In order to evaluate potential new groundwater source alternatives, three test cases were developed based on distance from the PWS intake point. The test cases were based on distances of 5 miles and 1 mile, and installing a well on-site. It was assumed that a pipeline would be required for all three test cases, and a storage tank and pump station would be required for the 5-mile alternative. It was also assumed that new wells would be installed, and that their depths would be similar to the depths of the existing wells, or other existing drinking water wells in the area.

A preliminary design was developed to identify sizing requirements for the required system components. A capital cost estimate was then developed based on the preliminary design of the required system components. An annual O&M cost was also estimated to reflect

the change (*i.e.*, from current expenditures) in O&M expenditures that would be needed if the alternative was implemented.

Non-economic factors were also identified. Ease of implementation was considered, as well as the reliability for providing adequate quantities of compliant water. Additional factors were; whether implementation of an alternative would require significant increase in the management or technical capability of the PWS, and whether the alternative had the potential for regionalization.

### **2.3.3 New Surface Water Source**

New surface water sources were investigated. Availability of adequate quality water was investigated for the main rivers in the study area, as well as the major reservoirs. TCEQ WAMs were inspected, and the WAM was run, where appropriate.

### **2.3.4 Treatment**

Treatment technologies considered potentially applicable to radium and gross alpha particle removal are IX, WRT Z-88 media, RO, EDR, and KMnO<sub>4</sub>-greensand filtration. RO and EDR are membrane processes that produce a considerable amount of liquid waste: a reject stream from RO treatment and a concentrate stream from EDR treatment. As a result, the treated volume of water is less than the volume of raw water that enters the treatment system. The amount of raw water used increases to produce the same amount of treated water if RO or EDR treatment is implemented. Because the TDS is not high, the use of RO or EDR would be considerably more expensive than the other potential technologies. Accordingly, RO and EDR were not considered further. However, RO is considered for POU and POE alternatives. IX, WRT Z-88 media, and KMnO<sub>4</sub>-greensand filtration are considered as alternative central treatment technologies. The treatment units were sized based on flow rates, and capital and annual O&M cost estimates were made based on the size of the treatment equipment required. Neighboring non-compliant PWSs were identified to look for opportunities where the costs and benefits of central treatment could be shared between systems.

Non-economic factors were also identified. Ease of implementation was considered, as well as reliability for providing adequate quantities of compliant water. Additional factors were whether implementation of an alternative would require significant increase in the management or technical capability of the PWS, and whether the alternative had the potential for regionalization.

## **2.4 COST OF SERVICE AND FUNDING ANALYSIS**

The primary purpose of the cost of service and funding analysis is to determine the financial impact of implementing compliance alternatives, primarily by examining the required rate increases, and also the fraction of household income that water bills represent. The current financial situation is also reviewed to determine what rate increases are necessary for the PWS to achieve or maintain financial viability.

## **2.4.1 Financial Feasibility**

A key financial metric is the comparison of average annual household water bill for a PWS customer to the MHI for the area. MHI data from the 2000 U.S. Census are used, at the most detailed level available for the community. Typically, county level data are used for small rural water utilities due to small population sizes. Annual water bills are determined for existing, base conditions, including consideration of additional rate increases needed under current conditions. Annual water bills are also calculated after adding incremental capital and operating costs for each of the alternatives to determine feasibility under several potential funding sources.

Additionally, the use of standard ratios provides insight into the financial condition of any business. Three ratios are particularly significant for water utilities:

- Current Ratio = current assets divided by current liabilities provides insight into the ability to meet short-term payments. For a healthy utility, the value should be greater than 1.0.
- Debt to Net Worth Ratio = total debt divided by net worth shows to what degree assets of the company have been funded through borrowing. A lower ratio indicates a healthier condition.
- Operating Ratio = total operating revenues divided by total operating expenses show the degree to which revenues cover ongoing expenses. The value is greater than 1.0 if the utility is covering its expenses.

## **2.4.2 Median Household Income**

The 2000 U.S. Census is used as the basis for MHI. In addition to consideration of affordability, the annual MHI may also be an important factor for sources of funds for capital programs needed to resolve water quality issues. Many grant and loan programs are available to lower income rural areas, based on comparisons of local income to statewide incomes. In the 2000 Census, MHI for the State of Texas was \$39,927, compared to the U.S. level of \$41,994.

## **2.4.3 Annual Average Water Bill**

The annual average household water bill was calculated for existing conditions and for future conditions incorporating the alternative solutions. Average residential consumption is estimated and applied to the existing rate structure to estimate the annual water bill. The estimates are generated from a long-term financial planning model that details annual revenue, expenditure, and cash reserve requirements over a 30-year period.

## **2.4.4 Financial Plan Development**

The financial planning model uses available data to establish base conditions under which the system operates. The model includes, as available:

- Accounts and consumption data
- Water tariff structure
- Beginning available cash balance
- Sources of receipts:
  - Customer billings
  - Membership fees
  - Capital Funding receipts from:
    - ❖ Grants
    - ❖ Proceeds from borrowing
- Operating expenditures:
  - Water purchases
  - Utilities
  - Administrative costs
  - Salaries
- Capital expenditures
- Debt service:
  - Existing principal and interest payments
  - Future principal and interest necessary to fund viable operations
- Net cash flow
- Restricted or desired cash balances:
  - Working capital reserve (based on 1-4 months of operating expenses)
  - Replacement reserves to provide funding for planned and unplanned repairs and replacements

From the model, changes in water rates are determined for existing conditions and for implementing the compliance alternatives.

#### **2.4.5 Financial Plan Results**

Results from the financial planning model are summarized in two areas: percentage of household income and total water rate increase necessary to implement the alternatives and maintain financial viability.

#### **2.4.5.1 Funding Options**

Results are summarized in a table that shows the following according to alternative and funding source:

- Percentage of the annual MHI that the average annual residential water bill represents.
- The first year in which a water rate increase would be required.
- The total increase in water rates required, compared to current rates.

Water rates resulting from the incremental capital costs of the alternative solutions are examined under a number of funding options. The first alternative examined is always funding from existing reserves plus future rate increases. Several funding options were analyzed to frame a range of possible outcomes.

- Grant funds for 100 percent of required capital. In this case, the PWS is only responsible for the associated O&M costs.
- Grant funds for 75 percent of required capital, with the balance treated as if revenue bond funded.
- Grant funds for 50 percent of required capital, with the balance treated as if revenue bond funded.
- State revolving fund loan at the most favorable available rates and terms applicable to the communities.
- If local MHI is greater than 75 percent of state MHI, standard terms, currently at 3.8 percent interest for non-rated entities. Additionally:
  - If local MHI = 70-75 percent of state MHI, 1 percent interest rate on loan.
  - If local MHI = 60-70 percent of state MHI, 0 percent interest rate on loan.
  - If local MHI = 50-60 percent of state MHI, 0 percent interest and 15 percent forgiveness of principal.
  - If local MHI less than 50 percent of state MHI, 0 percent interest and 35 percent forgiveness of principal.
- Terms of revenue bonds assumed to be 25-year term at 6.0 percent interest rate.

#### **2.4.5.2 General Assumptions Embodied in Financial Plan Results**

The basis used to project future financial performance for the financial plan model includes:

- No account growth (either positive or negative).
- No change in estimate of uncollectible revenues over time.
- Average consumption per account unchanged over time.

- No change in unaccounted for water as percentage of total (more efficient water use would lower total water requirements and costs).
- No inflation included in the analyses (although the model has provisions to add escalation of O&M costs, doing so would mix water rate impacts from inflation with the impacts from the alternatives being examined).
- Minimum working capital fund established for each district, based on specified months of O&M expenditures.
- O&M for alternatives begins 1 year after capital implementation.
- Balance of capital expenditures not funded from primary grant program is funded through debt (bond equivalent).
- Cash balance drives rate increases, unless provision chosen to override where current net cash flow is positive.

#### **2.4.5.3 Interpretation of Financial Plan Results**

Results from the financial plan model for each alternative are presented in Table 4.4 in Section 4 of this report. The model used six funding alternatives: paying cash up front (all revenue); 100 percent grant; 75 percent grant; 50 percent grant, State Revolving Fund (SRF); and obtaining a Loan/Bond. Table 4.4 shows the projected average annual water bill, the maximum percent of household income, and the percentage rate increase over current rates.

#### **2.4.5.4 Potential Funding Sources**

A number of potential funding sources exist for rural utilities. Both state and federal agencies offer grant and loan programs to assist rural communities in meeting their infrastructure needs.

Within Texas, the following state agencies offer financial assistance if needed:

- TWDB;
- Office of Rural Community Affairs; and
- Texas Department of Health (Texas Small Towns Environment Program).

Small rural communities can also get assistance from the federal government. The primary agencies providing aid are:

- United States Department of Agriculture, Rural Utilities Service; and
- United States Housing and Urban Development.




## SECTION 3 UNDERSTANDING SOURCES OF CONTAMINANTS

### 3.1 GROSS ALPHA AND RADIUM IN THE GULF COAST AQUIFER

The Gulf Coast aquifer parallels the Texas Gulf Coast and extends from the Texas-Louisiana border to the Rio Grande. Subunits of the Gulf Coast aquifer are from oldest to youngest, the Jasper, Evangeline, and Chicot aquifers. The aquifer is a leaky artesian system composed of middle to late Tertiary and younger interbedded and hydrologically connected layers of clay, silt, sand, and gravel (Baker 1979, Ashworth and Hopkins 1992). Most PWS wells of concern in Polk and Montgomery counties are completed in the Jasper aquifer.

The most recent gross alpha data from the TCEQ database (contaminants ID 4109 - gross alpha particle activity) were plotted to assess the spatial distribution of alpha radiation in the aquifer (Figure 3.1). Only one well with gross alpha was found for this aquifer in the TWDB database (storet code 80045); therefore, these data were not included in the analysis.

**Figure 3.1 Gross Alpha in Groundwater of the Gulf Coast Aquifer (TCEQ Database, 1095 Data Points from 2001 to 2005)**




1 Uranium concentrations were evaluated only in wells where gross alpha exceeded  
2 15 pCi/L. The MCL for uranium is 30 µg/L, which is equivalent to 20 pCi/L (using a  
3 conservative factor of 0.67 pCi/µg for converting mass concentration to radiation  
4 concentration). Therefore, a gross alpha level of 35 pCi/L in a well reflects a level from which  
5 the well fails to comply with either the MCL for gross alpha minus alpha radiation due to  
6 uranium which is 15 pCi/L, or with the uranium MCL (neglecting the activity due to radon  
7 which is rarely measured in PWS wells). Gross alpha >5 pCi/L requires analysis of  
8 radium-226. Radium-228 testing must be done regardless of gross alpha results (TCEQ 2004).  
9 The symbology for gross alpha levels in Figure 3.1 takes these threshold levels into account.

10 Relatively high gross alpha levels are common in Polk and Harris Counties, and to a lesser  
11 extent, in Montgomery and Walker Counties. High levels of gross alpha are also found in the  
12 southern part of the aquifer (Jim Wells and Kleberg Counties).

13 The most recent radium measurements from the TWDB and TCEQ databases were  
14 analyzed to assess the overall occurrence of this contaminant in the aquifer (Figure 3.2). In this  
15 study the terms *radium* or *radium combined* are generally used to refer to radium-226 and  
16 radium-228. Otherwise, radium-226 or radium-228 is specified. The values shown in  
17 Figure 3.2 generally represent the upper limit of the radium measurements, because radium-228  
18 was below its detection limit of 1 pCi/L for more than 75 percent of the data, and the detection  
19 limit was used when summing with radium-226 for the radium combined values. Radium-228  
20 can have negative values in the TWDB database when radiation of the sample is lower than  
21 background radiation at the laboratory; in these cases, zero was used for the sum. Although  
22 TCEQ allows PWSs to subtract the reported error from the radium concentrations to assess  
23 compliance, the following analysis of general trends used the most recent radium concentration  
24 and did not subtract the reported error. This approach is considered more conservative.

25 The most recent values for wells from which both isotopes of radium were analyzed are  
26 shown in Figure 3.2 (number of samples shown is 526; 432 from TCEQ database and 94 from  
27 TWDB database). The codes for the contaminants are: TWDB - storet codes 09503 and  
28 81366; and TCEQ databases - Contaminant ID 4020 and 4030, for radium-226 and radium-228,  
29 respectively. Radium-226 and radium-228 were combined, and the combined value for each  
30 well is shown. Only measurements from a single entry point that can be related to a specific  
31 well were used from the TCEQ database.

**Figure 3.2 Radium in Groundwater of the Gulf Coast Aquifer**  
(TCEQ Database, Data from 1998 to 2005, and TWDB Database, Data from 1988 to 1990)




Radium levels exceeding the 5 pCi/L MCL seem more likely to be found in the central to northern parts of the aquifer; however, this distribution may be an artifact of the higher density of measurements toward the northern part of the aquifer (Figure 3.2). Relatively high levels of radium are found in the area of Polk County and the neighboring counties to the west (San Jacinto, Walker, and Montgomery) in wells open to the Jasper aquifer.

### 3.1.1 Gross Alpha and Radium Trends

Gross alpha and radium trends were calculated with data from the TCEQ PWS database (Figures 3.3, 3.4, and 3.5). Only the most recent analyses with both parameters analyzed from a single entry point that can be related to a specific well are included in the analysis.

**Figure 3.3 Radium-226 vs. Gross Alpha in Groundwater of the Gulf Coast Aquifer  
(TCEQ Database from 2001 to 2005, 434 Samples)**



The average contribution of radium-226 to the gross alpha count is 14.4 percent (based on the slope in Figure 3.3). All samples of radium-226 greater than 4 pCi/L are above the regression line, which means that in wells with high levels of radium, the contribution of radium to gross alpha counts is higher (~15 - 20%). In five out of six wells in which gross alpha was greater than 35 pCi/L, radium-226 was greater than 7 pCi/L. Therefore, non compliance with the radium MCL is strongly related to non compliance with gross alpha MCL in the Gulf Coast aquifer.

Gross alpha and radium are highest in the Jasper aquifer, while the Evangeline and Chicot aquifers have radium exceeding the MCL in only in 3.8 and 1.7 percent of their wells, respectively (Table 3.1). Gross alpha levels are relatively high in both the Jasper and Evangeline aquifers, and low in the Chicot aquifer. Higher levels of gross alpha (>35pCi/L) are more frequently found in the Jasper aquifer (specifically in Polk County), whereas gross alpha levels in the Evangeline aquifer are more commonly in the medium (>5pCi/L) and high (>15pCi/L) levels (Table 3.1).


**Table 3.1 Distribution of Gross Alpha and Radium within the Gulf Coast Aquifers  
(Most Recent Data for Wells in the TCEQ Database)**

Aquifer	Radium				Gross Alpha				
	Number of wells with radium samples	Average radium (pCi/L)	Median radium (pCi/L)	% of wells with radium > 5 pCi/L	Wells with gross alpha samples	Median gross alpha (pCi/L)	% of wells with gross alpha > 5 pCi/L	% of wells with gross alpha > 15 pCi/L	% of wells with gross alpha > 35 pCi/L
Chicot	121	1.7	1.4	1.7	406	< 2	22.4	1.2	0.2
Evangeline	261	1.9	1.6	3.8	573	3.5	36.8	7.0	0.5
Jasper	49	3.2	2.6	10.2	142	2.5	30.3	4.9	1.4


Samples of radium-228 with concentrations equal to the detection limit of 1 pCi/L were assigned a value of 0.5 in the calculation of combined radium.

No correlation between radium and well depth was found for the three combined aquifers (Figure 3.4) nor when separately plotted (not shown). Correlation between gross alpha and well depth (plot not shown) is slightly higher ( $R^2 = 0.019$ ) but still low. Correlations of radium with general water quality parameters such as chloride and TDS are very small as well (Figure 3.5).

**Figure 3.4 Radium Concentrations vs. Well Depth  
(434 Wells in the Chicot, Evangeline and Jasper Aquifers)**




**Figure 3.5 Relationship Between Radium and Chloride Concentrations (186 Wells)  
and Radium and Total Dissolved Solids TDS Concentrations (163 Wells)  
in the Chicot, Evangeline and Jasper Aquifers**



### 3.1.2 Uranium in the Gulf Coast Aquifer

The National Uranium Resource Evaluation (NURE) database contains many uranium analyses from the Gulf Coast aquifer; therefore, it was used to assess the spatial distribution of uranium at the basin scale. The southern part of the aquifer has higher uranium levels than the northern part (Figure 3.6). A narrow strip of high uranium concentrations is found near the northwestern boundary of the aquifer where wells are open to the Jasper aquifer. High levels of uranium in the south and along the Jasper aquifer correspond to high levels of arsenic in these regions also. Another area with relatively high uranium levels is between the Colorado and San Antonio rivers (Wharton, Jackson and Victoria Counties). Most wells in this area obtain water from the Chicot aquifer. Water from wells in Polk County do not exceed the uranium MCL of 30  $\mu\text{g/L}$ . The relatively high gross alpha found in this county (Figure 3.1) is probably not related to uranium. This is discussed in more detail in Subsection 3.3 where individual wells are evaluated.

**Figure 3.6 Uranium Concentrations in Groundwater of the Gulf Coast Aquifer**




*Note: (NURE database, analyses from 1976 to 1980). In the NURE database there is one sample per well (number of samples shown is 2802).*

The TCEQ database contains only 62 single well source measurements of uranium in the Gulf Coast aquifer (uranium-234, Uranium-235, and uranium-238 are measured separately). Uranium in pCi/L is referred to as total uranium (*i.e.*, the sum of the three isotopes). A total of 55 out of these 62 most recent samples that have measurements of radium-226 and gross alpha in the same sample were used in Figure 3.7 to describe the relationship between uranium, radium, and gross alpha.



**Figure 3.7 Relationships Between Uranium, Radium-226, and  
Gross Alpha in Groundwater of the Gulf Coast Aquifer  
(Data from the TCEQ database from 2001 to 2005, total of 55 samples)**



The correlation between uranium and gross alpha concentrations (Figure 3.7a) is not as strong as the correlation of gross alpha and radium (Figure 3.7b). Uranium contributes about 37 percent of the alpha radiation on average (based on slope in Figure 3.7a), but variability is high. The slope in Figure 3.7b is slightly larger than in Figure 3.3 where all pairs of radium and gross alpha were included. In Figure 3.7, only wells in which gross alpha greater than 15 pCi/L were included because this is the level from which an analysis for uranium is required. The low negative correlation between radium and uranium (Figure 3.7c) implies that high gross alpha in the aquifer is due to either high uranium or high radium but most probably not high concentrations of both. Most of the samples in Figure 3.7c where uranium exceeds 20 pCi/L had low levels of radium.



## 3.2 HYDROGEOLOGY OF POLK AND MONTGOMERY COUNTIES

Subsurface deposits in Polk and Montgomery Counties and San Jacinto County in between consist mainly of sediments of Pliocene and Pleistocene age, making up the last progradation wedges in the Gulf Coast. Gulf Coast sediments consist of several progradation wedges of Tertiary age composed of alternating sandstones and clays corresponding to variations in sea level and in inland sediment input as well as in other factors. Those wedges are approximately parallel to the current shoreline, and the deposition process is still active today (*e.g.*, Mississippi River and delta). In the Gulf Coast lowlands, those deposits are generally divided into six or more operational units: the Fleming formation of Miocene age whose base includes the Oakville sandstones, the Goliad/Willis formations of Pliocene age, and the Lissie and Beaumont formations of Pleistocene age. The Lissie formation is sometimes divided into a lower unit (Lissie s.s. or Bentley) and an upper unit, the Montgomery formation. The general dip of the formations toward the Gulf of Mexico is 0.01 ft/ft or less on average. Some salt domes exist at depth in the south of Polk and Montgomery Counties, but they do not seem to alter the general structure of the Upper Tertiary formations.


The Gulf Coast aquifer is recognized as a major aquifer in the State of Texas (Ashworth and Hopkins 1995; Mace, *et al.* 2006). In the Tertiary Gulf Coast system, the general flow system consists in water infiltrating into the outcrop areas of the more permeable formations, some of it discharging into rivers and springs along short flow paths, and some of it flowing downdip into the deeper sections of the aquifers. The fate of that slowly moving water is to slowly percolate up by cross-formational flow and discharge into the Gulf of Mexico. This process is necessary to maintain mass balance in the regional flow system although, because of heavy pumping in some areas, the natural upward flow has been locally reversed. The northern confines of Polk County include the upper formations of the Jackson Group of Eocene age and the Catahoula formation of mostly Oligocene age. The Catahoula formation is generally recognized as the low-permeability base of the Gulf Coast aquifer, although it can locally produce water. The other hydrostratigraphic units of the Coastal Plain are the Jasper aquifer, the Burkeville confining system, and the Evangeline and Chicot aquifers (Baker 1979). The Jasper aquifer is composed of the base of the Fleming formation, that is, the Oakville Sandstones, as well as the Catahoula sandstones hydraulically connected to them. The upper part of the Fleming formation makes up the Burkeville confining system. The Evangeline aquifer includes mostly the Goliad Sands but also the upper sections of the Fleming formation when permeable. The remainder and younger formations of the section (Willis Sands, Lissie and Beaumont formations) make up the Chicot aquifer (Kasmarek and Robinson 2004). Polk and Montgomery Counties present a similar stratigraphy, only slightly shifted more toward recent sediments in Montgomery County. There, the oldest sediments at the surface are from the Fleming formation and they crop out in the extreme northwest area of the county. The succession is then the same in both counties with the addition of a large section of Beaumont Clay of Pleistocene age south of Lake Conroe along the West Fork San Jacinto River. Some Beaumont Clay also exists in southwest Polk County along Lake Livingston and the Trinity River.

The base of the Jasper aquifer is at a depth of 0 (outcrop area) to 3,000 ft below ground surface. The Oakville formation, forming the bulk of the Jasper aquifer, consists of fluvial fine- to coarse-grained, partially consolidated sand with silt and clay intercalations. Its thickness ranges from 700 to 1,200 ft (increasing downdip) in the Polk and Montgomery County area with a high net sand thickness (Kasmarek and Robinson 2004). The net sand thickness varies from <400 ft to >600 ft, with a sand fraction >40 percent (Galloway, *et al.* 1986). The net thickness of sand within the aquifer varies according to the geological conditions in which the sediments were deposited. The Goliad formation, approximately equivalent to the Evangeline aquifer, unconformably overlies the top of the Fleming formation, which is composed of mostly clays with some calcareous sand. The Upper Fleming formation depositional systems indicate an environment near the shoreline with fluvial sediments transitioning into fluvial, deltaic, and lagoonal sediments outside the study area toward the Gulf. This formation acts as a leaky confining layer between the Jasper and the Evangeline aquifers (“Burkeville confining system”) and has an approximate thickness of 300 ft. Goliad sand is medium- to coarse-grained and unconsolidated with intercalations of calcareous clay and marl, the bases of which are located at approximately 1,000 ft below ground surface. The fluvial and deltaic sand of the Goliad formation suggest another small retreat of the shoreline toward the Gulf. Their thickness is in the range from 0 in the outcrop area to a consistent 800 ft downdip to more than 1,000 ft in Southern Montgomery County. Goliad Sand grades into the generally coarse-grained Willis Sand whose depositional system arrangement is similar to that of the Goliad Sand. The Willis Sand makes up the Chicot aquifer with the overlying fine- to coarse-grained Lissie Sand. The top of the Lissie formation, with a higher clay content, and the Beaumont Clay, generally pressurize the more permeable sand of the Willis and Bentley formations, confining the Chicot aquifer. The Chicot aquifer is not well-expressed in Polk County, but its thickness can reach 200 ft in southern Montgomery County. Water quality and well yield are generally good in the Gulf Coast aquifer in northeast Texas, including in Polk and Montgomery Counties.


### 3.3 DETAILED ASSESSMENT FOR VISTA VERDE PWS – PWS 1700694

The Vista Verde PWS has one well. The most recent gross alpha for the Vista Verde well was 33.9 pCi/L; a level which requires radium and uranium testing. The spatial and hydrostratigraphic distribution of gross alpha levels from wells adjacent to the PWS is quite clear. The wells in the southern section bounded by the black straight lines (Figure 3.8) are all open to the Evangeline aquifer (as well as the wells in the eastern ellipse). The high gross alpha concentrations are also found in the southern area (Figure 3.8). Well G1700543A is the closest alternative PWS well (distance 2.4 km) with low gross alpha levels (4 pCi/L). The well penetrates the Jasper aquifer, which in this area does not show problems with radionuclide contamination. Well G1700382A also has gross alpha levels lower than the MCL, but still relatively high (11 pCi/L). The most recent radium concentration for this well is 2.3 pCi/L (see Figure 3.9) which is below the radium MCL. This well penetrates the Evangeline aquifer, and is about 1.6 km away from the Vista Verde PWS well (Figure 3.8). No correlation between gross alpha and well depth was found within the Evangeline wells of the southern section (Table 3.2).

**Figure 3.8 Gross Alpha (pCi/L) in the 5- and 1-km buffers of the Vista Verde PWS Wells (TCEQ Database)**



**Figure 3.9 Combined Radium (pCi/L) in the 5- and 1-km Buffers of the Vista Verde PWS Wells (TCEQ Database)**



Nondetects of radium-228 less than 1 pCi/L were assigned a value of 1 pCi/L for the combined radium values in Figure 3.9. The Vista Verde PWS well exceeds the radium MCL by 3.5 pCi/L. As for gross alpha, the Evangeline wells in the southern section show higher levels of radium. Also, the correlation between radium and well depth in the Evangeline wells of the southern section was low.

**Table 3.2 Most Recent Gross Alpha and Radium Levels within the 5-km Buffer of the Vista Verde PWS Well and Surrounding Wells (Figures 3.8 and 3.9)**

Well ID	Well Depth (ft)	Aquifer	Screen Top (ft)	Screen Bottom (ft)	Sampling Date	Gross Alpha (pCi/L)	Radium (pCi/L)
G1700005A	394	Evangeline			10/7/2003	17.3	2.6
G1700005B	447	Evangeline			10/7/2003	27.3	4.3
G1700382A	325	Evangeline			10/27/2003	10.8	2.2
G1700638A	290	Evangeline			7/30/2002	6.2	1.5
G1700638C	525	Evangeline			7/30/2002	3.1	
G1700638D	504	Evangeline			4/26/2004	25.8	5.2
G1700677A	485	Evangeline			6/23/2004	8.9	
<b>G1700694A</b>	<b>340</b>	<b>Evangeline</b>			<b>7/14/2004</b>	<b>33.9</b>	<b>8.5</b>
G1700097C	742	Jasper	375	742	1/25/2005	6.7	3.1
G1700134A	995	Jasper	800	995	6/19/2003	4.3	2.3
G1700176A	750	Jasper			6/27/2002	5.2	2.7
G1700176B	750	Jasper			6/27/2002	5.7	3.4
G1700220A	735	Jasper			6/26/2003	3.6	
G1700286A	908	Jasper			6/27/2002	4.9	2.1
G1700416A	490	Jasper	470	490	6/26/2003	7.4	2.9
G1700416B	495	Jasper	460	495	6/26/2003	4.6	1.8
G1700543A	710	Jasper			7/7/2003	3.5	
G1700588A	443	Jasper			9/27/2001	<2	
G1700643A	515	Jasper			7/11/2001	5.2	1.8

The Vista Verde well (**G1700694A**) has the highest levels of gross alpha and radium in this area (Table 3.2). The levels in the Vista Verde well exceeded the gross alpha and radium MCL in both the 2003 and 2004 measurements. The nearby Evangeline well (G1700382A) complied with these standards in 2001 and 2003, but the levels are substantially higher than in the nearest Jasper well (G1700543A). The uranium levels in this area are low and it is not a major source of alpha particles (Table 3.3).

**Table 3.3 History of Gross Alpha, Combined Radium, and Combined Uranium in Vista Verde and Two Nearby Wells (see Figure 3.8 for Locations)**

Well	Sampling Date	Gross Alpha (pCi/L)	Radium (pCi/L)	Uranium (pCi/L)
<b>G1700694A</b>	<b>9/24/2003</b>	<b>38.2</b>	<b>7</b>	<b>4.7</b>
<b>G1700694A</b>	<b>7/14/2004</b>	<b>33.9</b>	<b>8.5</b>	<b>4.6</b>
G1700382A	10/9/2001	17.6	3.4	4.6
G1700382A	10/27/2003	10.8	2.2	
G1700543A	8/6/2001	5	3.2	
G1700543A	7/7/2003	3.5		

**3.3.1 Summary of Alternative Groundwater Sources for the Vista Verde PWS  
(1700694)**

The nearby well - G1700382A (1.6 km from the Vista Verde PWS well - Evangeline Aquifer) complies with the MCL for radionuclides, although the level of gross alpha in this well was above 15 pCi/L in 2001. Well G1700543A (2.4 km from the Vista Verde well - Jasper aquifer) shows low levels of radionuclides (gross alpha <5 pCi/L). Another (less expensive) groundwater alternative may be deepening the Vista Verde well or drilling a new deeper well that would penetrate the Jasper aquifer. According to existing data, all wells within 10 km of the Vista Verde well and which are open to the Jasper aquifer, comply with radionuclide MCLs. Considering depths of adjacent wells penetrating the Jasper aquifer, this well would probably have to be 750 – 950 ft deep.

## **SECTION 4 ANALYSIS OF THE VISTA VERDE PWS**

### **4.1 DESCRIPTION OF EXISTING SYSTEM**

#### **4.1.1. Existing System**

The Vista Verde PWS is shown in Figure 4.1. The Vista Verde PWS is owned and operated by Karl Painter. The Vista Verde PWS is a water system that supplies Marvin Gardens, a small residential subdivision with 22 current connections, which will have 144 connections at full build out. It is located on the southern shore of Lake Conroe, approximately 10 miles northwest of the City of Conroe, Texas.

The water source for this PWS is one well, which is completed in the Evangeline aquifer (Code 121EVJP). The well is located in Montgomery County and is 340 feet deep. The total production of the well is 0.047 million gallons per day (mgd). Disinfection with hypochlorite and sequestration with polyphosphate for high iron levels is performed at the wellhead before water is pumped into the distribution system. There are two 900-gallon hydro-pneumatic tanks in the system and no elevated or ground storage.


Total combined radium-226 and radium-228 has been detected between 5.8 pCi/L to 7.5 pCi/L since 2004, which exceeds the combined radium MCL of 5 pCi/L. Gross alpha particle activity has been detected between 34 pCi/L to 38 pCi/L, which exceeds the MCL of 15 pCi/L. The Vista Verde PWS has not encountered any other water quality issues. TDS concentrations were measured at 416 mg/L in 2004.

The treatment employed for disinfection is not appropriate or effective for removal of combined radium or alpha particles, so optimization is not expected to be effective for increasing removal of this contaminant. Attractive options might be finding a new nearby water source, either groundwater at a different depth, or acceptable water from an adjacent PWS.

It may also be possible to identify radium-producing strata through comparison of well logs or through sampling of water produced by various strata intercepted by the well screen.

Basic system information is as follows:

- Population served: 66 current, 432 at full build out
- Connections: 22 current, 144 at full build out
- Estimated average daily flow: 0.056 mgd
- Total production capacity: 0.047 mgd





Raw water quality is summarized as follows:

- Typical total combined radium range: 5.8 pCi/L to 7.5 pCi/L
- Typical total alpha particle range: 34 to 38 pCi/L
- Total dissolved solids: 416 mg/L (one sample result)
- pH : 7.2 s.u. (one sample result)
- Calcium: 79.1 mg/L (one sample result)
- Magnesium: 18.3 mg/L (one sample result)
- Sodium: 51.3 mg/L (one sample result)
- Chloride: 64 mg/L (one sample result)
- Bicarbonate ( $\text{HCO}_3$ ): 346 mg/L (one sample result)
- Iron: 0.064 mg/L (one sample result)
- Fluoride: 0.4 mg/L (one sample result)

Vista Verde has already investigated possible solutions to its combined radium and alpha particle issues, including a new treatment system, blending from another source, and drilling a new groundwater well. The capital cost of a treatment system was considered but considered not cost effective. Another alternative examined was the drilling of a new groundwater well that would be completed to an undetermined depth. Drilling a new well was expected to avoid the radium problem. The estimated capital cost of completing the new well was between \$50,000 to over \$100,000, depending on the actual depth required.

#### **4.1.2 Capacity Assessment for the Vista Verde**

The project team conducted a capacity assessment of the Vista Verde PWS. The results of the evaluation are separated into four categories: general assessment of capacity, positive aspects of capacity, capacity deficiencies, and capacity concerns. The general assessment of capacity describes the overall impression of FMT capability of the water system. The positive aspects of capacity describe those factors that the system is doing well. These factors should provide opportunities for the system to build upon to improve capacity deficiencies. The capacity deficiencies noted are those aspects that are creating a particular problem for the system related to long-term sustainability. Primarily, these problems are related to the system's ability to meet current or future compliance, ensure proper revenue to pay the expenses of running the system, and to ensure proper operation of the system. The last category is capacity concerns. These are items that, in general, are not causing significant problems for the system at this time. However, the system may want to address them before these issues have the opportunity to cause problems.

The project team interviewed the following individuals:

- Karl Painter - Owner
- George Davis - Contract Operator

#### 4.1.2.1 General Structure of the Water System

The Vista Verde PWS serves 22 lots in the Marvin Gardens subdivision located near Conroe. It serves a population of about 70 people. The current owner, Karl Painter, lives in Odessa, and bought the water system in 2002 while it was under receivership. Prior to purchasing the Vista Verde PWS, he had no previous experience with water systems. The owner contracts with a certified water operator who has over 30 years' experience, but has only worked for Vista Verde for about a year.

The water system consists of one well and two pressure tanks, and all connections are metered. *H2O Billing* provides billing services and conveys phone messages to the operator. The owner stated that the system was not in compliance when he bought it, and he has invested \$100,000 to make system improvements. To increase revenues, he filed a rate case with TCEQ in 2004 and was able to increase the monthly minimum charge from \$25 to \$55. There are 144 lots that could still be developed; however, the existing well cannot produce enough water to serve them. This is discussed in more detail in the section on capacity deficiencies.

#### 4.1.2.2 General Assessment of Capacity

The system has an inadequate level of capacity. There are several major deficiencies regarding FMT capabilities of the system.

#### 4.1.2.3 Positive Aspects of Capacity

In assessing the overall capacity of a PWS, it is important to look at all aspects – positive and negative. It is important for owners of these PWSs to understand those characteristics that are working well, so that those activities can be continued or strengthened. In addition, these positive aspects can assist the owners in addressing the capacity deficiencies or concerns. The factors that were particularly important for the Vista Verde PWS are listed below.

- **Enforcement of Shut-off Policy for Delinquent Bills** – The owner indicated that collections were inadequate when he obtained the water system. In response, he implemented a strong policy for notice and termination of service for non-payment, which is enforced. When a customer becomes delinquent, the billing service notifies the operator to disconnect the water service. Furthermore, late fees and reconnect fees are imposed. As a result, the collection rate has increased substantially.
- **Efforts to Optimize the Distribution System** – The owner has made improvements to the water distribution system that include eliminating dead ends, burying exposed pipe, and installing flush valves.

#### 4.1.2.4 Capacity Deficiencies

The following capacity deficiencies, which impact the ability of the PWS to comply with current regulations and ensure long-term sustainability, were discovered while conducting the assessment:

- **Lack of Compliance with Radium Standard** – The PWS is under a Compliance Agreement with TCEQ which outlines the steps the PWS needs to take to return to compliance. The owner has been working to address the radium problem. So far, he has hired an engineer and obtained information on the costs associated with drilling a new well and is trying to obtain data on the depths of nearby wells, the associated water quality, and whether they also have radium problems. According to the owner, Montgomery County does not allow wells to be drilled on less than 1½-acre lots due to regulations regarding the proximity of wells to septic systems. The lots served by the Vista Verde PWS are generally ¼-acre. Therefore, to drill a new well, the owner would need to purchase additional land.

In addition, the owner has investigated the possibility of connecting to a water system about 1 mile away. There is also the possibility that the PWS could be annexed by nearby UD 8 or UD 9. If no alternative source can be obtained, the owner has considered treating the water with RO technology. However, he is concerned about the costs associated with disposal of the RO reject water, which would be considered a waste. The system needs to continue working toward compliance to avoid further escalation in enforcement actions.

- **Inadequate Financial Accounting for the Water System** – The Vista Verde PWS has a rate schedule approved by TCEQ that limits the company's rate of return. The owner indicated he does not maintain a budget and that the revenue generated by the residents was not enough to cover his expenses. He covers the deficit with his own money. Since he did not provide the project team with any financial information, it was not possible to determine if the amount of money collected is sufficient to cover the cost of current operation, repair and replacement, compliance with the radium regulation, or provide a reserve fund.
- **No Reserve Account** – The lack of a reserve account for anticipated expenses, emergencies, and future capital expenditures is a problem. The owner stated that he covers these expenses with his own funds. In addition, funds have not been set aside to address the current radium compliance problem.
- **Lack of Long-Term Planning for Sustainability** – The lack of planning negatively impacts the ability of the PWS to develop a budget and associated rate structure that will provide for long term needs.  
  
For example, the owner indicated the county has been grading the roads in the subdivision, and as a result, some of the distribution system pipes are exposed and leaking. The homeowners want the pipes replaced and moved. TCEQ records indicate that exposed pipe observed by a TCEQ inspector had been replaced with buried lines. Nevertheless, according to TCEQ records, parts of the water distribution system are believed not to be in conformance with the TCEQ's regulations for minimum burial depth and separation distances.
- **Unclear Rate Schedule** – The written rate schedule provided to the project team is not consistent with the verbal information provided by the owner. The

owner stated that each customer was charged a minimum monthly charge and an additional amount based on usage (per 1,000 gallons). However, the written rate schedule states that "...each residence will be charged for a minimum of 8,000 gallons per month..." and "...customers with a monthly use of between 0 and 8,000 gallons will be billed for 8 units of water at \$4.50 per unit or \$36.00." The rate schedule states: "Vista Verde water system encourages its customers to observe water conservation. The rate charged to its customers is based on the water usage. The rate schedule uses a graduated scale rate scale to encourage water conservation." However, further language in the rate schedule is contradictory and does not reflect the information provided by the owner. The rate schedule provided to customers needs to accurately reflect the method for calculating rates and how charges are billed. If, in fact, the system is charging rates as stated in the rate schedule, *i.e.*, for a minimum of 8,000 gallons, the PWS might be in violation of its tariff.

- **Violation Regarding Water Production** – The owner indicated he had received a Notice of Violation from TCEQ in 2004 because there was only one supply well and its capacity was insufficient to meet TCEQ regulations. Therefore, the Vista Verde PWS cannot connect any more residents to the system. Without an opportunity for growth, this system cannot be self-sustaining. Furthermore, the owner has not implemented a water conservation program, and it appears that the current rate structure does not encourage water conservation. Conservation reduces the demand on the source, reduces chemical and electrical costs, and minimizes wear and tear on equipment such as pumps. In many cases a system can avoid the need for additional source water by implementing an effective water conservation program. This program is critical for the Vista Verde PWS because of its limited source capacity.
- **Lack of Technical Capability**
  - **Water Treatment – Chlorination** – The operator checks the chlorine residual at the pumphouse once a week. To ensure public health protection, TCEQ requires a free residual chlorine level of 0.2 mg/L at the pumphouse and throughout the system. At the time of the site visit, there was no free residual chlorine at the pumphouse.
  - **Water Treatment – Chemical Addition** – The operator was not familiar with a chemical that was being injected at the water source. He was unclear what the chemical was being used for, was not monitoring the dosage, and had not replaced the chemical during the past year.
  - **Water Line Repair Procedures** – The operator indicated he does not have a procedure for disinfecting water lines after repairs.
- **Operator Safety** – During the site visit, the project team observed the operator attempting to unclog the chlorine line by blowing or sucking on it with his mouth. This is an example of unsafe operational practices.

#### 4.1.2.5 Potential Capacity Concerns

The following items were concerns regarding capacity but no specific FMT problems can be attributed to these items at this time. The system should address the items listed below to further improve technical, managerial, and financial capabilities and to improve the system's long-term sustainability.

- **Lack of Written Contract for Water Operations** – The Vista Verde PWS does not have a written agreement with the water operator for services; there is only a verbal agreement. It is always better to have the responsibilities in writing in the event there are ever disagreements about what was expected or what was actually done. In addition, it is a good idea to clearly define expectations for both parties.
- **Lack of Knowledge of SDWA Regulations** – The owner indicated he is not familiar with the SDWA regulations, and that he relies on the operator to operate the system in compliance with TCEQ regulations. In addition, he does not attend any water operations related training. Water system owners should be familiar with the SDWA requirements that apply to their system. They should learn about system needs through site visits and frequent discussions with operators. Lack of first-hand knowledge may result in poor decision-making.
- **Preventative Maintenance** –The operator flushes dead-ends once a month due to brown water complaints from the residents; however, there is no other type of preventative maintenance program. For example, at the time of the assessment, the chlorine injection system was clogged and not pumping chlorine into the system. Since the system is only checked once a week, the residents could be drinking water that has not been disinfected for up to a week at a time.

The operator does not maintain any spare parts for the chlorination or distribution systems. In the event of a line-break, he would have to borrow spare parts from one of the other water systems he operates. These operational practices could cause delays in making critical repairs. There is no scheduled maintenance for valve exercising. Routine valve exercising identifies valves that need replacement and ensures proper operation during the next line repair. Finally, a pile of empty plastic chlorine bleach bottles at the pumphouse indicated poor housekeeping.
- **Lack of Emergency Plan** - The system does not have a written emergency plan, nor does it have emergency equipment such as generators. In the event of a power outage, the residents would run out of water in a very short time because the system has limited storage capacity. The system should have an emergency or contingency plan that outlines what actions will be taken and by whom. The emergency plan should meet the needs of the facility, the geographical area, and the nature of the likely emergencies. Conditions such as storms, floods, major line breaks, electrical failure, drought, system contamination, or equipment

failure should be considered. The emergency plan should be updated annually, and larger facilities should practice implementation of the plan annually.

## 4.2 ALTERNATIVE WATER SOURCE DEVELOPMENT

### 4.2.1 Identification of Alternative Existing Public Water Supply Sources

Using data drawn from the TCEQ drinking water and TWDB groundwater well databases, the PWSs surrounding the Vista Verde PWS were reviewed with regard to their reported drinking water quality and production capacity. PWSs that appeared to have water supplies with water quality issues were ruled out from evaluation as alternative sources, while those without identified water quality issues were investigated further. If it was determined that these PWSs had excess supply capacity and might be willing to sell the excess, or might be a suitable location for a new groundwater well, the system was taken forward for further consideration.

Table 4.1 is a list of the selected PWSs within approximately 6.5 miles of Vista Verde. This distance was selected as the radius for the evaluation because of the relatively large number of large (>1 mgd) PWSs in proximity to the Vista Verde PWS. There are many other large PWSs less than 10 miles from the Vista Verde PWS, but the five large systems selected were considered to be sufficient for determining the realistic economic feasibility of purchasing water from a neighboring PWS or installing a well in the well field of a neighboring PWS.

**Table 4.1 Selected PWSs within 6.5 Miles of the Vista Verde PWS**

PWS ID	PWS Name	Distance from Falling Water	Comments/Other Issues
1700382	Pine Lake Subdivision North	0.6 miles	Small system (0.82 mgd) with no WQ issues.
1700350	April Plaza Marina	0.9 miles	Small system (0.053 mgd) with no radium data
1700154	Lake Lorraine WS	0.9 miles	Small system (0.184 mgd) with moderately high radium concentration
1700543	Lake Conroe Village	1.3 miles	Small system (0.144 mgd) with no WQ issues
1700378	Saddle and Surry Acres Water System	1.4 miles	Small system (0.072 mgd) with no WQ issues
17000116	Montgomery County Utility District 3	1.5 miles	Large (>1 mgd) system with no WQ issues
1700097	Stanley Lake Municipal Utility District	1.6 miles	Large (>1 mgd) system with no WQ issues
1700134	Lake Conroe Forest Subdivision	2.5 miles	Small system (0.216 mgd) with no WQ issues
1700286	Montgomery County Utility District 4	2.6 miles	Large (>1 mgd) system with no WQ issues
1700220	Montgomery County Utility District 9	2.7 miles	Large (>1 mgd) system with no WQ issues
1700176	Montgomery County Utility District 8	2.8 miles	Large (>1 mgd) system with no WQ issues

**Table 4.1 Selected PWSs within 6.5 Miles of the Vista Verde PWS**

PWS ID	PWS Name	Distance from Falling Water	Comments/Other Issues
1700022	City of Montgomery	4.1 miles	Large (>1 mgd) system with no WQ issues
1700546	Montgomery County Utility District 18	5.1 miles	Large (>1 mgd) system with no WQ issues
1700140	Lake Conroe Hills MUD	6.5 miles	Large (>1 mgd) system with no WQ issues

1

2 Since there are many large systems with good water quality near Vista Verde, small  
3 systems were dropped from consideration, and five PWSs were selected for further evaluation.  
4 These are summarized in Table 4.2.

5

**Table 4.2 Public Water Systems Within the Vicinity of the Vista Verde PWS Selected for Further Evaluation**

6

PWS ID	PWS Name	Pop	Conn	Total Production (mgd)	Ave Daily Usage (mgd)	Approx. Dist. from Vista Verde	Comments/Other Issues
1700116	Montgomery County Utility District 3	3492	1164	3.8	3.8	1.5 miles	Has excess capacity. Currently sell retail, but may consider wholesale. May consider annexing Marvin Gardens connections and provide retail.
1700097	Stanley Lake Municipal Utility District	995	2985	0.452	nd	1.6 miles	No excess capacity. However, based on WQ data, this PWS may provide a suitable location for a new well.
1700286	Montgomery County Utility District 4	3309	1103	0.572	nd	2.6 miles	Has excess capacity. Currently sell retail, but may consider wholesale. May consider annexing Marvin Gardens connections and provide retail.
1700220	Montgomery County Utility District 9	3783	1261	1.40	0.45	2.7 miles	No current excess capacity. However, based on WQ data, this PWS may provide a suitable location for a new well. Will have excess supply by 2007
1700176	Montgomery County Utility District 8	3708	1528	1.98	0.55	2.8 miles	No current excess capacity. However, based on WQ data, this PWS may provide a suitable location for a new well. Will have excess supply by 2007

#### 7 4.2.1.1 Montgomery County Utility District 3

8 Montgomery County Utility District (UD) 3 Water System is located northwest of the City  
9 of Conroe, approximately 1.5 miles to the northeast of Vista Verde. The PWS is owned and  
10 operated by Montgomery County UD 3 and is supplied by two groundwater wells completed in

the Evangeline aquifer (Code 121EVJP) and Jasper aquifer (Code 122JSPR). Well #1 in the Evangeline is 900 feet deep and has a pumping capacity of 1,000 gpm, and Well #2 in the Jasper is 740 feet deep and has a pumping capacity of 440 gpm, with a combined total production of 3.8 mgd. Water is disinfected with hypochlorite and treated with an orthophosphate rust inhibitor before being sent to a 25,000 gallon pressure tank. The Montgomery County UD 3 PWS serves a population of 3,492 and has 1,164 metered connections.

The Montgomery County UD 3 PWS does have sufficient excess capacity to supplement Vista Verde's existing supply; and may be willing to connect and provide water to the system wholesale or annex Marvin Gardens and provide water to their users on a retail basis. The Montgomery County UD 3 PWS is operated by the MUD board of directors, who decide whether to sell water wholesale.

#### **4.2.1.2 Stanley Lake Municipal Utility District Water System**

Stanley Lake MUD PWS is located east of the City of Montgomery, approximately 1.6 miles to the northwest of Vista Verde. The PWS is owned and operated by Stanley Lake MUD and is supplied by two groundwater wells completed in the Jasper aquifer (Code 122JSPR). Well #1 in the Jasper is 742 feet deep and has a pumping capacity of 1,212 gpm, and Well #2 in the Jasper is 1,300 feet deep and has a pumping capacity of 875 gpm, with a combined total annual production of 165 million gallons (MG). Stanley Lake MUD has requested permission from Lonestar Conservation District to pump an additional 75 MG of groundwater each year. Water is disinfected with hypochlorite and treated with an orthophosphate rust inhibitor before being sent to a 150,000 gallon storage tank. Stanley Lake MUD PWS serves a population of 3,000 and has approximately 1,000 metered connections.

The Stanley Lake MUD PWS does not currently have sufficient excess capacity to supplement Vista Verde's existing supply. It has not considered selling water wholesale, and believe its current permit would not allow wholesale water sale.

#### **4.2.1.3 Montgomery County Utility District 4 Water System**

The Montgomery County UD 4 PWS is located northwest of the City of Conroe, approximately 2.6 miles to the southeast of Vista Verde. The PWS is owned and operated by Montgomery County UD 4 and is supplied by one groundwater well completed in the Evangeline aquifer (Code 121EVJP). Well #1 in the Evangeline is 908 feet deep and has a pumping capacity of 1,180 gpm. Water is disinfected with hypochlorite and treated with an orthophosphate rust inhibitor before being sent to a 150,000 gallon ground storage tank. Montgomery County UD 4 PWS serves a population of 3,309 and has 1,103 metered connections.

Montgomery County UD 4 PWS has sufficient excess capacity to supplement Vista Verde's existing supply. The District's board of directors has not considered selling water wholesale in the past, but may consider it in the future.



#### **4.2.1.4 Montgomery County Utility District 9 Water System**

Montgomery County UD 9 PWS is located northwest of the City of Conroe, approximately 2.7 miles to the northeast of Vista Verde. The PWS is owned and operated by Montgomery County UD 9, which serves Walden Subdivision along with Montgomery County UD 8. UD 9 and UD 8 are interconnected and are operated as one system.

The Montgomery County UD 9 PWS is supplied by one groundwater well completed in the Jasper aquifer (Code 122JSPR). Well #1 is 750 feet deep and has a pumping capacity of 1,300 gpm. Daily usage is approximately 1.33 MGD.

Water is disinfected with hypochlorite and treated with an orthophosphate rust inhibitor before being sent to a storage tanks with a combined capacity of 1,644,000 gallons. Montgomery County MUD 9 PWS serves a population of 3,783 and has 1,021 metered connections.

The Montgomery County UD 9 PWS does not currently have sufficient excess capacity to supplement Vista Verde's existing supply and is currently at maximum capacity. A new 1,500 gpm well is projected to be completed by the end of 2006 and will nearly double its existing capacity. The Montgomery County UD 9 does not sell water wholesale, but may be willing to annex an area and provide retail water service to area users. The Montgomery County UD 9 PWS is operated by a board of directors who decide whether to sell water.

#### **4.2.1.5 Montgomery County Utility District 8 Water System**

Montgomery County UD 8 PWS is located northwest of the City of Conroe, approximately 2.8 miles to the northeast of Vista Verde. The PWS is owned and operated by Montgomery County UD 8, which serves Walden Subdivision along with Montgomery County UD 9 PWS. UD 8 and UD 9 are interconnected and are operated as one system.

The Montgomery County UD 8 PWS is supplied by two groundwater wells completed in the Jasper aquifer (Code 122JSPR). Both wells are 750 feet deep. Well #1 has a pumping capacity of 938 gpm and Well #2 has a pumping capacity of 900 gpm. The daily use is approximately 3.18 mgd. The system is currently at maximum capacity. A new 1,500 gpm well is scheduled to be installed at UD 9, which will provide more than adequate capacity for several years to come.

Water is disinfected with hypochlorite and treated with an orthophosphate rust inhibitor before being sent to ground storage tanks with a combined capacity of 1,250,000 gallons. The UD 8 PWS serves a population of 3,708 and has 1,194 metered connections.

The Montgomery County UD 8 PWS does not currently have sufficient excess capacity to supplement Vista Verde's existing supply. UD 8 does not sell water wholesale, but may be willing to annex an area and provide retail water service to area users. Montgomery County UD 8 PWS is operated by the UD board of directors who would decide whether to sell water.

## **4.2.2 Potential for New Groundwater Sources**

### **4.2.2.1 Installing New Compliant Wells**

Developing new wells or well fields is likely to be an attractive solution, provided good quality groundwater available in sufficient quantity can be identified. Since a number of water systems in the area do not have water quality problems, it is likely that compliant groundwater can be found.

Installation of a new well within in the vicinity of the system intake point is likely to be an attractive option for obtaining compliant water since the Vista Verde PWS is already familiar with operation of a water well. As a result, existing wells with good water quality should be investigated. Re-sampling and test pumping would be required to verify and determine the quality and quantity of water at those wells.

Installation of a new well to the Evangeline/Chicot or Jasper aquifers is a possibility for Vista Verde. Additionally, several PWSs located within 2 miles of Vista Verde have wells drilled to a depth of 900-1,000 feet and produce large quantities of compliant water.

The historic aquifer maps from the TWDB indicate that at the approximate location of the Vista Verde well, the fresh water-bearing sands of the Evangeline/Chicot aquifer begins at 70 feet deep and extend to approximately 150 feet deep. The water-bearing sands of the Jasper formation at the approximate location of Vista Verde appear to extend from 580 feet deep to approximately 2,300 feet deep.

The Vista Verde well is set at 340 feet deep, apparently located in between these two productive aquifers. It may be possible to adjust the screen depth of the existing well to access the Evangeline/Chicot aquifer water-bearing sand, although further study would be required to make that determination. The analysis in Section 3 suggests deepening the existing well to 900 feet. The Jasper aquifer has better quality water than the shallower aquifer.

Some of the alternatives suggest new wells be drilled in areas where existing wells produce compliant water with levels of combined radium-226 and radium-228 below the MCL of 5 pCi/L and levels of gross alpha particles below the MCL of 15 pCi/L. In developing the cost estimates, Parsons assumed the aquifer in these areas would produce the required amount of water with only one well. Site investigations and geological research, which are beyond the scope of this study, could indicate whether the aquifer at a particular site and depth would provide the amount of water needed or if more than one well would need to be drilled in separate areas. Two wells are used in cases where the PWS is large enough that two wells are required by TCEQ rules.

### **4.2.2.2 Results of Groundwater Availability Modeling**

The Gulf Coast aquifer system that extends along the entire Texas coastal region is the groundwater source for the PWS. Five hydrogeologic units compose the aquifer system, from land surface downward, the Chicot aquifer, the Evangeline aquifer, the Burkenville confining

unit, the Jasper aquifer, and the Catahoula confining unit. Both the Evangeline aquifer and the Jasper aquifer are the primary groundwater sources reported in the TCEQ database for wells located within 15 miles of the Vista Verde PWS, and throughout central Montgomery County.

Regional groundwater withdrawal throughout the northern part of the Gulf Coast aquifer system is extensive and likely to steadily increase over the next decades. Since the 1900s, large groundwater withdrawals have resulted in declines in the aquifer's potentiometric surface from tens to hundreds of feet conditions (Mace, *et al.* 2006). A groundwater availability model (GAM) for the northern part of the Gulf Coast aquifer was recently developed by the TWDB. Modeling was performed by the U.S. Geological Survey (USGS) to simulate historical conditions (Kasmerek and Robinson 2004), and to develop long-term groundwater projections (Kasmerek, Reece and Houston 2005). Modeling of a TWDB scenario based on 50-year regional projections by regional user groups anticipate extensive groundwater use and drop in aquifer levels, with the largest declines around the Houston metropolitan area.

GAM simulation data reported by Kasmerek, Reece and Houston (2005) indicate that over a 50-year simulation, withdrawals for the entire Gulf Coast aquifer are expected to peak at 920 mgd in 2020, and subsequently decrease to 850 mgd. Withdrawals from the Evangeline aquifer represent nearly half of that value, estimated at 420 mgd in 2000. This rate would steadily decrease to 315 mgd in 2020, and remain within 4 percent of this value for the remaining simulation period. Withdrawals from the Jasper aquifer represent only a fraction of those values, with an estimated 36 mgd withdrawal in 2000. The rate is projected to increase to 51 mgd by 2010, approximately 42 percent, and stabilize within 6 percent of that value through 2050. A minimum increase in water elevation of the Evangeline aquifer is anticipated throughout Montgomery County during the 50-year simulation period. For the Jasper aquifer, however, a depression cone centered in Montgomery and Jackson Counties is anticipated. A water level reduction from 50 to 100 feet is projected for 2050 in north central Montgomery County where the PWS is located.

The GAM of the northern part of the Gulf Coast aquifer was not run for the PWS because groundwater availability would reflect regional conditions largely driven by groundwater withdrawal from the Houston area. Water use by the small PWS would represent a minor addition to the regional water use, making potential changes in aquifer levels well beyond the spatial resolution of the regional GAM model.

#### **4.2.3 Potential for New Surface Water Sources**

Potential for development of new surface water sources for the Vista Verde PWS is minimum, even though the PWS is located near the shores of Lake Conroe. Availability of new surface water sources is limited over the entire river basin, and within the site vicinity.

The Vista Verde PWS is located in the San Jacinto basin where a severe reduction in surface water availability is expected by the year 2050. The TWDB's 2002 Water Plan anticipated a 90 percent reduction in water availability, from 112,662 acre-feet per year (AFY) in 2000 to 11,282 AFY in 2050.

The vicinity of the Vista Verde PWS has a minimum availability of surface water for new uses. The TCEQ availability map for the San Jacinto basin indicates that, over a 20-mile radius of the site, unappropriated flows for new uses are typically available from 25 to 75 percent of the time. This supply is inadequate because the TCEQ requires 100 percent supply availability for a PWS.

#### **4.2.4 Alternative Water Source Options for Detailed Consideration**

The initial review of alternative sources of water results in the following options for more-detailed consideration:

1. Vista Verde PWS (Alternative VV-1). A new groundwater well would be completed at a different depth in the vicinity of the existing well at Vista Verde and would utilize the rest of the existing system.
2. Montgomery County MUD 3 PWS (Alternative VV-2). This alternative involves purchasing finished drinking water from Montgomery County MUD 3 PWS, and constructing a pump station and pipeline to transfer the pumped water to the Vista Verde PWS. Based on the water quality data in the TCEQ database, it is expected that finished water from this system would be compliant with drinking water MCLs, though there may be a minor issue with iron to take into consideration. An agreement would need to be negotiated with Montgomery County MUD 3 PWS to provide this water..
3. Stanley Lake MUD PWS (Alternative VV-3). This alternative involves installing a new well at the Stanley Lake MUD well field, and constructing a pump station and pipeline to transfer the water to the Vista Verde PWS. Based on the water quality data in the TCEQ database, it is expected that groundwater from this well field would be compliant with drinking water MCLs, although there may be a minor issue with iron. An agreement would need to be negotiated with Stanley Lake MUD or land would have to be purchased to implement this alternative.
4. Montgomery County UD 4 PWS (Alternative VV-4). This alternative involves purchasing finished drinking water from Montgomery County UD 4, and constructing a pump station and pipeline to transfer the pumped water to the Vista Verde PWS. Based on the water quality data in the TCEQ database, it is expected that finished water from this system would be compliant with drinking water MCLs, though there may be a minor issue with iron to take into consideration. An agreement would need to be negotiated with Montgomery County UD 4 to provide this water.
5. Montgomery County UD 9 PWS (Alternative VV-5). This alternative involves purchasing finished drinking water from Montgomery County UD 9, and constructing a pump station and pipeline to transfer the pumped water to the Vista Verde PWS. Based on the water quality data in the TCEQ database, it is expected that finished water from this system would be compliant with drinking water MCLs,

although there may be a minor issue with iron to take into consideration. An agreement would need to be negotiated with Montgomery County Utility District 9 to provide this water.

6. Montgomery County UD 8 PWS (Alternative VV-6). This alternative involves purchasing finished drinking water from Montgomery County UD 8, and constructing a pump station and pipeline to transfer the pumped water to the Vista Verde PWS. Based on the water quality data in the TCEQ database, it is expected that finished water from this system would be compliant with drinking water MCLs, although there may be a minor issue with iron to take into consideration. An agreement would need to be negotiated with Montgomery County UD 8 to provide this water.

7. Alternatives VV-7 and VV-8 provide the estimated costs to install wells 5 miles and 1 mile, respectively, from Vista Verde.

### **4.3 TREATMENT OPTIONS**

#### **4.3.1 Centralized Treatment Systems**

Centralized treatment of the well water is identified as a potential option. Ion exchange, WRT Z-88, and  $\text{KMnO}_4$  treatment could all be potentially applicable. The central IX treatment alternative is VV-9, the central WRT Z-88 treatment alternative is VV-10, and the central  $\text{KMnO}_4$  treatment alternative is VV-11.

#### **4.3.2 Point-of-Use Systems**

POU treatment using resin-based adsorption technology or RO is valid for total radium removal. The POU treatment alternative is VV-12.

#### **4.3.3 Point-of-Entry Systems**

POE treatment using resin based adsorption technology or RO is valid for total radium removal. The POE treatment alternative is VV-13.

### **4.4 Bottled Water**

Providing bottled water is considered an interim measure to be used until a compliance alternative is implemented. Even though the community is small and people know each other, it would be reasonable to require a quarterly communication advising customers of the need to take advantage of the bottled water program. An alternative to providing delivered bottled water is to provide a central, publicly accessible dispenser for treated drinking water. Alternatives addressing bottled water are VV-14, VV-15, and VV-16.

## **4.5 ALTERNATIVE DEVELOPMENT AND ANALYSIS**

A number of potential alternatives for compliance with the MCLs for combined radium-226 and radium-228 and gross alpha particles have been identified. Each potential alternative is described in the following subsections. It should be noted that the cost information given is the capital cost and change in O&M costs associated with implementing the particular alternative. Appendix C contains cost estimates for the compliance alternatives. These compliance alternatives represent a range of possibilities, and a number of them are likely not feasible. However, all have been presented to provide a complete picture of the range of alternatives considered. It is anticipated that a PWS will be able to use the information contained herein to select the most attractive alternative(s) for more detailed evaluation and possible subsequent implementation.

### **4.5.1 Alternative VV-1: New Well at the Current Vista Verde Location**

This alternative involves completing a new deeper well at the current Vista Verde site, and tying it into the existing water system. The new well would be 900 feet deep. Based on the water quality data in the TCEQ database, it is expected that groundwater from this location at a different depth may be compliant with drinking water MCLs.

The estimated capital cost for this alternative includes completing the new well and constructing the connection piping and a new storage tank and feed pump set to supply water to the existing system. The estimated capital cost for this alternative is \$213,832, and the estimated annual O&M cost for this alternative is \$13,896.

The reliability of adequate amounts of compliant water under this alternative should be good. From the perspective of the Vista Verde PWS, this alternative would be characterized as easy to operate and repair, since O&M and repair of the current system is well understood, and Vista Verde personnel currently operate it. If the decision were made to perform blending, then the operational complexity would increase.

Obtaining agreements is not necessary for implementing this option, and should not impact the feasibility of this alternative.

### **4.5.2 Alternative VV-2: Purchase Water from Montgomery County Utility District 3**

This alternative would require constructing a pipeline from Montgomery County UD 3 to the Vista Verde PWS. A pump station would be required to overcome pipe friction and the elevation differences between Montgomery County UD 3 and Vista Verde, and a storage tank and feed pump set would also be required at the Vista Verde site. The required pipeline would be constructed of 4-inch pipe and would follow several minor roads, April Waters Drive West, and Highway 105, to the Vista Verde PWS. Using the route shown in Figure 4.1, the pipeline required would be 3.1 miles long. The pipeline would terminate at the new storage tank feed pump set.

The pump station would include two pumps (minimum 2 hp each), one of the pumps is a standby, and would be housed in a building. It is assumed the pumps and piping would be installed with capacity to meet all water demand for the Marvin Gardens Subdivision, since the incremental cost would be relatively small, and it would provide operational flexibility.

This alternative involves regionalization by definition, since the Vista Verde PWS would obtain drinking water from an existing larger supplier. It is possible that the Vista Verde PWS could turn over provision of drinking water to the Montgomery County UD 3 instead of purchasing water. Other non-compliant systems have not been identified near Vista Verde or along the pipeline route, so there is little chance to share in implementation of this alternative.

The estimated capital cost for this alternative includes constructing the pipeline, pump station, and storage tank and feed pump set. The estimated O&M cost for this alternative includes the purchase price for the treated water minus the cost related to current operation of the Vista Verde well, plus maintenance cost for the pipeline, and power and O&M labor and materials for the pump station. The estimated capital cost for this alternative is \$1.09 million, and the estimated annual O&M cost for this alternative is \$56,007.

The reliability of adequate amounts of compliant water under this alternative should be good. Montgomery County UD 3 provides treated surface water on a large scale, facilitating adequate O&M resources. From the perspective of the Vista Verde PWS, this alternative would be characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations is well understood. If the decision were made to perform blending, then the operational complexity would increase.

The feasibility of this alternative is dependent on an agreement being reached with the Montgomery County UD 3 to purchase treated drinking water.

#### **4.5.3 Alternative VV-3: New Well at Water from Stanley Lake Municipal Utility District**

This alternative would require constructing a pipeline from Stanley Lake MUD to the Vista Verde PWS. A pump station would be required to overcome pipe friction and the elevation differences between Stanley Lake MUD and Vista Verde, and a storage tank and feed pump set would also be required at the Vista Verde site. The required pipeline would be constructed of 4-inch pipe and would follow several minor roads, Stewart Road., Freeport Drive, and Highway 105, to the Vista Verde PWS. Using the route shown in Figure 4.1, the pipeline required would be 2.6 miles long. The pipeline would terminate at the new storage tank and feed pump set.

The pump station would include two pumps (minimum 2 hp each), one of the pumps is a standby, and would be housed in a building. It is assumed the pumps and piping would be installed with capacity to meet all water demand for the Marvin Gardens Subdivision, since the incremental cost would be relatively small, and it would provide operational flexibility.

This alternative has limited opportunity for regionalization in that Vista Verde could possibly turn over provision of drinking water to the Stanley Lake MUD instead of installing its own new well. Other non-compliant systems have not been identified near Vista Verde or along the pipeline route, so there is little opportunity to share in implementation of this alternative.

The estimated capital cost for this alternative includes constructing the pipeline, pump station, and storage tank and feed pump set. The estimated O&M cost for this alternative are related to maintenance cost for the pipeline, and power and O&M labor and materials for the pump station, storage, and feed pumps. The estimated capital cost for this alternative is \$1.02 million, and the estimated annual O&M cost for this alternative is \$29,222.

The reliability of adequate amounts of compliant water under this alternative should be good. From the Vista Verde's perspective, this alternative would be characterized as easy to operate and repair, since O&M and repair of pipelines and pumps stations is well understood, and Vista Verde currently operates pumps and wells.

The feasibility of this alternative is dependent on an agreement being reached with the Stanley Lake MUD to install a well in its well field.

#### **4.5.4 Alternative VV-4: Purchase Water from Montgomery County Utility District 4**

This alternative would require constructing a pipeline from Montgomery County UD 4 to the Vista Verde PWS. A pump station would be required to overcome pipe friction and the elevation differences between Montgomery County UD 4 and Vista Verde, and a storage tank and feed pump set would also be required at the Vista Verde site. The required pipeline would be constructed of 4-inch pipe and would follow several minor roads, S. Park Drive, April Wind Drive South, and Highway 105, to the Vista Verde PWS. Using the route shown in Figure 4.1, the pipeline required would be 4.4 miles long. The pipeline would terminate at the new storage tank and feed pumps.

The pump station would include two pumps (minimum 2 hp each), one of the pumps is a standby, and would be housed in a building. It is assumed the pumps and piping would be installed with capacity to meet all water demand for the Marvin Gardens Subdivision, since the incremental cost would be relatively small, and it would provide operational flexibility.

This alternative involves regionalization by definition, since Vista Verde would obtain drinking water from an existing larger supplier. It is possible that the Vista Verde PWS could turn over provision of drinking water to the Montgomery County UD 4 instead of purchasing water. Other non-compliant systems have not been identified near Vista Verde nor along the pipeline route, so there is little opportunity to share in implementation of this alternative.

The estimated capital cost for this alternative includes constructing the pipeline, pump station, and storage tank and feed pumps. The estimated O&M cost for this alternative includes the purchase price for the treated water minus the cost related to current operation of the Vista



Verde well, plus maintenance cost for the pipeline, and power and O&M labor and materials for the pump station. The estimated capital cost for this alternative is \$1.44 million, and the estimated annual O&M cost for this alternative is \$56,782.

The reliability of adequate amounts of compliant water under this alternative should be good. Montgomery County UD 4 provides treated surface water on a large scale, facilitating adequate O&M resources. From the perspective of the Vista Verde PWS, this alternative would be characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations is well understood. If the decision were made to perform blending, then the operational complexity would increase.

The feasibility of this alternative is dependent on an agreement being reached with the Montgomery County UD 4 to purchase treated drinking water.

#### **4.5.5 Alternative VV-5: Purchase Water from Montgomery County Utility District 9**

This alternative would require constructing a pipeline from Montgomery County UD 9 to the Vista Verde PWS. A pump station would be required to overcome pipe friction and the elevation differences between Montgomery County UD 9 and Vista Verde, and a storage tank and feed pumps would also be required at the Vista Verde site. The required pipeline would be constructed of 4-inch pipe and would follow several minor roads, Walden Road and Highway 105, to the Vista Verde PWS. Using the route shown in Figure 4.1, the pipeline required would be 6.9 miles long, and would terminate at the new storage tank and feed pumps.

The pump station would include two pumps (minimum 2 hp each), one of the pumps is a standby, and would be housed in a building. It is assumed the pumps and piping would be installed with capacity to meet all water demand for the Marvin Gardens Subdivision, since the incremental cost would be relatively small, and it would provide operational flexibility.

This alternative involves regionalization by definition, since Vista Verde would obtain drinking water from an existing larger supplier. It is possible that the Vista Verde PWS could turn over provision of drinking water to the Montgomery County UD 9 instead of purchasing water. Other non-compliant systems have not been identified near Vista Verde nor along the pipeline route, so there is little opportunity to share in implementation of this alternative.

The estimated capital cost for this alternative includes constructing the pipeline, pump station, and storage tank and feed pumps. The estimated O&M cost for this alternative includes the purchase price for the treated water minus the cost related to current operation of the Vista Verde well, plus maintenance cost for the pipeline, and power and O&M labor and materials for the pump station. The estimated capital cost for this alternative is \$2.05 million, and the estimated annual O&M cost for this alternative is \$57,639.

The reliability of adequate amounts of compliant water under this alternative should be good. Montgomery County UD 9 provides treated surface water on a large scale, facilitating adequate O&M resources. From the perspective of the Vista Verde, this alternative would be

characterized as easy to operate and repair, since O&M and repair of pipelines and pump stations is well understood. If the decision were made to perform blending, then the operational complexity would increase.

The feasibility of this alternative is dependent on an agreement being reached with the Montgomery County UD 9 to purchase treated drinking water.

#### **4.5.6 Alternative VV-6: Purchase Water from Montgomery County Utility District 8**

This alternative would require constructing a pipeline from Montgomery County UD 8 to the Vista Verde PWS. A pump station would be required to overcome pipe friction and the elevation differences between Montgomery County UD 8 and Vista Verde, and a storage tank and feed pump set would also be required at the Vista Verde site. The required pipeline would be constructed of 4-inch pipe and would follow several minor roads, Walden Road, and Highway 105, to the Vista Verde PWS. Using the route shown in Figure 4.1, the pipeline required would be 7.3 miles long. The pipeline would terminate at the new storage tank and feed pumps.

The pump station would include two pumps (minimum 2 hp each), one of the pumps is a standby, and would be housed in a building. It is assumed the pumps and piping would be installed with capacity to meet all water demand for the Marvin Gardens Subdivision, since the incremental cost would be relatively small, and it would provide operational flexibility.

This alternative involves regionalization by definition, since Vista Verde would obtain drinking water from an existing larger supplier. It is possible that the Vista Verde could turn over provision of drinking water to the Montgomery County UD 9 instead of purchasing water. Other non-compliant systems have not been identified near Vista Verde nor along the pipeline route, so there is little opportunity to share in implementation of this alternative.

The estimated capital cost for this alternative includes constructing the pipeline, pump station, and storage tank and feed pumps. The estimated O&M cost for this alternative includes the purchase price for the treated water minus the cost related to current operation of the Vista Verde well, plus maintenance cost for the pipeline, and power and O&M labor and materials for the pump station. The estimated capital cost for this alternative is \$2.15 million, and the estimated annual O&M cost for this alternative is \$57,784.

The reliability of adequate amounts of compliant water under this alternative should be good. Montgomery County UD 8 provides treated surface water on a large scale, facilitating adequate O&M resources. From the perspective of the Vista Verde PWS, this alternative would be characterized as easy to operate and repair, were made to perform blending, then the operational complexity would increase.

The feasibility of this alternative is dependent on an agreement being reached with the Montgomery County UD 8 to purchase treated drinking water.

#### **4.5.7 Alternative VV-7: New Well at 5 miles**

This alternative consists of installing one new well within 5 miles of the Vista Verde water system that would produce compliant water in place of the water produced by the existing wells. At this level of study, it is not possible to positively identify an existing well nor the location where a new well could be installed.

This alternative would require constructing one new 900-foot well, a new pump station with storage tank near the new well, and a pipeline from the new well/tank to a new storage tank and feed pump set for the Vista Verde PWS. The pump station and storage tank would be necessary to overcome pipe friction and changes in land elevation. For this alternative, the pipeline is assumed to be 5 miles long, and would be a 4-inch line that discharges to the new storage tank at the Vista Verde PWS. The pump station would include two pumps, including one standby, and would be housed in a building.

Depending on well location and capacity, this alternative could present some options for a more regional solution. It may be possible to share water and costs with another nearby system.

The estimated capital cost for this alternative includes installing the well, and constructing the pipeline, pump station, and storage tank and feed pumps. The estimated O&M cost for this alternative includes O&M for the pipeline and pump station. The estimated capital cost for this alternative is \$1.65 million, and the estimated annual O&M cost for this alternative is \$30,011.

The reliability of adequate amounts of compliant water under this alternative should be good, since water wells, pump stations, and pipelines are commonly employed. From the perspective of the Vista Verde PWS, this alternative would be similar to operate as the existing system. Vista Verde personnel have experience with O&M of wells, pipelines, and pump stations.

The feasibility of this alternative is dependent on the ability to find an adequate existing well or success in installing a well that produces an adequate supply of compliant water. It is possible an alternate groundwater source could not be found on land owned by Vista Verde, so landowner cooperation would likely be required at the new location.

#### **4.5.8 Alternative VV-8: New Well at 1 mile**

This alternative consists of installing one new well within 1 mile of Vista Verde that would produce compliant water in place of the water produced by the existing well. At this level of study, it is not possible to positively identify an existing well or the location where a new well could be installed.

This alternative would require constructing one new 900-foot well, a pipeline from the new well to a new storage tank, and pump set for the Vista Verde system. For this alternative, the pipeline is assumed to be 1 mile long, and would be a 4-inch line that discharges to the new storage tank at the Vista Verde PWS.

1 Depending on well location and capacity, this alternative could present some options for a  
2 more regional solution. It may be possible to share water and costs with another nearby  
3 system.

4 The estimated capital cost for this alternative includes installing the well and constructing  
5 the pipeline and pump station. The estimated O&M cost for this alternative includes O&M for  
6 the pipeline and pump station. The estimated capital cost for this alternative is \$409,002, and  
7 the estimated annual O&M cost for this alternative is \$14,084.

8 The reliability of adequate amounts of compliant water under this alternative should be  
9 good, since water wells, pump stations and pipelines are commonly employed. From the  
10 perspective of the Vista Verde PWS, this alternative would be similar to operate as the existing  
11 system. Vista Verde personnel have experience with O&M of wells, pipelines and pump  
12 stations.

13 The feasibility of this alternative is dependent on the ability to find an adequate existing  
14 well or success in installing a well that produces an adequate supply of compliant water. It is  
15 possible an alternate groundwater source would not be found on land owned by Vista Verde, so  
16 landowner cooperation may be required.

#### 17 **4.5.9 Alternative VV-9: Central IX Treatment**

18 The system would continue to pump water from Vista Verde PWS well, and would treat  
19 the water through an IX system prior to distribution. For this option, the entire flow of raw  
20 water would be treated to obtain compliant water because the radium concentration is relatively  
21 high. Water in excess of that currently being produced would be required for backwashing and  
22 regeneration of the resin beds.

23 The IX treatment plant would be located at the Vista Verde PWS well site, and would  
24 feature a 400 square foot (ft<sup>2</sup>) building with a paved driveway; the pre-constructed IX  
25 equipment on a skid, a 24"x50" commercial brine drum with regeneration equipment, two  
26 transfer pumps, a 5,000-gallon tank for storing the treated water, a 6,000-gallon tank for storing  
27 spent backwash water, and a 2,000-gallon tank for storing regenerant waste. The spent  
28 backwash water and regenerant waste would be trucked off-site for disposal. The treated water  
29 would be chlorinated and stored in the new treated water tank prior to being pumped into the  
30 distribution system. The entire facility is fenced.

31 The estimated capital cost for this alternative is \$306,820, and the estimated annual O&M  
32 cost is \$25,590.

33 Reliability of supply of adequate amounts of compliant water under this alternative is  
34 good, since IX treatment is a common and well-understood treatment technology. IX treatment  
35 does not require high pressure, but can be affected by interfering constituents in the water. The  
36 O&M efforts required for the central IX treatment plant may be significant, and operating  
37 personnel would require training with ion exchange.

#### **4.5.10 Alternative VV-10: WRT Z-88 Treatment**

The system would continue to pump water from the Vista Verde PWS well, and would treat the water through the WRT Z-88 adsorption system prior to distribution. The full flow of raw water would be treated by the WRT Z-88 system because the media specifically adsorb radium and do not affect other constituents. There is no liquid waste generated in this process. The WRT Z-88 media would be replaced and disposed by WRT in an approved low-level radioactive waste landfill after 1 to 2 years of operation.

This alternative consists of constructing the WRT Z-88 treatment system at the existing Vista Verde PWS well site. WRT owns the Z-88 equipment, and would pay for installation of the system and auxiliary facilities for an initial setup fee of \$51,000. The plant would comprise a 400 ft<sup>2</sup> building with a paved driveway; the pre-constructed Z-88 adsorption system (two 26" diameter x 115" tall vessels) owned by WRT; the piping system, and a water storage tank and feed pumps. The entire facility is fenced. The treated water would be chlorinated prior to distribution.

The estimated capital cost for this alternative is \$310,880, and the annual O&M cost is estimated to be \$23,883.

Based on many pilot testing results and some full-scale plant data, this technology appears to be reliable. It is very simple to operate and the media replacement and disposal would be handled by WRT. Because WRT owns the equipment the capital cost is relatively low. The main operating cost would be the treated water fee charged by WRT. One concern with this technology is the potential health effect the level of radioactivity accumulated in the WRT Z-88 vessel would have on O&M personnel after long-term operation.

#### **4.5.11 Alternative VV-11: KMnO<sub>4</sub>-Greensand Filtration**

The system would continue to pump water from Vista Verde PWS well, and would treat the water through a greensand filter system prior to distribution. For this option, the entire flow of raw water would be treated and the flow would be decreased when one of the two 50 percent filters is being backwashed by raw water.

The greensand plant, which would be located at the Vista Verde PWS well site, would feature a 400 ft<sup>2</sup> building with a paved driveway; the pre-constructed filters and a KMnO<sub>4</sub> solution tank on a skid; a 3,000-gallon spent backwash tank, piping systems, and a storage tank and feed pumps for treated water. The spent backwash would be allowed to settle in the spent backwash tank, and the water would be recycled to the head of the plant, and there would be periodic disposal of accumulated sludge. The entire facility would be fenced.

The estimated capital cost for this alternative is \$344,955 and the annual O&M is estimated to be \$21,540.

Reliability of the supply of adequate amounts of compliant water under this alternative is good, since KMnO<sub>4</sub>-greensand is an established treatment technology for radium removal. The

O&M efforts required are moderate and the operating personnel would need to ensure that  $\text{KMnO}_4$  is not overfed. The spent backwash water contains  $\text{MnO}_2$  particles with sorbed radium, and the level of radioactivity in the backwash is relatively low.

#### **4.5.12 Alternative VV-12: Point-of-Use Treatment**

This alternative consists of the continued operation of the Vista Verde well, plus treatment of water to be used for drinking or food preparation at the POU to remove radium and alpha particle activity. The purchase, installation, and maintenance of POU treatment systems to be installed “under the sink” would be necessary for this alternative. Blending is not an option in this case.

This alternative would require installing the POU treatment units in residences and other buildings that provide drinking or cooking water. Vista Verde staff would be responsible for purchase and maintenance of the treatment units, including media or membrane and filter replacement, periodic sampling, and necessary repairs. In houses, the most convenient point for installation of the treatment units is typically under the kitchen sink, with a separate tap installed for dispensing treated water. Installation of the treatment units in kitchens would require the entry by Vista Verde or contract personnel into the residences of customers. As a result, cooperation of customers would be important for success implementing this alternative. The treatment units could be installed so they could be accessed without house entry, but that would complicate the installation and increase costs.

For the cost estimate, it is assumed the POU radium and alpha particle activity treatment would involve RO. RO treatment processes typically produce a reject water stream that requires disposal. The reject stream results in an increase in the overall volume of water used. POU systems have the advantage of using only a minimum volume of treated water for human consumption. This minimizes the size of the treatment units, the water required for treatment, and the quantity of waste for disposal. For this alternative, it is assumed the increase in water consumption is insignificant in terms of supply cost, and that the reject waste stream could be discharged to the house septic or sewer system.

This alternative does not present options for a shared solution.

The estimated capital cost for this alternative includes the cost to purchase and install the POU treatment systems. The estimated O&M cost for this alternative includes the purchase and replacement of filters and media or membranes, as well as periodic sampling and record keeping. The estimated capital cost for this alternative is \$95,040, and the estimated annual O&M cost for this alternative is \$84,398. For the cost estimate, it is assumed that one POU treatment unit would be required for each of the 144 connections that will be in the Marvin Gardens Subdivision system at full-build-out.

The reliability of adequate amounts of compliant water under this alternative is fair, since it relies on the active cooperation of the customers for system installation, use, and maintenance, and only provides compliant water to single tap within a house. Additionally, the O&M efforts required for the POU systems would be significant, and current Vista Verde

personnel are inexperienced in this type of work. From the perspective of the Vista Verde PWS, this alternative would be characterized as more difficult to operate due to the in-home requirements and the large number of individual units. It should be noted that the POU treatment units would need to be more complex than units typically found in commercial retail outlets to meet regulatory requirements, making purchase and installation more expensive.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other water supply entities.

#### **4.5.13 Alternative VV-13: Point-of-Entry Treatment**

This alternative consists of the continued operation of the Vista Verde well, plus treatment of water as it enters residences to remove radium and alpha particle activity. The purchase, installation, and maintenance of the treatment systems at the point of entry to a household would be necessary for this alternative. Blending is not an option in this case.

This alternative would require the installation of the POE treatment units at houses and other buildings that provide drinking or cooking water. The Vista Verde PWS would be responsible for purchasing and maintaining the treatment units, including media or membrane and filter replacement, periodic sampling, and necessary repairs. It may also be desirable to modify piping so water for non-consumptive uses can be withdrawn upstream of the treatment unit. The POE treatment units would be installed outside the residences, so entry would not be necessary for O&M. Some cooperation from customers would be necessary for installation and maintenance of the treatment systems.

For the cost estimate, it is assumed the POE radium and alpha particle activity treatment would involve RO. RO treatment processes typically produce a reject water stream that requires disposal. The waste streams result in an increased overall volume of water used. POE systems treat a greater volume of water than POU systems. For this alternative, it is assumed the increase in water consumption is insignificant in terms of supply cost, and that the reject waste stream could be discharged to the house septic or sewer system.

This alternative does not present options for a shared solution.

The estimated capital cost for this alternative includes the cost to purchase and install the POE treatment systems. The estimated O&M cost for this alternative includes the purchase and replacement of filters and media or membranes, as well as periodic sampling and record keeping. The estimated capital cost for this alternative is \$1.66 million, and the estimated annual O&M cost for this alternative is \$195,998. For the cost estimate, it is assumed that one POU treatment unit would be required for each of the 144 connections that will be in the Marvin Gardens Subdivision system at full-build-out.

The reliability of adequate amounts of compliant water under this alternative is fair, but better than POU systems since it relies less on the active cooperation of the customers for system installation, use, and maintenance, and compliant water is supplied to all taps within a house. Additionally, the O&M efforts required for the POE systems would be significant, and

the current Vista Verde personnel are inexperienced in this type of work. From the perspective of the Vista Verde PWS, this alternative would be characterized as more difficult to operate due to the on-property requirements and the large number of individual units.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other water supply entities.

#### **4.5.14 Alternative VV-14: Public Dispenser for Treated Drinking Water**

This alternative consists of the continued operation of the Vista Verde well, plus dispensing treated water for drinking and cooking at a publicly accessible location. Implementing this alternative would require purchasing and installing a treatment unit where customers would be able to come and fill their own containers. This alternative also includes notifying customers of the importance of obtaining drinking water from the dispenser. In this way, only a relatively small volume of water requires treatment, but customers would be required to pick up and deliver their own water. Blending is not an option in this case. It should be noted that this alternative would be considered an interim measure until a compliance alternative is implemented.

Vista Verde personnel would be responsible for maintenance of the treatment unit, including media or membrane replacement, periodic sampling, and necessary repairs. The spent media or membranes will require disposal. This alternative relies on a great deal of cooperation and action from the customers in order to be effective.

This alternative does not present options for a regional solution.

The estimated capital cost for this alternative includes purchasing and installing the treatment system to be used for the drinking water dispenser. The estimated O&M cost for this alternative includes purchasing and replacing filters and media or membranes, as well as periodic sampling and record keeping. The estimated capital cost for this alternative is \$11,600, and the estimated annual O&M cost for this alternative is \$15,230.

The reliability of adequate amounts of compliant water under this alternative is fair, because of the large amount of effort required from the customers and the associated inconvenience. Vista Verde PWS has not provided this type of service in the past. From Vista Verde perspective this alternative would be characterized as relatively easy to operate, since these types of treatment units are highly automated, and there is only one unit.

The feasibility of this alternative is not dependent on the cooperation, willingness, or capability of other water supply entities.

#### **4.5.15 Alternative VV-15: 100 Percent Bottled Water Delivery**

This alternative consists of the continued operation of the Vista Verde well, but compliant drinking water will be delivered to customers in containers. This alternative involves setting up and operating a bottled water delivery program to serve all of the customers in the system.



1 It is expected that Vista Verde would find it most convenient and economical to contract a  
2 bottled water service. The bottle delivery program would have to be flexible enough to allow  
3 the delivery of smaller containers should customers be incapable of lifting and manipulating 5-  
4 gallon bottles. Blending is not an option in this case. It should be noted that this alternative  
5 would be considered an interim measure until a compliance alternative is implemented.

6 This alternative does not involve capital cost for construction, but would require some  
7 initial costs for system setup, and then ongoing costs to have the bottled water furnished. It is  
8 assumed for this alternative that bottled water is provided to 100 percent of the Vista Verde  
9 PWS customers.

10 This alternative does not present options for a regional solution.

11 The estimated initial capital cost is for setting up the program. The estimated O&M cost  
12 for this alternative includes program administration and purchase of the bottled water. The  
13 estimated capital cost for this alternative is \$20,836, and the estimated annual O&M cost for  
14 this alternative is \$273,540. For the cost estimate, it is assumed that each person requires one  
15 gallon of bottled water per day.

16 The reliability of adequate amounts of compliant water under this alternative is fair, since  
17 it relies on the active cooperation of customers to order and utilize the water. Management and  
18 administration of the bottled water delivery program would require attention from Vista Verde  
19 PWS personnel.

20 The feasibility of this alternative is not dependent on the cooperation, willingness, or  
21 capability of other water supply entities.

#### 22 **4.5.16 Alternative VV-16: Public Dispenser for Trucked Drinking Water**

23 This alternative consists of continued operation of the Vista Verde well, plus dispensing  
24 compliant water for drinking and cooking at a publicly accessible location. The compliant  
25 water would be purchased from the City of Conroe, and delivered by truck to a tank at a central  
26 location where customers would be able to fill their own containers. This alternative also  
27 includes notifying customers of the importance of obtaining drinking water from the dispenser.  
28 In this way, only a relatively small volume of water requires treatment, but customers are  
29 required to pick up and deliver their own water. Blending is not an option in this case. It  
30 should be noted that this alternative would be considered an interim measure until a compliance  
31 alternative is implemented.

32 Vista Verde would purchase a truck that would be suitable for hauling potable water, and  
33 install a storage tank. It is assumed the storage tank would be filled once a week, and that the  
34 chlorine residual would be tested for each truckload. The truck would have to meet  
35 requirements for potable water, and each load would be treated with bleach. This alternative  
36 relies on a great deal of cooperation and action from the customers for it to be effective.

1 This alternative presents limited options for a regional solution if two or more systems  
2 share the purchase and operation of the water truck.

3 The estimated capital cost for this alternative includes purchasing a water truck and  
4 construction of the storage tank to be used for the drinking water dispenser. The estimated  
5 O&M cost for this alternative includes O&M for the truck, maintenance for the tank, water  
6 quality testing, record keeping, and water purchase. The estimated capital cost for this  
7 alternative is \$102,986, and the estimated annual O&M cost for this alternative is \$14,781.

8 The reliability of adequate amounts of compliant water under this alternative is fair  
9 because of the large amount of effort required from the customers and the associated  
10 inconvenience. Current personnel have not provided this type of service in the past. From the  
11 perspective of Vista Verde, this alternative would be characterized as relatively easy to operate,  
12 but the water hauling and storage would have to be done with care to ensure sanitary  
13 conditions.

14 The feasibility of this alternative is not dependent on the cooperation, willingness, or  
15 capability of other water supply entities.

#### 16 **4.5.17 Summary of Alternatives**

17 Table 4.3 provides a summary of the key features of each alternative for the Vista Verde  
18 PWS.

1 **Table 4.3 Summary of Compliance Alternatives for Vista Verde PWS**

Alt No.	Alternative Description	Major Components	Capital Cost <sup>1</sup>	Annual O&M Cost	Total Annualized Cost	Reliability	System Impact	Remarks
VV -1	New well at Vista Verde Water System	- New well - Storage tank and feed pumps	\$213,832	\$13,896	\$32,539	Good	N	New, deeper well at the same location. Sharing cost with neighboring systems may be possible. Blending may be possible.
VV -2	Purchase water from Montgomery County Utility District 3	- Pump station - 3.1-mile pipeline	\$1,093,151	\$56,007	\$151,313	Good	N	Agreement must be successfully negotiated with Montgomery County Utility District 3 Water System. Sharing cost with neighboring systems may be possible. Blending may be possible.
VV -3	New Well at Stanley Lake MUD	- Pump station - 2.6-mile pipeline	\$1,019,142	\$29,222	\$118,076	Good	N	Agreement must be successfully negotiated with Stanley Lake MUD PWS, or land must be purchased. Sharing cost with neighboring systems may be possible. Blending may be possible.
VV -4	Purchase water from Montgomery County Utility District 4	- Pump station - 4.4-mile pipeline	\$1,439,789	\$56,782	\$182,309	Good	N	Agreement must be successfully negotiated with Montgomery County Utility District 4 Water System. Sharing cost with neighboring systems may be possible. Blending may be possible.
VV -5	Purchase water from Montgomery County Utility District 9	- Pump station - 6.9-mile pipeline	\$2,053,481	\$57,639	\$236,671	Good	N	Agreement must be successfully negotiated with Montgomery County Utility District 9 Water System. Sharing cost with neighboring systems may be possible. Blending may be possible.
VV -6	Purchase water from Montgomery County Utility District 8	- Pump station - 7.3-mile pipeline	\$2,151,114	\$57,784	\$245,328	Good	N	Agreement must be successfully negotiated with Montgomery County Utility District 8 Water System. Sharing cost with neighboring systems may be possible. Blending may be possible.
VV -7	Install new compliant well within 5 miles	- New well - Storage tank - Pump station - 5-mile pipeline	\$1,654,806	\$30,011	\$174,284	Good	N	There is good probability for finding good quality groundwater. Costs could possibly be shared with small systems along pipeline route.
VV -8	Install new compliant well within 1 mile	- New well - Storage tank - 1-mile pipeline	\$409,002	\$14,084	\$49,743	Good	N	There is good probability for finding good quality groundwater.
VV -9	Continue operation of Vista Verde well field with central IX treatment	- Central IX treatment plant	\$306,820	\$25,590	\$52,340	Good	T	Costs could possibly be shared with nearby small systems.
VV -10	Continue operation of Vista Verde well field	- Central WRT Z-88 treatment plant	\$310,880	\$23,883	\$50,987	Good	T	Costs could possibly be shared with nearby small systems.

Alt No.	Alternative Description	Major Components	Capital Cost <sup>1</sup>	Annual O&M Cost	Total Annualized Cost	Reliability	System Impact	Remarks
	with central WRT Z-88 treatment							
VV -11	Continue operation of Vista Verde well field with central KMnO <sub>4</sub> treatment	- Central KMnO <sub>4</sub> treatment plant	\$344,955	\$21,540	\$51,615	Good	T	Costs could possibly be shared with nearby small systems.
VV -12	Continue operation of Vista Verde well field, and POU treatment	- POU treatment units.	\$95,040	\$84,398	\$92,684	Fair	T, M	Only one compliant tap in home. Cooperation of residents required for installation, maintenance, and testing.
VV -13	Continue operation of Vista Verde well field, and POE treatment	- POE treatment units.	\$1,663,200	\$195,998	\$341,004	Fair (better than POU)	T, M	All home taps compliant and less resident cooperation required.
VV -14	Continue operation of Vista Verde well field, but furnish public dispenser for treated drinking water	- Water treatment and dispenser unit	\$11,600	\$15,230	\$16,241	Fair/interim measure	T	Does not provide compliant water to all taps, and requires a lot of effort by customers.
VV -15	Continue operation of Vista Verde well field, but furnish bottled drinking water for all customers	- Set up bottled water system	\$20,836	\$273,540	\$275,356	Fair/interim measure	M	Does not provide compliant water to all taps, and requires customers to order and use. Management of program may be significant.
VV -16	Continue operation of Vista Verde well field, but furnish public dispenser for trucked drinking water.	- Construct storage tank and dispenser - Purchase potable water truck	\$102,986	\$14,781	\$23,759	Fair/interim measure	M	Does not provide compliant water to all taps, and requires a lot of effort by customers.

Notes: N – No significant increase required in technical or management capability  
T – Implementation of alternative will require increase in technical capability  
M – Implementation of alternative will require increase in management capability  
1 – See cost breakdown in Appendix C  
2 – 20-year return period and 6 percent interest

## **4.6 COST OF SERVICE AND FUNDING ANALYSIS**

To evaluate the financial impact of implementing the compliance alternatives, a 30-year financial planning model was developed. This model can be found in Appendix D. The financial model is based on estimated cash flows, with and without implementation of the compliance alternatives. Data for such models are typically derived from established budgets, audited financial reports, published water tariffs, and consumption data.

Information regarding the Vista Verde PWS, documented for the FMT capacity assessment, was derived from interviews with the owner and the operator of the PWS. Water usage records for the facility were not available, and were estimated using a per capita usage of 130 gallons per day (gpd).

Separate financial records are not kept for O&M of the PWS. The owner of Vista Verde claimed that revenues are insufficient to cover the costs of operations. Without tracking both the revenues and expenses for the water system, it is not possible to determine if revenues generated from the sale of water are sufficient to cover the cost of current operations, maintenance, and compliance with the radium regulations. Since no written financial information was available, it was not possible to complete the financial analysis.

### **4.6.1 Vista Verde Financial data**

No separate financial data are maintained by the system operator for the Vista Verde PWS. Vista Verde retains a billing service to send out a monthly water bill of \$36 to each of the residences in the Marvin Gardens subdivision. The monthly water bill allows each residence up to 8,000 gallons per month. Accordingly, this value was used in the financial model as the basic monthly charge for unlimited water usage with no additional rate structure tiers. Financial data for system expenditures for the Vista Verde PWS were based on estimates and pro-rating of expenses by the system operator.

### **4.6.2 Current Financial Condition**

#### **4.6.2.1 Cash Flow Needs**

Based on estimates provided by the system operator, the current average annual water use by residential customers of Vista Verde is estimated to be \$432, or approximately 1.2 percent of the Census block annual MHI (\$36,786) for the Vista Verde area. Because of the lack of separate financial data exclusively for the water system, it is difficult to determine exact cash flow needs. However, it is anticipated that water usage revenues fall considerably short of expenditures with the system being subsidized by other revenues.

#### 4.6.2.2 Ratio Analysis

##### *Current Ratio*

The Current Ratio for the Vista Verde water system could not be determined due to lack of necessary financial data to determine this ratio.

##### *Debt to Net Worth Ratio*

A Debt-to-Net-Worth Ratio also could not be determined owing to lack of the necessary financial data to determine this ratio.

##### *Operating Ratio*

Because of the lack of complete separate financial data on expenses specifically related to the Vista Verde PWS, the Operating Ratio could not be accurately determined. However, it is assumed that the estimated operating expenditures of the Vista Verde PWS are approximately equal to the operating revenues.

#### 4.6.3 Financial Plan Results

Each compliance alternative for Vista Verde was evaluated, with emphasis on the impact on affordability (expressed as a percentage of household income), and the overall increase in water rates necessary to pay for the improvements. Each alternative was examined under the various funding options described in Subsection 2.4.

For SRF funding options, customer MHI compared to the state average determines the availability of subsidized loans. According to the 2000 U.S. Census, the Block Group MHI for customers of Vista Verde was \$36,786 or 92 percent of the statewide MHI average of \$39,927. Since Block Group incomes are in excess of 75 percent of the state average, Vista Verde would not qualify for any discount to the interest rate of 3.8 percent. In the event the SRFs are unavailable, a second funding option would be Revenue Bonds at an annual interest of 6 percent.

Results of the financial impact analysis are provided in Table 4.4 and Figure 4.2. Table 4.4 presents rate impacts assuming that any deficiencies in reserve accounts are funded immediately in the year following the occurrence of the deficiency, which would cause the first few years' water rates to be higher than they would be if the reserve account was built-up over a longer period of time. Figure 4.2 provides a bar chart that in terms of the yearly billing to an average customer (13,500 gallons/month consumption), shows the following:

- Current annual average bill,
- Projected annual average bill including rate increase, if needed, to match existing expenditures, and
- Projected annual bill including rate increases needed to fund implementation of a compliance alternative (this does not include funding for reserve accounts).

The two bars shown for each compliance alternative represent the rate changes necessary for revenues to match total expenditures assuming 100 percent grant funding and 100 percent

1 loan/bond funding. Most funding options will fall between 100 percent grant and 100 percent  
2 loan/bond funding, with the exception of 100 percent revenue financing. Establishing or  
3 increasing reserve accounts would require an increase in rates. If existing reserves are  
4 insufficient to fund a compliance alternative, rates would need to be raised before  
5 implementing the compliance alternative. This would allow for accumulation of sufficient  
6 reserves to avoid larger but temporary rate increases during the years the compliance  
7 alternative was being implemented.


8

1                                      **Table 4.4      Financial Impact on Households**



Alternative	Description		All Revenue	100% Grant	75% Grant	50% Grant	SRF	Bond
1	New Well at Vista Verde	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	5% 530% \$ 1,794	1% 73% \$ 500	2% 94% \$ 556	2% 114% \$ 612	2% 145% \$ 698	2% 155% \$ 725
2	Purchase Water from Montgomery County UD3	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	24% 2792% \$ 8,131	3% 313% \$ 1,137	4% 417% \$ 1,424	5% 521% \$ 1,712	6% 679% \$ 2,148	7% 729% \$ 2,286
3	New Well at Stanley Lake MUD	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	21% 2536% \$ 7,419	2% 160% \$ 732	3% 257% \$ 1,000	4% 355% \$ 1,268	5% 502% \$ 1,674	5% 549% \$ 1,803
4	Purchase Water from Montgomery County UD4	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	30% 3639% \$ 10,508	3% 317% \$ 1,149	5% 454% \$ 1,527	6% 591% \$ 1,906	7% 800% \$ 2,480	8% 866% \$ 2,663
5	Purchase Water from Montgomery County MUD9	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	43% 5137% \$ 14,711	3% 322% \$ 1,162	5% 518% \$ 1,702	7% 713% \$ 2,241	9% 1010% \$ 3,060	10% 1105% \$ 3,321
6	Purchase Water from Montgomery County MUD8	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	45% 5375% \$ 15,380	3% 323% \$ 1,164	5% 528% \$ 1,729	7% 733% \$ 2,295	9% 1044% \$ 3,153	10% 1143% \$ 3,426
7	New Well at 5 Miles	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	34% 4087% \$ 11,772	2% 165% \$ 744	3% 322% \$ 1,179	5% 480% \$ 1,614	7% 719% \$ 2,274	7% 796% \$ 2,484
8	New Well at 1 Mile	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	9% 1006% \$ 3,130	1% 74% \$ 503	2% 113% \$ 610	2% 152% \$ 718	3% 211% \$ 881	3% 230% \$ 933
9	Central Treatment - IX	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	7% 790% \$ 2,520	2% 140% \$ 677	2% 169% \$ 758	2% 198% \$ 838	3% 242% \$ 960	3% 257% \$ 999
10	Central Treatment - WRT Z-88	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	7% 795% \$ 2,534	2% 130% \$ 651	2% 160% \$ 733	2% 189% \$ 814	3% 234% \$ 938	3% 248% \$ 978
11	Central Treatment - KMnO4	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	8% 871% \$ 2,749	2% 117% \$ 616	2% 149% \$ 706	2% 182% \$ 797	3% 232% \$ 934	3% 248% \$ 978
12	Point-of-Use Treatment	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	5% 474% \$ 1,611	5% 474% \$ 1,567	5% 483% \$ 1,592	5% 492% \$ 1,617	5% 506% \$ 1,655	5% 510% \$ 1,667
13	Point-of-Entry Treatment	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	38% 4579% \$ 13,108	10% 1108% \$ 3,255	11% 1267% \$ 3,692	12% 1426% \$ 4,130	14% 1666% \$ 4,793	15% 1743% \$ 5,004
14	Public Dispenser for Treated Drinking Water	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	1% 81% \$ 526	1% 81% \$ 520	1% 82% \$ 523	1% 83% \$ 526	2% 85% \$ 531	2% 85% \$ 532
15	Supply Bottled Water to 100% of Population	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	13% 1549% \$ 4,438	13% 1549% \$ 4,429	13% 1551% \$ 4,434	13% 1553% \$ 4,439	14% 1556% \$ 4,448	14% 1557% \$ 4,450
16	Central Trucked Drinking Water	Max % of HH Income Max % Rate Increase Compared to Current Average Water Bill Required by Alternative	3% 262% \$ 1,043	1% 78% \$ 513	2% 88% \$ 540	2% 98% \$ 567	2% 113% \$ 609	2% 117% \$ 622

**Figure 4-2 Alternative Cost Summary**



## **SECTION 5 REFERENCES**

- Ashworth J. B., and Hopkins, J., 1995. Aquifers of Texas: Texas Water Development Board Report 345, 68 p.
- Baker, E. T., 1979, Stratigraphic and hydrogeologic framework of part of the Coastal Plain of Texas: Texas Department of Water Resources Report no. 236, 43p.
- Bluntzer R. L., 1992. Evaluation of ground-water resources of the Paleozoic and Cretaceous aquifers in the Hill Country of Central Texas: Texas Water Development Board Report 339, 130 p.
- Galloway, W. E., L. A. Jirik, R. A. Morton, and J. R. DuBar, 1986. Lower Miocene (Fleming) Depositional Episode of the Texas Coastal Plain and Continental Shelf: Structural Framework, Facies, and Hydrocarbon Resources. The University of Texas at Austin, Bureau of Economic Geology Report of Investigations No. 150, 50p.
- Kasmerek, M.C. and J.L. Robinson, 2004. Hydrogeology and Simulation of Groundwater Flow and Land-Surface Subsidence in the Northern Part of the Gulf Coast Aquifer System, Texas. U.S. Geological Survey Scientific Investigation Report 2004-5102.
- Kasmerek, M.C. B.D. Reece and N.A. Houston, 2005. Evaluation of Groundwater Flow and Land-Surface Subsidence Caused by Hypothetical Withdrawals in the Northern Part of the Gulf Coast Aquifer System, Texas. U.S. Geological Survey Scientific Investigation Report 2005-5024.
- Mace, R.E., S.C. Davidson, E.S. Angle and W.F. Mullican, 2006. Aquifers of the Gulf Coast of Texas. Report 365, TWDB, Austin, Feb 2006 [available online at <http://www.twdb.state.tx.us/gam/index.htm>].
- Raucher, Robert S., M.L. Hagenstad, J. Cotruvo, R. Narasimhan, K. Martin, H. Arora, R. Regunathan, J.A. Drago, and F. Pontius 2004. Conventional and Unconventional Approaches to Water Service Provision. AWWA Research Foundation and American Water Works Association.
- TCEQ 2004. Drinking Water Quality and Reporting Requirements for PWSs: 30 TAC 290 Subchapter F (290.104. Summary of Maximum Contaminant Levels, Maximum Residual Disinfectant Levels, Treatment Techniques, and Action Levels). Revised February 2004.
- USEPA 2002. Long Term Enhanced Surface Water Treatment Rule: A Quick Reference Guide. EPA-816-F-02-001.
- USEPA 2004. National primary drinking water regulations: analytical method for uranium: final rule: Federal Register: August 25, 2004 (Volume 69, Number 164). <http://www.epa.gov/fedrgstr/EPA-water/2004/August/Day-25/w19333.htm>.
- USEPA 2005. List of Drinking Water Contaminants & MCLs. Online. Last updated February 23, 2005. [www.epa.gov/safewater/mcl.html](http://www.epa.gov/safewater/mcl.html).

1  
2

**APPENDIX A  
PWS INTERVIEW FORM**

# CAPACITY DEVELOPMENT ASSESSMENT FORM

Prepared By \_\_\_\_\_

Date \_\_\_\_\_

## **Section 1. Public Water System Information**

1. PWS ID #  2. Water System Name 3. County 4. Owner Address Tele. E-mail Fax Message 5. Admin Address Tele. E-mail Fax Message 6. Operator Address Tele. E-mail Fax Message 7. Population Served 8. No. of Service Connections 9. Ownership Type 10. Metered (Yes or No) 11. Source Type 12. Total PWS Annual Water Used 

13. Number of Water Quality Violations (Prior 36 months)

Total Coliform Chemical/Radiological Monitoring (CCR, Public Notification, etc.) Treatment Technique, D/DBP

## **A. Basic Information**

1. Name of Water System:
2. Name of Person Interviewed:
3. Position:
4. Number of years at job:
5. Number of years experience with drinking water systems:
6. Percent of time (day or week) on drinking water system activities, with current position (how much time is dedicated exclusively to the water system, not wastewater, solid waste or other activities):
7. Certified Water Operator (Yes or No):  
  
    If Yes,  
    7a. Certification Level (water):  
  
    7b. How long have you been certified?
8. Describe your water system related duties on a typical day.

## **B. Organization and Structure**

1. Describe the organizational structure of the Utility. Please provide an organizational chart. (Looking to find out the governance structure (who reports to whom), whether or not there is a utility board, if the water system answers to public works or city council, etc.)

2. If not already covered in Question 1, to whom do you report?
3. Do all of the positions have a written job description?
  - 3a. If yes, is it available to employees?
  - 3b. May we see a copy?

<b>C. Personnel</b>
---------------------

1. What is the current staffing level (include all personnel who spend more than 10% of their time working on the water system)?
2. Are there any vacant positions? How long have the positions been vacant?
3. In your opinion, is the current staffing level adequate? If not adequate, what are the issues or staffing needs (how many and what positions)?
4. What is the rate of employee turnover for management and operators? What are the major issues involved in the turnover (e.g., operator pay, working conditions, hours)?
5. Is the system staffed 24 hours a day? How is this handled (on-site or on-call)? Is there an alarm system to call an operator if an emergency occurs after hours?

<b>D. Communication</b>
-------------------------

1. Does the utility have a mission statement? If yes, what is it?
2. Does the utility have water quality goals? What are they?
3. How are your work priorities set?
4. How are work tasks delegated to staff?
5. Does the utility have regular staff meetings? How often? Who attends?
6. Are there separate management meetings? If so, describe.
7. Do management personnel ever visit the treatment facility? If yes, how often?
8. Is there effective communication between utility management and state regulators (e.g., NMED)?
9. Describe communication between utility and customers.



<b>E. Planning and Funding</b>
--------------------------------

1. Describe the rate structure for the utility.
2. Is there a written rate structure, such as a rate ordinance? May we see it?
  - 2a. What is the average rate for 6,000 gallons of water?
3. How often are the rates reviewed?
4. What process is used to set or revise the rates?
5. In general, how often are the new rates set?
6. Is there an operating budget for the water utility? Is it separate from other activities, such as wastewater, other utilities, or general city funds?
7. Who develops the budget, how is it developed and how often is a new budget created or the old budget updated?
8. How is the budget approved or adopted?

9. In the last 5 years, how many budget shortfalls have there been (i.e., didn't collect enough money to cover expenses)? What caused the shortfall (e.g., unpaid bills, an emergency repair, weather conditions)?  
  
9a. How are budget shortfalls handled?
10. In the last 5 years how many years have there been budget surpluses (i.e., collected revenues exceeded expenses)?  
  
10a. How are budget surpluses handled (i.e., what is done with the money)?
11. Does the utility have a line-item in the budget for emergencies or some kind of emergency reserve account?
12. How do you plan and pay for short-term system needs?
13. How do you plan and pay for long- term system needs?
14. How are major water system capital improvements funded? Does the utility have a written capital improvements plan?
15. How is the facility planning for future growth (either new hook-ups or expansion into new areas)?
16. Does the utility have and maintain an annual financial report? Is it presented to policy makers?

17. Has an independent financial audit been conducted of the utility finances? If so, how often? When was the last one?
18. Will the system consider any type of regionalization with any other PWS, such as system interconnection, purchasing water, sharing operator, emergency water connection, sharing bookkeeper/billing or other?

<b>F. Policies, Procedures, and Programs</b>
--

1. Are there written operational procedures? Do the employees use them?
2. Who in the utility department has spending authorization? What is the process for obtaining needed equipment or supplies, including who approves expenditures?
3. Does the utility have a source water protection program? What are the major components of the program?
4. Are managers and operators familiar with current SDWA regulations?
5. How do the managers and operators hear about new or proposed regulations, such as arsenic, DBP, Groundwater Rule? Are there any new regulations that will be of particular concern to the utility?
6. What are the typical customer complaints that the utility receives?
7. Approximately how many complaints are there per month?

8. How are customer complaints handled? Are they recorded?
9. (If not specifically addressed in Question 7) If the complaint is of a water quality nature, how are these types of complaints handled?
10. Does the utility maintain an updated list of critical customers?
11. Is there a cross-connection control plan for the utility? Is it written? Who enforces the plan's requirements?
12. Does the utility have a written water conservation plan?
13. Has there been a water audit of the system? If yes, what were the results?
14. (If not specifically answered in 11 above) What is the estimated percentage for loss to leakage for the system?
15. Are you, or is the utility itself, a member of any trade organizations, such as AWWA or Rural Water Association? Are you an active member (i.e., attend regular meetings or participate in a leadership role)? Do you find this membership helpful? If yes, in what ways does it help you?

<b>G. Operations and Maintenance</b>
--------------------------------------

1. How is decision-making authority split between operations and management for the following items:
  - a. Process Control
  - b. Purchases of supplies or small equipment
  - c. Compliance sampling/reporting
  - d. Staff scheduling
2. Describe your utility's preventative maintenance program.
3. Do the operators have the ability to make changes or modify the preventative maintenance program?
4. How does management prioritize the repair or replacement of utility assets? Do the operators play a role in this prioritization process?
5. Does the utility keep an inventory of spare parts?
6. Where does staff have to go to buy supplies/minor equipment? How often?
  - 6a. How do you handle supplies that are critical, but not in close proximity (for example if chlorine is not available in the immediate area or if the components for a critical pump are not in the area)

7. Describe the system's disinfection process. Have you had any problems in the last few years with the disinfection system?

7a. Who has the ability to adjust the disinfection process?

8. How often is the disinfectant residual checked and where is it checked?

8a. Is there an official policy on checking residuals or is it up to the operators?

9. Does the utility have an O & M manual? Does the staff use it?

10. Are the operators trained on safety issues? How are they trained and how often?

11. Describe how on-going training is handled for operators and other staff. How do you hear about appropriate trainings? Who suggests the trainings – the managers or the operators? How often do operators, managers, or other staff go to training? Who are the typical trainers used and where are the trainings usually held?

12. In your opinion is the level of your on-going training adequate?

13. In your opinion is the level of on-going training for other staff members, particularly the operators, adequate?

14. Does the facility have mapping of the water utility components? Is it used on any routine basis by the operators or management? If so, how is it used? If not, what is the process used for locating utility components?
15. In the last sanitary survey, were any deficiencies noted? If yes, were they corrected?
16. How often are storage tanks inspected? Who does the inspection?
  - 16a. Have you experienced any problems with the storage tanks?

<b>H. SDWA Compliance</b>
---------------------------

1. Has the system had any violations (monitoring or MCL) in the past 3 years? If so, describe.
2. How were the violations handled?
3. Does the system properly publish public notifications when notified of a violation?
4. Is the system currently in violation of any SDWA or state regulatory requirements, including failure to pay fees, fines, or other administrative type requirements?
5. Does the utility prepare and distribute a Consumer Confidence Report (CCR)? Is it done every year? What type of response does the utility get to the CCR from customers?

<b>I. Emergency Planning</b>
------------------------------

1. Does the system have a written emergency plan to handle emergencies such as water outages, weather issues, loss of power, loss of major equipment, etc?
2. When was the last time the plan was updated?
3. Do all employees know where the plan is? Do they follow it?
4. Describe the last emergency the facility faced and how it was handled.



## Attachment A

**A. Technical Capacity Assessment Questions**

1. Based on available information of water rights on record and water pumped has the system exceeded its water rights in the past year? YES ☐ NO ☐

In any of the past 5 years? YES ☐ NO ☐ How many times? \_\_\_\_\_

2. Does the system have the proper level of certified operator? *(Use questions a – c to answer.)*  
YES ☐ NO ☐

a. What is the Classification Level of the system by NMED? \_\_\_\_\_

- b. Does the system have one or more certified operator(s)? [20 NMAC 7.4.20]

YES ☐ NO ☐

- c. If YES, provide the number of operators at each New Mexico Certification Level. [20 NMAC 7.4.12]

\_\_\_\_\_ NM Small System \_\_\_\_\_ Class 2

\_\_\_\_\_ NM Small System Advanced \_\_\_\_\_ Class 3

\_\_\_\_\_ Class 1 \_\_\_\_\_ Class 4

3. Did the system correct any sanitary deficiency noted on the most recent sanitary survey within 6 months of receiving that information? [20 NMAC 7.20.504]

YES ☐ NO ☐ No Deficiencies ☐

What was the type of deficiency? *(Check all that are applicable.)*

Source ☐ Storage ☐

Treatment ☐ Distribution ☐

Other \_\_\_\_\_

From the system's perspective, were there any other deficiencies that were not noted on the sanitary survey?  
Please describe.

4. Will the system's current treatment process meet known future regulations?

Radionuclides YES ☐ NO ☐ Doesn't Apply ☐

Arsenic YES ☐ NO ☐ Doesn't Apply ☐

Stage 1 Disinfectants and Disinfection By-Product (DBP)

YES ☐ NO ☐ Doesn't Apply ☐

Surface Water Treatment Rule YES ☐ NO ☐ Doesn't Apply ☐

5. Does the system have a current site plan/map? [20 NMAC 7.10.302 A.1.]

YES ☐ NO ☐

6. Has the system had a water supply outage in the prior 24 months?

YES ☐ NO ☐

What were the causes of the outage(s)? *(Include number of outages for each cause.)*

Drought \_\_\_\_\_ Limited Supply \_\_\_\_\_

System Failure \_\_\_\_\_ Other \_\_\_\_\_

7. Has the system ever had a water audit or a leak evaluation?

YES ☐ NO ☐ Don't Know ☐

If YES, please complete the following table.

Type of Investigation	Date Done	Water Loss (%)	What approach or technology was used to complete the investigation?	Was any follow-up done? If so, describe

8. Have all drinking water projects received NMED review and approval? [20 NMAC 7.10.201]

YES ☐ NO ☐

If NO, what types of projects have not received NMED review and approval.

Source ☐ Storage ☐

Treatment ☐ Distribution ☐

Other ☐ \_\_\_\_\_

9. What are the typical customer complaints that the utility receives?

10. Approximately how many complaints are there per month? \_\_\_\_\_

11. How are customer complaints handled? Are they recorded?

12. What is the age and composition of the distribution system? *(Collect this information from the Sanitary Survey)*

Pipe Material	Approximate Age	Percentage of the system	Comments
			Sanitary Survey Distribution System Records Attached

13. Are there any dead end lines in the system?  
 YES ☐ NO ☐

14. Does the system have a flushing program?  
 YES ☐ NO ☐

If YES, please describe.

15. Are there any pressure problems within the system?  
 YES ☐ NO ☐

If YES, please describe.

16. Does the system disinfect the finished water?  
 YES ☐ NO ☐

If yes, which disinfectant product is used? \_\_\_\_\_

Interviewer Comments on Technical Capacity:

## **B. Managerial Capacity Assessment Questions**

17. Has the system completed a 5-year Infrastructure Capital Improvement Plan (ICIP) plan?

YES ☐ NO ☐

If YES, has the plan been submitted to Local Government Division?

YES ☐ NO ☐

18. Does the system have written operating procedures?

YES ☐ NO ☐

19. Does the system have written job descriptions for all staff?

YES ☐ NO ☐

20. Does the system have:
- |                                     |                          |     |                          |
|-------------------------------------|--------------------------|-----|--------------------------|
| A preventative maintenance plan?    |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
| A source water protection plan?     |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
|                                     |                          | N/A | <input type="checkbox"/> |
| An emergency plan?                  |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
| A cross-connection control program? |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
| An emergency source?                |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
| System security measures?           |                          |     |                          |
| YES                                 | <input type="checkbox"/> | NO  | <input type="checkbox"/> |
21. Does the system report and maintain records in accordance with the drinking water regulations concerning:
- |                          |                          |    |                          |
|--------------------------|--------------------------|----|--------------------------|
| Water quality violations |                          |    |                          |
| YES                      | <input type="checkbox"/> | NO | <input type="checkbox"/> |
| Public notification      |                          |    |                          |
| YES                      | <input type="checkbox"/> | NO | <input type="checkbox"/> |
| Sampling exemptions      |                          |    |                          |
| YES                      | <input type="checkbox"/> | NO | <input type="checkbox"/> |
22. Please describe how the above records are maintained:
23. Describe the management structure for the water system, including board and operations staff. Please include examples of duties, if possible.
24. Please describe type and quantity of training or continuing education for staff identified above.
25. Describe last major project undertaken by the water system, including the following: project in detail, positive aspects, negative aspects, the way in which the project was funded, any necessary rate increases, the public response to the project, whether the project is complete or not, and any other pertinent information.

26. Does the system have any debt? YES ☐ NO ☐

If yes, is the system current with all debt payments?

YES ☐ NO ☐

If no, describe the applicable funding agency and the default.

27. Is the system currently contemplating or actively seeking funding for any project?

YES ☐ NO ☐

If yes, from which agency and how much?

Describe the project?

Is the system receiving assistance from any agency or organization in its efforts?

28. Will the system consider any type of regionalization with other PWS? (*Check YES if the system has already regionalized.*)

YES ☐ NO ☐

If YES, what type of regionalization has been implemented/considered/discussed? (*Check all that apply.*)

System interconnection ☐

Sharing operator ☐

Sharing bookkeeper ☐

Purchasing water ☐

Emergency water connection ☐

Other: \_\_\_\_\_

29. Does the system have any of the following? (*Check all that apply.*)

Water Conservation Policy/Ordinance ☐ Current Drought Plan ☐

Water Use Restrictions ☐ Water Supply Emergency Plan ☐

Interviewer Comments on Managerial Capacity:

**C. Financial Capacity Assessment**

30. Does the system have a budget?

YES ☐ NO ☐

If YES, what type of budget?

Operating Budget ☐Capital Budget ☐

31. Have the system revenues covered expenses and debt service for the past 5 years?

YES ☐ NO ☐

If NO, how many years has the system had a shortfall? \_\_\_\_\_

32. Does the system have a written/adopted rate structure?

YES ☐ NO ☐

33. What was the date of the last rate increase? \_\_\_\_\_

34. Are rates reviewed annually?

YES ☐ NO ☐

If YES, what was the date of the last review? \_\_\_\_\_

35. Did the rate review show that the rates covered the following expenses? (*Check all that apply.*)Operation & Maintenance ☐Infrastructure Repair & replacement ☐Staffing ☐Emergency/Reserve fund ☐Debt payment ☐

36. Is the rate collection above 90% of the customers?

YES ☐ NO ☐

37. Is there a cut-off policy for customers who are in arrears with their bill or for illegal connections?

YES ☐ NO ☐

If yes, is this policy implemented?

38. What is the residential water rate for 6,000 gallons of usage in one month. \_\_\_\_\_

39. In the past 12 months, how many customers have had accounts frozen or dropped for non-payment? \_\_\_\_\_

[Convert to % of active connections]

Less than 1% ☐ 1% - 3% ☐ 4% - 5% ☐ 6% - 10% ☐11% - 20% ☐ 21% - 50% ☐ Greater than 50% ☐ ]

40. The following questions refer to the process of obtaining needed equipment and supplies.

a. Can the water system operator buy or obtain supplies or equipment when they are needed?

YES ☐ NO ☐

b. Is the process simple or burdensome to the employees?

c. Can supplies or equipment be obtained quickly during an emergency?

YES ☐ NO ☐

d. Has the water system operator ever experienced a situation in which he/she couldn't purchase the needed supplies?

YES ☐ NO ☐

e. Does the system maintain some type of spare parts inventory?

YES ☐ NO ☐

If yes, please describe.

41. Has the system ever had a financial audit?

YES ☐ NO ☐

If YES, what is the date of the most recent audit? \_\_\_\_\_

42. Has the system ever had its electricity or phone turned off due to non-payment? Please describe.

Interviewer Comments on Financial Assessment:

43. What do you think the system capabilities are now and what are the issues you feel your system will be facing in the future? In addition, are there any specific needs, such as types of training that you would like to see addressed by NMED or its contractors?



## APPENDIX B COST BASIS

This section presents the basis for unit costs used to develop the conceptual cost estimates for the compliance alternatives. Cost estimates are conceptual in nature (+50%/-30%), and are intended to make comparisons between compliance options and to provide a preliminary indication of possible rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation. Capital cost includes an allowance for engineering and construction management. It is assumed that adequate electrical power is available near the site. The cost estimates specifically do not include costs for the following:

- Obtaining land or easements.
- Surveying.
- Mobilization/demobilization for construction.
- Insurance and bonds

In general, unit costs are based on recent construction bids for similar work in the area; when possible, consultations with vendors or other suppliers; published construction and O&M cost data; and USEPA cost guidance. Unit costs used for the cost estimates are summarized in Table B.1.

Unit costs for pipeline components are based on 2006 R.S. Means Building Construction Cost Data. The number of borings and encasements, and open cuts and encasements is estimated by counting the road, highway, railroad, stream, and river crossings for a conceptual routing of the pipeline. The number of air release valves is estimated by examining the land surface profile along the conceptual pipeline route. It is assumed gate valves and flush valves would be installed on average every 5,000 feet along the pipeline. Pipeline cost estimates are based on use of C-900 polyvinyl chloride pipe. Other pipe materials could be considered for more detailed development of attractive alternatives.

Pump station unit costs are based on experience with similar installations. The cost estimate for the pump stations include two pumps, station piping and valves, station electrical and instrumentation, minor site improvement, installation of a concrete pad, fence, building, and tools. Construction cost of a storage tank is based on R.S. Means Building Construction Data.

Labor costs are estimated based on R.S. Means Building Construction Data specific to each geographic area.

Electrical power cost is estimated to be \$0.136 kiloWatt hours (kWH). The annual cost for power to a pump station is calculated based on the pumping head and volume, and includes 11,800 kWH for pump building heating, cooling, and lighting, as recommended in USEPA publication, *Standardized Costs for Water Supply Distribution Systems* (1992).

1 In addition to the cost of electricity, pump stations have other maintenance costs. These  
2 costs cover: materials for minor repairs to keep the pumps operating; purchase of a  
3 maintenance vehicle, fuel costs, and vehicle maintenance costs; utilities; office supplies, small  
4 tools and equipment; and miscellaneous materials such as safety, clothing, chemicals, and  
5 paint. The non-power O&M costs are estimated based on the USEPA publication,  
6 *Standardized Costs for Water Supply Distribution Systems* (1992), which provides cost curves  
7 for O&M components. Costs from the 1992 report are adjusted to 2006 dollars based on the  
8 ENR construction cost index.

9 Pipeline maintenance costs include routine cleaning and flushing, as well as minor repairs  
10 to lines. The unit rate for pipeline maintenance is calculated based on the USEPA technical  
11 report, *Innovative and Alternate Technology Assessment Manual MCD 53* (1978). Costs from  
12 the 1978 report are adjusted to 2006 dollars based on the ENR construction cost index.

13 Storage tank maintenance costs include cleaning and renewal of interior lining and exterior  
14 coating. Unit costs for storage tank O&M are based on USEPA publication *Standardized Costs*  
15 *for Water Supply Distribution Systems* (1992). Costs from the 1992 report are adjusted to 2006  
16 dollars based on the ENR construction cost index.

17 The purchase price for POU water treatment units is based on vendor price lists for  
18 treatment units, plus installation. O&M costs for POU treatment units are also based on vendor  
19 price lists. It is assumed that a yearly water sample would be analyzed for the contaminant of  
20 concern.

21 The purchase price for POE water treatment units is based on vendor price lists for  
22 treatment units, plus an allowance for installation, including a concrete pad and shed, piping  
23 modifications, and electrical connection. O&M costs for POE treatment units are also based on  
24 vendor price lists. It is assumed that a yearly water sample would be analyzed for the  
25 contaminant of concern.

26 Central treatment plant costs, for both adsorption and coagulation/filtration, include  
27 pricing for buildings, utilities, and site work. Costs are based on pricing given in the various  
28 R.S. Means Construction Cost Data References, as well as prices obtained from similar work  
29 on other projects. Pricing for treatment equipment was obtained from vendors.

30 Well installation costs are based on quotations from drillers for installation of similar depth  
31 wells in the area. Well installation costs include drilling, a well pump, electrical and  
32 instrumentation installation, well finishing, piping, and water quality testing. O&M costs for  
33 water wells include power, materials, and labor. It is assumed that new wells located more than  
34 1 mile from the intake point of an existing system would require at least one storage tank and  
35 pump station.

36 Purchase price for the treatment unit dispenser is based on vendor price lists, plus an  
37 allowance for installation at a centralized public location. The O&M costs are also based on  
38 vendor price lists. It is assumed that weekly water samples would be analyzed for the  
39 contaminant of concern.

1        Costs for bottled water delivery alternatives are based on consultation with vendors that  
2 deliver residential bottled water. The cost estimate includes an initial allowance for set-up of  
3 the program, and a yearly allowance for program administration.

4        The cost estimate for a public dispenser for trucked water includes the purchase price for a  
5 water truck and construction of a storage tank. Annual costs include labor for purchasing the  
6 water, picking up and delivering the water, truck maintenance, and water sampling and testing.  
7 It is assumed the water truck would be required to make one trip per dispenser each week, and  
8 that chlorine residual would be determined for each truck load.

**Table B.1**  
**Summary of General Data**  
**Vista Verde Water Systems**  
**PWS #1700694**

**General PWS Information**

**Service Population** 432  
**Total PWS Daily Water Usage** 0.056 (mgd)

**Number of Connections** 144  
**Source** Calculated using assumed 150 gpcd

**Unit Cost Data**

**East Texas**

<b>General Items</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Central Treatment Unit Costs</b>	<b>Unit</b>	<b>Unit Cost</b>
Treated water purchase cost	<i>See alternative</i>		<i>General</i>		
Water purchase cost (trucked)	\$/1,000 gals	\$ 2.50	Site preparation	acre	\$ 4,000
			Slab	CY	\$ 1,000
Contingency	20%	n/a	Building	SF	\$ 60
Engineering & Constr. Management	25%	n/a	Building electrical	SF	\$ 8.00
Procurement/admin (POU/POE)	20%	n/a	Building plumbing	SF	\$ 8.00
			Heating and ventilation	SF	\$ 7.00
<b>Pipeline Unit Costs</b>	<b>Unit</b>	<b>Unit Cost</b>	Fence	LF	\$ 15
PVC water line, Class 200, 06"	LF	\$ 32	Paving	SF	\$ 2.00
Bore and encasement, 10"	LF	\$ 60	Chlorination point	EA	\$ 2,000
Open cut and encasement, 10"	LF	\$ 35			
Gate valve and box, 06"	EA	\$ 465	Building power	kwh/yr	\$ 0.136
Air valve	EA	\$ 1,000	Equipment power	kwh/yr	\$ 0.136
Flush valve	EA	\$ 750	Labor, O&M	hr	\$ 26
Metal detectable tape	LF	\$ 0.15	Analyses	test	\$ 200
Bore and encasement, length	Feet	200	<i>Ion exchange</i>		
Open cut and encasement, length	Feet	50	Electrical	JOB	\$ 50,000
			Piping	JOB	\$ 20,000
<b>Pump Station Unit Costs</b>	<b>Unit</b>	<b>Unit Cost</b>	Ion exchange package plant	UNIT	\$ 30,000
Pump	EA	\$ 7,500	Transfer pumps (10 hp)	EA	\$ 5,000
Pump Station Piping, 06"	EA	\$ 4,000	Clean water tank	gal	\$ 1.00
Gate valve, 06"	EA	\$ 590	Regenerant tank	gal	\$ 1.50
Check valve, 06"	EA	\$ 890	Backwash tank	gal	\$ 2.00
Electrical/Instrumentation	EA	\$ 10,000	Sewer connection fee	EA	\$ 15,000
Site work	EA	\$ 2,000			
Building pad	EA	\$ 4,000	Ion exchange materials	year	\$ 1,000
Pump Building	EA	\$ 10,000	Ion exchange chemicals	year	\$ 1,000
Fence	EA	\$ 5,870	Backwash discharge to sewer	kgal/year	\$ 5.00
Tools	EA	\$ 1,000	Waste haulage truck rental	days	\$ 700
			Mileage charge	mile	\$ 1.00
<b>Well Installation Unit Costs</b>	<b>Unit</b>	<b>Unit Cost</b>	Waste disposal fee	kgal/yr	\$ 200
Well installation	<i>See alternative</i>				
Water quality testing	EA	\$ 1,500	<i>WRT Z-88 package</i>		
Well pump	EA	\$ 7,500	Electrical	JOB	\$ 50,000
Well electrical/instrumentation	EA	\$ 5,000	Piping	JOB	\$ 20,000
Well cover and base	EA	\$ 3,000	WRT Z-88 package plant	UNIT	\$ 51,000
Piping	EA	\$ 2,500	(Initial setup cost for WRT Z-88 package)		
Storage Tank - 30,000 gals	EA	\$ 37,100			
			WRT treated water charge	1,000 gal/yr	\$ 6.70
Electrical Power	\$/kWH	\$ 0.136			
Building Power	kWH	11,800	<i>KMnO4-greensand package</i>		
Labor	\$/hr	\$ 26	Electrical	JOB	\$ 50,000
Materials	EA	\$ 1,200	Piping	JOB	\$ 20,000
Transmission main O&M	\$/mile	\$ 200	KMnO4-greensand package plant	UNIT	\$ 60,000
Tank O&M	EA	\$ 1,000	Backwash tank	gal	\$ 2.00
			Sewer connection fee	EA	\$ 15,000
<b>POU/POE Unit Costs</b>					
POU treatment unit purchase	EA	\$ 250	KMnO4-greensand materials	year	\$ 1,000
POU treatment unit installation	EA	\$ 150	KMnO4-greensand chemicals	year	\$ 1,000
POE treatment unit purchase	EA	\$ 3,000	Backwash discharge to sewer	1,000 gal/yr	\$ 5.00
POE - pad and shed, per unit	EA	\$ 2,000	Sludge truck rental	days	\$ 700
POE - piping connection, per unit	EA	\$ 1,000	Sludge truck mileage fee	miles	\$ 1.00
POE - electrical hook-up, per unit	EA	\$ 1,000	Sludge disposal fee	1,000 gal/yr	\$ 200.00
POU treatment O&M, per unit	\$/year	\$ 225			
POE treatment O&M, per unit	\$/year	\$ 1,000			
Contaminant analysis	\$/year	\$ 100			
POU/POE labor support	\$/hr	\$ 26			
<b>Dispenser/Bottled Water Unit Costs</b>					
Treatment unit purchase	EA	\$ 3,000			
Treatment unit installation	EA	\$ 5,000			
Treatment unit O&M	EA	\$ 500			
Administrative labor	hr	\$ 35			
Bottled water cost (inc. delivery)	gallon	\$ 1.60			
Water use, per capita per day	gpcd	1.0			
Bottled water program materials	EA	\$ 5,000			
Storage Tank - 5,000 gals	EA	\$ 7,025			
Site improvements	EA	\$ 4,000			
Potable water truck	EA	\$ 60,000			
Water analysis, per sample	EA	\$ 100			
Potable water truck O&M costs	\$/mile	\$ 1.00			

**APPENDIX C**  
**COMPLIANCE ALTERNATIVE CONCEPTUAL COST ESTIMATES**

This appendix presents the conceptual cost estimates developed for the compliance alternatives. The conceptual cost estimates are given in Tables C.1 through C.16. The cost estimates are conceptual in nature (+50%/-30%), and are intended for making comparisons between compliance options and to provide a preliminary indication of possible water rate impacts. Consequently, these costs are pre-planning level and should not be viewed as final estimated costs for alternative implementation.

**Table C.1**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *New Well at Vista Verde*  
**Alternative Number** *VV-1*

**Distance from PWS to new well location** 0.06 miles  
**Estimated well depth** 900 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 0  
**Number of feed tanks/pump sets needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	-	n/a	n/a	n/a
PVC water line, Class 200, 06"	300	LF	\$ 32.00	\$ 9,600
Bore and encasement, 10"	-	LF	\$ 60.00	\$ -
Open cut and encasement, 10"	-	LF	\$ 35.00	\$ -
Gate valve and box, 06"	1	EA	\$ 465.00	\$ 465
Air valve	-	EA	\$ 1,000.00	\$ -
Flush valve	1	EA	\$ 750.00	\$ 750
Metal detectable tape	300	LF	\$ 0.15	\$ 45
<b>Subtotal</b>				<b>\$ 10,860</b>
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 06"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 06"	4	EA	\$ 590	\$ 2,360
Check valve, 06"	2	EA	\$ 890	\$ 1,780
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 30,000 gals	1	EA	\$ 37,100	\$ 37,100
<b>Subtotal</b>				<b>\$ 93,110</b>
<i>Well Installation</i>				
Well installation	900	LF	\$ 25	\$ 22,500
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 43,500</b>

**Subtotal of Component Costs** **\$ 147,470**

Contingency 20% \$ 29,494  
Design & Constr Management 25% \$ 36,868

**TOTAL CAPITAL COSTS** **\$ 213,832**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	0.1	mile	\$ 200	\$ 11
<b>Subtotal</b>				<b>\$ 11</b>
<i>Pump Station(s) O&amp;M</i>				
Building Power	11,800	KWH	\$ 0.136	\$ 1,605
Pump Power	-	KWH	\$ 0.136	\$ -
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 26	\$ 9,530
Tank O&M	1	EA	\$ 1,000	\$ 1,000
<b>Subtotal</b>				<b>\$ 13,335</b>
<i>Well O&amp;M</i>				
Pump power	6,500	KWH	\$ 0.136	\$ 884
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 26	\$ 4,700
<b>Subtotal</b>				<b>\$ 6,784</b>

<i>O&amp;M Credit for Existing Well Closure</i>				
Pump power	2,460	KWH	\$ 0.136	\$ (335)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 26	\$ (4,700)
<b>Subtotal</b>				<b>\$ (6,234)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 13,896**

**Table C.2**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Purchase Water from Montgomery County UD3*  
**Alternative Number** *VV-2*

**Distance from Alternative to PWS (along pipe)** 3.1 miles  
**Total PWS annual water usage** 20,440 MG  
**Treated water purchase cost** \$ 1.65 per 1,000 gals  
**Number of Pump Stations Needed** 1  
**Number of feed tanks/pump sets needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	7	n/a	n/a	n/a
PVC water line, Class 200, 06"	16,313	LF	\$ 32.00	\$ 522,016
Bore and encasement, 10"	400	LF	\$ 60.00	\$ 24,000
Open cut and encasement, 10"	350	LF	\$ 35.00	\$ 12,250
Gate valve and box, 06"	3	EA	\$ 465.00	\$ 1,517
Air valve	3	EA	\$ 1,000.00	\$ 3,000
Flush valve	3	EA	\$ 750.00	\$ 2,447
Metal detectable tape	16,313	LF	\$ 0.15	\$ 2,447
<b>Subtotal</b>				<b>\$ 567,677</b>

*Pump Station(s) Installation*

Pump	4	EA	\$ 7,500	\$ 30,000
Pump Station Piping, 06"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 06"	8	EA	\$ 590	\$ 4,720
Check valve, 06"	4	EA	\$ 890	\$ 3,560
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 30,000 gals	2	EA	\$ 37,100	\$ 74,200
<b>Subtotal</b>				<b>\$ 186,220</b>

**Subtotal of Component Costs** **\$ 753,897**

Contingency 20% \$ 150,779  
Design & Constr Management 25% \$ 188,474

**TOTAL CAPITAL COSTS** **\$ 1,093,151**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	3.1	mile	\$ 200	\$ 618
<b>Subtotal</b>				<b>\$ 618</b>
<i>Water Purchase Cost</i>				
MCUD 2	20,440	1,000 gal	\$ 1.65	\$ 33,726
<b>Subtotal</b>				<b>\$ 33,726</b>

*Pump Station(s) O&M*

Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	9,026	kWH	\$ 0.136	\$ 1,228
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 26	\$ 19,060
Tank O&M	2	EA	\$ 1,000	\$ 2,000
<b>Subtotal</b>				<b>\$ 27,897</b>

*O&M Credit for Existing Well Closure*

Pump power	2,460	kWH	\$ 0.136	\$ (335)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 26	\$ (4,700)
<b>Subtotal</b>				<b>\$ (6,234)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 56,007**

**Table C.3**

**PWS Name** Vista Verde Water Systems  
**Alternative Name** New Well at Stanley Lake MUD  
**Alternative Number** VV-3

**Distance from PWS to new well location** 2.65 miles  
**Estimated well depth** 900 feet  
**Number of wells required** 1  
**Well installation cost (location specific)** \$25 per foot  
**Number of pump stations needed** 1  
**Number of feed tanks/pump sets needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	3	n/a	n/a	n/a
PVC water line, Class 200, 06"	13,981	LF	\$ 32.00	\$ 447,392
Bore and encasement, 10"	200	LF	\$ 60.00	\$ 12,000
Open cut and encasement, 10"	150	LF	\$ 35.00	\$ 5,250
Gate valve and box, 06"	3	EA	\$ 465.00	\$ 1,300
Air valve	3	EA	\$ 1,000.00	\$ 3,000
Flush valve	3	EA	\$ 750.00	\$ 2,097
Metal detectable tape	13,981	LF	\$ 0.15	\$ 2,097
<b>Subtotal</b>				<b>\$ 473,137</b>
<i>Pump Station(s) Installation</i>				
Pump	4	EA	\$ 7,500	\$ 30,000
Pump Station Piping, 06"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 06"	8	EA	\$ 590	\$ 4,720
Check valve, 06"	4	EA	\$ 890	\$ 3,560
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 30,000 gals	2	EA	\$ 37,100	\$ 74,200
<b>Subtotal</b>				<b>\$ 186,220</b>
<i>Well Installation</i>				
Well installation	900	LF	\$ 25	\$ 22,500
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 43,500</b>

**Subtotal of Component Costs \$ 702,857**

Contingency 20% \$ 140,571  
Design & Constr Management 25% \$ 175,714

**TOTAL CAPITAL COSTS \$ 1,019,142**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	2.6	mile	\$ 200	\$ 530
<b>Subtotal</b>				<b>\$ 530</b>
<i>Pump Station(s) O&amp;M</i>				
Building Power	23,600	KWH	\$ 0.136	\$ 3,210
Pump Power	10,835	KWH	\$ 0.136	\$ 1,474
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 26	\$ 19,060
Tank O&M	2	EA	\$ 1,000	\$ 2,000
<b>Subtotal</b>				<b>\$ 28,143</b>
<i>Well O&amp;M</i>				
Pump power	6,500	KWH	\$ 0.136	\$ 884
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 26	\$ 4,700
<b>Subtotal</b>				<b>\$ 6,784</b>
<i>O&amp;M Credit for Existing Well Closure</i>				
Pump power	2,460	KWH	\$ 0.136	\$ (335)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 26	\$ (4,700)
<b>Subtotal</b>				<b>\$ (6,234)</b>

**TOTAL ANNUAL O&M COSTS \$ 29,222**



**Table C.4**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Purchase Water from Montgomery County UD4*  
**Alternative Number** *VV-4*

**Distance from Alternative to PWS (along pipe)** 4.4 miles  
**Total PWS annual water usage** 20,440 MG  
**Treated water purchase cost** \$ 1.65 per 1,000 gals  
**Number of Pump Stations Needed** 1  
**Number of feed tanks/pump sets needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	13	n/a	n/a	n/a
PVC water line, Class 200, 06"	23,338	LF	\$ 32.00	\$ 746,816
Bore and encasement, 10"	400	LF	\$ 60.00	\$ 24,000
Open cut and encasement, 10"	650	LF	\$ 35.00	\$ 22,750
Gate valve and box, 06"	5	EA	\$ 465.00	\$ 2,170
Air valve	4	EA	\$ 1,000.00	\$ 4,000
Flush valve	5	EA	\$ 750.00	\$ 3,501
Metal detectable tape	23,338	LF	\$ 0.15	\$ 3,501
<b>Subtotal</b>				<b>\$ 806,738</b>
<i>Pump Station(s) Installation</i>				
Pump	4	EA	\$ 7,500	\$ 30,000
Pump Station Piping, 06"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 06"	8	EA	\$ 590	\$ 4,720
Check valve, 06"	4	EA	\$ 890	\$ 3,560
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 30,000 gals	2	EA	\$ 37,100	\$ 74,200
<b>Subtotal</b>				<b>\$ 186,220</b>

**Subtotal of Component Costs** **\$ 992,958**

Contingency 20% \$ 198,592  
Design & Constr Management 25% \$ 248,239

**TOTAL CAPITAL COSTS** **\$ 1,439,789**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	4.4	mile	\$ 200	\$ 884
<b>Subtotal</b>				<b>\$ 884</b>
<i>Water Purchase Cost</i>				
MCUD 4	20,440	1,000 gal	\$ 1.65	\$ 33,726
<b>Subtotal</b>				<b>\$ 33,726</b>
<i>Pump Station(s) O&amp;M</i>				
Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	12,765	kWH	\$ 0.136	\$ 1,736
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 26	\$ 19,060
Tank O&M	2	EA	\$ 1,000	\$ 2,000
<b>Subtotal</b>				<b>\$ 28,406</b>

*O&M Credit for Existing Well Closure*

Pump power	2,460	kWH	\$ 0.136	\$ (335)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 26	\$ (4,700)
<b>Subtotal</b>				<b>\$ (6,234)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 56,782**

**Table C.5**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Purchase Water from Montgomery County MUD9*  
**Alternative Number** *VV-5*

**Distance from Alternative to PWS (along pipe)** 6.9 miles  
**Total PWS annual water usage** 20,440 MG  
**Treated water purchase cost** \$ 1.65 per 1,000 gals  
**Number of Pump Stations Needed** 1  
**Number of feed tanks/pump sets needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	15	n/a	n/a	n/a
PVC water line, Class 200, 06"	36,203	LF	\$ 32.00	\$ 1,158,496
Bore and encasement, 10"	400	LF	\$ 60.00	\$ 24,000
Open cut and encasement, 10"	750	LF	\$ 35.00	\$ 26,250
Gate valve and box, 06"	7	EA	\$ 465.00	\$ 3,367
Air valve	7	EA	\$ 1,000.00	\$ 7,000
Flush valve	7	EA	\$ 750.00	\$ 5,430
Metal detectable tape	36,203	LF	\$ 0.15	\$ 5,430
<b>Subtotal</b>				<b>\$ 1,229,974</b>

*Pump Station(s) Installation*

Pump	4	EA	\$ 7,500	\$ 30,000
Pump Station Piping, 06"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 06"	8	EA	\$ 590	\$ 4,720
Check valve, 06"	4	EA	\$ 890	\$ 3,560
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 30,000 gals	2	EA	\$ 37,100	\$ 74,200
<b>Subtotal</b>				<b>\$ 186,220</b>

**Subtotal of Component Costs** **\$ 1,416,194**

Contingency 20% \$ 283,239  
Design & Constr Management 25% \$ 354,048

**TOTAL CAPITAL COSTS** **\$ 2,053,481**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	6.9	mile	\$ 200	\$ 1,371
<b>Subtotal</b>				<b>\$ 1,371</b>
<i>Water Purchase Cost</i>				
MCUD 9	20,440	1,000 gal	\$ 1.65	\$ 33,726
<b>Subtotal</b>				<b>\$ 33,726</b>

*Pump Station(s) O&M*

Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	15,488	kWH	\$ 0.136	\$ 2,106
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 26	\$ 19,060
Tank O&M	2	EA	\$ 1,000	\$ 2,000
<b>Subtotal</b>				<b>\$ 28,776</b>

*O&M Credit for Existing Well Closure*

Pump power	2,460	kWH	\$ 0.136	\$ (335)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 26	\$ (4,700)
<b>Subtotal</b>				<b>\$ (6,234)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 57,639**

**Table C.6**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Purchase Water from Montgomery County MUD8*  
**Alternative Number** *VV-6*

**Distance from Alternative to PWS (along pipe)** 7.3 miles  
**Total PWS annual water usage** 20.440 MG  
**Treated water purchase cost** \$ 1.65 per 1,000 gals  
**Number of Pump Stations Needed** 1  
**Number of feed tanks/pump sets needed** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	1	n/a	n/a	n/a
Number of Crossings, open cut	18	n/a	n/a	n/a
PVC water line, Class 200, 06"	38,490	LF	\$ 32.00	\$ 1,231,680
Bore and encasement, 10"	200	LF	\$ 60.00	\$ 12,000
Open cut and encasement, 10"	900	LF	\$ 35.00	\$ 31,500
Gate valve and box, 06"	8	EA	\$ 465.00	\$ 3,580
Air valve	7	EA	\$ 1,000.00	\$ 7,000
Flush valve	8	EA	\$ 750.00	\$ 5,774
Metal detectable tape	38,490	LF	\$ 0.15	\$ 5,774
<b>Subtotal</b>				<b>\$ 1,297,307</b>

*Pump Station(s) Installation*

Pump, 5 hp	4	EA	\$ 7,500	\$ 30,000
Pump Station Piping, 06"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 06"	8	EA	\$ 590	\$ 4,720
Check valve, 06"	4	EA	\$ 890	\$ 3,560
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 30,000 gals	2	EA	\$ 37,100	\$ 74,200
<b>Subtotal</b>				<b>\$ 186,220</b>

**Subtotal of Component Costs** **\$ 1,483,527**

Contingency 20% \$ 296,705  
Design & Constr Management 25% \$ 370,882

**TOTAL CAPITAL COSTS** **\$ 2,151,114**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	7.3	mile	\$ 200	\$ 1,458
<b>Subtotal</b>				<b>\$ 1,458</b>
<i>Water Purchase Cost</i>				
From BWA	20,440	1,000 gal	\$ 1.65	\$ 33,726
<b>Subtotal</b>				<b>\$ 33,726</b>

*Pump Station(s) O&M*

Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	15,917	kWH	\$ 0.136	\$ 2,165
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 26	\$ 19,060
Tank O&M	2	EA	\$ 1,000	\$ 2,000
<b>Subtotal</b>				<b>\$ 28,835</b>

*O&M Credit for Existing Well Closure*

Pump power	2,460	kWH	\$ 0.136	\$ (335)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 26	\$ (4,700)
<b>Subtotal</b>				<b>\$ (6,234)</b>

**TOTAL ANNUAL O&M COSTS** **\$ 57,784**

**Table C.7**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *New Well at 5 Miles*  
**Alternative Number** *VV-7*

Distance from PWS to new well location	5.0 miles
Estimated well depth	900 feet
Number of wells required	1
Well installation cost (location specific)	\$25 per foot
Number of pump stations needed	1
Number of feed tanks/pump sets needed	1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	2	n/a	n/a	n/a
Number of Crossings, open cut	12	n/a	n/a	n/a
PVC water line, Class 200, 06"	26,400	LF	\$ 32.00	\$ 844,800
Bore and encasement, 10"	1,800	LF	\$ 60.00	\$ 108,000
Open cut and encasement, 10"	100	LF	\$ 35.00	\$ 3,500
Gate valve and box, 06"	5	EA	\$ 465.00	\$ 2,455
Air valve	5	EA	\$ 1,000.00	\$ 5,000
Flush valve	5	EA	\$ 750.00	\$ 3,960
Metal detectable tape	26,400	LF	\$ 0.15	\$ 3,960
<b>Subtotal</b>				<b>\$ 971,675</b>
<i>Pump Station(s) Installation</i>				
Pump	4	EA	\$ 7,500	\$ 30,000
Pump Station Piping, 06"	2	EA	\$ 4,000	\$ 8,000
Gate valve, 06"	8	EA	\$ 590	\$ 4,720
Check valve, 06"	4	EA	\$ 890	\$ 3,560
Electrical/Instrumentation	2	EA	\$ 10,000	\$ 20,000
Site work	2	EA	\$ 2,000	\$ 4,000
Building pad	2	EA	\$ 4,000	\$ 8,000
Pump Building	2	EA	\$ 10,000	\$ 20,000
Fence	2	EA	\$ 5,870	\$ 11,740
Tools	2	EA	\$ 1,000	\$ 2,000
Storage Tank - 30,000 gals	2	EA	\$ 7,025	\$ 14,050
<b>Subtotal</b>				<b>\$ 126,070</b>
<i>Well Installation</i>				
Well installation	900	LF	\$ 25	\$ 22,500
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 43,500</b>
<b>Subtotal of Component Costs</b>				<b>\$ 1,141,245</b>
Contingency	20%			\$ 228,249
Design & Constr Management	25%			\$ 285,311
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 1,654,806</b>

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	5.0 mile		\$ 200	\$ 1,000
<b>Subtotal</b>				<b>\$ 1,000</b>
<i>Pump Station(s) O&amp;M</i>				
Building Power	23,600	kWH	\$ 0.136	\$ 3,210
Pump Power	13,173	kWH	\$ 0.136	\$ 1,792
Materials	2	EA	\$ 1,200	\$ 2,400
Labor	730	Hrs	\$ 26	\$ 19,060
Tank O&M	2	EA	\$ 1,000	\$ 2,000
<b>Subtotal</b>				<b>\$ 28,461</b>
<i>Well O&amp;M</i>				
Pump power	6,500	kWH	\$ 0.136	\$ 884
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 26	\$ 4,700
<b>Subtotal</b>				<b>\$ 6,784</b>
<i>O&amp;M Credit for Existing Well Closure</i>				
Pump power	2,460	kWH	\$ 0.136	\$ (335)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 26	\$ (4,700)
<b>Subtotal</b>				<b>\$ (6,234)</b>
<b>TOTAL ANNUAL O&amp;M COSTS</b>				<b>\$ 30,011</b>

**Table C.8**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *New Well at 1 Mile*  
**Alternative Number** *VV-8*

Distance from PWS to new well location 1.0 miles  
 Estimated well depth 900 feet  
 Number of wells required 1  
 Well installation cost (location specific) \$25 per foot  
 Number of pump stations needed 0  
 Number of feed tanks/pump sets needed 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline Construction</i>				
Number of Crossings, bore	-	n/a	n/a	n/a
Number of Crossings, open cut	2	n/a	n/a	n/a
PVC water line, Class 200, 06"	5,280	LF	\$ 32.00	\$ 168,960
Bore and encasement, 10"	-	LF	\$ 60.00	\$ -
Open cut and encasement, 10"	100	LF	\$ 35.00	\$ 3,500
Gate valve and box, 06"	1	EA	\$ 465.00	\$ 491
Air valve	1	EA	\$ 1,000.00	\$ 1,000
Flush valve	1	EA	\$ 750.00	\$ 792
Metal detectable tape	5,280	LF	\$ 0.15	\$ 792
<b>Subtotal</b>				<b>\$ 175,535</b>
<i>Pump Station(s) Installation</i>				
Pump	2	EA	\$ 7,500	\$ 15,000
Pump Station Piping, 06"	1	EA	\$ 4,000	\$ 4,000
Gate valve, 06"	4	EA	\$ 590	\$ 2,360
Check valve, 06"	2	EA	\$ 890	\$ 1,780
Electrical/Instrumentation	1	EA	\$ 10,000	\$ 10,000
Site work	1	EA	\$ 2,000	\$ 2,000
Building pad	1	EA	\$ 4,000	\$ 4,000
Pump Building	1	EA	\$ 10,000	\$ 10,000
Fence	1	EA	\$ 5,870	\$ 5,870
Tools	1	EA	\$ 1,000	\$ 1,000
Storage Tank - 30,000 gals	1	EA	\$ 7,025	\$ 7,025
<b>Subtotal</b>				<b>\$ 63,035</b>
<i>Well Installation</i>				
Well installation	900	LF	\$ 25	\$ 22,500
Water quality testing	2	EA	\$ 1,500	\$ 3,000
Well pump	1	EA	\$ 7,500	\$ 7,500
Well electrical/instrumentation	1	EA	\$ 5,000	\$ 5,000
Well cover and base	1	EA	\$ 3,000	\$ 3,000
Piping	1	EA	\$ 2,500	\$ 2,500
<b>Subtotal</b>				<b>\$ 43,500</b>

**Subtotal of Component Costs \$ 282,070**

Contingency 20% \$ 56,414  
 Design & Constr Management 25% \$ 70,518

**TOTAL CAPITAL COSTS \$ 409,002**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Pipeline O&amp;M</i>				
Pipeline O&M	1.0	mile	\$ 200	\$ 200
<b>Subtotal</b>				<b>\$ 200</b>
<i>Pump Station(s) O&amp;M</i>				
Building Power	11,800	kWH	\$ 0.136	\$ 1,605
Pump Power	-	kWH	\$ 0.136	\$ -
Materials	1	EA	\$ 1,200	\$ 1,200
Labor	365	Hrs	\$ 26	\$ 9,530
Tank O&M	1	EA	\$ 1,000	\$ 1,000
<b>Subtotal</b>				<b>\$ 13,335</b>
<i>Well O&amp;M</i>				
Pump power	6,500	kWH	\$ 0.136	\$ 884
Well O&M matl	1	EA	\$ 1,200	\$ 1,200
Well O&M labor	180	Hrs	\$ 26	\$ 4,700
<b>Subtotal</b>				<b>\$ 6,784</b>

<i>O&amp;M Credit for Existing Well Closure</i>				
Pump power	2,460	kWH	\$ 0.136	\$ (335)
Well O&M matl	1	EA	\$ 1,200	\$ (1,200)
Well O&M labor	180	Hrs	\$ 26	\$ (4,700)
<b>Subtotal</b>				<b>\$ (6,234)</b>

**TOTAL ANNUAL O&M COSTS \$ 14,084**

**Table C.9**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Central Treatment - IX*  
**Alternative Number** *VV-9*

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Ion Exchange Unit Purchase/Installation</i>				
Site preparation	0.75	acre	\$ 4,000	\$ 3,000
Slab	30	CY	\$ 1,000	\$ 30,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8	\$ 3,200
Building plumbing	400	SF	\$ 8	\$ 3,200
Heating and ventilation	400	SF	\$ 7	\$ 2,800
Fence	600	LF	\$ 15	\$ 9,000
Paving	3,200	SF	\$ 2	\$ 6,400
Electrical	1	JOB	\$ 50,000	\$ 50,000
Piping	1	JOB	\$ 20,000	\$ 20,000
Ion exchange package including:				
Regeneration system				
Brine tank				
IX resins & FRP vessels	1	UNIT	\$ 30,000	\$ 30,000
Transfer pumps (10 hp)	2	EA	\$ 5,000	\$ 10,000
Clean water tank	5,000	gal	\$ 1.00	\$ 5,000
Regenerant tank	2,000	gal	\$ 1.50	\$ 3,000
Backwash Tank	6,000	gal	\$ 2.00	\$ 12,000
<b>Sewer Connection Fee</b>	-	EA		\$ -
<b>Subtotal of Component Costs</b>				<b>\$ 211,600</b>
Contingency	20%			\$ 42,320
Design & Constr Management	25%			\$ 52,900
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 306,820</b>

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Ion Exchange Unit O&amp;M</i>				
Building Power	12,000	kwh/yr	\$ 0.095	\$ 1,140
Equipment power	10,000	kwh/yr	\$ 0.095	\$ 950
Labor	400	hrs/yr	\$ 26	\$ 10,400
Materials	1	year	\$ 1,000	\$ 1,000
Chemicals	1	year	\$ 1,000	\$ 1,000
Analyses	24	test	\$ 200	\$ 4,800
<b>Backwash disposal</b>	<b>4</b>	<b>kgal/yr</b>	<b>\$ 300.00</b>	<b>\$ 1,200</b>
<b>Subtotal</b>				<b>\$ 20,490</b>
<i>Haul Regenerant Waste and Brine</i>				
Waste haulage truck rental	3	days	\$ 700	\$ 2,100
Mileage charge	300	miles	\$ 1.00	\$ 300
<b>Waste disposal</b>	<b>9</b>	<b>kgal/yr</b>	<b>\$ 300.00</b>	<b>\$ 2,700</b>
<b>Subtotal</b>				<b>\$ 5,100</b>
				50%
<b>TOTAL ANNUAL O&amp;M COSTS</b>				<b>\$ 25,590</b>

**Table C.10**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Central Treatment - WRT Z-88*  
**Alternative Number** *VV-10*

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Coagulation/Filtration Unit Purchase/Installation</i>				
Site preparation	0.75	acre	\$ 4,000	\$ 3,000
Slab	30	CY	\$ 1,000	\$ 30,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8	\$ 3,200
Building plumbing	400	SF	\$ 8	\$ 3,200
Heating and ventilation	400	SF	\$ 7	\$ 2,800
Fence	600	LF	\$ 15	\$ 9,000
Paving	1,600	SF	\$ 2	\$ 3,200
Electrical	1	JOB	\$ 50,000	\$ 50,000
Piping	1	JOB	\$ 20,000	\$ 20,000
WRT Z-88 package including:				
Z-88 vessels				
Adsorption media	1	UNIT	\$ 51,000	\$ 51,000
<i>(Initial Setup Cost for WRT Z-88 package plant)</i>				
Transfer pumps (10 hp)	2	EA	\$ 5,000	\$ 10,000
Clean water tank	5,000	gal	\$ 1.00	\$ 5,000
<b>Subtotal of Component Costs</b>				<b>\$ 214,400</b>
Contingency	20%		\$	42,880
Design & Constr Management	25%		\$	53,600
<b>TOTAL CAPITAL COSTS</b>			<b>\$ 310,880</b>	

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Coagulation/Filtration Unit O&amp;M</i>				
Building Power	6,000	kwh/yr	\$ 0.095	\$ 570
Equipment power	5,000	kwh/yr	\$ 0.095	\$ 475
Labor	400	hrs/yr	\$ 26	\$ 10,400
Analyses	24	test	\$ 200	\$ 4,800
WRT treated water charge	1,140	kgal/yr	\$ 6.70	\$ 7,638
<b>Subtotal</b>				<b>\$ 23,883</b>
<b>TOTAL ANNUAL O&amp;M COSTS</b>				<b>\$ 23,883</b>

**Table C.11**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Central Treatment - KMnO4*  
**Alternative Number** *VV-11*

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Coagulation/Filtration Unit Purchase/Installation</i>				
Site preparation	0.50	acre	\$ 4,000	\$ 2,000
Slab	30	CY	\$ 1,000	\$ 30,000
Building	400	SF	\$ 60	\$ 24,000
Building electrical	400	SF	\$ 8	\$ 3,200
Building plumbing	400	SF	\$ 8	\$ 3,200
Heating and ventilation	400	SF	\$ 7	\$ 2,800
Fence	300	LF	\$ 15	\$ 4,500
Paving	1,600	SF	\$ 2	\$ 3,200
Electrical	1	JOB	\$ 50,000	\$ 50,000
Piping	1	JOB	\$ 20,000	\$ 20,000
KMnO4-Greensand package including:				
Greensand filters				
Solution tank	1	UNIT	\$ 60,000	\$ 60,000
Backwash tank	10,000	gal	\$ 2.00	\$ 20,000
Sewer connection fee	-	EA	\$ 15,000	\$ -
Transfer pumps (10 hp)	2	EA	\$ 5,000	\$ 10,000
Clean water tank	5,000	gal	\$ 1.00	\$ 5,000
<b>Subtotal of Component Costs</b>				<b>\$ 237,900</b>
Contingency	20%		\$	47,580
Design & Constr Management	25%		\$	59,475
<b>TOTAL CAPITAL COSTS</b>			<b>\$ 344,955</b>	

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Coagulation/Filtration Unit O&amp;M</i>				
Building Power	6,000	kwh/yr	\$ 0.095	\$ 570
Equipment power	6,000	kwh/yr	\$ 0.095	\$ 570
Labor	400	hrs/yr	\$ 26	\$ 10,400
Materials	1	year	\$ 1,000	\$ 1,000
Chemicals	1	year	\$ 1,000	\$ 1,000
Analyses	24	test	\$ 200	\$ 4,800
Backwash discharge to sewer	4	kgal/yr	\$ 200.00	\$ 800
<b>Subtotal</b>				<b>\$ 19,140</b>
<i>Sludge Disposal</i>				
Truck rental	2.0	days	\$ 700	\$ 1,400
Mileage	200	miles	\$ 1.00	\$ 200
Disposal fee	4	kgal/yr	\$ 200.00	\$ 800
<b>Subtotal</b>				<b>\$ 2,400</b>
<b>TOTAL ANNUAL O&amp;M COSTS</b>			<b>\$ 21,540</b>	



**Table C.12**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Point-of-Use Treatment*  
**Alternative Number** *VV-12*

Number of Connections for POU Unit Installation 144

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>POU-Treatment - Purchase/Installation</i>				
POU treatment unit purchase	144	EA	\$ 250	\$ 36,000
POU treatment unit installation	144	EA	\$ 150	\$ 21,600
<b>Subtotal</b>				<b>\$ 57,600</b>
<b>Subtotal of Component Costs</b>				<b>\$ 57,600</b>
Contingency	20%		\$	11,520
Design & Constr Management	25%		\$	14,400
Procurement & Administration	20%		\$	11,520
<b>TOTAL CAPITAL COSTS</b>			<b>\$</b>	<b>95,040</b>

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>O&amp;M</i>				
POU materials, per unit	144	EA	\$ 225	\$ 32,400
Contaminant analysis, 1/yr per unit	144	EA	\$ 100	\$ 14,400
Program labor, 10 hrs/unit	1,440	hrs	\$ 26	\$ 37,598
<b>Subtotal</b>				<b>\$ 84,398</b>
<b>TOTAL ANNUAL O&amp;M COSTS</b>				<b>\$ 84,398</b>

**Table C.13**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Point-of-Entry Treatment*  
**Alternative Number** *VV-13*

**Number of Connections for POE Unit Installation** 144

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>POE-Treatment - Purchase/Installation</i>				
POE treatment unit purchase	144	EA	\$ 3,000	\$ 432,000
Pad and shed, per unit	144	EA	\$ 2,000	\$ 288,000
Piping connection, per unit	144	EA	\$ 1,000	\$ 144,000
Electrical hook-up, per unit	144	EA	\$ 1,000	\$ 144,000
<b>Subtotal</b>				<b>\$ 1,008,000</b>

**Subtotal of Component Costs** **\$ 1,008,000**

Contingency	20%	\$ 201,600
Design & Constr Management	25%	\$ 252,000
Procurement & Administration	20%	\$ 201,600

**TOTAL CAPITAL COSTS** **\$ 1,663,200**

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>O&amp;M</i>				
POE materials, per unit	144	EA	\$ 1,000	\$ 144,000
Contaminant analysis, 1/yr per unit	144	EA	\$ 100	\$ 14,400
Program labor, 10 hrs/unit	1,440	hrs	\$ 26	\$ 37,598
<b>Subtotal</b>				<b>\$ 195,998</b>

**TOTAL ANNUAL O&M COSTS** **\$ 195,998**

**Table C.14**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Public Dispenser for Treated Drinking Water*  
**Alternative Number** *VV-14*

**Number of Treatment Units Recommended** 1

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Public Dispenser Unit Installation</i>				
POE-Treatment unit(s)	1	EA	\$ 3,000	\$ 3,000
Unit installation costs	1	EA	\$ 5,000	\$ 5,000
<b>Subtotal</b>				<b>\$ 8,000</b>
<b>Subtotal of Component Costs</b>				<b>\$ 8,000</b>
Contingency	20%			\$ 1,600
Design & Constr Management	25%			\$ 2,000
<b>TOTAL CAPITAL COSTS</b>				<b>11,600</b>

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Treatment unit O&M, 1 per unit	1	EA	\$ 500	\$ 500
Contaminant analysis, 1/wk per u	52	EA	\$ 100	\$ 5,200
Sampling/reporting, 1 hr/day	365	HRS	\$ 26	\$ 9,530
<b>Subtotal</b>				<b>\$ 15,230</b>
<b>TOTAL ANNUAL O&amp;M COSTS</b>				<b>\$ 15,230</b>

**Table C.15**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Supply Bottled Water to Population*  
**Alternative Number** *VV-15*

**Service Population** 432  
**Percentage of population requiring supply** 100%  
**Water consumption per person** 1.00 gpcd  
**Calculated annual potable water needs** 157,680 gallons

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Implementation</i>				
Initial program set-up	500	hours	\$ 35	\$ 17,363
<b>Subtotal</b>				<b>\$ 17,363</b>
<b>Subtotal of Component Costs</b>				<b>\$ 17,363</b>
Contingency	20%			\$ 3,473
<b>TOTAL CAPITAL COSTS</b>				<b>\$ 20,836</b>

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water purchase costs	157,680	gals	\$ 1.60	\$ 252,288
Program admin, 9 hrs/wk	468	hours	\$ 35	\$ 16,252
Program materials	1	EA	\$ 5,000	\$ 5,000
<b>Subtotal</b>				<b>\$ 273,540</b>
<b>TOTAL ANNUAL O&amp;M COSTS</b>				<b>\$ 273,540</b>

**Table C.16**

**PWS Name** *Vista Verde Water Systems*  
**Alternative Name** *Central Trucked Drinking Water*  
**Alternative Number** *VV-16*

**Service Population** 432  
**Percentage of population requiring supply** 100%  
**Water consumption per person** 1.00 gpcd  
**Calculated annual potable water needs** 157,680 gallons  
**Travel distance to compliant water source (roundtrip)** 20 miles

**Capital Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Storage Tank Installation</i>				
Storage Tank - 5,000 gals	1	EA	\$ 7,025	\$ 7,025
Site improvements	1	EA	\$ 4,000	\$ 4,000
Potable water truck	1	EA	\$ 60,000	\$ 60,000
<b>Subtotal</b>				<b>\$ 71,025</b>
<b>Subtotal of Component Costs</b>				<b>\$ 71,025</b>
Contingency	20%		\$	14,205
Design & Constr Management	25%		\$	17,756
<b>TOTAL CAPITAL COSTS</b>			<b>\$</b>	<b>102,986</b>

**Annual Operations and Maintenance Costs**

Cost Item	Quantity	Unit	Unit Cost	Total Cost
<i>Program Operation</i>				
Water delivery labor, 4 hrs/wk	208	hrs	\$ 26	\$ 5,431
Truck operation, 1 round trip/wk	1,040	miles	\$ 1.00	\$ 1,040
Water purchase	158	1,000 gals	\$ 2.50	\$ 394
Water testing, 1 test/wk	52	EA	\$ 100	\$ 5,200
Sampling/reporting, 2 hrs/wk	104	hrs	\$ 26	\$ 2,715
<b>Subtotal</b>				<b>\$ 14,781</b>
<b>TOTAL ANNUAL O&amp;M COSTS</b>				<b>\$ 14,781</b>

1  
2

**APPENDIX D  
EXAMPLE FINANCIAL MODEL**

**Table D.1 Example Financial Model**

Water System	Vista Verde
Funding Alternative	Bond
Alternative Description	New Well at Stanley Lake MUD

Sum of Amount		Year																							
Group	Type	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025		
Capital Expenditures	Capital Expenditures-Funded from Bonds	\$ -	\$ -	\$ -	#####	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
	Capital Expenditures-Funded from Grants	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
	Capital Expenditures-Funded from Revenue/Reserves	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
	Capital Expenditures-Funded from SRF Loans	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
	Capital Expenditures Sum	\$ -	\$ -	\$ -	#####	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	
Debt Service	Revenue Bonds	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724		
	State Revolving Funds	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
Debt Service Sum		\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724	\$ 79,724		
Operating Expenditures	Administrative Expenses	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000	\$ 3,000		
	Chemicals, Treatment	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000		
	Contract Labor	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000		
	Insurance	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000		
	Repairs	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000	\$ 4,000		
	Salaries & Benefits	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000	\$ 17,000		
	Supplies	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000		
	Utilities	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000	\$ 7,000		
	O&M Associated with Alternative Maintenance	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000	\$ 2,000		
	Accounting and Legal Fees	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100	\$ 100		
	Operating Expenditures Sum		\$ 39,100	\$ 39,100	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	\$ 68,322	
	Residential Operating Revenues	Residential Base Monthly Rate	\$ 59,098	\$ 59,098	\$ 118,360	\$ 221,946	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	
Residential Tier 1 Monthly Rate		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
Residential Tier2 Monthly Rate		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
Residential Tier3 Monthly Rate		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
Residential Tier4 Monthly Rate		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
Residential Unmetered Monthly Rate		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
Residential Operating Revenues Sum		\$ 59,098	\$ 59,098	\$ 118,360	\$ 221,946	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270	\$ 266,270		

Location_Name	Vista Verde
Alt_Desc	New Well at Stanley Lake MUD

[illegible]

## APPENDIX E RADIONUCLIDE GEOCHEMISTRY

Radionuclide impact on water quality is measured according to two scales: intrinsic measurement of radioactivity and impact on human beings. Activity or number of disintegrations per unit time is typically measured in pico Curies (pCi), whereas impact on living organisms is measured in millirems (mrem). Radioactive decay can generate alpha or beta particles, as well as gamma rays. Two radioactive elements with the same activity may have vastly different impacts on life, depending on the energy released during decay. Each radionuclide has a conversion factor from pCi to mrem as a function of exposure pathway. Activity is related to contaminant concentration and half-life. A higher concentration and a shorter half-life lead to increased activity. Given the ratio of the half-life of each (Table E.1), it is apparent that radium is approximately 1 million times more radioactive than uranium. Concentrations of gross alpha and beta emitters take into account the whole decay series and not just uranium and radium, as well as other elements such as K 40.

Uranium and thorium (atomic number 92 and 90, respectively), both radium sources, are common trace elements and have a crustal abundance of 2.6 and 10 mg/kg, respectively. They are abundant in acidic rocks. Intrusive rocks such as granites will partly sequester uranium and thorium in erosion-resistant accessory minerals (e.g., monazite, thorite) while uranium in volcanic rocks is much more labile and can be leached by surface water and groundwater. Lattice substitution in minerals (e.g.,  $\text{Ca}^{+2}$  and  $\text{U}^{+4}$  have almost the same ionic radius) as well as micrograins of uranium and thorium minerals are other possibilities. In sedimentary rocks, uranium and thorium aqueous concentrations are controlled mainly by the sorbing potential of the rocks (metal oxides, clays, and organic matter).

The geochemistry of uranium is complicated but can be summarized by the following. Uranium(VI) in oxidizing conditions exists as the soluble positively charged uranyl  $\text{UO}_2^{+2}$ . Solubility is higher at acid pHs, decreases at neutral pHs, and increases at alkaline pHs. The uranyl ion can easily form aqueous complexes, including with hydroxyl, fluoride, carbonate, and phosphate ligands. Hence, in the presence of carbonates, uranium solubility is considerably enhanced in the form of uranyl-carbonate ( $\text{UO}_2\text{CO}_3$ ) and other higher order carbonate complexes: uranyl-di-carbonate ( $\text{UO}_2(\text{CO}_3)_2^{-2}$ ) and uranyl-tri-carbonates  $\text{UO}_2(\text{CO}_3)_3^{-4}$ ). Adsorption of uranium is inversely related to its solubility and is highest at neutral pH's (De Soto 1978). Uranium sorbs strongly to metal oxides and clays. Uranium(IV) is the other commonly found redox state. In that state, however, uranium is not very soluble and precipitates as uraninite,  $\text{UO}_2$ , coffinite,  $\text{USiO}_4 \cdot n\text{H}_2\text{O}$  (if  $\text{SiO}_2 > 60$  mg/L, (Henry, *et al.* 1982, p.18), or related minerals. In most aquifers, no mineral controls uranium solubility in oxidizing conditions. However, uranite and coffinite are the controlling minerals if Eh drops below 0-100 mV.

Thorium exists naturally only in one redox state Th (IV).  $\text{Th}^{+4}$  forms complexes with most common aqueous anions. However, thorium solubility remains low except perhaps at higher pH when complexed by carbonate ions (USEPA 1999). Thorium sorbs strongly to metal oxides in a way similar to uranium.



Radium has an atomic number of 88. Radium originates from the radioactive decay of uranium and thorium. Ra226 is an intermediate product of U238 (the most common uranium isotope >99%, Table A-1) decay, whereas Ra228 belongs to the Th232 (~100% of natural thorium) decay series. Both radium isotopes further decay to radon and, ultimately, to lead. Radon is a gas and tends to volatilize from shallower units. Ra223 and Ra224 isotopes are also naturally present but in minute quantities. Ra224 belongs to the thorium decay series, whereas Ra223 derives from the much rarer U235 (~0.7%). Radium is an alkaline Earth element and belongs to the same group (2A in periodic table) as magnesium, calcium, strontium, and barium. It most resembles barium chemically, as evidenced by removal technologies such as ion exchange with Na and lime softening. Sorption on iron and manganese oxides is also a common trait of alkaline Earth elements. Radium exists only under one oxidation state, the divalent cation  $Ra^{+2}$ , similar to other alkaline Earth elements ( $Ca^{+2}$ ,  $Mg^{+2}$ ,  $Sr^{+2}$ , and  $Ba^{+2}$ ).  $RaSO_4$  is extremely insoluble (more so than barium sulfate), with a log K solubility product of -10.5, compared to that of barium sulfate at ~-10. Radium solubility is mostly controlled by sulfate activity.

**Table E.1 Uranium, Thorium, and Radium Abundance and Half-Lives**

Decay series	Uranium/thorium	Radium	Radon
U238	U238 – ~99.3% ( $4.47 \times 10^9$ yrs)	Ra226 - (1,599 yrs)	Rn222 - (3.8 days)
	U234 – 0.0055% ( $0.246 \times 10^9$ yrs)	Intermediate product of U238 decay	
U235	U235 - ~0.7% ( $0.72 \times 10^9$ yrs)	Ra223 – (11.4 days)	Rn219 - (4 seconds)
Th232	Th232 – ~100% ( $14.0 \times 10^9$ yrs)	Ra228 - (5.76 yrs) Ra224 - (3.7 days)	Rn220 - (~1 min)

NOTE: half-life from Parrington et al. (1996)

#### EPA Maximum Contaminant Levels

- Uranium: 30 parts per billion
- Gross alpha : 15 pCi/L
- Beta particles and photon emitters: 4 mrem/yr
- Radium-226 and radium-228: 5 pCi/L

**Appendix References:**

- Bluntzer R. L., 1992, Evaluation of ground-water resources of the Paleozoic and Cretaceous Aquifers in the Hill Country of Central Texas: Texas Water Development Board Report 339, 130 p.
- DeSoto, R.H. 1978. Uranium geology and exploration: lecture notes and references: Golden, CO, Colorado School of Mines, March, 396 p.
- Henry, C. D., Galloway, W. E., and Smith, G. E., Ho, C. L., Morton, J. P., and Gluck, J. K. 1982. Geochemistry of groundwater in the Miocene Oakville sandstone—a major aquifer and uranium host of the Texas coastal plain: The University of Texas at Austin, Bureau of Economic Geology Report of Investigations No. 118, 63 p.
- Kim, Y, Tieh, T. T., and Ledger, E. B. 1995. Aquifer mineralogy and natural radionuclides in groundwater—the lower Paleozoic of Central Texas: Gulf Coast Association of Geological Societies Transactions, Vol. XLV.
- Parrington, J. R., Knox, H. D., Breneman, S. L., Baum, E. M., and Feiner, F. 1996. Nuclides and isotopes, chart of the nuclides: San Jose, California, General Electric Company and KAPL, Inc., 15th edition.
- USEPA 1999. Understanding variations in partition coefficients, K<sub>d</sub>, values: Environment Protection Agency report EPA-402-R-99-004A, August, Volume II: Review of geochemistry and available K<sub>d</sub> values for cadmium, cesium, chromium, lead, plutonium, radon, strontium, thorium, tritium (<sup>3</sup>H), and uranium. Variously paginated.